9304300321-01

NOTES:

1. SCALE: NONE.
2. ITEMS NOT SHOWN IN FRONT VIEW ARRANGEMENT, THAT ARE LISTED IN EQUIPMENT LIST ARE TO BE MOUNTED INSIDE CABINET.
3. FOR PANEL P864, USE EQUIP LIST ESK-4CEC104
   FOR PANEL P865, USE EQUIP LIST ESK-4CEC204
   FOR PANEL P866, USE EQUIP LIST ESK-4CEC304
   FOR PANEL P867, USE EQUIP LIST ESK-4CEC404
   FOR PANEL P868, USE EQUIP LIST ESK-4CEC504
   FOR PANEL P869, USE EQUIP LIST ESK-4CEC604
4. PROVIDE REAR ACCESS DOORS ON EACH CABINET, PER G.E. SPEC 22A2877.
5. CABINET DEPTH, 36 " REF.
6. ALL DIMENSIONS ARE IN INCHES, UNLESS OTHERWISE SPECIFIED.
7. FOR ALL PANEL ENTRIES, NAMEPLATES WILL BE SUPPLIED IN ACCORDANCE WITH ESK-2M, FIGURE XXXI-A. ENGRAVING TO BE 2 LINES AS FOLLOWS:
   CONTACT SSS
   PRIOR TO PANEL ENTRY

REFERENCE DRAWINGS:

RELAY ROOM ARRANGEMENT, 12177-EE-27B.

SI
APERTURE
CARD

9304300321 E

07-~~18~~ 27-91

QA CAT.II

ARRANGEMENT - PROTECTIVE RELAY
PANELS P864,P865,P866,P867,P868,P869

NINE MILE POINT NUCLEAR STATION-UNIT 2

NIAGARA MOHAWK POWER CORPORATION

STONE & WEBSTER ENGINEERING CORPORATION

REDRAWN	
12	4/8/88
	ECN-830

12177-ESK-4CEC04

9304300321 E