



- NOTES:
- UNOCCUPIED PANEL AREA TYPICAL AS SHOWN THAT CAN BE USED FOR ADDITION OF COMPONENTS MUST BE KEPT CLEAR OF WIRING, SUFFICIENT ROUTING OF WIRING TO BE SUCH THAT ADDITION OF COMPONENTS CAN BE DONE WITH MINIMUM OF REWORK.
 - FOR PANEL PARTS/EQUIPMENT LIST ESK-4CEC128.
 - PROVIDE REAR ACCESS DOORS PER I.E. SPEC. 22A2877.
 - ITEMS NOT SHOWN IN FRONT VIEW ARRANGEMENT, THAT ARE LISTED IN EQUIPMENT LIST ARE TO BE MOUNTED INSIDE CABINET.
 - TRIM SEPARATORS TO BE ADDED TO FRONT OF PANELS, AS SHOWN.
 - DOTTED LINE INDICATES BARRIER THAT IS TO BE PROVIDED IN REAR OF PANEL.
 - CABINET DEPTH 30" P.F.F.
 - ALL DIMENSIONS ARE IN INCHES, UNLESS OTHERWISE SPECIFIED.
 - SCALE ENDS
 - SEE ESK-18ANN880 FOR ADDITIONAL NOTES.
 - NOT APPLICABLE.
 - FOR ALL PANEL ENTRIES, NAMEPLATES WILL BE SUPPLIED IN ACCORDANCE WITH ESK-2M, FIGURE XXXI-A, ENGRAVING TO BE 2 LINES AS FOLLOWS:
CONTACT: SSS
PROR TO PANEL ENTRY
- REFERENCE DRAWINGS:
CONTROL ROOM ARRANGMENT, 12177-EE-27A
COMMUNICATIONS PLAN, 12177-EE-80C

SI APERTURE CARD

9305040043
07-91

NUCLEAR SAFETY RELATED &
NUCLEAR NON-SAFETY RELATED

NIAGARA MOHAWK NINE MILE POINT NUCLEAR STATION - UNIT 2 SCRIBA, N.Y.

ARRANGEMENT
HVAC DIVISION II &
DIVISION III
2CEC-PNL871

NO.	DATE	BY	DESCRIPTION	APP.	NO.	DATE	BY	DESCRIPTION	APP.
12	11/11/98	JBP	REVISED PER ECN'S 2E80926, 2E80927, 2E80928, 2E80929, 2E80930, 2E80931, 2E80932, 2E80933, 2E80934, 2E80935, 2E80936, 2E80937, 2E80938, 2E80939, 2E80940, 2E80941, 2E80942, 2E80943, 2E80944, 2E80945, 2E80946, 2E80947, 2E80948, 2E80949, 2E80950, 2E80951, 2E80952, 2E80953, 2E80954, 2E80955, 2E80956, 2E80957, 2E80958, 2E80959, 2E80960, 2E80961, 2E80962, 2E80963, 2E80964, 2E80965, 2E80966, 2E80967, 2E80968, 2E80969, 2E80970, 2E80971, 2E80972, 2E80973, 2E80974, 2E80975, 2E80976, 2E80977, 2E80978, 2E80979, 2E80980, 2E80981, 2E80982, 2E80983, 2E80984, 2E80985, 2E80986, 2E80987, 2E80988, 2E80989, 2E80990, 2E80991, 2E80992, 2E80993, 2E80994, 2E80995, 2E80996, 2E80997, 2E80998, 2E80999, 2E81000	AKJ	AKJ	SCALE	NONE	DRAWING NO.	ESK-4CEC20

9305040043-01

9305040043