

07-172-91 2

REVISED

NINE MILE POINT NUCLEAR STATION UNIT 2
ELECTRICAL PREVENTIVE MAINTENANCE PROCEDURE
PROCEDURE NO. N2-EPM-GEN-W665

DC/UPS WEEKLY CHECKS

<u>APPROVALS</u>	<u>SIGNATURES</u>	<u>REVISION 3</u>	<u>REVISION 4</u>	<u>REVISION 5</u>
Site Superintendent Maintenance Nuclear K. A. Dahlberg	<u>K. A. Dahlberg</u>	<u>3/5/88</u> <u>KAO</u>	_____	_____
Station Superintendent NMPNS Unit 2 R. B. Abbott	<u>R. B. Abbott</u>	<u>3/7/88</u> <u>RBA</u>	_____	_____
General Superintendent Nuclear Generation T. J. Perkins	<u>T. J. Perkins</u>	<u>3/11/88</u> <u>TJP</u>	_____	_____

Summary of Pages

Revision 3 (Effective 3/11/88)

<u>Pages</u>	<u>Date</u>
1-7,9-12,14,16, 18,20,22,24,26, 28,30-32	March 1991 (This includes TCN-4 through TCN-8, Reissue and Publication Change *1)
27,29	April 1991 (Publication Change *2)
8,13,15,17,19,21,23,25	June 1991 (PCE 15719)


Periodic Review, 4/2/90, No Changes

NIAGARA MOHAWK POWER CORPORATION

THIS PROCEDURE NOT TO BE
USED AFTER April 1992
SUBJECT TO PERIODIC REVIEW.

9305040320 911031
PDR ADCK 05000410
S PDR

9305040320



DC/UPS WEEKLY CHECKS

1.0 PURPOSE

1.1 This procedure describes the steps necessary to perform preventive maintenance on the Three Phase Thyristor Battery Chargers, 24/48 and 125 VDC Normal Batteries by checking the Pilot Cells, and the UPS Inverters.

1.2 Applicability - This procedure is applicable to Three Phase Thyristor Battery Chargers, 24/48 and 125 VDC Batteries, and the UPS Inverters located as follows:

24/48 VDC Batteries

	<u>Battery</u>	<u>Battery Charger</u>	<u>Distribution Panel</u>	<u>Location</u>
1.2.1	2BWS-BAT3A(+)	2BWS-CHGR3A1	2BWS-PNL300A	Control Bldg. El. 214'-0"
1.2.2	2BWS-BAT3B(+)	2BWS-CHGR3B1	2BWS-PNL300B	Control Bldg. El. 214'-0"
1.2.3	2BWS-BAT3C(-)	2BWS-CHGR3C1	2BWS-PNL300A	Control Bldg. El. 214'-0"
1.2.4	2BWS-BAT3D(-)	2BWS-CHGR3D1	2BWS-PNL300B	Control Bldg. El. 214'-0"

125 VDC Batteries

	<u>Battery</u>	<u>Battery Charger</u>	<u>DC Switchgear Distribution Panel</u>	<u>Location</u>
1.2.5	2BYS-BAT1A	2BYS-CHGR1A1	2BYS-SWG001A	Swthgr Bldg. El. 237'-0"
1.2.6	2BYS-BAT1B	2BYS-CHGR1B1	2BYS-SWG001B	Swthgr Bldg. El. 237'-0"
1.2.7	2BYS-BAT1C	2BYS-CHGR1C1	2BYS-SWG001C	Swthgr Bldg. El. 214'-0"

Three Phase Thyristor Battery Chargers

	<u>Battery Charger</u>	<u>600 VAC Power Supply</u>	<u>125 VDC Power Supply</u>	<u>Location</u>
1.2.8	2BYS*CHGR2A1	2LAC*PNL100A	2BYS*SWG002A	CSA, 261'
1.2.9	2BYS*CHGR2A2	2EJS*PNL100A	2BYS*SWG002A	CSA, 261'
1.2.10	2BYS*CHGR2B1	2LAC*PNL300B	2BYS*SWG002B	CSB, 261'
1.2.11	2BYS*CHGR2B2	2EJS*PNL300B	2BYS*SWG002B	CSB, 261'
1.2.12	2BYS*CHGR2C1	2EHS*MCC201	2CES*IPNL414	CSH, 261'
1.2.13	2BYS*CHGR2C2	2EHS*MCC201	2CES*IPNL414	CSH, 261'

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Ups Inverters

	<u>Inverter ID</u>	<u>Normal Power</u>	<u>Alternate Power</u>	<u>Backup Power</u>	<u>Location</u>
1.2.14	2VBA*UPS2A	2EJS*PNL100A-7	2LAC*PNL100A-19	2BYS*SWG002A-3C	CSA, 261'
1.2.15	2VBA*UPS2B	2EJS*PNL100B-7	2LAC*PNL300B-19	2BYS*SWG002B-3C	CSB, 261'

1.3 Frequency - This procedure should normally be performed at least once per week or more frequently as required.

1.4 Safety Classification - Non-Safety Related (1.2.1 through 1.2.7) and Safety Related (1.2.8 through 1.2.15).

1.5 EQ Requirements

1.5.1 The Three Phase Thyristor Battery Chargers, 2BYS*CHGR2A1, 2A2, 2B1, 2B2, 2C1 and 2C2 are equipment qualified for a mild environment.

1.5.2 The UPS Inverters, 2VBA*UPS2A and 2B are equipment qualified for a mild environment.

1.5.3 The Safety Related Maintenance Requirements of EQMPDS (E034AAA, AAB, AAC) for Battery Chargers and (E035AAA, AAB) for UPS Inverters are incorporated in this procedure as applicable.

1.6 Discussion

1.6.1 Post maintenance test is not applicable to this procedure.

2.0 REFERENCES

2.1 AP-3.3.2, Radiation Work Permit Procedure. | *

2.2 NMPC Accident Prevention Rules. | *

2.3 AP-4.2, Control of Equipment Markups.

2.4 Power Conversion Products Instruction Manual for Three Phase Thyristor Controlled Battery Charger, DOCNO: 14476-5, Access No. 430003001.

2.5 Power Conversion Products Instruction Manual for Three Phase Thyristor Controlled Battery Charger, DOCNO: 14476-1, Access No. 430000090.

2.6 Gould Inc., Installation and Operating Instructions for Lead Calcium Stationary Batteries, DOCNO: MAE-935, Access No. 430002560, NMPC File Sequence No. N20037.

2.7 Elgar Corp., Instruction Manual, Elgar Uninterruptable Power System, Model UPS 253-1-106, DOCNO: UPS253-1-106, Access No. 430002188 (25KVA Unit).

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

- 2.8 IEEE Standard 450 - 1980 Recommended Practice for Maintenance Testing and Replacement of Large Lead Storage Batteries for Generating Stations and Substations.
- 2.9 INFO O & MR - 308.
- 2.10 12177-EE-1BB, 1BG, 1BH, 1BR, 1BY, 1CB, 1CC, 1CM, 1CN, 1CT, 1X, and 1Y One Line Diagrams.
- 2.11 12177-EE-10AJ, 125VDC One Line Diagram, Normal Panels 2BYS-SWG001A,B,C.
- 2.12 12177-EE-M01C, 01D, 01E, 01F, and 01G, Plant Master One Line Diagrams.
- 2.13 EQMPDS - E034AAA, E034AAB, E034AAC.
- 2.14 EQMPDS - E035AAA, E035AAB.
- 2.15 IE Notice 84-83, Battery related problems.
- 2.16 Problem Report #PR09022, Battery Charge Setpoints.

TCN-8

3.0 TECHNICAL SPECIFICATIONS

- 3.1 Section 3/4.8.2, DC Sources.
- 3.2 Sections 3/4.8.3, Onsite Power Distribution.

4.0 SPECIAL TOOLS, MATERIALS, AND MEASURING AND TEST EQUIPMENT

4.1 M&TE

- 4.1.1 Hydrometer, C&D PL-00636 or equivalent.
- 4.1.2 Mettler Paar DMA-35 Digital Hydrometer.
- 4.1.3 Fluke digital multimeter (8062A) or equivalent.
- 4.1.4 Thermometer, C&D PL-00644 or equivalent (shall not contain mercury).
- 4.1.5 Fluke/Y8100 Current Probe or equivalent.

4.2 Special Tools

- 4.2.1 Non-metallic ruler capable of measuring in increments of 1/16".
- 4.2.2 Brass suede brush (symbol # 95-11-159).

5.0 PRECAUTIONS AND LIMITATIONS

- 5.1 Personnel shall strictly adhere to the requirements of NMPC Accident Prevention Rules.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

- 5.2 Do not allow flame or sparks near the battery area. Explosion and fire is possible from hydrogen gas emitted from the cells.
 - 5.3 Never place tools across battery connections, causing sparks. Handles of tools should be insulated to help prevent explosion causing sparks.
 - 5.4 Approved chemical goggles or a face shield, apron and acid-resistant gloves shall be worn when working on batteries or handling acid.
 - 5.5 Battery room ventilation should be kept in operation at all times to limit the build-up of hydrogen.
 - 5.6 Always wear rubber gloves when working with equipment that may possibly be energized.
 - 5.7 Ensure the eye wash facility is functional.
 - 5.8 If the equipment does not meet any of the test or inspection criteria in this procedure, restore the equipment to a safe condition and immediately notify the SSS of the failure. He will determine if an Occurrence Report should be initiated.
 - 5.9 A neutralizing solution (baking soda-water) and cloths should be readily available in case acid is spilled on equipment or personnel.
 - 5.10 Ensure that the work area is clean to prevent entry of foreign matter.
 - 5.11 Voltage is present at many points inside the charger and inverter even after the AC and DC breakers have been opened.
 - 5.12 Do not use organic solvents and/or hydrocarbon based grease during battery maintenance.
- 6.0 PREREQUISITES
- 6.1 Plant Conditions - Any
 - 6.2 System Conditions - Any
 - 6.3 Obtain permission from SSS to start work and have SSS initial on Data Sheet.
 - 6.3.1 PLANT IMPACT: N/A
 - 6.4 Notify CSO of intent to perform maintenance.
 - 6.5 Notify QA and initial on Data Sheet.
 - 6.6 Personnel performing this procedure have read it in its entirety and are thoroughly familiar with its contents.

1. 關於...

2.

3.

- 6.7 Verify the test equipment is currently calibrated and record the test equipment as used.
- 6.8 Those steps or sections in this procedure not performed or applicable due to a particular situation should be marked "N/A" on the Data Sheet with explanations noted in the Remarks Section.

7.0 PROCEDURE

7.1 General Test Method

7.1.1 This test is conducted by measuring pilot cell voltage and specific gravity, charger voltage and current, and recording the measurements on the Data Sheet. A visual inspection of each battery room shall be conducted at this time.

7.1.2 Record pilot cell number on Data Sheet.

7.2 Measure temperature of pilot cell.

NOTE: When electrolyte is exactly at the High Level Line, place a (✓) check on the Data Sheet; otherwise indicate level as above (+) or below (-) High Level Line.

7.3 Measure and record the deviation of the Electrolyte level from the bottom of the High Level line. Specify whether the measurement is above or below the High Level line. Do this by using a (-) sign if below and a (+) if above the High Level line. Pilot cell electrolyte level should be above the Low Level mark but less than or equal to 1/4 inch above the High Level mark.

7.4 Measure the electrolyte specific gravity for the pilot cell as follows and record on Data Sheet.

NOTE: When a specific gravity reading of less than 1.200 occurs take readings at the top, middle, and bottom of that cell. The average of the three readings will reflect the true specific gravity of that cell. When the specific gravity is 1.200 or above, leave the appropriate columns on the Data Sheet blank and take only one reading (middle) and record. Averaging does not apply to 24/48VDC batteries.

7.4.1 At the sample tube, fill and empty the hydrometer several times in the middle of the cell before reading the specific gravity of the cell. On the 24/48VDC batteries, the measurement can only be taken from the top of the cell.

7.4.1.1 When three (3) readings are taken on a cell, calculate and record the average uncorrected specific gravity for that cell on the Data Sheet.

NOTE: Mettler Paar DMA-35 density meter is self-correcting for temperature. Step 7.4.2 shall not be performed when using the DMA-35. TCN-7

4

1

1

1

1

1

1

1

1

1

1

1

1

1

7.4.2 Correct specific gravity for temperature by adding 0.001 point for every 3°F (1.7°C) above 77°F (25°C) or subtracting 0.001 for every 3°F (1.7°C) below 77°F (25°C).

TABLE 7.4.2

125VDC AND 24/48VDC BATTERIES
CORRECTION FACTOR FOR TEMPERATURE

Temp Range	91	88	85	82	79	74	71	68	65	62	59
Hi	91	88	85	82	79	74	71	68	65	62	59
Lo	89	86	83	80	75	72	69	66	63	60	57
Corr. Factor	+0.044	+0.003	+0.002	+0.001	0	-0.001	-0.002	-0.003	-0.004	-0.005	-0.006

NOTE: IF Battery Level is at High Level Mark, no level correction is necessary. *T

7.4.3 Take the temperature corrected specific gravity and correct for level per Table 7.4.3-A for 125VDC Pilot Cells, or Table 7.4.3-B for 24/48 VDC Pilot Cells

TABLE 7.4.3-A

125VDC BATTERIES
CORRECTION FACTORS FOR LEVEL

Level	+1/4	+3/16	+1/8	+1/16	0			
Corr. Factor	+0.006	+0.0045	+0.003	+0.0015	0			
Level	-1/16	-1/8	-3/16	-1/4	-5/16	-3/8	-7/16	-1/2
Corr. Factor	-0.0015	-0.003	-0.0045	-0.006	-0.0075	-0.009	-0.0105	-0.012

TABLE 7.4.3-B

24/48VDC BATTERIES
CORRECTION FACTORS FOR LEVEL

Level	+1/4	+3/16	+1/8	+1/16	0			
Corr. Factor	+0.010	+0.0075	+0.005	+0.0025	0			
Level	-1/16	-1/8	-3/16	-1/4	-5/16	-3/8	-7/16	-1/2
Corr. Factor	-0.0025	-0.005	-0.0075	-0.010	-0.0125	-0.015	-0.0175	-0.020

1

2

3

4


5

6

7

NOTE: Pilot cell voltage readings shall be taken from the positive post of the pilot cell and the positive post of the next cell in sequence. Refer to Figure 7.5 below.

FIGURE 7.5
BATTERY CELL VOLTAGE READING METHOD



- 7.5 Using the Fluke multimeter, measure to 0.01 volt the pilot cell voltage.
- 7.6 Using the panel meter, read the charger voltage at the charger panel. Record the "As-Found" charger voltage on Data Sheet.
- 7.7 If charger voltage is out of tolerance, notify SSS, and adjust to normal value. Record "As-Left" charger voltage on Data Sheet.

TABLE 7.7
BATTERY VOLTAGES

Battery	Mode	Minimum	Normal	Maximum
24V	Float	26	27	27
24V	Equalize	--	28	30.0
125V	Float	130	135	135
125V	Equalize	--	140	142

TCN-8
TCN-8

NOTE: If corrected gravity of pilot cells are less than or equal to 1.200, the battery charging current must be less than 2 amps.

- 7.8 Measure Battery Charging Current
 - 7.8.1 125VDC Batteries
 - 7.8.1.1 Using a Fluke on the millivolt scale, record the voltage across the battery circuit shunt by measuring the voltage across the battery ammeter located in the DC Switchgear distribution panel. Convert this readings to battery amperage using the following formula: MILLIVOLTS x 20 = AMPERES.

Vertical text on the left side of the page, possibly a page number or header.

7.8.2 24/48VDC Batteries

7.8.2.1 Using a current probe measure the battery charging current at the +24V or -24V battery lead.

7.9 Visually check each battery for the following conditions:

7.9.1 Batteries and battery area clean.

7.9.2 No cracked cells or electrolyte leakage.

7.9.3 Battery room ventilation and ambient temperature normal (65°F [18.3°C] to 90°F [32.2°C]).

7.9.4 The electrolyte level of all cells above the low level mark.

7.9.5 Add water to bring all cell levels to the midpoint between high and low level marks. | 15719

7.9.6 Inspection/cleaning of Intercell connectors for corrosion.

7.9.6.1 Inspect all cell terminals and intercell connectors for any signs of corrosion. Record on Data Sheet the location and cell numbers of any corrosion which is found.

7.9.6.2 Clean cell terminals and intercell connectors of any corrosion, and neutralize the area using a baking soda-water solution (1lb. of soda per gallon of water).

7.9.6.3 As necessary, apply a thin coat of NO-OX-ID "A" grease to the surfaces which have been cleaned.

7.9.6.4 Verify that no visible corrosion exists on any cell terminals or intercell connectors.

7.10 Battery Charger (EO)


NOTE: This section is to be performed for Safety Related Inservice battery chargers (only) listed in Steps 1.2.8 through 1.2.13.

7.10.1 Cleaning

WARNING: Hazardous voltages are present inside the battery chargers.

7.10.1.1 Check interior for cleanliness.

7.10.1.2 Clean exterior, if necessary.



7.10.2 Charger Meter Checks

7.10.2.1 Using a Fluke, verify voltmeter operation by measuring the voltage across the inservice battery charger voltmeter. Record the fluke reading on Data Sheet.

7.10.2.2 Using a Fluke on millivolt scale, measure the voltage across the inservice battery charger ammeter shunt. For battery chargers 2BYS*CHGR2A1, 2A2, 2B1, and 2B2 convert this reading to battery charger amperage using the following formula: $\text{MILLIVOLT} \times 10 = \text{AMPERES}$. For battery chargers 2BYS*CHGR2C1, 2C2 convert this reading to battery charger amperage using the following formula: $\text{MILLIVOLTS} \times 1.5 = \text{AMPERES}$. Record the fluke reading on Data Sheet.

7.11 UPS Inverters (EQ)

WARNING: Hazardous voltages are present inside the inverters.

NOTE: This section is to be performed on Safety Related UPS Inverters only (listed in Steps 1.2.14 and 1.2.15).

7.11.1 Inverter Air Filters

7.11.1.1 Inspect air filters.

7.11.1.2 Clean or replace air filters as required.

7.11.1.3 Install air filters, if necessary.

7.11.2 Check inverter and rectifier for obvious overheating of components.

7.11.3 Inverter Fans

7.11.3.1 Verify operability of fan.

7.11.4 Voltage Checks

NOTE: Voltmeter selector switch must be in proper position to check outputs.

7.11.4.1 With the voltmeter select switch in the (inverter) position, check inverter output voltage by using a Fluke to measure the As Found voltage across the inverter voltmeter (120VAC). Record the Fluke reading on Data Sheet. Reading should be 120VAC, ± 2.4 VAC. (117.6 - 122.4 VAC)

NOTE: Adjust output as close to 120 VAC as practical to ensure operation within allowable tolerance.

7.11.4.2 IF reading is not 120 (117.6 TO 122.4) VAC THEN adjust R2 on the PWM, **TCN-6** Analog Logic (5490030) Circuit Board (J-7) as required to obtain 120 VAC ± 2.4 VAC Inverter Output, otherwise step N/A.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

7.11.4.3 Record final inverter output voltage on Data Sheet.

7.11.4.4 With the voltmeter select switch in the (rectifier) position, check rectifier output voltage by using a Fluke to measure the voltage across the rectifier voltmeter (140.5VDC). Record the Fluke reading on Data Sheet. Reading should be 140.5VDC \pm 1VDC.

8.0 RETURN TO NORMAL

8.1 Operations (SSS/ASSS) notified maintenance is complete.

9.0 ACCEPTANCE CRITERIA

9.1 The following criteria apply to batteries 2BWS-BAT 3A, 3B, 3C, 3D and 2BYS-BAT1A, 1B, 1C.

9.1.1 Each Pilot Cell's specific gravity shall be greater than or equal to 1.200 or battery charging current shall be equal to or less than 2 amps on float charge.

9.1.2 Each Pilot Cell's voltage shall be equal to or greater than 2.13 VDC.

9.1.3 Each Pilot Cell's electrolyte level should be above the MINIMUM LEVEL INDICATION MARK and no more than 1/4" above the MAXIMUM LEVEL INDICATION MARK.

9.2 The following criteria apply to UPS 2VBA*UPS2A and 2VBA*UPS2B.

9.2.1 Inverter output voltage 120VAC, -2.4, +2.4 VAC (117.6-122.4 VAC).

9.2.2 Rectifier output voltage 140.5 \pm 1VDC.

10.0 ATTACHMENTS

10.1 Data Sheets.

TCN-4

22
23
24
25
26
27
28
29
30

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS:

INITIAL / DATE

Prerequisites

- | | | | |
|-----|---------------------------------|--------|------------|
| 6.1 | Plant conditions satisfactory. | Maint. | _____/____ |
| 6.2 | System conditions satisfactory. | Maint. | _____/____ |
| 6.3 | SSS permission. | SSS | _____/____ |

PLANT IMPACT: N/A

- | | | | |
|-----|------------------------------------|--------|------------|
| 6.4 | CSO notified. | CSO | _____/____ |
| 6.5 | QA notified. | Maint. | _____/____ |
| 6.6 | Personnel familiar with procedure. | Maint. | _____/____ |

6.7	<u>Test Equipment</u>	<u>I.D. No.</u>	<u>Cal. Due Date</u>	
	<u>Hydrometer</u>	_____	_____	
	<u>Voltmeter</u>	_____	_____	
	<u>Thermometer</u>	_____	_____	
	<u>Current Probe</u>	_____	_____	
	_____	_____	_____	
	_____	_____	_____	
			Maint.	_____/____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

- 7.1.2 Pilot cell Number _____ Maint. _____/_____
- 7.2 Pilot cell temperature. _____ Maint. _____/_____
Temp. _____ $\bar{\quad}$ /°F $\bar{\quad}$ /°C
- 7.3 Pilot cell electrolyte at high level line
 $\bar{\quad}$ / (check if applicable) - Indicate level -
if above (+) or below (-). Level _____. Maint. _____/_____
- 7.4.1 Specific gravity. _____ Maint. _____/_____ | TCN-7
- 7.4.2 Specific gravity corrected for _____ Maint. _____/_____
temperature _____. Maint. Verifier _____/_____
 $\bar{\quad}$ / N/A, DMA-35 used. | TCN-7
- *7.4.3 Specific gravity corrected for _____ Maint. _____/_____
level _____. (shall be ≥ 1.200) Maint. Verifier _____/_____
 $\bar{\quad}$ / - N/A, No Level Correction required.
- *7.5 Pilot cell voltage (≥ 2.13 VDC). _____ Maint. _____/_____
Volts-DC _____
- 7.6 Charger No. 2BWS-CHGR3A1 "As-Found" _____ VDC Maint. _____/_____
- 7.7 Charger No. 2BWS-CHGR3A1 "As-Left" _____ VDC Maint. _____/_____
- *7.8.2.1 Charging current (less than 2 amps). _____ Maint. _____/_____
_____ Amps
- 7.9 Visual
- 7.9.1 Battery and area clean. _____ Maint. _____/_____
- 7.9.2 No cracked cells or leakage. _____ Maint. _____/_____
- 7.9.3 Room temperature normal. _____ Maint. _____/_____
- 7.9.4 All cell electrolyte levels above the low
level mark. _____ Maint. _____/_____

*Denotes Trendable Data

11

2

3

4

5

6

...

Battery No. 2BWS-BAT3A (+)

Attachment 10.1
Page 3 of 22.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.9.5 All cell levels to midpoint between high and low level marks.

N/A, no water added.

Maint. _____/_____

15719

7.9.6 Inspection/cleaning for corrosion.

7.9.6.1 All cell terminals and intercell connectors inspected for corrosion. Record the location and cell number of any corrosion.

Maint. _____/_____

7.9.6.2 Cell terminals and intercell connectors cleaned of corrosion and neutralized /NA

Maint. _____/_____

7.9.6.3 NO-OX-ID "A" grease applied as necessary. /NA

Maint. _____/_____

7.9.6.4 Verify that no visible corrosion exists on any cell terminals or intercell connectors.

Maint. _____/_____

100

100

100

100

100

100

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.1.2	Pilot cell Number _____	Maint.	_____/____
7.2	Pilot cell temperature. _____ Temp. _____ $\bar{\quad}$ °F $\bar{\quad}$ °C	Maint.	_____/____
7.3	Pilot cell electrolyte at high level line $\bar{\quad}$ / (check if applicable) - Indicate level - if above (+) or below (-). Level _____.	Maint.	_____/____
7.4.1	Specific gravity. _____	Maint.	_____/____
7.4.2	Specific gravity corrected for temperature _____. $\bar{\quad}$ / N/A, DMA-35 used.	Maint. Verifier	_____/____
*7.4.3	Specific gravity corrected for level _____. (shall be \geq 1.200) $\bar{\quad}$ / - N/A, No Level Correction required.	Maint. Verifier	_____/____
*7.5	Pilot cell voltage (\geq 2.13VDC). Volts-DC _____	Maint.	_____/____
7.6	Charger No. <u>2BWS-CHGR3B1</u> "As-Found" _____ VDC	Maint.	_____/____
7.7	Charger No. <u>2BWS-CHGR3B1</u> "As-Left" _____ VDC	Maint.	_____/____
*7.8.2.1	Charging current (less than 2 amps). _____ Amps	Maint.	_____/____
7.9	<u>Visual</u>		
7.9.1	Battery and area clean.	Maint.	_____/____
7.9.2	No cracked cells or leakage.	Maint.	_____/____
7.9.3	Room temperature normal.	Maint.	_____/____
7.9.4	All cell electrolyte levels above the low level mark.	Maint.	_____/____

TCN-7

TCN-7

*Denotes Trendable Data

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.9.5 All cell levels to midpoint between high and low level marks.

N/A, no water added.

Maint.

_____/____

15719

7.9.6 Inspection/cleaning for corrosion.

7.9.6.1 All cell terminals and intercell connectors inspected for corrosion. Record the location and cell number of any corrosion.

Maint.

_____/____

7.9.6.2 Cell terminals and intercell connectors cleaned of corrosion and neutralized /NA

Maint.

_____/____

7.9.6.3 NO-OX-ID "A" grease applied as necessary. /NA

Maint.

_____/____

7.9.6.4 Verify that no visible corrosion exists on any cell terminals or intercell connectors.

Maint.

_____/____

10-10-10

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.1.2	Pilot cell Number _____	Maint.	_____/____
7.2	Pilot cell temperature. _____ Temp. _____ $\bar{\quad}$ /°F $\bar{\quad}$ /°C	Maint.	_____/____
7.3	Pilot cell electrolyte at high level line $\bar{\quad}$ / (check if applicable) - Indicate level - if above (+) or below (-). Level _____.	Maint.	_____/____
7.4.1	Specific gravity. _____	Maint.	_____/____
7.4.2	Specific gravity corrected for temperature _____. $\bar{\quad}$ / N/A, DMA-35 used.	Maint. Verifier	_____/____
*7.4.3	Specific gravity corrected for level _____. (shall be ≥ 1.200) $\bar{\quad}$ / - N/A, No Level Correction required.	Maint. Verifier	_____/____
*7.5	Pilot cell voltage (≥ 2.13 VDC). Volts-DC _____	Maint.	_____/____
7.6	Charger No. <u>2BWS-CHGR3C1</u> "As-Found" _____ VDC	Maint.	_____/____
7.7	Charger No. <u>2BWS-CHGR3C1</u> "As-Left" _____ VDC	Maint.	_____/____
*7.8.2.1	Charging current (less than 2 amps). _____ Amps	Maint.	_____/____
7.9	<u>Visual</u>		
7.9.1	Battery and area clean.	Maint.	_____/____
7.9.2	No cracked cells or leakage.	Maint.	_____/____
7.9.3	Room temperature normal.	Maint.	_____/____
7.9.4	All cell electrolyte levels above the low level mark.	Maint.	_____/____

*Denotes Trendable Data

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.9.5 All cell levels to midpoint between high and low level marks.

N/A, no water added.

Maint.

_____/____

15719

7.9.6 Inspection/cleaning for corrosion.

7.9.6.1 All cell terminals and intercell connectors inspected for corrosion. Record the location and cell number of any corrosion.

Maint.

_____/____

7.9.6.2 Cell terminals and intercell connectors cleaned of corrosion and neutralized /NA

Maint.

_____/____

7.9.6.3 NO-OX-ID "A" grease applied as necessary. /NA


Maint.

_____/____

7.9.6.4 Verify that no visible corrosion exists on any cell terminals or intercell connectors.

Maint.

_____/____



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.1.2	Pilot cell Number _____	Maint.	_____/____
7.2	Pilot cell temperature. _____ Temp. _____ $\frac{\quad}{\quad}$ °F $\frac{\quad}{\quad}$ °C	Maint.	_____/____
7.3	Pilot cell electrolyte at high level line $\frac{\quad}{\quad}$ (check if applicable) - Indicate level - if above (+) or below (-). Level _____.	Maint.	_____/____
7.4.1	Specific gravity. _____	Maint.	_____/____ TCN-7
7.4.2	Specific gravity corrected for temperature _____. $\frac{\quad}{\quad}$ / N/A, DMA-35 used.	Maint. Verifier	_____/____ TCN-7
*7.4.3	Specific gravity corrected for level _____. (shall be ≥ 1.200) $\frac{\quad}{\quad}$ - N/A, No Level Correction required.	Maint. Verifier	_____/____
*7.5	Pilot cell voltage (≥ 2.13 VDC). Volts-DC _____	Maint.	_____/____
7.6	Charger No. <u>2BWS-CHGR3D1</u> "As-Found" _____ VDC	Maint.	_____/____
7.7	Charger No. <u>2BWS-CHGR3D1</u> "As-Left" _____ VDC	Maint.	_____/____
*7.8.2.1	Charging current (less than 2 amps). _____ Amps	Maint.	_____/____
7.9	<u>Visual</u>		
7.9.1	Battery and area clean.	Maint.	_____/____
7.9.2	No cracked cells or leakage.	Maint.	_____/____
7.9.3	Room temperature normal.	Maint.	_____/____
7.9.4	All cell electrolyte levels above the low level mark.	Maint.	_____/____

*Denotes Trendable Data

DATA SHEET

DC/UPS WEEKLY CHECKS

N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.9.5 All cell levels to midpoint between high and low level marks.

N/A, No water added.

Maint.

_____/____

15719

7.9.6 Inspection/cleaning for corrosion.

7.9.6.1 All cell terminals and intercell connectors inspected for corrosion. Record the location and cell number of any corrosion.

Maint.

_____/____

7.9.6.2 Cell terminals and intercell connectors cleaned of corrosion and neutralized /NA

Maint.

_____/____

7.9.6.3 NO-OX-ID "A" grease applied as necessary. /NA

Maint.

_____/____

7.9.6.4 Verify that no visible corrosion exists on any cell terminals or intercell connectors.

Maint.

_____/____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Battery No. 2BYS-BAT1A

Attachment 10.1
Page 10 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.1.2	Pilot cell Number _____	Maint.	_____/____
7.2	Pilot cell temperature. _____ Temp. _____ $\bar{\square}$ /°F $\bar{\square}$ /°C	Maint.	_____/____
7.3	Pilot cell electrolyte at high level line $\bar{\square}$ / (check if applicable) - Indicate level - if above (+) or below (-). Level _____.	Maint.	_____/____
7.4.1	Specific gravity. _____ TOP _____ MIDDLE _____ BOTTOM _____	Maint.	_____/____
7.4.1.1	Average specific gravity _____ $\bar{\square}$ / Not Applicable	Maint. Verifier	_____/____
7.4.2	Specific gravity corrected for temperature _____. $\bar{\square}$ / N/A, DMA-35 used.	Maint. Verifier	_____/____
*7.4.3	Specific gravity corrected for level _____. (shall be ≥ 1.200) $\bar{\square}$ / - N/A, No Level Correction required.	Maint. Verifier	_____/____
*7.5	Pilot cell voltage (≥ 2.13 VDC). Volts-DC _____	Maint.	_____/____
7.6	Charger No. <u>2BYS-CHGR1A1</u> "As-Found" _____ VDC	Maint.	_____/____
7.7	Charger No. <u>2BYS-CHGR1A1</u> "As-Left" _____ VDC	Maint.	_____/____
*7.8.1.1	Charging current (less than 2 amps). _____ Amps	Maint.	_____/____
7.9	<u>Visual</u>		
7.9.1	Battery and area clean.	Maint.	_____/____
7.9.2	No cracked cells or leakage.	Maint.	_____/____
7.9.3	Room temperature normal.	Maint.	_____/____

*Denotes Trendable Data

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

DATA SHEET

DC/UPS WEEKLY CHECKS

N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

- | | | | |
|---------|----------------------------------------------------------------------------------------------------------------------------|--------|---------------|
| 7.9.4 | All cell electrolyte levels above the low level mark. | Maint. | _____ / _____ |
| 7.9.5 | All cell levels to midpoint between high and low level marks. | | |
| | <input type="checkbox"/> N/A, no water added. | Maint. | _____ / _____ |
| 7.9.6 | Inspection/cleaning for corrosion. | | |
| 7.9.6.1 | All cell terminals and intercell connectors inspected for corrosion. Record the location and cell number of any corrosion. | | |
| | _____ | | |
| | _____ | | |
| | _____ | | |
| | | Maint. | _____ / _____ |
| 7.9.6.2 | Cell terminals and intercell connectors cleaned of corrosion and neutralized <u> </u> /NA | Maint. | _____ / _____ |
| 7.9.6.3 | NO-OX-ID "A" grease applied as necessary. <u> </u> /NA | Maint. | _____ / _____ |
| 7.9.6.4 | Verify that no visible corrosion exists on any cell terminals or intercell connectors. | Maint. | _____ / _____ |

15719

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Battery No. 2BYS-BAT1B

Attachment 10.1
Page 12 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.1.2	Pilot cell Number _____	Maint.	_____/____
7.2	Pilot cell temperature. Temp. _____ $\bar{\quad}$ /°F $\bar{\quad}$ /°C	Maint.	_____/____
7.3	Pilot cell electrolyte at high level line $\bar{\quad}$ / (check if applicable) - Indicate level - if above (+) or below (-). Level _____.	Maint.	_____/____
7.4.1	Specific gravity. _____ TOP _____ MIDDLE _____ BOTTOM _____	Maint.	_____/____
7.4.1.1	Average specific gravity _____ $\bar{\quad}$ / Not Applicable	Maint. Verifier	_____/____
7.4.2	Specific gravity corrected for temperature _____. $\bar{\quad}$ / N/A, DMA-35 used.	Maint. Verifier	_____/____
*7.4.3	Specific gravity corrected for level _____. (shall be ≥ 1.200) $\bar{\quad}$ / - N/A, No Level Correction required.	Maint. Verifier	_____/____
*7.5	Pilot cell voltage (≥ 2.13 VDC). Volts-DC _____	Maint.	_____/____
7.6	Charger No. <u>2BYS-CHGR1B1</u> "As-Found" _____ VDC	Maint.	_____/____
7.7	Charger No. <u>2BYS-CHGR1B1</u> "As-Left" _____ VDC	Maint.	_____/____
*7.8.1.1	Charging current (less than 2 amps). _____ Amps	Maint.	_____/____
7.9	<u>Visual</u>		
7.9.1	Battery and area clean.	Maint.	_____/____
7.9.2	No cracked cells or leakage.	Maint.	_____/____
7.9.3	Room temperature normal.	Maint.	_____/____

TCN-7

TCN-7

*Denotes Trendable Data

Battery No. 2BYS-BAT1B

Attachment 10.1
Page 13 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

- | | | | | |
|---------|----------------------------------------------------------------------------------------------------------------------------|--------|---------------|-------|
| 7.9.4 | All cell electrolyte levels above the low level mark. | Maint. | _____ / _____ | |
| 7.9.5 | All cell levels to midpoint between high and low level marks. | | | 15719 |
| | <input type="checkbox"/> N/A, no water added. | Maint. | _____ / _____ | |
| 7.9.6 | Inspection/cleaning for corrosion. | | | |
| 7.9.6.1 | All cell terminals and intercell connectors inspected for corrosion. Record the location and cell number of any corrosion. | | | |
| | _____ | | | |
| | _____ | | | |
| | _____ | | | |
| | | Maint. | _____ / _____ | |
| 7.9.6.2 | Cell terminals and intercell connectors cleaned of corrosion and neutralized <u> </u> /NA | Maint. | _____ / _____ | |
| 7.9.6.3 | NO-OX-ID "A" grease applied as necessary. <u> </u> /NA | Maint. | _____ / _____ | |
| 7.9.6.4 | Verify that no visible corrosion exists on any cell terminals or intercell connectors. | Maint. | _____ / _____ | |

Battery No. 2BYS-BAT1C

Attachment 10.1
Page 14 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.1.2	Pilot cell Number _____	Maint.	_____/____
7.2	Pilot cell temperature. _____ Temp. _____ $\bar{\quad}$ /°F $\bar{\quad}$ /°C	Maint.	_____/____
7.3	Pilot cell electrolyte at high level line $\bar{\quad}$ / (check if applicable) - Indicate level - if above (+) or below (-). Level _____.	Maint.	_____/____
7.4.1	Specific gravity. _____ TOP _____ MIDDLE _____ BOTTOM _____	Maint.	_____/____
7.4.1.1	Average specific gravity _____ $\bar{\quad}$ / Not Applicable	Maint. Verifier	_____/____
7.4.2	Specific gravity corrected for temperature _____. $\bar{\quad}$ / N/A, DMA-35 used.	Maint. Verifier	_____/____
*7.4.3	Specific gravity corrected for level _____. (shall be ≥ 1.200) $\bar{\quad}$ / - N/A, No Level Correction required.	Maint. Verifier	_____/____
*7.5	Pilot cell voltage (≥ 2.13 VDC). Volts-DC _____	Maint.	_____/____
7.6	Charger No. <u>2BYS-CHGR1C1</u> "As-Found" _____ VDC	Maint.	_____/____
7.7	Charger No. <u>2BYS-CHGR1C1</u> "As-Left" _____ VDC	Maint.	_____/____
*7.8.1.1	Charging current (less than 2 amps). _____ Amps	Maint.	_____/____
7.9	<u>Visual</u>		
7.9.1	Battery and area clean.	Maint.	_____/____
7.9.2	No cracked cells or leakage.	Maint.	_____/____
7.9.3	Room temperature normal.	Maint.	_____/____

*Denotes Trendable Data

1920 10 10 10 10 10

Battery No. 2BYS-BAT1C

Attachment 10.1
Page 15 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.9.4 All cell electrolyte levels above the low level mark. Maint. _____/_____

7.9.5 All cell levels to midpoint between high and low level marks. _____/_____

N/A, no water added. Maint. _____/_____

7.9.6 Inspection/cleaning for corrosion.

7.9.6.1 All cell terminals and intercell connectors inspected for corrosion. Record the location and cell number of any corrosion.

7.9.6.2 Cell terminals and intercell connectors cleaned of corrosion and neutralized /NA Maint. _____/_____

7.9.6.3 NO-OX-ID "A" grease applied as necessary. /NA Maint. _____/_____

7.9.6.4 Verify that no visible corrosion exists on any cell terminals or intercell connectors. Maint. _____/_____

15719

100

Battery No. 2BYS*CHGR2A1.2A2

Attachment 10.1 | *
Page 16 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.10	Charger No. _____		
7.10.1	<u>Charger Cleaning</u>		
7.10.1.1	Checked interior.	Maint.	_____/____
7.10.1.2	Cleaned exterior.	Maint.	_____/____
7.10.2	<u>Charger Meter Checks</u>		
*7.10.2.1	Fluke reading: _____ volts.	Maint.	_____/____
*7.10.2.2	Fluke reading: _____ millivolts.	Maint.	_____/____
	Converted reading: millivolts x 10 = _____ amps.	Maint.	_____/____

*Denotes Trendable Data

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter. Maint. _____/_____

7.11.1.3 Installed filter. Maint. _____/_____

7.11.2 Checked for signs of overheating. Maint. _____/_____

7.11.3 Inverter Fan

7.11.3.1 Verified operability. Maint. _____/_____

7.11.4 Voltage Checks


*7.11.4.1 Inverter output voltage fluke reading As Found:
_____ VAC. Maint. _____/_____

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required. Maint. _____/_____

7.11.4.3 Final Inverter Output Voltage Fluke Reading.
_____ VAC. Maint. _____/_____
(Reading 120 VAC \pm 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:
_____ VDC Maint. _____/_____ | * 2
(Reading 140.5VDC \pm 1VDC)

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.10 Charger No. _____

7.10.1 Charger Cleaning

7.10.1.1 Checked interior. Maint. _____/_____

7.10.1.2 Cleaned exterior. Maint. _____/_____

7.10.2 Charger Meter Checks

*7.10.2.1 Fluke reading: _____ volts. Maint. _____/_____

*7.10.2.2 Fluke reading: _____ millivolts. Maint. _____/_____

Converted reading: _____

millivolts x 10 = _____ amps. Maint. _____/_____

*Denotes Trendable Data

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter. Maint. _____/_____

7.11.1.3 Installed filter. Maint. _____/_____

7.11.2 Checked for signs of overheating. Maint. _____/_____

7.11.3 Inverter Fan

7.11.3.1 Verified operability. Maint. _____/_____

7.11.4 Voltage Checks


*7.11.4.1 Inverter output voltage fluke reading As Found:
_____ VAC. Maint. _____/_____

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required. Maint. _____/_____

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.
_____ VAC. Maint. _____/_____
(Reading 120 VAC ± 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:
_____ VDC Maint. _____/_____ | *2
(Reading 140.5VDC, ±1VDC)

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.10 Charger No. _____

7.10.1 Charger Cleaning

7.10.1.1 Checked interior. Maint. _____/_____

7.10.1.2 Cleaned exterior. Maint. _____/_____

7.10.2 Charger Meter Checks

*7.10.2.1 Fluke reading: _____ volts. Maint. _____/_____

*7.10.2.2 Fluke reading: _____ millivolts. Maint. _____/_____

Converted reading:
millivolts x 1.5 = _____ amps. Maint. _____/_____

*Denotes Trendable Data

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Return to Normal

8.1 Operations notified maintenance is complete. Maint. _____/_____

Acceptance Criteria

9.1 The following criteria apply to batteries
2BWS-BAT3A, 3B, 3C, 3D and 2BYS-BAT1A, 1B, 1C.

9.1.1 Each pilot cell specific gravity shall be
greater than or equal to 1.200 or battery
charging current shall be equal to or less
than 2 amps on float charge. Maint. _____/_____

9.1.2 Each pilot cell's voltage shall be equal
to or greater than 2.13 VDC. Maint. _____/_____

9.1.3 Each pilot cell's electrolyte level shall
be above the MINIMUM LEVEL INDICATION MARK
and no more than 1/4" above the MAXIMUM
LEVEL INDICATION MARK. Maint. _____/_____


9.2 The following criteria apply to UPS 2VBA*UPS2A
2VBA*UPS2B.


9.2.1 Inverter output voltage 120VAC ± 2.4 , VAC
(117.6 - 122.4 VAC) Maint. _____/_____ | TCN 4

9.2.2 Rectifier output voltage 140.5 ± 1 VDC. Maint. _____/_____
Maint.

Signature Table

	INITIALS	SIGNATURE	PRINTED NAME
Performed by:	_____	_____	_____
Performed by:	_____	_____	_____
Performed by:	_____	_____	_____
Performed by:	_____	_____	_____
Performed by:	_____	_____	_____
Verifier:	_____	_____	_____
Verifier:	_____	_____	_____





DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665


A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>WAR 18-18-91</u>
7.11.1.3	Installed filter.	Maint.	<u>WAR 18-18-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>WAR 18-18-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>WAR 18-18-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.50</u> VAC.	Maint.	<u>WAR 18-18-91</u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>WAR 18-18-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.50</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>WAR 18-18-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.53</u> VDC (Reading 140.5VDC \pm 1VDC)	Maint.	<u>WAR 18-18-91#2</u>

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter. Maint. WAR 18-18-91

7.11.1.3 Installed filter. Maint. WAR 18-18-91

7.11.2 Checked for signs of overheating. Maint. WAR 18-18-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability. Maint. WAR 18-18-91 SEE NOTE #2

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:
119.86 VAC. Maint. WAR 18-18-91

7.11.4.2 Inverter Output Voltage adjusted
~~X~~ N/A, Not Required. Maint. WAR 18-18-91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.
119.86 VAC. Maint. WAR 18-18-91
(Reading 120 VAC \pm 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:
140.76 VDC Maint. WAR 18-18-91
(Reading 140.5VDC, \pm 1VDC)

*Denotes Trendable Data

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

MH 8-11-91

7.11.1.3 Installed filter.

Maint.

MH 1

7.11.2 Checked for signs of overheating.

Maint.

MH 1

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

MH 1

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

119.6 VAC.

MH 1

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required.

Maint.

MH 1

7.11.4.3 Final Inverter Output Voltage Fluke Reading.
119.6 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

MH 1

*7.11.4.4 Rectifier output voltage fluke reading:
140.5 VDC
(Reading 140.5VDC \pm 1VDC)

Maint.

MH 8-11-91 *2

*Denotes Trendable Data

THE UNIVERSITY OF CHICAGO PRESS

34

34

34

34

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

MH 1 8-11-91

7.11.1.3 Installed filter.

Maint.

MH 1

7.11.2 Checked for signs of overheating.

Maint.

MH 1

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

MH 1

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120. VAC.

MH 1

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required.

Maint.

MH 1

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.

120. VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

MH 1

*7.11.4.4 Rectifier output voltage fluke reading:

140.7 VDC
(Reading 140.5VDC, \pm 1VDC)

Maint.

MH 18-11-91 *2

*Denotes Trendable Data



Vertical text or markings along the left edge of the page, possibly bleed-through from the reverse side.

Vertical text or markings along the right edge of the page, possibly bleed-through from the reverse side.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>BEA 17/28/91</u>
7.11.1.3	Installed filter.	Maint.	<u>BEA 17/28/91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>BEA 17/28/91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>BEA 17/28/91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.5</u> VAC.	Maint.	<u>BEA 17/28/91</u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>BEA 17/28/91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.5</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>BEA 17/28/91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.5</u> VDC (Reading 140.5VDC \pm 1VDC)	Maint.	<u>BEA 17/28/91</u> *2

*Denotes Trendable Data

[The following text is extremely faint and largely illegible. It appears to be a list or a series of entries, possibly containing names and dates. The text is organized into several vertical columns.]

[Illegible text block 1]

[Illegible text block 2]

[Illegible text block 3]

[Illegible text block 4]

[Illegible text block 5]

[Illegible text block 6]

[Illegible text block 7]

[Illegible text block 8]

[Illegible text block 9]

[Illegible text block 10]

[Illegible text block 11]

[Illegible text block 12]

[Illegible text block 13]

[Illegible text block 14]

[Illegible text block 15]

[Illegible text block 16]

[Illegible text block 17]

[Illegible text block 18]

[Illegible text block 19]

[Illegible text block 20]

[Illegible text block 21]

[Illegible text block 22]

[Illegible text block 23]

[Illegible text block 24]

[Illegible text block 25]

[Illegible text block 26]

[Illegible text block 27]

[Illegible text block 28]

[Illegible text block 29]

[Illegible text block 30]

[Illegible text block 31]

[Illegible text block 32]

[Illegible text block 33]

[Illegible text block 34]

[Illegible text block 35]

[Illegible text block 36]

[Illegible text block 37]

[Illegible text block 38]

[Illegible text block 39]

[Illegible text block 40]

[Illegible text block 41]

[Illegible text block 42]

[Illegible text block 43]

[Illegible text block 44]

[Illegible text block 45]

[Illegible text block 46]

[Illegible text block 47]

[Illegible text block 48]

[Illegible text block 49]

[Illegible text block 50]

[Illegible text block 51]

[Illegible text block 52]

[Illegible text block 53]

[Illegible text block 54]

[Illegible text block 55]

[Illegible text block 56]

[Illegible text block 57]

[Illegible text block 58]

[Illegible text block 59]

[Illegible text block 60]

[Illegible text block 61]

[Illegible text block 62]

[Illegible text block 63]

[Illegible text block 64]

[Illegible text block 65]

[Illegible text block 66]

[Illegible text block 67]

[Illegible text block 68]

[Illegible text block 69]

[Illegible text block 70]

[Illegible text block 71]

[Illegible text block 72]

[Illegible text block 73]

[Illegible text block 74]

[Illegible text block 75]

[Illegible text block 76]

[Illegible text block 77]

[Illegible text block 78]

[Illegible text block 79]

[Illegible text block 80]

[Illegible text block 81]

[Illegible text block 82]

[Illegible text block 83]

[Illegible text block 84]

[Illegible text block 85]

[Illegible text block 86]

[Illegible text block 87]

[Illegible text block 88]

[Illegible text block 89]

[Illegible text block 90]

[Illegible text block 91]

[Illegible text block 92]

[Illegible text block 93]

[Illegible text block 94]

[Illegible text block 95]

[Illegible text block 96]

[Illegible text block 97]

[Illegible text block 98]

[Illegible text block 99]

[Illegible text block 100]

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

BEJ 17/28/91

7.11.1.3 Installed filter.

Maint.

BEJ 17/28/91

7.11.2 Checked for signs of overheating.

Maint.

BEJ 17/28/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

BEJ 17/28/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

119.8 VAC.

BEJ 17/28/91

7.11.4.2 Inverter Output Voltage adjusted

N/A, Not Required.

Maint.

BEJ 17/28/91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.

119.8 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

BEJ 17/28/91


*7.11.4.4 Rectifier output voltage fluke reading:

140.7 VDC
(Reading 140.5VDC, \pm 1VDC).

Maint.

BEJ 17/28/91 *2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

SN 18-4-91

7.11.1.3 Installed filter.

Maint.

SN 18-4-91

7.11.2 Checked for signs of overheating.

Maint.

SN 18-4-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

SN 18-4-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.0 VAC.

SN 18-4-91

7.11.4.2 Inverter Output Voltage adjusted

N/A, Not Required.

Maint.

SN 18-4-91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

Maint.

120.0 VAC.
(Reading 120 VAC \pm 2.4 VAC)

SN 18-4-91

*7.11.4.4 Rectifier output voltage fluke reading:

Maint.

140.0 VDC
(Reading 140.5VDC \pm 1VDC)

SN 18-4-91*2

*Denotes Trendable Data

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>SN 18-4-91</u>
7.11.1.3	Installed filter.	Maint.	<u>SN 18-4-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>SN 18-4-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>SN 18-4-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.0</u> VAC.	Maint.	<u>SN 18-4-91</u>
7.11.4.2	Inverter Output Voltage adjusted 8 N/A, Not Required.	Maint.	<u>SN 18-4-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120.0</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>SN 18-4-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>170.0</u> VDC (Reading 140.5VDC, \pm 1VDC)	Maint.	<u>SN 18-4-91</u> *2

*Denotes Trendable Data

10

10

10

10

10

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>MH / 7-14-91</u>
7.11.1.3	Installed filter.	Maint.	<u>MH /</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>MH /</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>MH /</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.5</u> VAC.	Maint.	<u>MH /</u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>MH /</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.5</u> VAC. (Reading 120 VAC ± 2.4 VAC)	Maint.	<u>MH /</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.5</u> VDC (Reading 140.5VDC ±1VDC)	Maint.	<u>MH / 7-14-91*2</u>

*Denotes Trendable Data

1

2

3

4

5

6

7

8

9

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>MH</u> / <u>7-14-91</u>
7.11.1.3	Installed filter.	Maint.	<u>MH</u> / <u> </u>
7.11.2	Checked for signs of overheating.	Maint.	<u>MH</u> / <u> </u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>MH</u> / <u> </u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.9</u> VAC.	Maint.	<u>MH</u> / <u> </u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>MH</u> / <u> </u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.9</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>MH</u> / <u> </u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.7</u> VDC (Reading 140.5VDC, \pm 1VDC)	Maint.	<u>MH</u> / <u>7-14-91</u> *2

*Denotes Trendable Data

4

4

4

4

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

BC. 17/21/91

7.11.1.3 Installed filter.

Maint.

BC. 17/21/91

7.11.2 Checked for signs of overheating.

Maint.

BC. 17/21/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

BC. 17/21/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

119.46 VAC.

BC. 17/21/91

7.11.4.2 Inverter Output Voltage adjusted

~~X~~ N/A, Not Required.

Maint.

BC. 17/21/91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

119.46 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

BC. 17/21/91

*7.11.4.4 Rectifier output voltage fluke reading:


140.55 VDC

(Reading 140.5VDC \pm 1VDC)

Maint.

BC. 17/21/91*2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

BC. 12/21/91

7.11.1.3 Installed filter.

Maint.

BC. 12/21/91

7.11.2 Checked for signs of overheating.

Maint.

BC. 12/21/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

BC. 12/21/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

119.87 VAC.

BC. 12/21/91

7.11.4.2 Inverter Output Voltage adjusted
~~X~~ N/A, Not Required.

Maint.

BC. 12/21/91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.

119.87 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

BC. 12/21/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.81 VDC
(Reading 140.5VDC, \pm 1VDC)

Maint.

BC. 12/21/91 *2

*Denotes Trendable Data

23

24

25

26

27

28

29

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. Jm 1/7/91

7.11.1.3 Installed filter.

Maint. Jm 1/7/91

7.11.2 Checked for signs of overheating.

Maint. Jm 1/7/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. Jm 1/7/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

119.56 VAC.

Maint. Jm 1/7/91

7.11.4.2 Inverter Output Voltage adjusted
N/A, Not Required.

Maint. Jm 1/7/91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.
119.56 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint. Jm 1/7/91

*7.11.4.4 Rectifier output voltage fluke reading:
140.57 VDC
(Reading 140.5VDC \pm 1VDC)

Maint. Jm 1/7/91 *2

*Denotes Trendable Data

1

2

3

4

5

6

7

8

9

10

11

12

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. TM 17/1/91

7.11.1.3 Installed filter.

Maint. TM 17/1/91

7.11.2 Checked for signs of overheating.

Maint. TM 17/1/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. TM 17/1/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

119.9 VAC.

Maint. TM 17/1/91

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required.

Maint. TM 17/1/91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.

119.9 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint. TM 17/1/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.8 VDC
(Reading 140.5VDC, \pm 1VDC)

Maint. TM 17/1/91 #2

*Denotes Trendable Data

.

.

.

.

.

.

.

.

.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

SN 17791

7.11.1.3 Installed filter.

Maint.

SN 17791

7.11.2 Checked for signs of overheating.

Maint.

SN 17791

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

SN 17791

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.1 VAC.

SN 17791

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required.

Maint.

SN 17791

7.11.4.3 Final Inverter Output Voltage Fluke Reading.
120.1 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

SN 17791

*7.11.4.4 Rectifier output voltage fluke reading:
140.3 VDC
(Reading 140.5VDC \pm 1VDC)

Maint.

SN 17791 *2

*Denotes Trendable Data

1
2
3
4
5

.

6
7

.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

SN 177-91

7.11.1.3 Installed filter.

Maint.

SN 177-91

7.11.2 Checked for signs of overheating.

Maint.

SN 177-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

SN 177-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.3 VAC.

SN 177-91

7.11.4.2 Inverter Output Voltage adjusted

~~SN/A~~, Not Required.

Maint.

SN 177-91

7.11.4.3 Final Inverter Output Voltage

Fluke Reading.

120.3 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

SN 177-91

*7.11.4.4 Rectifier output voltage fluke reading:


140.4 VDC

(Reading 140.5VDC, \pm 1VDC)

Maint.

SN 177-91 *2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

TM 16/17/91

7.11.1.3 Installed filter.

Maint.

TM 16/17/91

7.11.2 Checked for signs of overheating.

Maint.

TM 16/17/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

TM 16/17/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

TM 16/17/91

119.7 VAC.

7.11.4.2 Inverter Output Voltage adjusted

~~DN/A~~, Not Required.

Maint.

TM 16/17/91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

119.7 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

TM 16/17/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.5 VDC

(Reading 140.5VDC \pm 1VDC)

Maint.

TM 16/17/91 *2

*Denotes Trendable Data

42

43

44

45

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

TM 16/17/91

7.11.1.3 Installed filter.

Maint.

TM 16/17/91

7.11.2 Checked for signs of overheating.

Maint.

TM 16/17/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

TM 16/17/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.5 VAC.

TM 16/17/91

7.11.4.2 Inverter Output Voltage adjusted
~~EP~~N/A, Not Required.

Maint.

TM 16/17/91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.
120.5 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.


TM 16/17/91

*7.11.4.4 Rectifier output voltage fluke reading:
140.6 VDC
(Reading 140.5VDC, \pm 1VDC)

Maint.

TM 16/17/91 *2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>KCK</u> / <u>6-23-91</u>
7.11.1.3	Installed filter.	Maint.	<u>KCK</u> / <u>6-23-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>KCK</u> / <u>6-23-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>KCK</u> / <u>6-23-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.45</u> VAC.	Maint.	<u>KCK</u> / <u>6-23-91</u>
7.11.4.2	Inverter Output Voltage adjusted N/A, Not Required.	Maint.	<u>KCK</u> / <u>6-23-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.45</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>KCK</u> / <u>6-23-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.35</u> VDC (Reading 140.5VDC \pm 1VDC)	Maint.	<u>KCK</u> / <u>6-23-91</u> *2

*Denotes Trendable Data

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>100K / 6-23-91</u>
7.11.1.3	Installed filter.	Maint.	<u>100K / 6-23-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>100K / 6-23-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>100K / 6-23-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.55</u> VAC.	Maint.	<u>100K / 6-23-91</u>
7.11.4.2	Inverter Output Voltage adjusted E N/A, Not Required.	Maint.	<u>100K / 6-23-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120.55</u> VAC. (Reading 120 VAC ± 2.4 VAC)	Maint.	<u>100K / 6-23-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.81</u> VDC (Reading 140.5VDC, ±1VDC)	Maint.	<u>100K / 6-23-91</u> #2

*Denotes Trendable Data

PMT REQUIRED DYES AND

4

8

12

16

20

24

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. RW 16-9-91

7.11.1.3 Installed filter.

Maint. RW 1

7.11.2 Checked for signs of overheating.

Maint. RW 1

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. RW 1

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

126.3 VAC.

Maint. RW 1

7.11.4.2 Inverter Output Voltage adjusted
~~N/A~~, Not Required.

Maint. RW 1


7.11.4.3 Final Inverter Output Voltage Fluke Reading.
126.3 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint. RW 1

*7.11.4.4 Rectifier output voltage fluke reading:
146.46 VDC
(Reading 140.5VDC \pm 1VDC)

Maint. RW 16-9-91 | *2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>RJW</u> / <u>6-9-91</u>
7.11.1.3	Installed filter.	Maint.	<u>RJW</u> /
7.11.2	Checked for signs of overheating.	Maint.	<u>RJW</u> /
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>RJW</u> /
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.67</u> VAC.	Maint.	<u>RJW</u> /
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>RJW</u> /
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120.67</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>RJW</u> /
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.7</u> VDC (Reading 140.5VDC, \pm 1VDC)	Maint.	<u>RJW</u> / <u>✓</u> *2

*Denotes Trendable Data



Vertical text or markings along the left edge of the page, possibly bleed-through from the reverse side.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

gmy 16/5/91

7.11.1.3 Installed filter.

Maint.

gmy 16/5/91

7.11.2 Checked for signs of overheating.

Maint.

gmy 16/5/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

gmy 16/5/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.22 VAC.

gmy 16/5/91

7.11.4.2 Inverter Output Voltage adjusted
~~N/A~~, Not Required.

Maint.

gmy 16/5/91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

120.22 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

gmy 16/5/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.51 VDC
(Reading 140.5VDC \pm 1VDC)

Maint.

gmy 16/5/91 *2

*Denotes Trendable Data

1 34

14

14

14

14

14

14

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

msj 16/5/91

7.11.1.3 Installed filter.

Maint.

msj 16/5/91

7.11.2 Checked for signs of overheating.

Maint.

msj 16/5/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

msj 16/5/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.60 VAC.

msj 16/5/91

7.11.4.2 Inverter Output Voltage adjusted
XN/A, Not Required.

Maint.

msj 16/5/91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.
120.60 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

msj 16/5/91


*7.11.4.4 Rectifier output voltage fluke reading:

Maint.

140.79 VDC
(Reading 140.5VDC, \pm 1VDC)

msj 16/5/91 *2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

BC. 15-26-91

7.11.1.3 Installed filter.

Maint.

BC. 15-26-91

7.11.2 Checked for signs of overheating.

Maint.

BC. 15-26-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

BC. 15-26-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.16 VAC.

BC. 15-26-91

7.11.4.2 Inverter Output Voltage adjusted

~~N/A~~, Not Required.

Maint.

BC. 15-26-91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

120.16 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

BC. 15-26-91

*7.11.4.4 Rectifier output voltage fluke reading:


140.51 VDC

(Reading 140.5VDC \pm 1VDC)

Maint.

BC. 15-26-91*2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>BC, 5-26-91</u>
7.11.1.3	Installed filter.	Maint.	<u>BC, 5-26-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>BC, 5-26-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>BC, 5-26-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.78</u> VAC.	Maint.	<u>BC, 5-26-91</u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>BC, 5-26-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.78</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>BC, 5-26-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.76</u> VDC (Reading 140.5VDC, \pm 1VDC)	Maint.	<u>BC, 5-26-91</u> *2

*Denotes Trendable Data

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

101

102

103

104

105

106

107

108

109

110

111

112

113

114

115

116

117

118

119

120

121

122

123

124

125

126

127

128

129

130

131

132

133

134

135

136

137

138

139

140

141

142

143

144

145

146

147

148

149

150

151

152

153

154

155

156

157

158

159

160

161

162

163

164

165

166

167

168

169

170

171

172

173

174

175

176

177

178

179

180

181

182

183

184

185

186

187

188

189

190

191

192

193

194

195

196

197

198

199

200

201

202

203

204

205

206

207

208

209

210

211

212

213

214

215

216

217

218

219

220

221

222

223

224

225

226

227

228

229

230

231

232

233

234

235

236

237

238

239

240

241

242

243

244

245

246

247

248

249

250

251

252

253

254

255

256

257

258

259

260

261

262

263

264

265

266

267

268

269

270

271

272

273

274

275

276

277

278

279

280

281

282

283

284

285

286

287

288

289

290

291

292

293

294

295

296

297

298

299

300

301

302

303

304

305

306

307

308

309

310

311

312

313

314

315

316

317

318

319

320

321

322

323

324

325

326

327

328

329

330

331

332

333

334

335

336

Battery No. 2VBA*UPS2A

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

MH 1 5-20-91

7.11.1.3 Installed filter.

Maint.

MH 1 5-20-91

7.11.2 Checked for signs of overheating.

Maint.

MH 1 5-20-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

MH 1 5-20-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.2 VAC.

MH 1 5-20-91

7.11.4.2 Inverter Output Voltage adjusted
E N/A, Not Required.

Maint.

MH 1 5-20-91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

120.2 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

MH 1 5-20-91

*7.11.4.4 Rectifier output voltage fluke reading:

140.4 VDC
(Reading 140.5VDC \pm 1VDC)

Maint.

MH 1 5-20-91 *2

*Denotes Trendable Data

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

MH 15-20-91

7.11.1.3 Installed filter.

Maint.

MH 15-20-91

7.11.2 Checked for signs of overheating.

Maint.

MH 15-20-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

MH 15-20-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

119.9 VAC.

MH 15-20-91

7.11.4.2 Inverter Output Voltage adjusted

N/A, Not Required.

Maint.

MH 15-20-91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.

119.9 VAC.

Maint.

MH 15-20-91

(Reading 120 VAC \pm 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:

140.7 VDC

Maint.

MH 15-20-91 *2

(Reading 140.5VDC, \pm 1VDC)

*Denotes Trendable Data

1

2

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

WJA 15/12/91

7.11.1.3 Installed filter.

Maint.

WJA 15/12/91

7.11.2 Checked for signs of overheating.

Maint.

WJA 15/12/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

WJA 15/12/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.9 VAC.

WJA 15/12/91

7.11.4.2 Inverter Output Voltage adjusted

~~5/13/91~~ ~~NTA~~, Not Required.

Maint.

WJA 15/12/91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

WJA 5/15/91 ~~120.9~~ VAC.

Maint.

WJA 15/12/91

(Reading 120 VAC \pm 2.4 VAC)

120.00

*7.11.4.4 Rectifier output voltage fluke reading:

140.51 VDC

Maint.

WJA 15/12/91 *2

(Reading 140.5VDC \pm 1VDC)

*Denotes Trendable Data

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665


A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>WJH 15/12/91</u>
7.11.1.3	Installed filter.	Maint.	<u>WJH 15/12/91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>WJH 15/12/91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>WJH 15/12/91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.24</u> VAC.	Maint.	<u>WJH 15/12/91</u>
7.11.4.2	Inverter Output Voltage adjusted X N/A, Not Required.	Maint.	<u>WJH 15/12/91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120.28</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>WJH 15/12/91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.84</u> VDC (Reading 140.5VDC, \pm 1VDC)	Maint.	<u>WJH 15/12/91</u> *2

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>J/W, 5/6/91</u>
7.11.1.3	Installed filter.	Maint.	<u>J/W, 5/6/91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>J/W, 5/6/91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>J/W, 5/6/91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.6</u> VAC.	Maint.	<u>J/W, 5/6/91</u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>J/W, 5/6/91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.6</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>J/W, 5/6/91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.5</u> VDC (Reading 140.5VDC \pm 1VDC)	Maint.	<u>J/W, 5/6/91*2</u>

*Denotes Trendable Data

1
2
3

4

5
6

7

8

9

10

11

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

J/W 5/6/91

7.11.1.3 Installed filter.

Maint.

J/W 5/6/91

7.11.2 Checked for signs of overheating.

Maint.

J/W 5/6/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

J/W 5/6/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.1 VAC.

J/W 5/6/91

7.11.4.2 Inverter Output Voltage adjusted

~~X~~ N/A, Not Required.

Maint.

J/W 5/6/91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.

120.1 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

J/W 5/6/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.8 VDC

(Reading 140.5VDC, \pm 1VDC)

Maint.

J/W 5/6/91

*Denotes Trendable Data

1

2

3

4

5

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665


A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>BC . 14-29-91</u>
7.11.1.3	Installed filter.	Maint.	<u>BC . 14-29-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>BC . 14-29-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>BC . 14-29-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.62</u> VAC.	Maint.	<u>BC . 14-29-91</u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>BC . 14-29-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.62</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>BC . 14-29-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.48</u> VDC (Reading 140.5VDC \pm 1VDC)	Maint.	<u>BC . 14-29-91*2</u>

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

BC . 14-29-91

7.11.1.3 Installed filter.

Maint.

BC . 14-29-91

7.11.2 Checked for signs of overheating.

Maint.

BC . 14-29-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

BC . 14-29-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.04 VAC.

BC . 14-29-91

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required.

Maint.

BC . 14-29-91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.

120.04 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

BC . 14-29-91

*7.11.4.4 Rectifier output voltage fluke reading:

140.83 VDC

(Reading 140.5VDC, \pm 1VDC)

Maint.

BC . 14-29-91 *2

*Denotes Trendable Data

Vertical text on the left margin, possibly bleed-through from the reverse side of the page.

A small, faint mark or character located near the bottom center of the page.

Faint marks or characters in the bottom right corner of the page.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter

Maint. M.H. 4-21-91

7.11.1.3 Installed filter

Maint. M.H. 4-21-91

7.11.2 Checked for signs of overheating

Maint. M.H. 4-21-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability

Maint. M.H. 4-21-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

119.6 VAC.

Maint. M.H. 4-21-91

7.11.4.2 Inverter Output Voltage adjusted

N/A; Not Required.

Maint. M.H. 4-21-91

7.11.4.3 Final Inverter Output Voltage Fluke Reading

119.6 VAC.

(Reading 120 VAC \pm 2% VAC)

Maint. M.H. 4-21-91

*7.11.4.4 Rectifier output voltage fluke reading

140.5 VDC

(Reading 140.5VDC \pm 1VDC)

Maint. M.H. 4-21-91

*Denotes Trendable Data

10

11

12

13

14

15

16

17

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd)

INITIAL / DATE

Procedure

Procedure	Maint.	INITIAL / DATE
UPS Inverters No. 2VBA*UPS2B		
7-11-1 Inverter Air Filters		
7-11-1.2 Cleaned or replaced filter.	Maint.	MH-1-4-21-91
7-11-1.3 Installed filter.	Maint.	MH-1-4-21-91
7-11-2 Checked for signs of overheating.	Maint.	MH-1-4-21-91
7-11-3 Inverter Fan		
7-11-3.1 Verified operability.	Maint.	MH-1-4-21-91
7-11-4 Voltage Checks		
*7-11-4.1 Inverter output voltage fluke reading As Found:	Maint.	MH-1-4-21-91
120 VAC.		
7-11-4.2 Inverter Output Voltage adjusted	Maint.	MH-1-4-21-91
N/A, Not Required.		
7-11-4.3 Final Inverter Output Voltage	Maint.	MH-1-4-21-91
Fluke Reading		
120 VAC		
(Reading: 120 VAC, ± 2.4 VAC)		
*7-11-4.4 Rectifier output voltage fluke reading:	Maint.	MH-1-4-21-91
140.3 VDC		
(Reading: 140.5VDC, ± 1VDC)		

*Denotes Trendable Data

1

2

3

4

5

6

7

8

9

10

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. RST / 4/7/91

7.11.1.3 Installed filter.

Maint. RST / 4/7/91

7.11.2 Checked for signs of overheating.

Maint. RST / 4/7/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. RST / 4/7/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint. RST / 4/7/91

120.4 VAC.

7.11.4.2 Inverter Output Voltage adjusted
~~W~~ N/A, Not Required.

Maint. RST / 4/7/91 | ~~TCN-6~~


7.11.4.3 Final Inverter Output Voltage Fluke Reading.
120.4 VAC.
(Reading 120 VAC ± 2.4 VAC)

Maint. RST / 4/7/91

*7.11.4.4 Rectifier output voltage fluke reading:
140.4 VAC. VDC RST 4/7/91
(Reading 140.5VDC ± 1VDC)

Maint. RST / 4/7/91

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

RST / 4/7/91

7.11.1.3 Installed filter.

Maint.

RST / 4/7/91

7.11.2 Checked for signs of overheating.

Maint.

RST / 4/7/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

RST / 4/7/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.7 VAC.

RST / 4/7/91

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required.

Maint.

RST / 4/7/91 | TCN-6

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.
120.7 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.


RST / 4/7/91

*7.11.4.4 Rectifier output voltage fluke reading:
140.8 VAC. VDC RST 4/7/91
(Reading 140.5VDC, \pm 1VDC)

Maint.

RST / 4/7/91

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

> Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. KCK / 4-14-91

7.11.1.3 Installed filter.

Maint. KCK / 4-14-91

7.11.2 Checked for signs of overheating.

Maint. KCK / 4-14-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. KCK / 4-14-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint. KCK / 4-14-91

119.66 VAC.

7.11.4.2 Inverter Output Voltage adjusted
N/A, Not Required.

Maint. KCK / 4-14-91 **TCB-6**

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

Maint. KCK / 4-14-91

119.66 VAC.

(Reading 120 VAC \pm 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:

Maint. KCK / 4-14-91

140.39 VAC VDC

(Reading 140.5VDC \pm 1VDC)

*Denotes Trendable Data

SGM
4/8/91

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter. Maint. icck / 4-14-91

7.11.1.3 Installed filter. Maint. icck / 4-14-91

7.11.2 Checked for signs of overheating. Maint. icck / 4-14-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability. Maint. icck / 4-14-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:
Maint. icck / 4-14-91

120.08 VAC.

7.11.4.2 Inverter Output Voltage adjusted
ØN/A, Not Required. Maint. icck / 4-14-91 ~~TCN 6~~

7.11.4.3 Final Inverter Output Voltage
Fluke Reading.
120.08 VAC. Maint. icck / 4-14-91
(Reading 120 VAC ± 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:
Maint. icck / 4-14-91
140.93 VAC. VDC
(Reading 140.5VDC, ±1VDC)

SGM
4/8/91

*Denotes Trendable Data

100

100

100

100

100

100

100

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. TM / 3/24/91

7.11.1.3 Installed filter.

Maint. TM / 3/24/91

7.11.2 Checked for signs of overheating.

Maint. TM / 3/24/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. TM / 3/24/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint. TM / 3/24/91

119.8 VAC.

7.11.4.2 Inverter Output Voltage adjusted
 N/A, Not Required.

Maint. TM / 3/24/91 **TC-6**

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

Maint. TM / 3/24/91

119.8 VAC.
(Reading 120 VAC \pm 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:

Maint. TM / 3/24/91

140.4 VAC.
(Reading 140.5VDC \pm 1VDC)

*Denotes Trendable Data

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>Tm 13/24/91</u>
7.11.1.3	Installed filter.	Maint.	<u>Tm 13/24/91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>Tm 13/24/91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>Tm 13/24/91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120</u> VAC.	Maint.	<u>Tm 13/24/91</u>
7.11.4.2	Inverter Output Voltage adjusted E N/A, Not Required.	Maint.	<u>Tm 13/24/91</u> TCN-6
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120</u> VAC. (Reading 120 VAC ± 2.4 VAC)	Maint.	<u>Tm 13/24/91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.7</u> VAC. (Reading 140.5VDC, ±1VDC)	Maint.	<u>Tm 13/24/91</u>

*Denotes Trendable Data

12

13

14

15

16

17

18

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665


A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>BC. 13-31-91</u>
7.11.1.3	Installed filter.	Maint.	<u>BC. 13-31-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>BC. 13-31-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>BC. 13-31-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.52</u> VAC.	Maint.	<u>BC. 13-31-91</u>
7.11.4.2	Inverter Output Voltage adjusted N/A , Not Required.	Maint.	<u>BC. 13-31-91</u> TCN-6
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.52</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>BC. 13-31-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.46</u> VAC. (Reading 140.5VDC \pm 1VDC)	Maint.	<u>BC. 13-31-91</u>

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>BC, 13-31-91</u>
7.11.1.3	Installed filter.	Maint.	<u>BC, 13-31-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>BC, 13-31-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>BC, 13-31-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120</u> VAC.	Maint.	<u>BC, 13-31-91</u>
7.11.4.2	Inverter Output Voltage adjusted <input checked="" type="checkbox"/> N/A, Not Required.	Maint.	<u>BC, 13-31-91</u> TCN-6
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120</u> VAC. (Reading 120 VAC ± 2.4 VAC)	Maint.	<u>BC, 13-31-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.83</u> VAC. (Reading 140.5VDC, ±1VDC)	Maint.	<u>BC, 13-31-91</u>

*Denotes Trendable Data

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665


A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>gmpy</u> 13/11/91
7.11.1.3	Installed filter.	Maint.	<u>gmpy</u> 13/11/91
7.11.2	Checked for signs of overheating.	Maint.	<u>gmpy</u> 13/11/91
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>gmpy</u> 13/11/91
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.45</u> VAC.	Maint.	<u>gmpy</u> 13/11/91
7.11.4.2	Inverter Output Voltage adjusted N/A , Not Required.	Maint.	<u>gmpy</u> 13/11/91 TCN-6
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120.45</u> VAC. (Reading 120 VAC ± 2.4 VAC)	Maint.	<u>gmpy</u> 13/11/91
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.47</u> VAC. (Reading 140.5VDC ±1VDC)	Maint.	<u>gmpy</u> 13/11/91

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665


A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>mpj 13/11/91</u>
7.11.1.3	Installed filter.	Maint.	<u>mpj 13/11/91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>mpj 13/11/91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>mpj 13/11/91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.75</u> VAC.	Maint.	<u>mpj 13/11/91</u>
7.11.4.2	Inverter Output Voltage adjusted N/A , Not Required.	Maint.	<u>mpj 13/11/91</u> TCN-6
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>120.75</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>mpj 13/11/91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.87</u> VAC. (Reading 140.5VDC, \pm 1VDC)	Maint.	<u>mpj 13/11/91</u>

*Denotes Trendable Data



Battery No. 2VBA*UPS2A

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

Attachment 10.1
Page 17 of 22.

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. WJA 13/1/91

7.11.1.3 Installed filter.

Maint. WJA 13/1/91

7.11.2 Checked for signs of overheating.

Maint. WJA 13/1/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. WJA 13/1/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

119.95 VAC.

Maint. WJA 13/1/91

7.11.4.2 Inverter Output Voltage adjusted

~~X~~ N/A, Not Required.

Maint. WJA 13/1/91 TCR-6

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

119.95 VAC.
(Reading 120 VAC \pm 2.4 VAC)


Maint. WJA 13/1/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.50 VAC.
(Reading 140.5VDC \pm 1VDC)

Maint. WJA 13/1/91

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EMP-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

WJA 13/09/91

7.11.1.3 Installed filter.

Maint.

WJA 13/09/91

7.11.2 Checked for signs of overheating.

Maint.

WJA 13/09/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

WJA 13/09/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

19.93 VAC.

WJA 13/09/91

7.11.4.2 Inverter Output Voltage adjusted

~~N/A~~, Not Required.

Maint.

WJA 13/09/91 TCN-6

7.11.4.3 Final Inverter Output Voltage

Fluke Reading.

19.93 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

WJA 13/09/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.58 VAC.

(Reading 140.5VDC, \pm 1VDC)

Maint.

WJA 13/09/91

*Denotes Trendable Data

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

60

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-ERM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.)

INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2A</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>KOK / 3-3-91</u>
7.11.1.3	Installed filter.	Maint.	<u>KOK / 3-3-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>KOK / 3-3-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>KOK / 3-3-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>119.7</u> VAC.	Maint.	<u>KOK / 3-3-91</u>
7.11.4.2	Adjust Inverter Output Voltage <u>adjusted</u> <input checked="" type="checkbox"/> N/A, Not Required	Maint.	<u>KOK / 3-3-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading. <u>119.7</u> VAC. (Reading 120 VAC \pm 2.4 VAC)	Maint.	<u>KOK / 3-3-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.4</u> VDC. (reading 140.5VDC \pm 1VDC)	Maint.	<u>KOK / 3-3-91</u>

TCN-6
1.29.90
TCN

TCN
TCN

*Denotes Trendable Data

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.): INITIAL / DATE

Procedure

- 7.11 UPS Inverters No. 2VBA*UPS2B
- 7.11.1 Inverter Air Filters
- 7.11.1.2 Cleaned or replaced filter. Maint. KCK / 3-3-91
- 7.11.1.3 Installed filter. Maint. KCK / 3-3-91
- 7.11.2 Checked for signs of overheating. Maint. KCK / 3-3-91
- 7.11.3 Inverter Fan
- 7.11.3.1 Verified operability. Maint. KCK / 3-3-91
- 7.11.4 Voltage Checks
- *7.11.4.1 Inverter output voltage fluke reading As Found:
120.09 VAC. Maint. KCK / 3-3-91
- 7.11.4.2 Adjust Inverter Output Voltage Adjusted
 N/A, Not Required. Maint. KCK / 3-3-91
- 7.11.4.3 Final Inverter Output Voltage
Fluke Reading
120.09 VAC. Maint. KCK / 3-3-91
(Reading 120 VAC ± 2.4 VAC)
- *7.11.4.4 Rectifier output voltage fluke reading:
140.8 VDC. Maint. KCK / 3-3-91
(reading 140.5VDC, ±1VDC)

TC 6
2D
1.29.90
27
1/24/90

TC
TC

*Denotes Trendable Data

4

4

4

4

Equipment No. 2VBA*UPS2A

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. MH / 2-24-91

7.11.1.3 Installed filter.

Maint. MH / 2-24-91

7.11.2 Checked for signs of overheating.

Maint. MH / 2-24-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. MH / 2-24-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.3 VAC.

Maint. MH / 2-24-91 TC:

7.11.4.2 ~~Adjust~~ Inverter Output Voltage adjusted
 N/A, Not Required

Maint. MH / 2-24-91 TC:

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

120.3 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint. MH / 2-24-91

*7.11.4.4 Rectifier output voltage fluke reading:

140.5 VDC.


(reading 140.5VDC \pm 1VDC)

Maint. MH / 2-24-91

17-6
22
1-29-90
27
1/28/90

*Denotes Trendable Data

February 1990
~~September 1989~~



Equipment No. 2BYS*CHGR2C1,2C2

Attachment 10.1*
Page 20 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.10 Charger No. 2C1

7.10.1 Charger Cleaning

7.10.1.1 Checked interior.

Maint. MH / 2-24-91

7.10.1.2 Cleaned exterior.

Maint. MH / 2-24-91

7.10.2 Charger Meter Checks

*7.10.2.1 Fluke reading: 134.9 volts.

Maint. MH / 2-24-91

*7.10.2.2 Fluke reading: 5.1 millivolts.
Converted reading:

Maint. MH / 2-24-91

millivolts x 1.5 = 7.6 amps

Maint. MH / 2-24-91

*Denotes Trendable Data

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both primary and secondary data collection techniques. The primary data was gathered through direct observation and interviews with key stakeholders. Secondary data was obtained from existing reports and databases.

The third section details the results of the data analysis. It shows a clear trend of increasing activity over the period studied. The data indicates that the majority of transactions occur during the middle of the day, with a significant peak in the afternoon.

Finally, the document concludes with a series of recommendations based on the findings. It suggests that the current processes are largely effective but could be improved by implementing more robust data security measures. Additionally, regular audits should be conducted to ensure the accuracy of the records.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. WJH 12/17/91

7.11.1.3 Installed filter.

Maint. WJH 12/17/91

7.11.2 Checked for signs of overheating.

Maint. WJH 12/17/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. WJH 12/17/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint. WJH 12/17/91 TCN

120.7 VAC.

7.11.4.2 ~~Adjust~~ Inverter Output Voltage adjusted
~~N/A~~, Not Required

Maint. WJH 12/17/91 TCN

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

Maint. WJH 12/17/91

120.7 VAC.
(Reading 120 VAC ± 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:

Maint. WJH 12/17/91

140.4 VDC.
(reading 140.5VDC ±1VDC)

*Denotes Trendable Data

TCN-6
1:29:00
7/25/90

February 1990
September 1989

2

3

4

5

6

7

8

9

10

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. WJH 12/17/91

7.11.1.3 Installed filter.

Maint. WJH 12/17/91

7.11.2 Checked for signs of overheating.

Maint. WJH 12/17/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. WJH 12/17/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.8 VAC.

Maint. WJH 12/17/91

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted~~
 N/A, Not Required.

Maint. WJH 12/17/91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading

120.8 VAC.

(Reading 120 VAC ± 2.4 VAC)

Maint. WJH 12/17/91

*7.11.4.4 Rectifier output voltage fluke reading:

140.8 VDC.

(reading 140.5VDC, ±1VDC)

Maint. WJH 12/17/91

TCN
20
1:27:00
12/17/91

TC

TCN

*Denotes Trendable Data

1

2

3

4

5

6

Equipment No. 2VBA*UPS2A

Attachment 10.1
Page 17 of 22

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-ERM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. MH 12-10-91

7.11.1.3 Installed filter.

Maint. MH 12-10-91

7.11.2 Checked for signs of overheating.

Maint. MH 12-10-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. MH 12-10-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.5 VAC.

Maint. MH 12-10-91 TC

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted~~
 N/A, Not Required

Maint. MH 12-10-91 TC

7.11.4.3 Final Inverter Output Voltage Fluke Reading.
120.5 VAC.
(Reading 120 VAC ± 2.4 VAC)

Maint. MH 12-10-91


*7.11.4.4 Rectifier output voltage fluke reading:
140.5 VDC.
(reading 140.5VDC ±1VDC)

Maint. MH 12-10-91

TC-6
1.29.90
1/25/90

*Denotes Trendable Data

February 1990
September 1989



Equipment No. 2VBA*UPS2B

DATA SHEET

**DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665**

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE


Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>MH, 2-10-91</u>
7.11.1.3	Installed filter.	Maint.	<u>MH, 2-10-91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>MH, 2-10-91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>MH, 2-10-91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.7</u> VAC.	Maint.	<u>MH, 2-10-91</u>
7.11.4.2	Adjust Inverter Output Voltage adjusted <input type="checkbox"/> N/A, Not Required.	Maint.	<u>MH, 2-10-91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading <u>120.7</u> VAC. (Reading 120 VAC ± 2.4 VAC)	Maint.	<u>MH, 2-10-91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.8</u> VDC. (reading 140.5VDC, ±1VDC)	Maint.	<u>MH, 2-10-91</u>

TCN 6
2D
1-29-90
27
1/25/90

TCN
TCN

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. kkk / 2-3-91

7.11.1.3 Installed filter.

Maint. kkk / 2-3-91

7.11.2 Checked for signs of overheating.

Maint. kkk / 2-3-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. kkk / 2-3-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.5 VAC.

Maint. kkk / 2-3-91

7.11.4.2 ~~Adjust~~ Inverter Output Voltage adjusted
 N/A, Not Required

Maint. kkk / 2-3-91

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

120.5 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint. kkk / 2-3-91

*7.11.4.4 Rectifier output voltage fluke reading:

140.5 VDC.
(reading 140.5VDC \pm 1VDC)

Maint. kkk / 2-3-91

*Denotes Trendable Data

February 1990
~~September 1989~~

17-6
1.29.90
1/21/90

TC:

TCN

11

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

11

12

13

14

15

16

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedures

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. icck / 2-3-91

7.11.1.3 Installed filter.

Maint. icck / 2-3-91

7.11.2 Checked for signs of overheating.

Maint. icck / 2-3-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. icck / 2-3-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.7 VAC.
~~140.8~~

Maint. icck / 2-3-91

TCI

20
1.29.90
27
1/28/90

7.11.4.2 Adjust Inverter Output Voltage adjusted
 N/A, Not Required.

Maint. icck / 2-3-91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading
120.7 VAC.
(Reading 120 VAC ± 2.4 VAC)


Maint. icck / 2-3-91

TCN

*7.11.4.4 Rectifier output voltage fluke reading:
140.8 VDC.
(reading 140.5VDC, ±1VDC)

Maint. icck / 2-3-91

*Denotes Trendable Data



Equipment No. 2VBA*UPS2A

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint. N/A

7.11.1.3 Installed filter.

Maint. ABC 1-28-91

7.11.2 Checked for signs of overheating.

Maint. ABC 1-28-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint. ABC 1-28-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.5 VAC.

Maint. ABC 1-28-91 | TCS

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted~~
~~BCN/A~~, Not Required

Maint. ABC 1-28-91 | TCS

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

120.5 VAC.
(Reading 120 VAC ± 2.4 VAC)

Maint. ABC 1-28-91

*7.11.4.4 Rectifier output voltage fluke reading:


140.48 VDC.
(reading 140.5VDC ±1VDC)

Maint. ABC 1-28-91

17-6
22
1-29-90
1/28/90

*Denotes Trendable Data

February 1990
~~September 1989~~



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

N/A

7.11.1.3 Installed filter.

Maint.

ABC 1-28-91
ABC 1-28-91

7.11.2 Checked for signs of overheating.

Maint.

ABC 1-28-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

ABC 1-28-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.8 VAC.

ABC 1-28-91

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted~~
ECN/A, Not Required.

Maint.

ABC 1-28-91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading
120.8 VAC.
(Reading 120 VAC ± 2.4 VAC)

Maint.

ABC 1-28-91

*7.11.4.4 Rectifier output voltage fluke reading:
140.8 VDC.
(reading 140.5VDC, ±1VDC)

Maint.

ABC 1-28-91

TCN 6
20
1-29-90
27
1/28/90

TC
TC

*Denotes Trendable Data

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both primary and secondary data collection techniques. The primary data was gathered through direct observation and interviews with key stakeholders. Secondary data was obtained from existing reports and databases.

The analysis phase involved using statistical software to identify trends and correlations within the data. The results show a clear upward trend in certain areas, while others remain relatively stable. These findings are crucial for understanding the overall performance and identifying areas for improvement.

Finally, the document concludes with a series of recommendations based on the findings. It suggests implementing new procedures to streamline operations and improve efficiency. Additionally, it recommends regular communication and reporting to keep all parties informed of the progress and any challenges encountered.

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

BEJ / 1-7-91

7.11.1.3 Installed filter.

Maint.

BEJ / 1-7-91

7.11.2 Checked for signs of overheating.

Maint.

BEJ / 1-7-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

BEJ / 1-7-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

BEJ / 1-7-91

120.28 VAC.

TCN

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted.~~

Maint.

BEJ / 1-7-91

N/A, Not Required

TCN

7.11.4.3 Final Inverter Output Voltage Fluke Reading.

Maint.

BEJ / 1-7-91

120.28 VAC.

(Reading 120 VAC \pm 2.4 VAC)

*7.11.4.4 Rectifier output voltage fluke reading:

Maint.


BEJ / 1-7-91

140.45 VDC.

(reading 140.5VDC \pm 1VDC)

*Denotes Trendable Data

127-6
27
1-29-90
37
1/28/90



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

BEA, 1-7-91

7.11.1.3 Installed filter.

Maint.

BEA, 1-7-91

7.11.2 Checked for signs of overheating.

Maint.

BEA, 1-7-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

BEA, 1-7-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.78 VAC.

Maint.

BEA, 1-7-91

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted~~
 N/A, Not Required.

Maint.

BEA, 1-7-91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading

120.78 VAC.

(Reading 120 VAC \pm 2.4 VAC)

Maint.

BEA, 1-7-91

*7.11.4.4 Rectifier output voltage fluke reading:
140.82 VDC.

(reading 140.5VDC, \pm 1VDC)


Maint.

BEA, 1-7-91

TCN 6
20
1.29.90
27
1/24/90

TCN
TCN

*Denotes Trendable Data



2VBA*UPS2A

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

UPS Inverters No. 2VBA*UPS2A

7.11

Inverter Air Filters

7.11.1

7.11.1.2 Cleaned or replaced filter.

Maint.

NP 11-13-91

7.11.1.3 Installed filter.

Maint.

NP 11-13-91

7.11.2 Checked for signs of overheating.

Maint.

NP 11-13-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

NP 11-13-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.65 VAC.

Maint.

NP 11-13-91

TCN

7.11.4.2 ~~Adjust~~ Inverter Output Voltage adjusted
 N/A, Not Required

Maint.

NP 11-13-91

TCN

7.11.4.3 Final Inverter Output Voltage Fluke Reading.
120.65 VAC.
(Reading 120 VAC \pm 2.4 VAC)

Maint.

NP 11-13-91

*7.11.4.4 Rectifier output voltage fluke reading:
140.45 VDC.
(reading 140.5VDC \pm 1VDC)

Maint.

NP 11-13-91

*Denotes Trendable Data

February 1990
~~September 1989~~

TCN-6
1-29-90
1/21/90

10

10

10

DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2B

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

DP 11-13-91

7.11.1.3 Installed filter.

Maint.

DP 11-13-91

7.11.2 Checked for signs of overheating.

Maint.

DP 11-13-91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

DP 11-13-91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

120.81 VAC.

Maint.

DP 11-13-91

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted~~.
~~N/A~~, Not Required.

Maint.

DP 11-13-91

7.11.4.3 Final Inverter Output Voltage
Fluke Reading
120.81 VAC.
(Reading 120 VAC ± 2.4 VAC)

Maint.

DP 11-13-91

*7.11.4.4 Rectifier output voltage fluke reading:
140.85 VDC.
(reading 140.5VDC, ±1VDC)


Maint.

DP 11-13-91

TCN
20
1.29.90
27
1/18/90

TCN
TCN

*Denotes Trendable Data



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.):

INITIAL / DATE

Procedure

7.11 UPS Inverters No. 2VBA*UPS2A

7.11.1 Inverter Air Filters

7.11.1.2 Cleaned or replaced filter.

Maint.

DMP 11/20/91

7.11.1.3 Installed filter.

Maint.

DMP 11/20/91

7.11.2 Checked for signs of overheating.

Maint.

DMP 11/20/91

7.11.3 Inverter Fan

7.11.3.1 Verified operability.

Maint.

DMP 11/20/91

7.11.4 Voltage Checks

*7.11.4.1 Inverter output voltage fluke reading As Found:

Maint.

120.83 VAC.

DMP 11/20/91

TCN

7.11.4.2 ~~Adjust~~ Inverter Output Voltage ~~adjusted~~
N/A, Not Required

Maint.

DMP 11/20/91

TCN

7.11.4.3 Final Inverter Output Voltage Fluke Reading.
120.83 VAC.
(Reading 120 VAC ± 2.4 VAC)

Maint.

DMP 11/20/91

*7.11.4.4 Rectifier output voltage fluke reading:
140.51 VDC.
(reading 140.5VDC ±1VDC)


Maint.

DMP 11/20/91

*Denotes Trendable Data

TCN-6
1.29.90
11/20/90

February 1990



DATA SHEET

DC/UPS WEEKLY CHECKS
N2-EPM-GEN-W665

A. VERIFICATION OF PROCEDURE STEPS (Cont'd.): INITIAL / DATE

Procedure

7.11	<u>UPS Inverters No. 2VBA*UPS2B</u>		
7.11.1	<u>Inverter Air Filters</u>		
7.11.1.2	Cleaned or replaced filter.	Maint.	<u>DHP 1/20/91</u>
7.11.1.3	Installed filter.	Maint.	<u>DHP 1/20/91</u>
7.11.2	Checked for signs of overheating.	Maint.	<u>DHP 1/20/91</u>
7.11.3	<u>Inverter Fan</u>		
7.11.3.1	Verified operability.	Maint.	<u>DHP 1/20/91</u>
7.11.4	<u>Voltage Checks</u>		
*7.11.4.1	Inverter output voltage fluke reading As Found: <u>120.93</u> VAC.	Maint.	<u>DHP 1/20/91</u>
7.11.4.2	Adjust Inverter Output Voltage adjusted N/A , Not Required.	Maint.	<u>DHP 1/20/91</u>
7.11.4.3	Final Inverter Output Voltage Fluke Reading <u>120.93</u> VAC. (Reading 120 VAC ± 2.4 VAC)	Maint.	<u>DHP 1/20/91</u>
*7.11.4.4	Rectifier output voltage fluke reading: <u>140.85</u> VDC. (reading 140.5VDC, ±1VDC)	Maint.	<u>DHP 1/20/91</u>

TCN W.
20
1-29-90
27
1/28/91

TCI
TCN

*Denotes Trendable Data

