

07-119A-91

# ORIGINAL

## OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
 Incident Investigation Team

Title: Nine Mile Point Nuclear Power Plant  
 Interview of: ANIL JULKA

Docket No.

LOCATION: Scriba, New York

DATE: Friday, August 23, 1991

PAGES: 1 - 20

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300  
 Washington, D.C. 20006  
 (202) 293-3950.

9305060241 911031  
 PDR ADDCK 05000410  
 S PDR


1000



## ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
5	24	FSAR CHAPTER 7.4 (INCLUDED THE PERIOD)
6	9	HPCS INSTEAD OF HPSC (TYPO)
6	11	We did loose instead of didn't (Do not know the reason for this discrepancy)
10	5	Lower should be higher
10	6	lower voltage should be high voltage
10	10	no audible should be no credible.
11	17	graded should be degraded
11	19	sat should be set
13	11	lock, or should be lockout
14	7	I looked should be we looked (I personally did not inspect transformer at that time).
15	18	those connection should be their condition
16	4	reductions <sup>for</sup> should be deductions from
18	12	floor should be flour

Date 10/2/21 Signature Anil K. Julla



UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

-----  
Interview of :  
ANIL JULKA :  
(Closed) :  
-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Friday, August 23, 1991

The interview commenced, pursuant to notice,  
at 1:10 p.m.

PRESENT FOR THE IIT:  
Jose Ibarra, NRC  
Jim Stoner, Duke, NRC

1. 2. 3.



## P R O C E E D I N G S

[1:10 p.m.]

1  
2  
3 MR. IBARRA: This is Jose Ibarra from the NRC.  
4 I'm a team member from the IIT and with me I have Jim  
5 Stoner.


6 Today we will be interviewing Anil Julka from  
7 Niagara Mohawk. Anil, would you please state your name,  
8 your position, experience with the company?

9 MR. JULKA: Okay. My name is Anil Julka. I'm an  
10 electrical design supervisor for Niagara Mohawk electrical  
11 design group. I have been with Niagara Mohawk for  
12 approximately five years now.

13 My previous experience includes AEs and  
14 Westinghouse.

15 MR. IBARRA: Can you tell me your involvement or  
16 your responsibility in assessing what happened on August  
17 13th?

18 MR. JULKA: Okay. After the event I'm also part  
19 of the TSC task force for evaluation. After the event I got  
20 a call that we had declared a site area emergency so I came  
21 up to the site and at first they were just evaluating what  
22 had happened. And I got here around 9 o'clock or so or a  
23 little after that. And our main concern, we were  
24 hypothesizing at that point. We knew there was a  
25 transformer fault, but we were hypothesizing how the fault






1 had started.

2           So, I guess my primary responsibility that day was  
3 the major support for, you know, reactor shutdown. And  
4 after that my primary responsibility was tasked with  
5 reviewing the electrical distribution system to see what  
6 type of transients had occurred, and reviewing if the system  
7 had operated as designed and assist UPS people with the  
8 trouble shooting efforts and also with the main transformer  
9 wherever they needed help. So those were my primary  
10 responsibilities.

11           MR. IBARRA: One of the obvious faults was  
12 lighting. What assessments have gone on in lighting to  
13 assure that what the operator saw was correct and also final  
14 assessments as to what this is going to mean?

15           MR. JULKA: Okay. We have reviewed the entire  
16 plant lighting system. You know, we have five types of  
17 lighting systems. We have a normal lighting, emergency  
18 lighting, essential, egress and eight-hour battery pack  
19 lighting system.

20           During this event the essential portion of the  
21 lighting system was lost because of the loss of UPS. The  
22 normal lighting was still available, the emergency lighting  
23 was still available. In some of the areas we do have  
24 anomaly in the system that in some stairways there is a  
25 concern which was expressed, I guess, back in '89 that if we



1 loose UPS, certain areas -- stairwell areas get -- the  
2 eight-hour battery packs do not come on because they are fed  
3 from the normal source and since the lighting there is fed  
4 from UPS you could loose the UPS and the eight-hour battery  
5 packs do not come on.

6           At that time we did make an evaluation using  
7 Appendix R and it was documented that the Appendix R  
8 lighting was required for loss of normal power also in this  
9 case. And at that time also we did not loose normal power.  
10 So what -- last year, I guess, we started looking at the  
11 entire UPS loading issue because the electrical group was  
12 concerned about the loading on the UPS's. And at that time  
13 we decided that we should fix that anomaly also. So,  
14 rather than leave it as a modification of 89-042 which will  
15 address that issue and there's more that's currently being  
16 scheduled for refuel outage and thereafter.

17           So, our evaluation of the incident really says  
18 that, yeah, we did loose essential lighting. They did -- my  
19 understanding from talking -- looking at the operator's  
20 report is that they had to use flashlight in certain areas,  
21 but those are open stairways, so there is enough light  
22 coming in from other sides, so it wasn't completely dark,  
23 but there was some lighting coming in from the other sides.

24           Other than that anomaly we have not really found  
25 anything else which is contradictory to our commitments.



1 MR. IBARRA: There was an issue then with lighting  
2 in '89, an UPS redistribution of loads in '90, correct?

3 MR. JULKA: State that again? I didn't follow  
4 that.

5 MR. IBARRA: In 1990, there was a study done on  
6 the redistribution of the lighting according to the new UPS  
7 that were going to be put in?

8 MR. JULKA: I believe that was '91. Don't quote  
9 me on that. I thought we did it earlier this year.

10 MR. IBARRA: But, is the lighting issue separate  
11 from the distribution issue?

12 MR. JULKA: That's correct. That's correct.

13 MR. IBARRA: Two different studies?


14 MR. JULKA: Different studies, right.

15 MR. IBARRA: Okay. But the lighting issue was a  
16 few years before the distribution on the UPS?

17 MR. JULKA: The lighting issue came up in '89.

18 MR. IBARRA: Okay. The instruments that failed in  
19 the control room, can you tell us what happened there and  
20 how, and the assessment you've done so far?

21 MR. JULKA: First of all, in our commitment, we  
22 did not loose any of the safety related instrumentation in  
23 the plant, even control room. Our commitment in USAR or  
24 FSAR Chapter 74, is that we need four safety systems for  
25 safe shutdown which is the reactor core isolation cooling



1 system, which is called RCIC; you got standby liquid control  
2 system, SLS; RHR shutdown cooling mode and remote shutdown  
3 system. These systems and control and instrumentation for  
4 these systems was available, at least electrically,  
5 although I have heard that RCIC went in off for a while  
6 because of a valve, but it was not due to the UPS loss or  
7 any -- the event that happened that day. And my  
8 understanding is also that at the time RCIC was declared  
9 inop, it was not really required and we still had HPSC  
10 available.


11 We didn't lose plant annunciators, computers,  
12 feedwater control. Those are some of the things -- there is  
13 a complete list of things we have which were lost and we  
14 have evaluated those things and we have a separate group set  
15 up who is going to be doing the safety assessment of all  
16 these things which were lost to insure that they will not  
17 require our preliminary indication as that, yes, they were  
18 not required for safe shutdown of the plant. They assist  
19 operators, but in no way are necessary for a safe shutdown.

20 MR. IBARRA: Was Rixie or RCIC all of it  
21 inoperable or only portions of it inoperable?

22 MR. JULKA: Portions of it.

23 MR. IBARRA: So you did have one channel available  
24 versus -- two channels?

25 MR. JULKA: Well, in the initial portion of the





1 event it was available to support core cooling. But there  
2 was a lack of full close indication for the valves, AOV-156,  
3 that's the primary containment isolation valve.

4 But it was not really needed at the time it was  
5 declared inop.

6 MR. IBARRA: The computer systems were not  
7 available, can you tell me what those were fed off of and  
8 does that make sense that they would have lost those?

9 MR. JULKA: Yeah. Well, most of the plant  
10 computer system is fed of 1G, UPS 1G which was lost during  
11 this event and the LWS computer is fed off the UPS 1B. So  
12 we lost five of the non-safety UPS's which are all the same  
13 type, Exide, 1A, 1B, 1C, 1D and 1G. So loss of those will  
14 result in loss of plant computer system and that's -- since  
15 they are non-safety and they do feed the computer systems.


16 MR. IBARRA: Your regulatory guide 197  
17 instrumentation, was that all purple?

18 MR. JULKA: I don't have full details on that, but  
19 my -- I would suspect they were, but don't --

20 MR. IBARRA: How about the post-accident  
21 monitoring instrumentation?

22 MR. JULKA: Yeah. Post-accident should be  
23 operable.

24 MR. IBARRA: Okay. On the Appendix R assessment,  
25 the assessment of whether the capability existed to put out



1 fires, can you tell me a little bit about your involvement,  
2 your group involvement in that assessment?

3 MR. JULKA: We have an Appendix R engineer in our  
4 group. He looked at the Appendix R issue and our commitment  
5 in FSAR for Appendix R is in accordance with the fire  
6 protection guidelines, you know, reg guide Appendix R  
7 scenario in our plant is considered with the loss of normal  
8 off-site power identified in any given area you have a  
9 capability to shut down the plant.

10 We didn't really get into that scenario in this  
11 case because normal power was still available. So our  
12 evaluation really states, you know, that Appendix R  
13 compliance was not really impacted.

14 MR. IBARRA: When was your group called to look at  
15 that electrically?

16 MR. JULKA: Our group was never really called to  
17 look at anything electrically, except to look at the entire  
18 electrical distribution system. It was my decision, I  
19 guess, for now that within my group that we should look at  
20 every system there is which is, in fact, to make sure that  
21 loss of these UPS systems would not really affect any  
22 electrical related systems in the plant. And our compliance  
23 to USAR was still valid.

24 MR. IBARRA: Since a few of the instruments were  
25 inoperable previous to the event itself, are you going to



1 have any involvement with assessing the impact that some of  
2 those instruments being inoperable would have -- did have on  
3 the event -- being able to indicate in the control room?

4 MR. JULKA: Yeah, that will be assess as part of  
5 our safety assessment.

6 MR. STONER: Have you reviewed -- completed a  
7 review of the electrical distribution system, and have you  
8 made a determination whether the system -- the in-plant  
9 systems as well as the switch yard systems operated as  
10 designed, including the associated protective systems?

11 MR. JULKA: Yeah. We had a pretty extensive  
12 review of the protective relaying associated with the unit  
13 protection system. And we also had a fellow from GE, Mel  
14 Crenshaw do an independent assessment for us. From what we  
15 have seen so far, our preliminary report has been put out.  
16 We have not seen any anomalies in the protective relaying  
17 area, I think everything operated as it was supposed to.

18 Everything -- all the relays operated as designed  
19 and isolated the fault. So we don't really see any  
20 anomalies there.

21 MR. STONER: Does any of the information available  
22 indicate that there were any perturbations that were  
23 superimposed upon the voltages that were supplied -- or,  
24 excuse me, are the source for the UPS systems or the safety  
25 buses, and if not, would you expect -- what kind of




1 perturbations may you have expected to be seen there, if  
2 any?

3 MR. JULKA: Initially, when the event happened and  
4 we did not have the oscillographs from Scriba. We did -- in  
5 our initial information was that UPS's tripped on lower  
6 voltage. We did suspect some lower voltage transients at  
7 that time. But from noon on the 8/13 -- the day of the  
8 event, we received the copies of the oscillographs from  
9 Scriba and at that time it was very clear to us that from  
10 what was shown on the 345 side that there were no audible  
11 phase transients in the plant.

12 The voltage did that and we did experience  
13 undervoltage, especially in the B phase. You know, there  
14 were the associated undervoltage in the other two phases and  
15 that under voltage was carried through the plant and that  
16 was evident from the trouble shooting that we have done on  
17 UPS to date and also at the same time, since our safety  
18 systems are normally fed from the 115 kV offsite source  
19 which originates from the 345 kV at the Scriba station, we  
20 did see a dip in that voltage.

21 The reason I say that is because we did see  
22 undervoltage relay flags on the divisional buses come in.  
23 However, at that time it was not sufficient to initiate any  
24 actions required due to the undervoltage. Mainly, the  
25 diesel didn't start, you know, that undervoltage really





1 starts the diesel.

2           So, I guess overall we didn't really foresee any  
3 extraordinary voltage transients. We did find undervoltage  
4 in the plant for a few cycles while the line 23 which is the  
5 345 kV line was disconnected from the system. We did  
6 accomplish a fast transfer as designed and all the loads  
7 were transferred over to the reserve station service which  
8 is a normal feed for the safety related buses.

9           So, we don't really see any anomalies there in the  
10 electrical distribution system.

11           MR. STONER: From the information available, could  
12 you and have you approximated what the voltage is -- may  
13 have been on the three phases at the input source to the six  
14 -- to the UPS systems and to the 4160 volt safety systems?

15           MR. JULKA: Yeah. On the safety systems we  
16 suspect the voltage got below 92.5 which is our commitment  
17 for the graded voltage level relays. It went down below  
18 that and the 80 percent which is the backup protection for  
19 loss of voltage, and that sat for three seconds, those  
20 didn't come in. So I think all we know is it got down to  
21 below 92.5 and not 80 for three seconds.

22           I imagine looking then in a rough approximation  
23 will be we were maybe around 78-79 percent for just cycles.  
24 And on the UPS, as per our discussions before, initially we  
25 calculated from the Scriba station, we found out what the




1 voltages there were and we transformed those voltages back  
2 to the plant and UPS's are fed from 208/120\*/Wye system.

3 We did find the voltages, especially in the B  
4 phase, dipped down to 65 some odd volts. But that was  
5 based on that fault that was on the 345 side. Then we also  
6 calculated a voltage based on if the low voltage winding  
7 phase B was shorted out, what the voltages would be. So  
8 those two extreme voltage evaluations tell us that the  
9 voltage was between 48 and 65.

10 In all reality, I guess we would suspect that  
11 voltage was around 55, somewhere in the middle if those were  
12 the two extreme cases and we know that neither one of them  
13 really were true. So, it's really a hypothesis and we have  
14 bounded the voltage which is consistent with the evaluation  
15 which is being done with the UPS right now.

16 MR. STONER: What protective relay actions  
17 occurred during this event?

18 MR. JULKA: Okay. Since the phase B main  
19 transformer had fault in it the differential relay for the  
20 main transformer B operated and the unit differential which  
21 also connects the generator, includes the generator and  
22 transformer region; that also operated. We had fault  
23 pressure relays on the transformer which operated. And  
24 those were the primary relays which operated and they  
25 operated the lock out -- different lock out relays and




1 different schemes which initiates a turbine trip. At the  
2 same time we also noticed start-up -- generator to start-up  
3 overcurrent relays came in and operated a different set of  
4 schemes.

5 Our conclusion is that those came in after the 345  
6 kV line was disconnected from the system. Since those  
7 relays have an on-line contact in series with them, that  
8 those relays should only come on when the unit is off-line.  
9 So, we imagine those relays came in a little later after the  
10 generator was disconnected from the system. And they do  
11 operate another lock, or relay which sends a slow transfer  
12 signal and that was another evidence that fast transfer did  
13 take place, because those relays came in later on and our  
14 charts show that the 115 kV lines did pick up the load soon  
15 after disconnecting from the 345.

16 MR. IBARRA: Anil, can you explain how come the  
17 diesel generators did not come on?

18 MR. JULKA: The diesel generators are started only  
19 if the degraded voltage relays on the safety buses -- the  
20 voltage stays degraded for 30 seconds. And we did not -- we  
21 did initiate the relays, but we did not initiate the timers.  
22 Our timers did not have enough time because the voltage did  
23 not dip for that long.

24 MR. IBARRA: What is the assessment so far, as far  
25 as the -- where the fault occurred on the high side and the



1 low side, can you explain?

2 MR. JULKA: I think it's the hypothesis, right now  
3 -- our initial indication we had was that the above ground  
4 currents flowing in the 345 kV system. So, I had initially  
5 hypothesized the ground to be in the -- or whatever the word  
6 is, to be on the high side.

7 With all the transformer exposed, I looked at the  
8 transformer. So far they are saying that the fault may have  
9 started on the low side. So, I don't think there is a  
10 definite conclusion on that as yet. I think we can only  
11 determine that after the transformer is sent out for  
12 evaluation and they open it up and see that it -- we know  
13 definitely that the 345 kV system had a ground in it --  
14 ground current flowing through it.

15 MR. IBARRA: What would be the difference in  
16 assessment if it occurred on one side and the other side as  
17 far as the protection of the system?

18 MR. JULKA: The protection schemes would operate  
19 either way. The only difference would be if there was a  
20 ground fault on the low voltage side prior to short -- you  
21 know, shorting out completely. I think the ground voltage  
22 relays on the generator side may have operated quicker.  
23 They are disconnected after the lockout relay operates.

24 So it was a race in time, I guess with different  
25 relays operating time. But I would have expected that the






1 generator ground relays may have come in if the fault had  
2 started on the ground side. On the low voltage side.

3 MR. IBARRA: How long does it take to clear a  
4 fault and get back on line?

5 MR. JULKA: If a fast transfer is going to take  
6 place is going to take place we should clear the fault  
7 within six cycles and transfer over to the other reserve  
8 transformers. So our commitment in the FSAR is the six  
9 cycles from the initiation from the lockout. After the  
10 lockout relay operate the initiator timer, which is set for  
11 six cycles, and if the transfer does not take place in six  
12 cycles we disconnect the offsite sources and we go for a  
13 slow transfer.

14 And there's another relay which monitors that and  
15 only connects the buses after 30 seconds and it also  
16 disconnects, feedwater -- all the large motors, feedwater  
17 condensate booster, recirc pump is tripped to low speed, so  
18 those connection did take place. That's where there was  
19 some confusion in it initially whether it was a fast  
20 transfer or slow transfer because we did have a trip of the  
21 feedwater recirc pump and condensate booster pumps. But  
22 looking at the charts we have established that fast transfer  
23 did take place and we had to review other things on why  
24 those pumps tripped.

25 MR. IBARRA: Can you explain the in-plant



1 monitoring system, what's available and what -- during this  
2 incident?

3 MR. JULKA: Not a whole lot. I guess we have --  
4 we had to make all our reductions for the 345 kV side. We  
5 had an oscillograph in the plant which is an old style --  
6 old type which was not working at the time of the event. So  
7 we did not really have too much information on the plant  
8 side. We had to make our deductions from the high voltage  
9 side.

10 MR. STONER: You indicated there was no operation  
11 of the generator neutral ground relay. Has that system been  
12 checked to verify that it is in service?

13 MR. JULKA: Right. We did check the resistor. We  
14 checked the transformer and they have verified that the  
15 system is in tact. We had a concern after -- you know, the  
16 different theories on other transformer came out, that since  
17 a fault could happen on the low voltage side, so we wanted  
18 to check out the generator grounding system, isophase bus  
19 and the other transformers. So they have checked that out  
20 and they have verified that, yeah, it does work properly.  
21 There is no damage to that piece of equipment.

22 MR. STONER: Have you been able to determine  
23 whether the generator surge arresters may have operated on  
24 the isolated phase bus system?

25 MR. JULKA: We asked them to check that, but I




1 don't have the final indication if there was a damage there  
2 or if they operated at this time. But we should have that  
3 information by tomorrow.

4 MR. STONER: Do those arresters have counters or  
5 would the determination of their operation simply be a  
6 matter of inspection?

7 MR. JULKA: It will be just a matter of  
8 inspection.

9 MR. IBARRA: Can you tell me what other  
10 consultants have helped you in your assessment of this  
11 event as far as distribution is concerned -- electrical  
12 distribution?

13 MR. JULKA: Well, the assessment was made by our  
14 group, but we had some consultants verify what we had done  
15 for an independent review. And that was Mel Crenshaw from  
16 GE. He has prepared a report and I have given a copy to  
17 Jim Stoner -- of his report. Plus there were some, you  
18 know, other people at Niagara Mohawk -- people. There were  
19 some consultants called in from Stone and Webster for  
20 different evaluations to -- you know, make out some lists  
21 and stuff; like load lists, and also helped with the UPS in  
22 the plant. Since I didn't think UPS was clearly system  
23 engineering, design had to be involved in that so we had  
24 people we called in from Stone and Webster to stay full time  
25 at the UPS issue.



1 MR. IBARRA: Who are the people from Stone and  
2 Webster looking at distribution?

3 MR. JULKA: There was nobody from Stone and  
4 Webster looking at distribution. There was one guy from  
5 Stone and Webster -- Steve Tsombaris who looked at the UPS  
6 and helped with the UPS testing. We had on our distribution  
7 side, we had Leon Blasiak, he's an ex-Niagara Mohawk  
8 retiree who was initially involved. So he was involved with  
9 looking at some of the Scriba stuff -- voltages.

10 We had one guy, Ranjit Das who was here to help  
11 with the fire protection and Appendix R from ASTA which is a  
12 floor engineering -- he is ex-Stone and Webster, but now he  
13 works for ASTA, so we called him for some assistance in the  
14 lighting and Appendix R issues since he's a known Appendix R  
15 engineer in the industry right now and he was involved with  
16 the original design.

17 And we had three -- we had four more people who  
18 were assisting us down in Salina Meadows with the  
19 preparation of the load list, plant impact statements. That  
20 included, you know, Steve Erikson, Pat O'Brien, Roger Wyatt,  
21 and there were two other people who were helping us put it  
22 together over the week last weekend.

23 MR. IBARRA: Initially when the UPS went down,  
24 they were able to bring them up on the maintenance bus or  
25 the maintenance side, yet I guess two hours into the event





1 they tried to line it up with the normal AC. Do you have  
2 any idea why they would try to do that? And why not leave  
3 it on the maintenance?

4 MR. JULKA: Repeat that question again, I think  
5 I'm --

6 MR. IBARRA: Originally they brought the UPS back  
7 up on the maintenance -- the alternate power supply. And  
8 yet later on into the event, a few hours later, they tried  
9 to switch to the normal line up. Do you happen to have any  
10 reason why they would do that and not just leave it as it  
11 was?

12 MR. JULKA: No. I guess I don't -- I'm not that  
13 familiar with the operations procedures so I would rather  
14 not answer that question.

15 MR. IBARRA: But as far as you're -- the quality  
16 of power from the alternate source in the normal AC source  
17 going into the UPS, is it the same?

18 MR. JULKA: Yeah. The regulation is the same on  
19 the voltages. It's plus or minus two percent. But I think  
20 initially when the UPS went down the operations people  
21 started to recover and after a couple of hours we had our  
22 system engineer in, so at that time I think they may be  
23 trying to connect that to the regular source.

24 MR. IBARRA: If we looked past the UPS to let's  
25 say the 120 site, would we notice any difference in the bus



1 -- in the AC whether it was off the inverter or whether it  
2 was off the maintenance?

3 MR. JULKA: No. It doesn't really matter, I  
4 guess, downstream if they get plus or minus two percent. I  
5 think that's covered by -- the UPS's regulate that. And so,  
6 you know, there was no concern on the -- the UPS systems do  
7 have loads which are sensitive for the voltage regulation  
8 and since the loads were disconnected so there was no  
9 deviation farther down the line.

10 MR. IBARRA: Okay. That's all that we have. That  
11 terminates the interview.

12 [Whereupon, at 1:45 p.m., the taking of the  
13 interview was concluded.]

14

15

16

17

18

19

20


21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

In the Matter of:

NAME OF PROCEEDING: Interview of Anil Julka

DOCKET NUMBER: (Not applicable)


PLACE OF PROCEEDING: Scriba, New York

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

*Mark Handy*

---

Mark Handy  
Official Reporter  
Ann Riley & Associates, Ltd.



# OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Incident Investigation Team

Title: Nine Mile Point Nuclear Power Plant  
Interview of: ANIL JULKA

Docket No.

LOCATION: Scriba, New York

DATE: Friday, August 23, 1991


PAGES: 1 - 20

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950.

*Dupe of*

~~9305060-241~~






## ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
5	24	FSAR CHAPTER 7.4 (INCLUDED THE PERIOD)
6	9	HPCS INSTEAD OF HPSC (TYPO)
6	11	We did loose instead of didn't (Do not know the reason for this discrepancy.)
10	5	lower should be higher
10	6	lower voltage should be high voltage
10	10	no audible should be no credible.
11	17	graded should be degraded
11	19	sat should be set
13	11	lock, or should be lockout
14	7	I looked should be we looked (I personally did not inspect transformer at that time).
15	18	those connection should be their condition
16	4	reductions <sup>for</sup> should be deductions from
18	12	floor should be flour

Date 10/2/91 Signature Anil K. Jilka



UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

-----  
Interview of :  
ANIL JULKA :  
(Closed) :  
-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Friday, August 23, 1991

The interview commenced, pursuant to notice,  
at 1:10 p.m.

PRESENT FOR THE IIT:  
Jose Ibarra, NRC  
Jim Stoner, Duke, NRC



## P R O C E E D I N G S

[1:10 p.m.]

1  
2  
3 MR. IBARRA: This is Jose Ibarra from the NRC.  
4 I'm a team member from the IIT and with me I have Jim  
5 Stoner.


6 Today we will be interviewing Anil Julka from  
7 Niagara Mohawk. Anil, would you please state your name,  
8 your position, experience with the company?

9 MR. JULKA: Okay. My name is Anil Julka. I'm an  
10 electrical design supervisor for Niagara Mohawk electrical  
11 design group. I have been with Niagara Mohawk for  
12 approximately five years now.

13 My previous experience includes AEs and  
14 Westinghouse.

15 MR. IBARRA: Can you tell me your involvement or  
16 your responsibility in assessing what happened on August  
17 13th?

18 MR. JULKA: Okay. After the event I'm also part  
19 of the TSC task force for evaluation. After the event I got  
20 a call that we had declared a site area emergency so I came  
21 up to the site and at first they were just evaluating what  
22 had happened. And I got here around 9 o'clock or so or a  
23 little after that. And our main concern, we were  
24 hypothesizing at that point. We knew there was a  
25 transformer fault, but we were hypothesizing how the fault



1 had started.

2           So, I guess my primary responsibility that day was  
3 the major support for, you know, reactor shutdown. And  
4 after that my primary responsibility was tasked with  
5 reviewing the electrical distribution system to see what  
6 type of transients had occurred, and reviewing if the system  
7 had operated as designed and assist UPS people with the  
8 trouble shooting efforts and also with the main transformer  
9 wherever they needed help. So those were my primary  
10 responsibilities.

11           MR. IBARRA: One of the obvious faults was  
12 lighting. What assessments have gone on in lighting to  
13 assure that what the operator saw was correct and also final  
14 assessments as to what this is going to mean?

15           MR. JULKA: Okay. We have reviewed the entire  
16 plant lighting system. You know, we have five types of  
17 lighting systems. We have a normal lighting, emergency  
18 lighting, essential, egress and eight-hour battery pack  
19 lighting system.

20           During this event the essential portion of the  
21 lighting system was lost because of the loss of UPS. The  
22 normal lighting was still available, the emergency lighting  
23 was still available. In some of the areas we do have  
24 anomaly in the system that in some stairways there is a  
25 concern which was expressed, I guess, back in '89 that if we





1 loose UPS, certain areas -- stairwell areas get -- the  
2 eight-hour battery packs do not come on because they are fed  
3 from the normal source and since the lighting there is fed  
4 from UPS you could loose the UPS and the eight-hour battery  
5 packs do not come on.

6 At that time we did make an evaluation using  
7 Appendix R and it was documented that the Appendix R  
8 lighting was required for loss of normal power also in this  
9 case. And at that time also we did not loose normal power.  
10 So what -- last year, I guess, we started looking at the  
11 entire UPS loading issue because the electrical group was  
12 concerned about the loading on the UPS's. And at that time  
13 we decided that we should fix that anomaly also. So,  
14 rather than leave it as a modification of 89-042 which will  
15 address that issue and there's more that's currently being  
16 scheduled for refuel outage and thereafter.

17 So, our evaluation of the incident really says  
18 that, yeah, we did loose essential lighting. They did -- my  
19 understanding from talking -- looking at the operator's  
20 report is that they had to use flashlight in certain areas,  
21 but those are open stairways, so there is enough light  
22 coming in from other sides, so it wasn't completely dark,  
23 but there was some lighting coming in from the other sides.

24 Other than that anomaly we have not really found  
25 anything else which is contradictory to our commitments.



1 MR. IBARRA: There was an issue then with lighting  
2 in '89, an UPS redistribution of loads in '90, correct?

3 MR. JULKA: State that again? I didn't follow  
4 that.

5 MR. IBARRA: In 1990, there was a study done on  
6 the redistribution of the lighting according to the new UPS  
7 that were going to be put in?

8 MR. JULKA: I believe that was '91. Don't quote  
9 me on that. I thought we did it earlier this year.

10 MR. IBARRA: But, is the lighting issue separate  
11 from the distribution issue?

12 MR. JULKA: That's correct. That's correct.

13 MR. IBARRA: Two different studies?


14 MR. JULKA: Different studies, right.

15 MR. IBARRA: Okay. But the lighting issue was a  
16 few years before the distribution on the UPS?

17 MR. JULKA: The lighting issue came up in '89.

18 MR. IBARRA: Okay. The instruments that failed in  
19 the control room, can you tell us what happened there and  
20 how, and the assessment you've done so far?

21 MR. JULKA: First of all, in our commitment, we  
22 did not loose any of the safety related instrumentation in  
23 the plant, even control room. Our commitment in USAR or  
24 FSAR Chapter 74, is that we need four safety systems for  
25 safe shutdown which is the reactor core isolation cooling



1 system, which is called RCIC; you got standby liquid control  
2 system, SLS; RHR shutdown cooling mode and remote shutdown  
3 system. These systems and control and instrumentation for  
4 these systems was available, at least electrically,  
5 although I have heard that RCIC went in off for a while  
6 because of a valve, but it was not due to the UPS loss or  
7 any -- the event that happened that day. And my  
8 understanding is also that at the time RCIC was declared  
9 inop, it was not really required and we still had HPSC  
10 available.

11 We didn't lose plant annunciators, computers,  
12 feedwater control. Those are some of the things -- there is  
13 a complete list of things we have which were lost and we  
14 have evaluated those things and we have a separate group set  
15 up who is going to be doing the safety assessment of all  
16 these things which were lost to insure that they will not  
17 require our preliminary indication as that, yes, they were  
18 not required for safe shutdown of the plant. They assist  
19 operators, but in no way are necessary for a safe shutdown.

20 MR. IBARRA: Was Rixie or RCIC all of it  
21 inoperable or only portions of it inoperable?

22 MR. JULKA: Portions of it.

23 MR. IBARRA: So you did have one channel available  
24 versus -- two channels?

25 MR. JULKA: Well, in the initial portion of the



1 event it was available to support core cooling. But there  
2 was a lack of full close indication for the valves, AOV-156,  
3 that's the primary containment isolation valve.

4 But it was not really needed at the time it was  
5 declared inop.

6 MR. IBARRA: The computer systems were not  
7 available, can you tell me what those were fed off of and  
8 does that make sense that they would have lost those?

9 MR. JULKA: Yeah. Well, most of the plant  
10 computer system is fed of 1G, UPS 1G which was lost during  
11 this event and the LWS computer is fed off the UPS 1B. So  
12 we lost five of the non-safety UPS's which are all the same  
13 type, Exide, 1A, 1B, 1C, 1D and 1G. So loss of those will  
14 result in loss of plant computer system and that's -- since  
15 they are non-safety and they do feed the computer systems.

16 MR. IBARRA: Your regulatory guide 197  
17 instrumentation, was that all purple?

18 MR. JULKA: I don't have full details on that, but  
19 my -- I would suspect they were, but don't --

20 MR. IBARRA: How about the post-accident  
21 monitoring instrumentation?

22 MR. JULKA: Yeah. Post-accident should be  
23 operable.

24 MR. IBARRA: Okay. On the Appendix R assessment,  
25 the assessment of whether the capability existed to put out





1 fires, can you tell me a little bit about your involvement,  
2 your group involvement in that assessment?

3 MR. JULKA: We have an Appendix R engineer in our  
4 group. He looked at the Appendix R issue and our commitment  
5 in FSAR for Appendix R is in accordance with the fire  
6 protection guidelines, you know, reg guide Appendix R  
7 scenario in our plant is considered with the loss of normal  
8 off-site power identified in any given area you have a  
9 capability to shut down the plant.

10 We didn't really get into that scenario in this  
11 case because normal power was still available. So our  
12 evaluation really states, you know, that Appendix R  
13 compliance was not really impacted.

14 MR. IBARRA: When was your group called to look at  
15 that electrically?

16 MR. JULKA: Our group was never really called to  
17 look at anything electrically, except to look at the entire  
18 electrical distribution system. It was my decision, I  
19 guess, for now that within my group that we should look at  
20 every system there is which is, in fact, to make sure that  
21 loss of these UPS systems would not really affect any  
22 electrical related systems in the plant. And our compliance  
23 to USAR was still valid.

24 MR. IBARRA: Since a few of the instruments were  
25 inoperable previous to the event itself, are you going to



1 have any involvement with assessing the impact that some of  
2 those instruments being inoperable would have -- did have on  
3 the event -- being able to indicate in the control room?

4 MR. JULKA: Yeah, that will be assess as part of  
5 our safety assessment.

6 MR. STONER: Have you reviewed -- completed a  
7 review of the electrical distribution system, and have you  
8 made a determination whether the system -- the in-plant  
9 systems as well as the switch yard systems operated as  
10 designed, including the associated protective systems?

11 MR. JULKA: Yeah. We had a pretty extensive  
12 review of the protective relaying associated with the unit  
13 protection system. And we also had a fellow from GE, Mel  
14 Crenshaw do an independent assessment for us. From what we  
15 have seen so far, our preliminary report has been put out.  
16 We have not seen any anomalies in the protective relaying  
17 area, I think everything operated as it was supposed to.

18 Everything -- all the relays operated as designed  
19 and isolated the fault. So we don't really see any  
20 anomalies there.

21 MR. STONER: Does any of the information available  
22 indicate that there were any perturbations that were  
23 superimposed upon the voltages that were supplied -- or,  
24 excuse me, are the source for the UPS systems or the safety  
25 buses, and if not, would you expect -- what kind of




1 perturbations may you have expected to be seen there, if  
2 any?

3 MR. JULKA: Initially, when the event happened and  
4 we did not have the oscillographs from Scriba. We did -- in  
5 our initial information was that UPS's tripped on lower  
6 voltage. We did suspect some lower voltage transients at  
7 that time. But from noon on the 8/13 -- the day of the  
8 event, we received the copies of the oscillographs from  
9 Scriba and at that time it was very clear to us that from  
10 what was shown on the 345 side that there were no audible  
11 phase transients in the plant.

12 The voltage did that and we did experience  
13 undervoltage, especially in the B phase. You know, there  
14 were the associated undervoltage in the other two phases and  
15 that under voltage was carried through the plant and that  
16 was evident from the trouble shooting that we have done on  
17 UPS to date and also at the same time, since our safety  
18 systems are normally fed from the 115 kV offsite source  
19 which originates from the 345 kV at the Scriba station, we  
20 did see a dip in that voltage.

21 The reason I say that is because we did see  
22 undervoltage relay flags on the divisional buses come in.  
23 However, at that time it was not sufficient to initiate any  
24 actions required due to the undervoltage. Mainly, the  
25 diesel didn't start, you know, that undervoltage really



1 starts the diesel.

2           So, I guess overall we didn't really foresee any  
3 extraordinary voltage transients. We did find undervoltage  
4 in the plant for a few cycles while the line 23 which is the  
5 345 kV line was disconnected from the system. We did  
6 accomplish a fast transfer as designed and all the loads  
7 were transferred over to the reserve station service which  
8 is a normal feed for the safety related buses.

9           So, we don't really see any anomalies there in the  
10 electrical distribution system.

11           MR. STONER: From the information available, could  
12 you and have you approximated what the voltage is -- may  
13 have been on the three phases at the input source to the six  
14 -- to the UPS systems and to the 4160 volt safety systems?

15           MR. JULKA: Yeah. On the safety systems we  
16 suspect the voltage got below 92.5 which is our commitment  
17 for the graded voltage level relays. It went down below  
18 that and the 80 percent which is the backup protection for  
19 loss of voltage, and that sat for three seconds, those  
20 didn't come in. So I think all we know is it got down to  
21 below 92.5 and not 80 for three seconds.

22           I imagine looking then in a rough approximation  
23 will be we were maybe around 78-79 percent for just cycles.  
24 And on the UPS, as per our discussions before, initially we  
25 calculated from the Scriba station, we found out what the






1 voltages there were and we transformed those voltages back  
2 to the plant and UPS's are fed from 208/120\*/Wye system.

3 We did find the voltages, especially in the B  
4 phase, dipped down to 65 some odd volts. But that was  
5 based on that fault that was on the 345 side. Then we also  
6 calculated a voltage based on if the low voltage winding  
7 phase B was shorted out, what the voltages would be. So  
8 those two extreme voltage evaluations tell us that the  
9 voltage was between 48 and 65.

10 In all reality, I guess we would suspect that  
11 voltage was around 55, somewhere in the middle if those were  
12 the two extreme cases and we know that neither one of them  
13 really were true. So, it's really a hypothesis and we have  
14 bounded the voltage which is consistent with the evaluation  
15 which is being done with the UPS right now.

16 MR. STONER: What protective relay actions  
17 occurred during this event?

18 MR. JULKA: Okay. Since the phase B main  
19 transformer had fault in it the differential relay for the  
20 main transformer B operated and the unit differential which  
21 also connects the generator, includes the generator and  
22 transformer region; that also operated. We had fault  
23 pressure relays on the transformer which operated. And  
24 those were the primary relays which operated and they  
25 operated the lock out -- different lock out relays and




1 different schemes which initiates a turbine trip. At the  
2 same time we also noticed start-up -- generator to start-up  
3 overcurrent relays came in and operated a different set of  
4 schemes.

5 Our conclusion is that those came in after the 345  
6 kV line was disconnected from the system. Since those  
7 relays have an on-line contact in series with them, that  
8 those relays should only come on when the unit is off-line.  
9 So, we imagine those relays came in a little later after the  
10 generator was disconnected from the system. And they do  
11 operate another lock, or relay which sends a slow transfer  
12 signal and that was another evidence that fast transfer did  
13 take place, because those relays came in later on and our  
14 charts show that the 115 kV lines did pick up the load soon  
15 after disconnecting from the 345.

16 MR. IBARRA: Anil, can you explain how come the  
17 diesel generators did not come on?

18 MR. JULKA: The diesel generators are started only  
19 if the degraded voltage relays on the safety buses -- the  
20 voltage stays degraded for 30 seconds. And we did not -- we  
21 did initiate the relays, but we did not initiate the timers.  
22 Our timers did not have enough time because the voltage did  
23 not dip for that long.

24 MR. IBARRA: What is the assessment so far, as far  
25 as the -- where the fault occurred on the high side and the



1 low side, can you explain?

2 MR. JULKA: I think it's the hypothesis, right now  
3 -- our initial indication we had was that the above ground  
4 currents flowing in the 345 kV system. So, I had initially  
5 hypothesized the ground to be in the -- or whatever the word  
6 is, to be on the high side.

7 With all the transformer exposed, I looked at the  
8 transformer. So far they are saying that the fault may have  
9 started on the low side. So, I don't think there is a  
10 definite conclusion on that as yet. I think we can only  
11 determine that after the transformer is sent out for  
12 evaluation and they open it up and see that it -- we know  
13 definitely that the 345 kV system had a ground in it --  
14 ground current flowing through it.

15 MR. IBARRA: What would be the difference in  
16 assessment if it occurred on one side and the other side as  
17 far as the protection of the system?

18 MR. JULKA: The protection schemes would operate  
19 either way. The only difference would be if there was a  
20 ground fault on the low voltage side prior to short -- you  
21 know, shorting out completely. I think the ground voltage  
22 relays on the generator side may have operated quicker.  
23 They are disconnected after the lockout relay operates.

24 So it was a race in time, I guess with different  
25 relays operating time. But I would have expected that the




1 generator ground relays may have come in if the fault had  
2 started on the ground side. On the low voltage side.

3 MR. IBARRA: How long does it take to clear a  
4 fault and get back on line?

5 MR. JULKA: If a fast transfer is going to take  
6 place is going to take place we should clear the fault  
7 within six cycles and transfer over to the other reserve  
8 transformers. So our commitment in the FSAR is the six  
9 cycles from the initiation from the lockout. After the  
10 lockout relay operate the initiator timer, which is set for  
11 six cycles, and if the transfer does not take place in six  
12 cycles we disconnect the offsite sources and we go for a  
13 slow transfer.

14 And there's another relay which monitors that and  
15 only connects the buses after 30 seconds and it also  
16 disconnects, feedwater -- all the large motors, feedwater  
17 condensate booster, recirc pump is tripped to low speed, so  
18 those connection did take place. That's where there was  
19 some confusion in it initially whether it was a fast  
20 transfer or slow transfer because we did have a trip of the  
21 feedwater recirc pump and condensate booster pumps. But  
22 looking at the charts we have established that fast transfer  
23 did take place and we had to review other things on why  
24 those pumps tripped.

25 MR. IBARRA: Can you explain the in-plant





1 monitoring system, what's available and what -- during this  
2 incident?


3 MR. JULKA: Not a whole lot. I guess we have --  
4 we had to make all our reductions for the 345 kV side. We  
5 had an oscillograph in the plant which is an old style --  
6 old type which was not working at the time of the event. So  
7 we did not really have too much information on the plant  
8 side. We had to make our deductions from the high voltage  
9 side.

10 MR. STONER: You indicated there was no operation  
11 of the generator neutral ground relay. Has that system been  
12 checked to verify that it is in service?

13 MR. JULKA: Right. We did check the resistor. We  
14 checked the transformer and they have verified that the  
15 system is in tact. We had a concern after -- you know, the  
16 different theories on other transformer came out, that since  
17 a fault could happen on the low voltage side, so we wanted  
18 to check out the generator grounding system, isophase bus  
19 and the other transformers. So they have checked that out  
20 and they have verified that, yeah, it does work properly.  
21 There is no damage to that piece of equipment.

22 MR. STONER: Have you been able to determine  
23 whether the generator surge arresters may have operated on  
24 the isolated phase bus system?

25 MR. JULKA: We asked them to check that, but I



1 don't have the final indication if there was a damage there  
2 or if they operated at this time. But we should have that  
3 information by tomorrow.

4 MR. STONER: Do those arresters have counters or  
5 would the determination of their operation simply be a  
6 matter of inspection?

7 MR. JULKA: It will be just a matter of  
8 inspection.

9 MR. IBARRA: Can you tell me what other  
10 consultants have helped you in your assessment of this  
11 event as far as distribution is concerned -- electrical  
12 distribution?

13 MR. JULKA: Well, the assessment was made by our  
14 group, but we had some consultants verify what we had done  
15 for an independent review. And that was Mel Crenshaw from  
16 GE. He has prepared a report and I have given a copy to  
17 Jim Stoner -- of his report. Plus there were some, you  
18 know, other people at Niagara Mohawk -- people. There were  
19 some consultants called in from Stone and Webster for  
20 different evaluations to -- you know, make out some lists  
21 and stuff; like load lists, and also helped with the UPS in  
22 the plant. Since I didn't think UPS was clearly system  
23 engineering, design had to be involved in that so we had  
24 people we called in from Stone and Webster to stay full time  
25 at the UPS issue.



1 MR. IBARRA: Who are the people from Stone and  
2 Webster looking at distribution?

3 MR. JULKA: There was nobody from Stone and  
4 Webster looking at distribution. There was one guy from  
5 Stone and Webster -- Steve Tsombaris who looked at the UPS  
6 and helped with the UPS testing. We had on our distribution  
7 side, we had Leon Blasiak, he's an ex-Niagara Mohawk  
8 retiree who was initially involved. So he was involved with  
9 looking at some of the Scriba stuff -- voltages.

10 We had one guy, Ranjit Das who was here to help  
11 with the fire protection and Appendix R from ASTA which is a  
12 floor engineering -- he is ex-Stone and Webster, but now he  
13 works for ASTA, so we called him for some assistance in the  
14 lighting and Appendix R issues since he's a known Appendix R  
15 engineer in the industry right now and he was involved with  
16 the original design.

17 And we had three -- we had four more people who  
18 were assisting us down in Salina Meadows with the  
19 preparation of the load list, plant impact statements. That  
20 included, you know, Steve Erikson, Pat O'Brien, Roger Wyatt,  
21 and there were two other people who were helping us put it  
22 together over the week last weekend.

23 MR. IBARRA: Initially when the UPS went down,  
24 they were able to bring them up on the maintenance bus or  
25 the maintenance side, yet I guess two hours into the event



1 they tried to line it up with the normal AC. Do you have  
2 any idea why they would try to do that? And why not leave  
3 it on the maintenance?

4 MR. JULKA: Repeat that question again, I think  
5 I'm --

6 MR. IBARRA: Originally they brought the UPS back  
7 up on the maintenance -- the alternate power supply. And  
8 yet later on into the event, a few hours later, they tried  
9 to switch to the normal line up. Do you happen to have any  
10 reason why they would do that and not just leave it as it  
11 was?

12 MR. JULKA: No. I guess I don't -- I'm not that  
13 familiar with the operations procedures so I would rather  
14 not answer that question.

15 MR. IBARRA: But as far as you're -- the quality  
16 of power from the alternate source in the normal AC source  
17 going into the UPS, is it the same?

18 MR. JULKA: Yeah. The regulation is the same on  
19 the voltages. It's plus or minus two percent. But I think  
20 initially when the UPS went down the operations people  
21 started to recover and after a couple of hours we had our  
22 system engineer in, so at that time I think they may be  
23 trying to connect that to the regular source.

24 MR. IBARRA: If we looked past the UPS to let's  
25 say the 120 site, would we notice any difference in the bus





1 -- in the AC whether it was off the inverter or whether it  
2 was off the maintenance?

3 MR. JULKA: No. It doesn't really matter, I  
4 guess, downstream if they get plus or minus two percent. I  
5 think that's covered by -- the UPS's regulate that. And so,  
6 you know, there was no concern on the -- the UPS systems do  
7 have loads which are sensitive for the voltage regulation  
8 and since the loads were disconnected so there was no  
9 deviation farther down the line.

10 MR. IBARRA: Okay. That's all that we have. That  
11 terminates the interview.

12 [Whereupon, at 1:45 p.m., the taking of the  
13 interview was concluded.]

14

15

16

17

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


In the Matter of:

NAME OF PROCEEDING: Interview of Anil Julka

DOCKET NUMBER: (Not applicable)

PLACE OF PROCEEDING: Scriba, New York

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



---

Mark Handy  
Official Reporter  
Ann Riley & Associates, Ltd.

