

ORIGINAL

07-159A-91

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Incident Investigation Team

Title: Nine Mile Point Nuclear Power Plant  
Interview of: EARL SCOTT "TOM"  
TOMLINSON III

Docket No.

LOCATION: Scriba, New York

DATE: Monday, August 26, 1991

PAGES: 1 - 34

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950.

9305060305 911031  
PDR ADOCK 05000410  
S PDR



ADDENDUM TO INTERVIEW OF Tom Tomlinson / Reactor Engineering Super  
(Name/Position)

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
7	9	Senses not sends cooling values closed
9	23	should be <del>SHM-A001</del> CNM-A0V101 and CNM-A0V109
9	25	heater string; not heater stream
15	3	should be heater bay
17	29	in the
21	24	above and below refusal
24	13	reject to the condenser
24	15	automatically open
24	23	in opening to bypass the tower
27	1	heater string
27	20	open not to open
28	21	heat removal not head removal
29	20	technical message

Page 1 of 1 Signature [Signature] Date 6/26/97

0

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

-----

Interview of :  
EARL SCOTT "TOM" TOMLINSON III :  
(Closed) :

-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Monday, August 26, 1991

The interview commenced, pursuant to notice,  
at 2:10 p.m.

PRESENT FOR THE IIT:

- John Kauffman, NRC
- Jose Ibarra, NRC
- Richard Conte, NRC

17



## P R O C E E D I N G S

[2:10 p.m.]

1  
2  
3 MR. KAUFFMAN: Good afternoon. It's August 26,  
4 1991 at 2:10 p.m. My name is John Kauffman, I'm here  
5 conducting an interview of Tom Tomlinson at the Niagara  
6 Mohawk Power Company, Unit Two, P Admin Building.

7 We're investigating a plant event and transient of  
8 August 13, 1991 and we'll be interviewing Tom Tomlinson.

9 MR. IBARRA: I'm Jose Ibarra from the IIT team.

10 MR. CONTE: Rich Conte, NRC, Region One.

11 MR. TOMLINSON: I'm Tom Tomlinson from Unit Two,  
12 Reactor Engineering Operations Department.

13 MR. KAUFFMAN: Okay, Tom, we would like you to  
14 start by telling us a little bit about your background and  
15 experience that you bring to your present job and a little  
16 bit about your involvement here with the event  
17 investigation?

18 MR. TOMLINSON: I've been with Niagara Mohawk  
19 since 1984 when I graduated from RPI with a degree in  
20 nuclear engineering. I've been in the reactor engineering  
21 department since that time. And I now hold the position of  
22 supervisor, reactor engineering.

23 As part of that position I'm responsible for the  
24 plant scram response and post-trip review. In the  
25 operations department, the reactor engineer reports to the





1 operations manager. I currently hold an SRO license for  
2 Unit Two and I have a PE license from the State of New York.

3 MR. KAUFFMAN: Tom, when did you get licensed?  
4 How long have you held a license and did you stand on shift  
5 time?

6 MR. TOMLINSON: I have not stood on shift time.  
7 No, I'm a staff license and I received that license  
8 approximately a year ago.

9 MR. KAUFFMAN: Okay, Rich, you have a list of  
10 specific questions, you may as well start on your list.

11 MR. CONTE: Okay. First, what involvement did you  
12 have in the day's events? When did you first hear about the  
13 event and where were you? Were you coming in?

14 MR. TOMLINSON: I was in my car and I got a phone  
15 call in my car at 6:30 in the morning from the on-shift STA.  
16 The STA's report to me in the operations organization. The  
17 on-shift STA, Tom Tuttle, called me and told me that we were  
18 in a site area emergency and that they were having trouble  
19 identifying the position of six control rods and I arrived  
20 on site approximately a quarter of seven.

21 I first proceeded to the control room to try and  
22 help with the rod position indication problems, by that time  
23 they had all-rod-in indications and they were having  
24 intermittent problems with one rod, 1431. I then, because  
25 we were in a site area emergency, proceeded to the technical



1 support center and took up the role of reactor analyst  
2 coordinator in the TSC. I spent all day there until we  
3 terminated the event later that night.

4 MR. CONTE: What issues did you get involved in as  
5 reactor analyst coordinator at the tech support center?  
6 What broad issues were you working on with your people?

7 MR. TOMLINSON: Well, by that time we had  
8 ascertained that we did have all rods in so the core  
9 conditions were known at that time. Indications had already  
10 been restored. Typically my position down there does things  
11 like fuel damage, core damage calculations, and all that and  
12 that was not necessary, so I spent most of my time helping  
13 the site emergency director with operational type concerns,  
14 trying to help him, lead him through the emergency plan and  
15 understanding plant conditions as they arose throughout the  
16 day.

17 MR. CONTE: And the site emergency director was  
18 Marty McCormick?

19 MR. TOMLINSON: That's correct.

20 MR. CONTE: He was stationed at the STS -- at the  
21 TSC?

22 MR. TOMLINSON: That's correct.

23 MR. CONTE: Okay. One of the concerns throughout  
24 the day was getting the UPS back on its normal supply; were  
25 you involved in that at all in terms of giving advice



1 whether they should do it or not do it?

2 MR. TOMLINSON: Not directly. That was the SED's  
3 decision and I'm not sure who else was involved in that  
4 decision.

5 MR. CONTE: Okay. All right, I guess I'm ready to  
6 move into some of the more specific questions about  
7 equipment problems that we've been tracking as a team. And  
8 I guess for each of these items, I would like, if you can  
9 remember, four basic questions on each of them; whether or  
10 not it's addressed in your assessment report, and I guess  
11 for the record we ought to identify that you're also the  
12 group leader for the licensees assessment group and you're  
13 looking into the area of plant response, primarily the post-  
14 trip review. Is that correct?

15 MR. TOMLINSON: That's correct.

16 MR. CONTE: Okay. If it's in your report or not,  
17 to the best of your ability why it happened, include, you  
18 know -- identify if it's any speculation or not, and whether  
19 or not you know whether there's corrective actions in terms  
20 of work requests out, startup issues -- whether it's a  
21 startup issue or not. Okay.

22 The first one that we have a question about is the  
23 -- the event where there was a loss of drywell cooling.  
24 Coupled with that, I guess, there was some issue with a LOCA  
25 bypass switch associated with that control circuit, could



1 you explain that or do you know why there was a loss of  
2 drywell cooling? Is that a consequential failure from the  
3 UPS failure?

4 MR. TOMLINSON: To the best of my knowledge the  
5 failure of drywell cooling was caused by a optical isolator  
6 that provides information to the interlocks for drywell  
7 cooling. The drywell cooling fans trip off if a signal --  
8 if they get a signal that the cooling water valves are  
9 closed. And in that logic there is an optical isolator it  
10 has both safety related and black power on it. Losing the  
11 black power side of that optical isolator, I believe the  
12 logic signal -- the logic for the fans believe that those  
13 drywell cooling valves were closed, and therefore tripped  
14 the fans off.

15 MR. IBARRA: Tom, do you know what UPS this is out  
16 of?

17 MR. TOMLINSON: I do not know.

18 There are LOCA bypass switches which -- which  
19 bypass that interlock. I know that the on-shift ASSS, Mike  
20 Eron, investigated that during the event, identified the  
21 fact that there was black power needed in that LOCA bypass  
22 switch circuit somewhere and was making preparations for a  
23 temp mod to bypass that circuit or jumper out that logic if  
24 needed. I don't know specifics.

25 MR. CONTE: What's being done with that LOCA





1 bypass switch?

2 MR. TOMLINSON: There's a -- I believe there's a  
3 plant change request that has been put in the system to  
4 reevaluate that logic scheme.

5 MR. CONTE: Okay. So it's sound to me like  
6 there's some understanding as to why drywell cooling failed  
7 because of the loss of power -- not failed, but tripped, the  
8 loss of power to optical isolators, apparently its circuit  
9 or the logic circuits sends cooling valves closed, shut down  
10 the fan and when you attempted or considered using the LOCA  
11 bypass switches to get them started you also found they  
12 wouldn't work?

13 MR. TOMLINSON: That's correct.

14 MR. CONTE: And you identified, I guess it was Mr.  
15 Eron identified, that black power was needed for those  
16 switches to work?

17 MR. TOMLINSON: That's correct.

18 MR. CONTE: In the control circuit?

19 MR. TOMLINSON: That's correct.

20 MR. CONTE: Any questions?

21 MR. IBARRA: Is that going to be part of your  
22 event assessment?

23 MR. TOMLINSON: That is mentioned in my report,  
24 yes.

25 MR. KAUFFMAN: In the event, how were the fans



1 restored?

2 MR. TOMLINSON: They were restored when the power  
3 was restored.

4 MR. KAUFFMAN: Was it automatic?

5 MR. TOMLINSON: No. You have to manually start  
6 those.

7 MR. CONTE: I guess a specific question on the  
8 safety relief valves: Does anybody know when they were  
9 first identified to have lifted? It's our understanding  
10 from the operator's viewpoint that wasn't something that  
11 they noticed in light of all the others things that they had  
12 to verify. Do you know from the sequence in time when it  
13 was first identified that there had been two valves lifted?

14 MR. TOMLINSON: What I know of that event is that  
15 later in the day Tom Tuttle, the shift technical advisor,  
16 was reviewing indications in the control room and found on  
17 the strip chart recorder for SRV tailpipe temperatures that  
18 we did have indication that two SRVs lifted.

19 MR. CONTE: Do you know about what time he was  
20 doing that?

21 MR. TOMLINSON: I do not know. It was not right  
22 away.

23 MR. CONTE: Is it safe to say that it was after 7  
24 o'clock?

25 MR. TOMLINSON: It was after 7 o'clock.



1 MR. CONTE: Okay.

2 MR. KAUFFMAN: For a transient that was the type  
3 of transient that was experienced in the plant's initial  
4 conditions and your knowledge level and training, would you  
5 expect SRVs to lift on this type of a trip?

6 MR. TOMLINSON: Yes, I would. I would expect SRVs  
7 to lift on a load reject from high power. It was not  
8 surprising to me.

9 MR. CONTE: Do you remember what the highest  
10 pressure you saw on your review was?

11 MR. TOMLINSON: Yes, 1070 pounds was the highest  
12 pressure we saw.

13 MR. CONTE: Okay.

14 Another question: It's our understanding that by  
15 design the condensate demineralizer's bypass valve opens on  
16 a trip from 100 percent power. Is that correct?

17 MR. TOMLINSON: That's correct. There are two  
18 valves that open on a turbine trip from high power. I  
19 believe the setpoint is 30 percent; a turbine trip from  
20 greater than 30 percent power -- no, that's not correct.  
21 It's 80 percent.

22 MR. CONTE: What are they?

23 MR. TOMLINSON: That's CNM AOV-101 and AOV-109.  
24 Those are the condensate demineralizer bypass valves and the  
25 low pressure heater stream bypass valve.



1 MR. KAUFFMAN: Why do those valves open? What's  
2 the function?

3 MR. TOMLINSON: They open to allow 115 percent  
4 nuclear design boiler flow on the event of a turbine trip to  
5 maintain level. Both those valves are designed to go open  
6 in the scenario, and both valves did open, as designed.

7 MR. CONTE: You say the designators on these  
8 valves were CNM. Is that containment monitoring?

9 MR. TOMLINSON: That's condensate system.

10 MR. CONTE: Oh, it's condensate system.

11 I want to get the numbers again. AOV-101 and 109?

12 MR. TOMLINSON: That's correct.

13 MR. CONTE: That 101 is the bypass; the 109 is the  
14 feedwater?

15 MR. TOMLINSON: I'm not positive.

16 MR. CONTE: You're not sure. Okay.

17 MR. KAUFFMAN: Does your investigation look at  
18 whether the loss of the UPS might have also caused these to  
19 go open if the automatic signal hadn't worked?

20 MR. TOMLINSON: My investigation did not. I can't  
21 speak for the UPS investigation.

22 MR. CONTE: I need to understand this. I really  
23 didn't understand what you said; my mind was drifting. At  
24 115 percent of flow -- say that again, as to why those  
25 valves go open.





1 MR. TOMLINSON: In order to provide extra flow to  
2 the reactor in the case where you take a high-power turbine  
3 trip.

4 MR. CONTE: Oh, extra feed.

5 MR. TOMLINSON: Extra feed.

6 MR. CONTE: To mitigate the effects of the level  
7 drop.

8 MR. TOMLINSON: Correct.

9 MR. CONTE: I see. Okay.


10 Reactor core isolation cooling, RCIC, the auto-  
11 controller, is that a real problem? Has it been a problem  
12 in the past?

13 MR. TOMLINSON: That controller was identified  
14 earlier -- I can't say how earlier -- that the controller  
15 needed tuning, and there is an outstanding WR to  
16 troubleshoot that. It was a problem we knew about.

17 MR. CONTE: There was an outstanding work request  
18 on it?

19 MR. TOMLINSON: I believe it was a work request  
20 waiting to be worked.

21 MR. KAUFFMAN: Can you describe to me the  
22 decision process the operators would go through when there  
23 is an outstanding work request on an item of known equipment  
24 problem on their operability determination, their decision  
25 on whether or not they should enter an LCO? Do they wait



1 until the work is done or started?

2 MR. TOMLINSON: I guess I don't understand your  
3 question.

4 MR. KAUFFMAN: I guess my question is, there's a  
5 work request on this controller; RCIC is in tech specs; it  
6 has certain functions it's supposed to do. How would the  
7 operator determine whether this problem makes it inoperable  
8 or not? I'm really looking to understand the process, not  
9 necessarily specifics in this case.

10 MR. TOMLINSON: I guess what you're asking me is  
11 the thought process for an operability determination from  
12 the SSS point of view.

13 MR. KAUFFMAN: Right, maybe the review process  
14 that the work request would get to make sure that that's all  
15 done and documented.

16 MR. TOMLINSON: I don't think I can speak for the  
17 work control process. I know from an SSS point of view he  
18 would review the concern that was brought up on the work  
19 request and make a decision at that point based on his  
20 knowledge of the system, as to whether that would affect its  
21 operability. In cases where something just needs to be  
22 tuned, that may or may not affect its operability.

23 MR. KAUFFMAN: Okay.

24 MR. IBARRA: As far as RCIC, has Niagara Mohawk  
25 determined that it is a generic type problem, or what have



1 you all done as far as researching the kind of problems  
2 you're having?

3 MR. TOMLINSON: For this particular event, we have  
4 not completed the troubleshooting effort. I can't answer  
5 your question for generic implications. A system engineer  
6 would be better qualified to answer that type of question.

7 MR. CONTE: Does that go for the position  
8 indicator problem with the check valves also?

9 MR. TOMLINSON: As to whether it's a generic  
10 problem?

11 MR. CONTE: Right.

12 MR. TOMLINSON: A system engineer would be able to  
13 track those types of problems.

14 MR. CONTE: Are these two items or equipment  
15 problems mentioned in your report?

16 MR. TOMLINSON: Both of those are mentioned in my  
17 report, yes.

18 MR. CONTE: I guess it's my understanding you  
19 really don't know what the position problem is, also. I  
20 think there are outstanding work requests on that, too.

21 MR. TOMLINSON: I do not know if those work  
22 requests have been closed out yet or not.

23 MR. CONTE: Okay.

24 The performance of the condensate valve, 84 -- I  
25 guess for the record would you give me the official



1 designator for the 84 valve?

2 MR. TOMLINSON: That would be CNM MOV-84.

3 MR. CONTE: That's A, B, and C?

4 MR. TOMLINSON: A, B, and C. Those are the feed  
5 pump suction valves.

6 MR. CONTE: Those valves were shut, I guess, in  
7 the startup process of getting condensate, and then they  
8 couldn't be opened. Is there any understanding of why they  
9 couldn't be opened?

10 MR. TOMLINSON: I believe we're still  
11 troubleshooting that -- system engineers are troubleshooting  
12 that to try and determine exactly why those valves would  
13 not reopen. They were shut in an effort to restart the  
14 condensate booster pumps. That is a procedural requirement.  
15 Then they would not reopen.

16 MR. CONTE: Do you have an understanding of why  
17 those valves are to be shut by procedure?

18 MR. TOMLINSON: I believe the reason we shut those  
19 valves is that we have had a history of problems with the  
20 feed pump suction pressure relief valves, and the procedure  
21 was changed a while back to require closing those valves so  
22 you didn't pop those suction relief valves.

23 I know the system engineer is reviewing that  
24 procedure requirement and considering changing that.

25 MR. IBARRA: Tom, what's the location of this





1 valve?

2 MR. TOMLINSON: I believe those valves are in the  
3 heater base.

4 MR. CONTE: Any other questions on 84?

5 MR. KAUFFMAN: Well, my understanding of the  
6 general problem was that there was a high DP across the  
7 valve, and the valves couldn't open because of the high DP.  
8 Is that generally correct?

9 MR. CONTE: I know that that's a standing theory,  
10 but I don't know whether there has been anything yet to  
11 prove that or not.

12 MR. CONTE: Is this in in your report?

13 MR. TOMLINSON: That is covered in my report, yes.

14 MR. KAUFFMAN: I know when we talked to the system  
15 engineer he said that the valves were tested, or are tested,  
16 during startup against the kind of DPs that were seen in  
17 this event.

18 MR. TOMLINSON: And they were also tested in the  
19 factory.

20 MR. KAUFFMAN: Do you have any theories, or can  
21 you share with us the theories, for why the valves may not  
22 have opened?

23 MR. TOMLINSON: This is one of those specific  
24 technical issues that I delegate out to system engineers to  
25 troubleshoot, so I don't know anything other than what



1 they've already told me.

2 MR. KAUFFMAN: Okay.

3 MR. CONTE: Condenser vacuum and off-gas: Was  
4 off-gas isolation a consequential failure of the UPS power  
5 supply via the radiation monitoring failure?

6 MR. TOMLINSON: That's what I believe, that RE-13-  
7 Alpha and Bravo lost power and caused an isolation in the  
8 off-gas system.

9 MR. CONTE: RE meaning --?

10 MR. TOMLINSON: Radiation element.

11 MR. CONTE: Alpha and Bravo.

12 MR. TOMLINSON: Correct.

13 MR. CONTE: Lost power, and that caused the  
14 isolation.

15 So I guess the condenser vacuum didn't taper off  
16 too bad, but the operators were concerned about getting the  
17 hoppers on line; is that correct?

18 MR. TOMLINSON: That's true.

19 MR. CONTE: Did the hoppers perform acceptably?  
20 I should say that the hoppers are mechanical pumps; is that  
21 correct?

22 MR. TOMLINSON: That's correct.

23 MR. CONTE: How many of those mechanical vacuum  
24 pumps do you have?

25 MR. TOMLINSON: We have two.



1 MR. CONTE: They were using both of them.

2 MR. TOMLINSON: I don't know that for sure.

3 MR. CONTE: Do they bypass any radiation  
4 monitoring?

5 MR. TOMLINSON: Yes. They bypass the whole off-  
6 gas system.

7 MR. CONTE: Is there effluent monitored at all?  
8 Where do they go out -- the main stack?

9 MR. TOMLINSON: Yes. It still goes out the main  
10 stack.

11 MR. CONTE: And they were in use for how long? Do  
12 you know?

13 MR. TOMLINSON: I don't know.

14 MR. CONTE: Is there anything mentioned in your  
15 report about condenser vacuum, the off-gas isolation, and  
16 the mechanical vacuum pumps? I think what I'm hearing is  
17 that everything performed normally.

18 MR. TOMLINSON: The off-gas isolation is mentioned  
19 in the report, and there was a lot of trouble in this area  
20 in regard to maintaining turbine seal steam. There was a  
21 known problem with the pressure control valve that provides  
22 aux steam to the clean-steam reboiler; that valve would not  
23 work. Then they were required to swap over to steam from  
24 the auxiliary boiler to the clean steam reboiler, and they  
25 had a problem with that valve. It took some field effort in



1 order to get that valve open, so there was a lot of effort  
2 focused in that area early on in the event. Those things  
3 are included in my report.

4 MR. CONTE: The trip of the Division 2 hydrogen  
5 and oxygen sampling pump, is there an understanding of why  
6 that happened? Supposedly that's safety-grade power. It  
7 should not have been affected. Is that correct?

8 MR. TOMLINSON: That's true. It should not have  
9 been affected, and we are still investigating that one.

10 MR. CONTE: Okay.

11 Is that in your report?

12 MR. TOMLINSON: That is mentioned in my report,  
13 yes, and an explanation, whenever we get that, will also be  
14 included.

15 MR. IBARRA: Do we know the time frame of when  
16 they might come up with a possible explanation?

17 MR. TOMLINSON: We are currently working on it. I  
18 don't know when we're going to finish.

19 MR. CONTE: The GEM system, the gaseous effluent  
20 monitoring system -- I guess there are two, one on the --

21 MR. TOMLINSON: There are two, the stack GEMS and  
22 the vent GEMS.

23 MR. CONTE: Okay. Were they both powered off as a  
24 result of UPS? Were they affected?

25 MR. TOMLINSON: The vent GEMS, which is the





1 reactor building vent, was not operable, was out of service,  
2 before the event. That was out of service for normal  
3 calibration, so that was not in service prior to or after  
4 the event.

5 The stack GEMS was in service prior to the event,  
6 did lose power; then, when power was restored, the computer  
7 did not properly reboot itself. That was found by chem  
8 techs out in the plant, reported to the control room. If  
9 you look through the SSS log, you'll find that at 8:05 it  
10 was recorded in the SSS log as "stack GEMS inop." Really  
11 what that is is, that was reported from the field that it  
12 was still not functioning properly, that in fact it had been  
13 out since the loss of power. At that point the computer  
14 department got involved, rebooted the system, and it was  
15 finally restored to normal operation at approximately 8:47.

16 MR. CONTE: What was monitoring the stack with  
17 GEMS out?

18 MR. KAUFFMAN: I guess there were two times we're  
19 interested in, right? Before UPS was restored and after UPS  
20 was restored.

21 MR. CONTE: Yes.

22 MR. KAUFFMAN: If there's a different.

23 MR. TOMLINSON: I think chemistry is best suited  
24 to answer that question. I know that they had an in-line  
25 particulate filter that was discussed in the TSC during the



1 event that, after we thought things had finally stabilized,  
2 was removed and analyzed to ensure that, during the entire  
3 event, nothing was released of that nature.

4 We did have downwind teams out looking for  
5 releases. Chemistry, I believe, was doing their normal grab  
6 samples.

7 MR. KAUFFMAN: Do you recall when the field teams  
8 were dispatched and in place in the field?

9 MR. TOMLINSON: I don't know that detail.

10 MR. IBARRA: Can you tell me what other radiation  
11 monitors you have that would have been operable during this  
12 time?

13 MR. TOMLINSON: That's a big question.

14 MR. IBARRA: Do you have safety-related rad  
15 monitors?

16 MR. TOMLINSON: There are safety-related rad  
17 monitors in the control building ventilation system.

18 MR. IBARRA: And those did not go down?

19 MR. TOMLINSON: Those did not go down.

20 I'm sure there are a lot of others, but I just  
21 can't name them for you right now.

22 MR. CONTE: Before we leave the stack GEMS, off-  
23 gas is an input, that isolated, is that correct?

24 MR. TOMLINSON: That's off a separate rad monitor.

25 MR. CONTE: That is a separate rad monitor so



1 anything going out off-gas could have been monitored?

2 MR. TOMLINSON: Well, off-gas was isolated right  
3 away.

4 MR. CONTE: Okay, so --

5 MR. TOMLINSON: Off it's own rad monitor.

6 MR. CONTE: All right. What else -- at the time  
7 that -- after the event, what else is feeding that main  
8 stack from a ventilation point of view? Reactor building  
9 ventilation, or is that a separate --

10 MR. TOMLINSON: That's separate. Turbine building  
11 ventilation goes out through that stack.

12 MR. CONTE: Main stack?


13 MR. TOMLINSON: Yes.

14 MR. CONTE: Okay. Is there a monitor upstream  
15 that was operable? From an instrument point of view that  
16 are not in line and downwind or the grab sampling, do you  
17 know?

18 MR. TOMLINSON: I do not know.

19 MR. CONTE: Okay. Just -- I'm trying to get a  
20 little bit of understanding of the design -- how about  
21 what's going in the reactor building -- is the reactor  
22 building, the effluent, monitored by safety grade radiation  
23 monitoring, that was not affected by this power outage?

24 MR. TOMLINSON: There are, above and below refill  
25 floor rad monitors, HVR RE-14's and 32's that do monitor



1 that.

2 MR. CONTE: So, if there's anything going out of  
3 the reactor building, you could have gotten something from  
4 those radiation monitors?

5 MR. TOMLINSON: Yes.

6 MR. CONTE: That you just mentioned.

7 MR. TOMLINSON: And they would automatically  
8 isolate the building and start the standby gas treatment  
9 system.

10 MR. CONTE: Okay. Is there any information -- I'm  
11 done on the radiation monitoring, by the way. Is there any  
12 information when the first indication of the RCIC valve  
13 position problem was noted? In other words, when the  
14 operators first -- is there any records to indicate or based  
15 on operator statements, personnel statements or logs that  
16 when RCIC was injecting and they had the controller problem  
17 that there was something abnormal with the position  
18 indications on that testable check valves?

19 MR. TOMLINSON: The first I know of any abnormal  
20 indications on that testable check was after the system had  
21 been secured, the operators then noticed abnormal  
22 indications.

23 MR. KAUFFMAN: You say "after it was secured",  
24 does that mean within five or 10 minutes after it was  
25 secured or an hour or two hours after it was secured? I'm





1 just trying to get a ballpark for the time.

2 MR. CONTE: It's my understanding that it was  
3 placed in standby like an hour after the event or an hour  
4 and a half. Do you have any idea when that -- when that was  
5 first indicated?

6 MR. TOMLINSON: I can't recall, no.

7 MR. CONTE: Okay. The reports of water hammer, I  
8 guess you were down in the TSC when those reports came in,  
9 did you have any involvement in those reports, with the  
10 emergency director?

11 MR. TOMLINSON: There were two different reports  
12 for water hammer. The -- I can't remember which order they  
13 came in now. One of the concerns was in the RHR system,  
14 when we were warming up the lines preparing it for shutdown  
15 cooling, there was word from the field that they heard loud  
16 banging noises in one of the RHR heat exchanger rooms and I  
17 was involved at some point in the TSC in the discussions  
18 about, you know, providing engineering walkdown of that  
19 system prior to continuing with placing it in service and  
20 engineering was directed, at that point, during the event,  
21 to actually go out and do a walkdown of accessible piping  
22 and I believe that was done. That is included in my report  
23 and the engineering paperwork. It's just a letter saying  
24 that no problems were found. It's in my report.

25 There was also water hammer noises heard from



1 trying to place the reactor water cleanup system back in  
2 service. I believe the walkdown of that piping was actually  
3 deferred until after the event had been terminated, later on  
4 in the evening. Engineering did a walkdown of the system  
5 that was accessible and found no problems. And provided me  
6 with a write up on that.

7 MR. CONTE: Do you have -- from a response point  
8 of view, do you have an understanding of why they occurred?  
9 Or is it speculation, or you just don't have any idea?

10 MR. TOMLINSON: I can speculate that the cleanup  
11 system was in trying to place a hot system in reject to the  
12 condenser. You took a very large DP across the pressure  
13 control valve for a reject of the condenser and caused that  
14 cavitation. I don't know about the RHR system.

15 MR. CONTE: Okay. The cooling tower bypass valve,  
16 52 valve, went open, is that a consequential failing?

17 MR. TOMLINSON: There are three gates in the  
18 cooling tower that open -- that bypass the cooling tower.  
19 Those gates -- motor-operated gates, aromatically open on  
20 low basin temperature. The temperature -- the temperature  
21 instruments lost power, failed low giving the control  
22 circuit a signal that we had low basin temperature and  
23 therefore those MOG's acted properly in opening the bypass  
24 tower.

25 MR. CONTE: So that's a consequential failure with



1 the UPS?

2 MR. TOMLINSON: Yes.

3 MR. CONTE: Okay.

4 MR. TOMLINSON: We did, however, look at that and  
5 decided that we would write a plant change request to  
6 evaluate whether loosing one power supply to those  
7 temperatures switches should cause the valves to open. We  
8 thought that that needed further evaluation and there is a  
9 plant change request to evaluate that.

10 MR. CONTE: And this is addressed in your report?

11 MR. TOMLINSON: Yes.

12 MR. CONTE: Good. Reactor coolant sample sink  
13 the temperature control valve, apparently there was -- it  
14 was initially thought that the isolation valve was not  
15 opened, operators did open the isolation valve? Was there a  
16 malfunction in the temperature control valve at the sink, or  
17 what?

18 MR. TOMLINSON: That was a chem tech at the  
19 sample sink and I talked to the chemistry supervisor, Tim  
20 Kurtz, he told me that the reset pushbutton down in the  
21 sink -- I don't fully understand the setup down there --  
22 needs to be held in for something like five seconds. And in  
23 the heat of the battle the chem techs just did not hold the  
24 button in long enough and that was the only problem down  
25 there.



1 MR. CONTE: Did they eventually get a sample?

2 MR. TOMLINSON: Yes. I believe they did. The  
3 corrective action on Tim Kurtz's part was to make up an  
4 operator aid to remind people that the button needed to be  
5 held in for five seconds, and he's working on getting that  
6 installed.

7 MR. CONTE: Okay. We also go information that  
8 apparently there was an overflow in two sumps in the reactor  
9 building. Is there an understanding why that happened, is  
10 that another consequential failure or malfunction?


11 MR. TOMLINSON: We don't know. There was a slight  
12 backup and there was water on the floor in there -- in two  
13 of the sumps, I should say. And we, I guess, just assumed  
14 that the water came from that sump. Rad waste can't give us  
15 any indications of why that may have happened, and the sumps  
16 are operating properly now, so.

17 MR. CONTE: Those sump pumps are powered from  
18 what?

19 MR. TOMLINSON: I don't know for sure. They would  
20 be black power.

21 MR. CONTE: There's an item -- I guess Mr. Helker  
22 had an item on one of his lists that he presented in his  
23 interview. He talks about CNM AOV-101 open, needs to be  
24 shut pre-startup. Is that the bypass valve?

25 MR. TOMLINSON: That's the bypass valve around the





1 heater strain.

2 MR. CONTE: Oh, okay. And that's just --

3 MR. TOMLINSON: It's 101 -- back to our previous  
4 question at 101, is the bypass from the heater strain, 109  
5 is our bypass around the condensate deminizers.

6 MR. CONTE: Okay. And he's just tickling himself  
7 to make sure that the valve is --

8 MR. TOMLINSON: That open item is identified in my  
9 report.

10 MR. CONTE: It is?

11 MR. TOMLINSON: That that valve needs to be shut  
12 prior to startup.

13 MR. CONTE: But as far as what you're -- what I'm  
14 hearing is that valve function normally as designed?

15 MR. KAUFFMAN: Tom, another question on condensate  
16 was one of the condensate booster pumps tripped and the  
17 standby pump started early in the event, do you have an  
18 understanding of why that happened?

19 MR. TOMLINSON: We know the min flow valves failed  
20 to open. Systems engineering, again, addressed this  
21 particular issue. I believe that the system -- the whole  
22 condensate feed water system just took a very high flow rate  
23 due to all these valves being opened and caused low suction  
24 pressure. That's why the feed pumps tripped we believe and  
25 it's easy to understand why the booster pumps would also



1 have some lower suction pressure, so we believe that caused  
2 that to trip also.

3 MR. CONTE: The reactor vessel upset range, it's  
4 not on the process computer, it was apparently lost because  
5 of not being powered from safety related buses, what is it's  
6 function in the safety scheme of things here, the reactor  
7 vessel upset range?

8 MR. TOMLINSON: I guess I can't answer the  
9 question on its design basis from the plant.

10 MR. CONTE: Is that being looked into by the --

11 MR. TOMLINSON: My report did submit a plant  
12 change request to evaluate that and I requested that be  
13 placed on the process computer and evaluate placing it on  
14 safety grade power.

15 MR. CONTE: What range does it cover on the  
16 vessel? Do you know? Inches to inches?

17 MR. TOMLINSON: I believe it's upper range is  
18 approximately 325. I'm not quite sure where the lower band  
19 is.

20 MR. CONTE: Two more items. We're almost done  
21 here. The residual hand removal system, MOV-142 apparently  
22 did not open. There's an outstanding work request on it; we  
23 have a number, 193350, this is the RHR discharge to the rad  
24 waste line. Is there any -- is that the -- is that a --  
25 could that valve have been the cause of the water hammer or




1 is there a different problem as to why it didn't open? Is  
2 that an MOV problem or what?

3 MR. TOMLINSON: That problem was fixed early on in  
4 the day. That was some type of problem with the operator,  
5 dirty contacts, or something in the MOV and by the time the  
6 day was done, that valve was operating properly. That valve  
7 is -- I don't believe that valve is used for the initial  
8 part of the heat up, so I don't know whether it was involved  
9 in that water hammer or not.

10 MR. CONTE: Okay. Any -- in your report, any view  
11 on rod position indication? It's my understanding that the  
12 design is that the read switches are powered from one of the  
13 UPS's and the display lights are on another UPS in the  
14 control room. Is there any recommendation -- is that  
15 considered a problem at this point? Is there any thought to  
16 any design changes on that?

17 MR. TOMLINSON: That whole issue is identified in  
18 my report. The initial discrepancies have all been  
19 explained by the system engineer.

20 I know that our technical man, John Conway, is  
21 very concerned over rod position information not being  
22 safety grade power. Although that's the common design in  
23 the industry for that to be non-safety power. I don't know  
24 where we're going with that issue, I know we will discuss  
25 that as part of our SORC review.



1           Your specific question about being off two  
2 different UPS's, I wasn't aware of that.

3           MR. CONTE:    Okay.


4           MR. TOMLINSON:  The system engineer would have  
5 been more heavily involved in that.  He basically just --  
6 again, this is an issue that I just of panned off to system  
7 engineering and they resolved it for me and told me that all  
8 the indications were explainable and I don't know whether  
9 they have any continued open items to review of that nature.

10          MR. IBARRA:  The UPS loading, our investigation  
11 has shown to be heavily on the one or not equally  
12 distributed, that might have helped the situation, or not  
13 the situation because all UPS went down, but it might help  
14 in the future if only one UPS goes down.  Is that an issue  
15 that you all will be reviewing?

16          MR. TOMLINSON:  UPS loading is not a new issue.  
17 That has been going on in this plant for quite some time.  
18 We've already done several things to the UPS's to change the  
19 loadings.  Stripped some of the loads off and there are  
20 other plans in the works to change out some of the UPS's and  
21 to change some of the loadings.  So it's been an on going  
22 issue for some time now.

23          MR. IBARRA:  But in the light of what happened,  
24 will that be reviewed?

25          MR. TOMLINSON:  I'm sure it's already being





1 reviewed. That's not my area, I don't know.

2 MR. IBARRA: Okay.

3 MR. CONTE: One of the, just kind of summary  
4 questions -- or comment, it was very difficult to find out  
5 what loads were off those UPS's. As an individual who was  
6 probably trying to review the plant response and getting  
7 answers to questions about what happened and why that  
8 happened I'm sure you must have been somewhat frustrated by  
9 that. Why do you think that exists? Why doesn't the plant  
10 have a good drawing with loads lists or whatever that  
11 reflect what the loads are off the UPS?

12 MR. TOMLINSON: I guess I'm not really -- I don't  
13 really know why and I know we do have load lists for our  
14 safety related UPS's. Maybe it was just a matter of  
15 priority and operations has asked for that in the past, but  
16 that, as you know, is a very difficult task. It may just  
17 come down to priority.

18 MR. IBARRA: In the scenario that was run  
19 yesterday where you loose one of the UPS, UPS 1B, apparently  
20 there might still be some discrepancy as to what powers  
21 want, because there was some inconsistencies. Do you know  
22 anything about that?

23 MR. TOMLINSON: About the loss of the UPS,  
24 yesterday?

25 MR. IBARRA: Yes.



1 MR. TOMLINSON: Very little.

2 MR. IBARRA: Okay.

3 MR. KAUFFMAN: Earlier you mentioned your report  
4 was going to SORC, can you tell us when you anticipate the  
5 SORC meeting review?

6 MR. TOMLINSON: I know they're meeting right now  
7 to discuss some of the preliminary stuff. I don't know when  
8 the report is going to actually be reviewed in detail by  
9 SORC. It was supposed to be this past weekend and it didn't  
10 happen, so I don't know.

11 MR. CONTE: Who's going to make the decision on  
12 what issues need to be resolved by startup or not, is it the  
13 assessment groups or is it plant management, SORC?

14 MR. TOMLINSON: I would have to say it would be  
15 SORC to make that decision.


16 MR. CONTE: So in your report you really don't  
17 make recommendations in terms of this needs to be resolved  
18 by startup?

19 MR. TOMLINSON: No.

20 MR. CONTE: Okay. You're just identifying --

21 MR. TOMLINSON: Identify all of the issues and  
22 make sure something is happening to address each issue.  
23 Safety assessment may do some of that assessment of what  
24 needs to be resolved, I don't know.

25 MR. CONTE: I don't have anything else.



1 MR. IBARRA: I don't either.

2 MR. KAUFFMAN: I just have one kind of a general  
3 question. Are there any things that you think that came out  
4 of this event or that we haven't quizzed you about and  
5 talked about here today or are all the relatively major  
6 single handed things here on the table here at this meeting?

7 MR. TOMLINSON: Well, there's a long list of  
8 deficiencies that were identified and I think we've talked  
9 about most of the big ones.

10 MR. KAUFFMAN: A list of deficiencies that you  
11 identified, is that typical for the number of failures or  
12 problems experienced by say following a normal plant trip  
13 versus kind of unusual?

14 MR. TOMLINSON: The number of deficiencies?

15 MR. KAUFFMAN: Well, we had problems in feedwater,  
16 problems in --

17 MR. TOMLINSON: The number of deficiencies for  
18 this one is no more than normally is. Usually my number of  
19 deficiencies is maybe a half dozen. Things on the entire  
20 event, didn't work like they should have worked or something  
21 like that.

22 MR. CONTE: Now, that's taking away the  
23 consequential factors, I mean the things that happened  
24 because of UPS? If you take away the stuff because of the  
25 loss of UPS failure, how -- what does that list come down



1 to, is that a half a dozen, a dozen, in your mind, without  
2 counting them?

3 MR. TOMLINSON: It get significantly smaller. By  
4 eliminating all the things that happened because of UPS  
5 failure and transformer failure it's probably down to fairly  
6 normal type of a list.

7 MR. CONTE: Half a dozen list?

8 MR. TOMLINSON: That sounds about right.

9 MR. CONTE: For normal post-trip review?

10 MR. TOMLINSON: Yes.

11 MR. KAUFFMAN: Okay. If there are no more  
12 questions, that's the end of the interview.

13 MR. CONTE: Let's go off the record.

14 [Whereupon, at 2:55 p.m. the taking of the  
15 interview was concluded.]

16

17

18

19

20

21

22

23

24

25






REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

In the Matter of:

NAME OF PROCEEDING: Interview of Earl Scott  
"Tom" Tomlinson III  
DOCKET NUMBER: (Not applicable)  
PLACE OF PROCEEDING: Scriba, New York

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

  
\_\_\_\_\_  
Mark Handy  
Official Reporter  
Ann Riley & Associates, Ltd.



OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Incident Investigation Team

Title: Nine Mile Point Nuclear Power Plant  
Interview of: EARL SCOTT "TOM"  
TOMLINSON III

Docket No.

LOCATION: Scriba, New York

DATE: Monday, August 26, 1991

PAGES: 1 - 34

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950.

Dupe of

~~9305060305~~



ADDENDUM TO INTERVIEW OF Tom Taylorson / Rescor Engineering Supv  
(Name/Position)

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
7	9	Senses not sends cooling values closed
9	23	should be <del>EXHA</del> <del>AA</del> <del>not</del> CNM-AAV101 and CNM-AAV109
9	25	heater string; not heater stream
15	3	should be heater bay
17	79	in the
21	24	above and below refusal
24	13	reject to the condenser
24	19	automatically open
24	23	in opening to bypass the tower
27	1	heater string
27	20	open not to open
28	21	heat removal not heat removal
29	20	technical manager

Page 1 of 1 Signature [Signature] Date 6/16/91

13

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

-----  
Interview of :  
EARL SCOTT "TOM" TOMLINSON III :  
(Closed) :  
-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Monday, August 26, 1991

The interview commenced, pursuant to notice,  
at 2:10 p.m.

PRESENT FOR THE IIT:  
John Kauffman, NRC  
Jose Ibarra, NRC  
Richard Conte, NRC

1. 2





## P R O C E E D I N G S

[2:10 p.m.]

1  
2  
3 MR. KAUFFMAN: Good afternoon. It's August 26,  
4 1991 at 2:10 p.m. My name is John Kauffman, I'm here  
5 conducting an interview of Tom Tomlinson at the Niagara  
6 Mohawk Power Company, Unit Two, P Admin Building.

7 We're investigating a plant event and transient of  
8 August 13, 1991 and we'll be interviewing Tom Tomlinson.

9 MR. IBARRA: I'm Jose Ibarra from the IIT team.

10 MR. CONTE: Rich Conte, NRC, Region One.

11 MR. TOMLINSON: I'm Tom Tomlinson from Unit Two,  
12 Reactor Engineering Operations Department.

13 MR. KAUFFMAN: Okay, Tom, we would like you to  
14 start by telling us a little bit about your background and  
15 experience that you bring to your present job and a little  
16 bit about your involvement here with the event  
17 investigation?

18 MR. TOMLINSON: I've been with Niagara Mohawk  
19 since 1984 when I graduated from RPI with a degree in  
20 nuclear engineering. I've been in the reactor engineering  
21 department since that time. And I now hold the position of  
22 supervisor, reactor engineering.

23 As part of that position I'm responsible for the  
24 plant scram response and post-trip review. In the  
25 operations department, the reactor engineer reports to the



1 operations manager. I currently hold an SRO license for  
2 Unit Two and I have a PE license from the State of New York.

3 MR. KAUFFMAN: Tom, when did you get licensed?  
4 How long have you held a license and did you stand on shift  
5 time?

6 MR. TOMLINSON: I have not stood on shift time.  
7 No, I'm a staff license and I received that license  
8 approximately a year ago.

9 MR. KAUFFMAN: Okay, Rich, you have a list of  
10 specific questions, you may as well start on your list.

11 MR. CONTE: Okay. First, what involvement did you  
12 have in the day's events? When did you first hear about the  
13 event and where were you? Were you coming in?

14 MR. TOMLINSON: I was in my car and I got a phone  
15 call in my car at 6:30 in the morning from the on-shift STA.  
16 The STA's report to me in the operations organization. The  
17 on-shift STA, Tom Tuttle, called me and told me that we were  
18 in a site area emergency and that they were having trouble  
19 identifying the position of six control rods and I arrived  
20 on site approximately a quarter of seven.

21 I first proceeded to the control room to try and  
22 help with the rod position indication problems, by that time  
23 they had all-rod-in indications and they were having  
24 intermittent problems with one rod, 1431. I then, because  
25 we were in a site area emergency, proceeded to the technical



1 support center and took up the role of reactor analyst  
2 coordinator in the TSC. I spent all day there until we  
3 terminated the event later that night.

4 MR. CONTE: What issues did you get involved in as  
5 reactor analyst coordinator at the tech support center?  
6 What broad issues were you working on with your people?

7 MR. TOMLINSON: Well, by that time we had  
8 ascertained that we did have all rods in so the core  
9 conditions were known at that time. Indications had already  
10 been restored. Typically my position down there does things  
11 like fuel damage, core damage calculations, and all that and  
12 that was not necessary, so I spent most of my time helping  
13 the site emergency director with operational type concerns,  
14 trying to help him, lead him through the emergency plan and  
15 understanding plant conditions as they arose throughout the  
16 day.

17 MR. CONTE: And the site emergency director was  
18 Marty McCormick?

19 MR. TOMLINSON: That's correct.

20 MR. CONTE: He was stationed at the STS -- at the  
21 TSC?

22 MR. TOMLINSON: That's correct.

23 MR. CONTE: Okay. One of the concerns throughout  
24 the day was getting the UPS back on its normal supply; were  
25 you involved in that at all in terms of giving advice



1 whether they should do it or not do it?

2 MR. TOMLINSON: Not directly. That was the SED's  
3 decision and I'm not sure who else was involved in that  
4 decision.

5 MR. CONTE: Okay. All right, I guess I'm ready to  
6 move into some of the more specific questions about  
7 equipment problems that we've been tracking as a team. And  
8 I guess for each of these items, I would like, if you can  
9 remember, four basic questions on each of them; whether or  
10 not it's addressed in your assessment report, and I guess  
11 for the record we ought to identify that you're also the  
12 group leader for the licensees assessment group and you're  
13 looking into the area of plant response, primarily the post-  
14 trip review. Is that correct?

15 MR. TOMLINSON: That's correct.

16 MR. CONTE: Okay. If it's in your report or not,  
17 to the best of your ability why it happened, include, you  
18 know -- identify if it's any speculation or not, and whether  
19 or not you know whether there's corrective actions in terms  
20 of work requests out, startup issues -- whether it's a  
21 startup issue or not. Okay.

22 The first one that we have a question about is the  
23 -- the event where there was a loss of drywell cooling.  
24 Coupled with that, I guess, there was some issue with a LOCA  
25 bypass switch associated with that control circuit, could





1 you explain that or do you know why there was a loss of  
2 drywell cooling? Is that a consequential failure from the  
3 UPS failure?

4 MR. TOMLINSON: To the best of my knowledge the  
5 failure of drywell cooling was caused by a optical isolator  
6 that provides information to the interlocks for drywell  
7 cooling. The drywell cooling fans trip off if a signal --  
8 if they get a signal that the cooling water valves are  
9 closed. And in that logic there is an optical isolator it  
10 has both safety related and black power on it. Losing the  
11 black power side of that optical isolator, I believe the  
12 logic signal -- the logic for the fans believe that those  
13 drywell cooling valves were closed, and therefore tripped  
14 the fans off.

15 MR. IBARRA: Tom, do you know what UPS this is out  
16 of?

17 MR. TOMLINSON: I do not know.

18 There are LOCA bypass switches which -- which  
19 bypass that interlock. I know that the on-shift ASSS, Mike  
20 Eron, investigated that during the event, identified the  
21 fact that there was black power needed in that LOCA bypass  
22 switch circuit somewhere and was making preparations for a  
23 temp mod to bypass that circuit or jumper out that logic if  
24 needed. I don't know specifics.

25 MR. CONTE: What's being done with that LOCA



1 bypass switch?

2 MR. TOMLINSON: There's a -- I believe there's a  
3 plant change request that has been put in the system to  
4 reevaluate that logic scheme.

5 MR. CONTE: Okay. So it's sound to me like  
6 there's some understanding as to why drywell cooling failed  
7 because of the loss of power -- not failed, but tripped, the  
8 loss of power to optical isolators, apparently its circuit  
9 or the logic circuits sends cooling valves closed, shut down  
10 the fan and when you attempted or considered using the LOCA  
11 bypass switches to get them started you also found they  
12 wouldn't work?

13 MR. TOMLINSON: That's correct.

14 MR. CONTE: And you identified, I guess it was Mr.  
15 Eron identified, that black power was needed for those  
16 switches to work?

17 MR. TOMLINSON: That's correct.

18 MR. CONTE: In the control circuit?

19 MR. TOMLINSON: That's correct.

20 MR. CONTE: Any questions?

21 MR. IBARRA: Is that going to be part of your  
22 event assessment?

23 MR. TOMLINSON: That is mentioned in my report,  
24 yes.

25 MR. KAUFFMAN: In the event, how were the fans



1 restored?

2 MR. TOMLINSON: They were restored when the power  
3 was restored.

4 MR. KAUFFMAN: Was it automatic?

5 MR. TOMLINSON: No. You have to manually start  
6 those.

7 MR. CONTE: I guess a specific question on the  
8 safety relief valves: Does anybody know when they were  
9 first identified to have lifted? It's our understanding  
10 from the operator's viewpoint that wasn't something that  
11 they noticed in light of all the others things that they had  
12 to verify. Do you know from the sequence in time when it  
13 was first identified that there had been two valves lifted?

14 MR. TOMLINSON: What I know of that event is that  
15 later in the day Tom Tuttle, the shift technical advisor,  
16 was reviewing indications in the control room and found on  
17 the strip chart recorder for SRV tailpipe temperatures that  
18 we did have indication that two SRVs lifted.

19 MR. CONTE: Do you know about what time he was  
20 doing that?

21 MR. TOMLINSON: I do not know. It was not right  
22 away.

23 MR. CONTE: Is it safe to say that it was after 7  
24 o'clock?

25 MR. TOMLINSON: It was after 7 o'clock.



1 MR. CONTE: Okay.

2 MR. KAUFFMAN: For a transient that was the type  
3 of transient that was experienced in the plant's initial  
4 conditions and your knowledge level and training, would you  
5 expect SRVs to lift on this type of a trip?

6 MR. TOMLINSON: Yes, I would. I would expect SRVs  
7 to lift on a load reject from high power. It was not  
8 surprising to me.

9 MR. CONTE: Do you remember what the highest  
10 pressure you saw on your review was?

11 MR. TOMLINSON: Yes, 1070 pounds was the highest  
12 pressure we saw.

13 MR. CONTE: Okay.

14 Another question: It's our understanding that by  
15 design the condensate demineralizer's bypass valve opens on  
16 a trip from 100 percent power. Is that correct?

17 MR. TOMLINSON: That's correct. There are two  
18 valves that open on a turbine trip from high power. I  
19 believe the setpoint is 30 percent; a turbine trip from  
20 greater than 30 percent power -- no, that's not correct.  
21 It's 80 percent.

22 MR. CONTE: What are they?

23 MR. TOMLINSON: That's CNM AOV-101 and AOV-109.  
24 Those are the condensate demineralizer bypass valves and the  
25 low pressure heater stream bypass valve.





1 MR. KAUFFMAN: Why do those valves open? What's  
2 the function?

3 MR. TOMLINSON: They open to allow 115 percent  
4 nuclear design boiler flow on the event of a turbine trip to  
5 maintain level. Both those valves are designed to go open  
6 in the scenario, and both valves did open, as designed.

7 MR. CONTE: You say the designators on these  
8 valves were CNM. Is that containment monitoring?

9 MR. TOMLINSON: That's condensate system.

10 MR. CONTE: Oh, it's condensate system.

11 I want to get the numbers again. AOV-101 and 109?

12 MR. TOMLINSON: That's correct.

13 MR. CONTE: That 101 is the bypass; the 109 is the  
14 feedwater?

15 MR. TOMLINSON: I'm not positive.

16 MR. CONTE: You're not sure. Okay.

17 MR. KAUFFMAN: Does your investigation look at  
18 whether the loss of the UPS might have also caused these to  
19 go open if the automatic signal hadn't worked?

20 MR. TOMLINSON: My investigation did not. I can't  
21 speak for the UPS investigation.

22 MR. CONTE: I need to understand this. I really  
23 didn't understand what you said; my mind was drifting. At  
24 115 percent of flow -- say that again, as to why those  
25 valves go open.



1 MR. TOMLINSON: In order to provide extra flow to  
2 the reactor in the case where you take a high-power turbine  
3 trip.

4 MR. CONTE: Oh, extra feed.

5 MR. TOMLINSON: Extra feed.

6 MR. CONTE: To mitigate the effects of the level  
7 drop.

8 MR. TOMLINSON: Correct.

9 MR. CONTE: I see. Okay.

10 Reactor core isolation cooling, RCIC, the auto-  
11 controller, is that a real problem? Has it been a problem  
12 in the past?

13 MR. TOMLINSON: That controller was identified  
14 earlier -- I can't say how earlier -- that the controller  
15 needed tuning, and there is an outstanding WR to  
16 troubleshoot that. It was a problem we knew about.

17 MR. CONTE: There was an outstanding work request  
18 on it?

19 MR. TOMLINSON: I believe it was a work request  
20 waiting to be worked.

21 MR. KAUFFMAN: Can you describe to me the  
22 decision process the operators would go through when there  
23 is an outstanding work request on an item of known equipment  
24 problem on their operability determination, their decision  
25 on whether or not they should enter an LCO? Do they wait



1 until the work is done or started?

2 MR. TOMLINSON: I guess I don't understand your  
3 question.

4 MR. KAUFFMAN: I guess my question is, there's a  
5 work request on this controller; RCIC is in tech specs; it  
6 has certain functions it's supposed to do. How would the  
7 operator determine whether this problem makes it inoperable  
8 or not? I'm really looking to understand the process, not  
9 necessarily specifics in this case.


10 MR. TOMLINSON: I guess what you're asking me is  
11 the thought process for an operability determination from  
12 the SSS point of view.

13 MR. KAUFFMAN: Right, maybe the review process  
14 that the work request would get to make sure that that's all  
15 done and documented.

16 MR. TOMLINSON: I don't think I can speak for the  
17 work control process. I know from an SSS point of view he  
18 would review the concern that was brought up on the work  
19 request and make a decision at that point based on his  
20 knowledge of the system, as to whether that would affect its  
21 operability. In cases where something just needs to be  
22 tuned, that may or may not affect its operability.

23 MR. KAUFFMAN: Okay.

24 MR. IBARRA: As far as RCIC, has Niagara Mohawk  
25 determined that it is a generic type problem, or what have



1 you all done as far as researching the kind of problems  
2 you're having?

3 MR. TOMLINSON: For this particular event, we have  
4 not completed the troubleshooting effort. I can't answer  
5 your question for generic implications. A system engineer  
6 would be better qualified to answer that type of question.

7 MR. CONTE: Does that go for the position  
8 indicator problem with the check valves also?

9 MR. TOMLINSON: As to whether it's a generic  
10 problem?

11 MR. CONTE: Right.

12 MR. TOMLINSON: A system engineer would be able to  
13 track those types of problems.

14 MR. CONTE: Are these two items or equipment  
15 problems mentioned in your report?


16 MR. TOMLINSON: Both of those are mentioned in my  
17 report, yes.

18 MR. CONTE: I guess it's my understanding you  
19 really don't know what the position problem is, also. I  
20 think there are outstanding work requests on that, too.

21 MR. TOMLINSON: I do not know if those work  
22 requests have been closed out yet or not.

23 MR. CONTE: Okay.

24 The performance of the condensate valve, 84 -- I  
25 guess for the record would you give me the official





1 designator for the 84 valve?

2 MR. TOMLINSON: That would be CNM MOV-84.

3 MR. CONTE: That's A, B, and C?

4 MR. TOMLINSON: A, B, and C. Those are the feed  
5 pump suction valves.

6 MR. CONTE: Those valves were shut, I guess, in  
7 the startup process of getting condensate, and then they  
8 couldn't be opened. Is there any understanding of why they  
9 couldn't be opened?

10 MR. TOMLINSON: I believe we're still  
11 troubleshooting that -- system engineers are troubleshooting  
12 that to try and determine exactly why those valves would  
13 not reopen. They were shut in an effort to restart the  
14 condensate booster pumps. That is a procedural requirement.  
15 Then they would not reopen.

16 MR. CONTE: Do you have an understanding of why  
17 those valves are to be shut by procedure?

18 MR. TOMLINSON: I believe the reason we shut those  
19 valves is that we have had a history of problems with the  
20 feed pump suction pressure relief valves, and the procedure  
21 was changed a while back to require closing those valves so  
22 you didn't pop those suction relief valves.

23 I know the system engineer is reviewing that  
24 procedure requirement and considering changing that.

25 MR. IBARRA: Tom, what's the location of this



2000



1 valve?

2 MR. TOMLINSON: I believe those valves are in the  
3 heater base.

4 MR. CONTE: Any other questions on 84?

5 MR. KAUFFMAN: Well, my understanding of the  
6 general problem was that there was a high DP across the  
7 valve, and the valves couldn't open because of the high DP.  
8 Is that generally correct?

9 MR. CONTE: I know that that's a standing theory,  
10 but I don't know whether there has been anything yet to  
11 prove that or not.

12 MR. CONTE: Is this in in your report?

13 MR. TOMLINSON: That is covered in my report, yes.

14 MR. KAUFFMAN: I know when we talked to the system  
15 engineer he said that the valves were tested, or are tested,  
16 during startup against the kind of DPs that were seen in  
17 this event.

18 MR. TOMLINSON: And they were also tested in the  
19 factory.

20 MR. KAUFFMAN: Do you have any theories, or can  
21 you share with us the theories, for why the valves may not  
22 have opened?

23 MR. TOMLINSON: This is one of those specific  
24 technical issues that I delegate out to system engineers to  
25 troubleshoot, so I don't know anything other than what



1 they've already told me.

2 MR. KAUFFMAN: Okay.

3 MR. CONTE: Condenser vacuum and off-gas: Was  
4 off-gas isolation a consequential failure of the UPS power  
5 supply via the radiation monitoring failure?

6 MR. TOMLINSON: That's what I believe, that RE-13-  
7 Alpha and Bravo lost power and caused an isolation in the  
8 off-gas system.

9 MR. CONTE: RE meaning --?

10 MR. TOMLINSON: Radiation element.

11 MR. CONTE: Alpha and Bravo.

12 MR. TOMLINSON: Correct.

13 MR. CONTE: Lost power, and that caused the  
14 isolation.

15 So I guess the condenser vacuum didn't taper off  
16 too bad, but the operators were concerned about getting the  
17 hoppers on line; is that correct?

18 MR. TOMLINSON: That's true.

19 MR. CONTE: Did the hoppers perform acceptably?  
20 I should say that the hoppers are mechanical pumps; is that  
21 correct?

22 MR. TOMLINSON: That's correct.

23 MR. CONTE: How many of those mechanical vacuum  
24 pumps do you have?

25 MR. TOMLINSON: We have two.



1 MR. CONTE: They were using both of them.

2 MR. TOMLINSON: I don't know that for sure.

3 MR. CONTE: Do they bypass any radiation  
4 monitoring?

5 MR. TOMLINSON: Yes. They bypass the whole off-  
6 gas system.

7 MR. CONTE: Is there effluent monitored at all?  
8 Where do they go out -- the main stack?


9 MR. TOMLINSON: Yes. It still goes out the main  
10 stack.

11 MR. CONTE: And they were in use for how long? Do  
12 you know?

13 MR. TOMLINSON: I don't know.

14 MR. CONTE: Is there anything mentioned in your  
15 report about condenser vacuum, the off-gas isolation, and  
16 the mechanical vacuum pumps? I think what I'm hearing is  
17 that everything performed normally.

18 MR. TOMLINSON: The off-gas isolation is mentioned  
19 in the report, and there was a lot of trouble in this area  
20 in regard to maintaining turbine seal steam. There was a  
21 known problem with the pressure control valve that provides  
22 aux steam to the clean-steam reboiler; that valve would not  
23 work. Then they were required to swap over to steam from  
24 the auxiliary boiler to the clean steam reboiler, and they  
25 had a problem with that valve. It took some field effort in





1 order to get that valve open, so there was a lot of effort  
2 focused in that area early on in the event. Those things  
3 are included in my report.

4 MR. CONTE: The trip of the Division 2 hydrogen  
5 and oxygen sampling pump, is there an understanding of why  
6 that happened? Supposedly that's safety-grade power. It  
7 should not have been affected. Is that correct?

8 MR. TOMLINSON: That's true. It should not have  
9 been affected, and we are still investigating that one.

10 MR. CONTE: Okay.

11 Is that in your report?

12 MR. TOMLINSON: That is mentioned in my report,  
13 yes, and an explanation, whenever we get that, will also be  
14 included.

15 MR. IBARRA: Do we know the time frame of when  
16 they might come up with a possible explanation?

17 MR. TOMLINSON: We are currently working on it. I  
18 don't know when we're going to finish.

19 MR. CONTE: The GEM system, the gaseous effluent  
20 monitoring system -- I guess there are two, one on the --

21 MR. TOMLINSON: There are two, the stack GEMS and  
22 the vent GEMS.

23 MR. CONTE: Okay. Were they both powered off as a  
24 result of UPS? Were they affected?

25 MR. TOMLINSON: The vent GEMS, which is the



1 reactor building vent, was not operable, was out of service,  
2 before the event. That was out of service for normal  
3 calibration, so that was not in service prior to or after  
4 the event.

5 The stack GEMS was in service prior to the event,  
6 did lose power; then, when power was restored, the computer  
7 did not properly reboot itself. That was found by chem  
8 techs out in the plant, reported to the control room. If  
9 you look through the SSS log, you'll find that at 8:05 it  
10 was recorded in the SSS log as "stack GEMS inop." Really  
11 what that is is, that was reported from the field that it  
12 was still not functioning properly, that in fact it had been  
13 out since the loss of power. At that point the computer  
14 department got involved, rebooted the system, and it was  
15 finally restored to normal operation at approximately 8:47.

16 MR. CONTE: What was monitoring the stack with  
17 GEMS out?

18 MR. KAUFFMAN: I guess there were two times we're  
19 interested in, right? Before UPS was restored and after UPS  
20 was restored.

21 MR. CONTE: Yes.

22 MR. KAUFFMAN: If there's a different.

23 MR. TOMLINSON: I think chemistry is best suited  
24 to answer that question. I know that they had an in-line  
25 particulate filter that was discussed in the TSC during the



1 event that, after we thought things had finally stabilized,  
2 was removed and analyzed to ensure that, during the entire  
3 event, nothing was released of that nature.

4 We did have downwind teams out looking for  
5 releases. Chemistry, I believe, was doing their normal grab  
6 samples.

7 MR. KAUFFMAN: Do you recall when the field teams  
8 were dispatched and in place in the field?

9 MR. TOMLINSON: I don't know that detail.

10 MR. IBARRA: Can you tell me what other radiation  
11 monitors you have that would have been operable during this  
12 time?

13 MR. TOMLINSON: That's a big question.

14 MR. IBARRA: Do you have safety-related rad  
15 monitors?

16 MR. TOMLINSON: There are safety-related rad  
17 monitors in the control building ventilation system.

18 MR. IBARRA: And those did not go down?

19 MR. TOMLINSON: Those did not go down.

20 I'm sure there are a lot of others, but I just  
21 can't name them for you right now.

22 MR. CONTE: Before we leave the stack GEMS, off-  
23 gas is an input, that isolated, is that correct?

24 MR. TOMLINSON: That's off a separate rad monitor.

25 MR. CONTE: That is a separate rad monitor so

THE UNIVERSITY OF CHICAGO

PHYSICS DEPARTMENT

PHYSICS 435

LECTURE 1

1.1. THE CLASSICAL LIMIT

1.2. QUANTUM MECHANICS

1.3. THE SCHROEDINGER EQUATION

1.4. THE HEISENBERG UNCERTAINTY PRINCIPLE

1.5. THE DIRAC EQUATION

1.6. THE PAULI EXCLUSION PRINCIPLE

1.7. THE SPIN-ORBIT INTERACTION

1.8. THE FINITE POTENTIAL WELL

1.9. THE TUNNELING EFFECT

1.10. THE HYDROGEN ATOM

1.11. THE HYPERFINE SPLITTING

1.12. THE ZEEMAN EFFECT

1.13. THE LAMBERT-OSWALD THEORY

1.14. THE SPECTRUM OF THE HYDROGEN ATOM

1.15. THE RYDBERG CONSTANT

1 anything going out off-gas could have been monitored?

2 MR. TOMLINSON: Well, off-gas was isolated right  
3 away.

4 MR. CONTE: Okay, so --

5 MR. TOMLINSON: Off it's own rad monitor.

6 MR. CONTE: All right. What else -- at the time  
7 that -- after the event, what else is feeding that main  
8 stack from a ventilation point of view? Reactor building  
9 ventilation, or is that a separate --

10 MR. TOMLINSON: That's separate. Turbine building  
11 ventilation goes out through that stack.

12 MR. CONTE: Main stack?

13 MR. TOMLINSON: Yes.

14 MR. CONTE: Okay. Is there a monitor upstream  
15 that was operable? From an instrument point of view that  
16 are not in line and downwind or the grab sampling, do you  
17 know?

18 MR. TOMLINSON: I do not know.

19 MR. CONTE: Okay. Just -- I'm trying to get a  
20 little bit of understanding of the design -- how about  
21 what's going in the reactor building -- is the reactor  
22 building, the effluent, monitored by safety grade radiation  
23 monitoring, that was not affected by this power outage?

24 MR. TOMLINSON: There are, above and below refill  
25 floor rad monitors, HVR RE-14's and 32's that do monitor





1 that.

2 MR. CONTE: So, if there's anything going out of  
3 the reactor building, you could have gotten something from  
4 those radiation monitors?

5 MR. TOMLINSON: Yes.

6 MR. CONTE: That you just mentioned.

7 MR. TOMLINSON: And they would automatically  
8 isolate the building and start the standby gas treatment  
9 system.

10 MR. CONTE: Okay. Is there any information -- I'm  
11 done on the radiation monitoring, by the way. Is there any  
12 information when the first indication of the RCIC valve  
13 position problem was noted? In other words, when the  
14 operators first -- is there any records to indicate or based  
15 on operator statements, personnel statements or logs that  
16 when RCIC was injecting and they had the controller problem  
17 that there was something abnormal with the position  
18 indications on that testable check valves?

19 MR. TOMLINSON: The first I know of any abnormal  
20 indications on that testable check was after the system had  
21 been secured, the operators then noticed abnormal  
22 indications.

23 MR. KAUFFMAN: You say "after it was secured",  
24 does that mean within five or 10 minutes after it was  
25 secured or an hour or two hours after it was secured? I'm



1 just trying to get a ballpark for the time.

2 MR. CONTE: It's my understanding that it was  
3 placed in standby like an hour after the event or an hour  
4 and a half. Do you have any idea when that -- when that was  
5 first indicated?

6 MR. TOMLINSON: I can't recall, no.

7 MR. CONTE: Okay. The reports of water hammer, I  
8 guess you were down in the TSC when those reports came in,  
9 did you have any involvement in those reports, with the  
10 emergency director?

11 MR. TOMLINSON: There were two different reports  
12 for water hammer. The -- I can't remember which order they  
13 came in now. One of the concerns was in the RHR system,  
14 when we were warming up the lines preparing it for shutdown  
15 cooling, there was word from the field that they heard loud  
16 banging noises in one of the RHR heat exchanger rooms and I  
17 was involved at some point in the TSC in the discussions  
18 about, you know, providing engineering walkdown of that  
19 system prior to continuing with placing it in service and  
20 engineering was directed, at that point, during the event,  
21 to actually go out and do a walkdown of accessible piping  
22 and I believe that was done. That is included in my report  
23 and the engineering paperwork. It's just a letter saying  
24 that no problems were found. It's in my report.

25 There was also water hammer noises heard from



1 trying to place the reactor water cleanup system back in  
2 service. I believe the walkdown of that piping was actually  
3 deferred until after the event had been terminated, later on  
4 in the evening. Engineering did a walkdown of the system  
5 that was accessible and found no problems. And provided me  
6 with a write up on that.

7 MR. CONTE: Do you have -- from a response point  
8 of view, do you have an understanding of why they occurred?  
9 Or is it speculation, or you just don't have any idea?

10 MR. TOMLINSON: I can speculate that the cleanup  
11 system was in trying to place a hot system in reject to the  
12 condenser. You took a very large DP across the pressure  
13 control valve for a reject of the condenser and caused that  
14 cavitation. I don't know about the RHR system.

15 MR. CONTE: Okay. The cooling tower bypass valve,  
16 52 valve, went open, is that a consequential failing?

17 MR. TOMLINSON: There are three gates in the  
18 cooling tower that open -- that bypass the cooling tower.  
19 Those gates -- motor-operated gates, aromatically open on  
20 low basin temperature. The temperature -- the temperature  
21 instruments lost power, failed low giving the control  
22 circuit a signal that we had low basin temperature and  
23 therefore those MOG's acted properly in opening the bypass  
24 tower.

25 MR. CONTE: So that's a consequential failure with



1 the UPS?

2 MR. TOMLINSON: Yes.

3 MR. CONTE: Okay.

4 MR. TOMLINSON: We did, however, look at that and  
5 decided that we would write a plant change request to  
6 evaluate whether loosing one power supply to those  
7 temperatures switches should cause the valves to open. We  
8 thought that that needed further evaluation and there is a  
9 plant change request to evaluate that.

10 MR. CONTE: And this is addressed in your report?

11 MR. TOMLINSON: Yes.

12 MR. CONTE: Good. Reactor coolant sample sink  
13 the temperature control valve, apparently there was -- it  
14 was initially thought that the isolation valve was not  
15 opened, operators did open the isolation valve? Was there a  
16 malfunction in the temperature control valve at the sink, or  
17 what?

18 MR. TOMLINSON: That was a chem tech at the  
19 sample sink and I talked to the chemistry supervisor, Tim  
20 Kurtz, he told me that the reset pushbutton down in the  
21 sink -- I don't fully understand the setup down there --  
22 needs to be held in for something like five seconds. And in  
23 the heat of the battle the chem techs just did not hold the  
24 button in long enough and that was the only problem down  
25 there.





1 MR. CONTE: Did they eventually get a sample?

2 MR. TOMLINSON: Yes. I believe they did. The  
3 corrective action on Tim Kurtz's part was to make up an  
4 operator aid to remind people that the button needed to be  
5 held in for five seconds, and he's working on getting that  
6 installed.

7 MR. CONTE: Okay. We also go information that  
8 apparently there was an overflow in two sumps in the reactor  
9 building. Is there an understanding why that happened, is  
10 that another consequential failure or malfunction?

11 MR. TOMLINSON: We don't know. There was a slight  
12 backup and there was water on the floor in there -- in two  
13 of the sumps, I should say. And we, I guess, just assumed  
14 that the water came from that sump. Rad waste can't give us  
15 any indications of why that may have happened, and the sumps  
16 are operating properly now, so.

17 MR. CONTE: Those sump pumps are powered from  
18 what?

19 MR. TOMLINSON: I don't know for sure. They would  
20 be black power.

21 MR. CONTE: There's an item -- I guess Mr. Helker  
22 had an item on one of his lists that he presented in his  
23 interview. He talks about CNM AOV-101 open, needs to be  
24 shut pre-startup. Is that the bypass valve?

25 MR. TOMLINSON: That's the bypass valve around the



1 heater strain.

2 MR. CONTE: Oh, okay. And that's just --

3 MR. TOMLINSON: It's 101 -- back to our previous  
4 question at 101, is the bypass from the heater strain, 109  
5 is our bypass around the condensate deminizers.

6 MR. CONTE: Okay. And he's just tickling himself  
7 to make sure that the valve is --

8 MR. TOMLINSON: That open item is identified in my  
9 report.

10 MR. CONTE: It is?

11 MR. TOMLINSON: That that valve needs to be shut  
12 prior to startup.

13 MR. CONTE: But as far as what you're -- what I'm  
14 hearing is that valve function normally as designed?

15 MR. KAUFFMAN: Tom, another question on condensate  
16 was one of the condensate booster pumps tripped and the  
17 standby pump started early in the event, do you have an  
18 understanding of why that happened?

19 MR. TOMLINSON: We know the min flow valves failed  
20 to open. Systems engineering, again, addressed this  
21 particular issue. I believe that the system -- the whole  
22 condensate feed water system just took a very high flow rate  
23 due to all these valves being opened and caused low suction  
24 pressure. That's why the feed pumps tripped we believe and  
25 it's easy to understand why the booster pumps would also



1 have some lower suction pressure, so we believe that caused  
2 that to trip also.

3 MR. CONTE: The reactor vessel upset range, it's  
4 not on the process computer, it was apparently lost because  
5 of not being powered from safety related buses, what is it's  
6 function in the safety scheme of things here, the reactor  
7 vessel upset range?

8 MR. TOMLINSON: I guess I can't answer the  
9 question on its design basis from the plant.

10 MR. CONTE: Is that being looked into by the --

11 MR. TOMLINSON: My report did submit a plant  
12 change request to evaluate that and I requested that be  
13 placed on the process computer and evaluate placing it on  
14 safety grade power.

15 MR. CONTE: What range does it cover on the  
16 vessel? Do you know? Inches to inches?

17 MR. TOMLINSON: I believe it's upper range is  
18 approximately 325. I'm not quite sure where the lower band  
19 is.

20 MR. CONTE: Two more items. We're almost done  
21 here. The residual hand removal system, MOV-142 apparently  
22 did not open. There's an outstanding work request on it; we  
23 have a number, 193350, this is the RHR discharge to the rad  
24 waste line. Is there any -- is that the -- is that a --  
25 could that valve have been the cause of the water hammer or



1 is there a different problem as to why it didn't open? Is  
2 that an MOV problem or what?

3 MR. TOMLINSON: That problem was fixed early on in  
4 the day. That was some type of problem with the operator,  
5 dirty contacts, or something in the MOV and by the time the  
6 day was done, that valve was operating properly. That valve  
7 is -- I don't believe that valve is used for the initial  
8 part of the heat up, so I don't know whether it was involved  
9 in that water hammer or not.

10 MR. CONTE: Okay. Any -- in your report, any view  
11 on rod position indication? It's my understanding that the  
12 design is that the read switches are powered from one of the  
13 UPS's and the display lights are on another UPS in the  
14 control room. Is there any recommendation -- is that  
15 considered a problem at this point? Is there any thought to  
16 any design changes on that?

17 MR. TOMLINSON: That whole issue is identified in  
18 my report. The initial discrepancies have all been  
19 explained by the system engineer.

20 I know that our technical man, John Conway, is  
21 very concerned over rod position information not being  
22 safety grade power. Although that's the common design in  
23 the industry for that to be non-safety power. I don't know  
24 where we're going with that issue, I know we will discuss  
25 that as part of our SORC review.





1           Your specific question about being off two  
2 different UPS's, I wasn't aware of that.

3           MR. CONTE:   Okay.


4           MR. TOMLINSON:   The system engineer would have  
5 been more heavily involved in that.  He basically just --  
6 again, this is an issue that I just of panned off to system  
7 engineering and they resolved it for me and told me that all  
8 the indications were explainable and I don't know whether  
9 they have any continued open items to review of that nature.

10          MR. IBARRA:   The UPS loading, our investigation  
11 has shown to be heavily on the one or not equally  
12 distributed, that might have helped the situation, or not  
13 the situation because all UPS went down, but it might help  
14 in the future if only one UPS goes down.  Is that an issue  
15 that you all will be reviewing?

16          MR. TOMLINSON:   UPS loading is not a new issue.  
17 That has been going on in this plant for quite some time.  
18 We've already done several things to the UPS's to change the  
19 loadings.  Stripped some of the loads off and there are  
20 other plans in the works to change out some of the UPS's and  
21 to change some of the loadings.  So it's been an on going  
22 issue for some time now.

23          MR. IBARRA:   But in the light of what happened,  
24 will that be reviewed?

25          MR. TOMLINSON:   I'm sure it's already being



1 reviewed. That's not my area, I don't know.

2 MR. IBARRA: Okay.


3 MR. CONTE: One of the, just kind of summary  
4 questions -- or comment, it was very difficult to find out  
5 what loads were off those UPS's. As an individual who was  
6 probably trying to review the plant response and getting  
7 answers to questions about what happened and why that  
8 happened I'm sure you must have been somewhat frustrated by  
9 that. Why do you think that exists? Why doesn't the plant  
10 have a good drawing with loads lists or whatever that  
11 reflect what the loads are off the UPS?

12 MR. TOMLINSON: I guess I'm not really -- I don't  
13 really know why and I know we do have load lists for our  
14 safety related UPS's. Maybe it was just a matter of  
15 priority and operations has asked for that in the past, but  
16 that, as you know, is a very difficult task. It may just  
17 come down to priority.

18 MR. IBARRA: In the scenario that was run  
19 yesterday where you loose one of the UPS, UPS 1B, apparently  
20 there might still be some discrepancy as to what powers  
21 want, because there was some inconsistencies. Do you know  
22 anything about that?

23 MR. TOMLINSON: About the loss of the UPS,  
24 yesterday?

25 MR. IBARRA: Yes.



1 MR. TOMLINSON: Very little.

2 MR. IBARRA: Okay.

3 MR. KAUFFMAN: Earlier you mentioned your report  
4 was going to SORC, can you tell us when you anticipate the  
5 SORC meeting review?

6 MR. TOMLINSON: I know they're meeting right now  
7 to discuss some of the preliminary stuff. I don't know when  
8 the report is going to actually be reviewed in detail by  
9 SORC. It was supposed to be this past weekend and it didn't  
10 happen, so I don't know.

11 MR. CONTE: Who's going to make the decision on  
12 what issues need to be resolved by startup or not, is it the  
13 assessment groups or is it plant management, SORC?

14 MR. TOMLINSON: I would have to say it would be  
15 SORC to make that decision.


16 MR. CONTE: So in your report you really don't  
17 make recommendations in terms of this needs to be resolved  
18 by startup?

19 MR. TOMLINSON: No.

20 MR. CONTE: Okay. You're just identifying --

21 MR. TOMLINSON: Identify all of the issues and  
22 make sure something is happening to address each issue.  
23 Safety assessment may do some of that assessment of what  
24 needs to be resolved, I don't know.

25 MR. CONTE: I don't have anything else.



1 MR. IBARRA: I don't either.

2 MR. KAUFFMAN: I just have one kind of a general  
3 question. Are there any things that you think that came out  
4 of this event or that we haven't quizzed you about and  
5 talked about here today or are all the relatively major  
6 single handed things here on the table here at this meeting?

7 MR. TOMLINSON: Well, there's a long list of  
8 deficiencies that were identified and I think we've talked  
9 about most of the big ones.

10 MR. KAUFFMAN: A list of deficiencies that you  
11 identified, is that typical for the number of failures or  
12 problems experienced by say following a normal plant trip  
13 versus kind of unusual?

14 MR. TOMLINSON: The number of deficiencies?

15 MR. KAUFFMAN: Well, we had problems in feedwater,  
16 problems in --

17 MR. TOMLINSON: The number of deficiencies for  
18 this one is no more than normally is. Usually my number of  
19 deficiencies is maybe a half dozen. Things on the entire  
20 event, didn't work like they should have worked or something  
21 like that.

22 MR. CONTE: Now, that's taking away the  
23 consequential factors, I mean the things that happened  
24 because of UPS? If you take away the stuff because of the  
25 loss of UPS failure, how -- what does that list come down





1 to, is that a half a dozen, a dozen, in your mind, without  
2 counting them?

3 MR. TOMLINSON: It get significantly smaller. By  
4 eliminating all the things that happened because of UPS  
5 failure and transformer failure it's probably down to fairly  
6 normal type of a list.

7 MR. CONTE: Half a dozen list?

8 MR. TOMLINSON: That sounds about right.

9 MR. CONTE: For normal post-trip review?

10 MR. TOMLINSON: Yes.

11 MR. KAUFFMAN: Okay. If there are no more  
12 questions, that's the end of the interview.

13 MR. CONTE: Let's go off the record.

14 [Whereupon, at 2:55 p.m. the taking of the  
15 interview was concluded.]

16

17

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE


This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

In the Matter of:

NAME OF PROCEEDING: Interview of Earl Scott  
"Tom" Tomlinson III  
DOCKET NUMBER: (Not applicable)

PLACE OF PROCEEDING: Scriba, New York

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

  
\_\_\_\_\_  
Mark Handy  
Official Reporter  
Ann Riley & Associates, Ltd.

