

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U.S. Nuclear Regulatory Commission
Incident Investigation Team

Title: IIT Exit Meeting Nine
Mile Point, Unit Two

Docket No.

LOCATION: Scriba, New York


DATE: Tuesday, August 27, 1991 PAGES: 1 - 17

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950



1 PARTICIPANTS:

2

3 For the Incident Investigation Team:

4

5 Jack Rosenthal, Team Leader, Office for Analysis and
6 Evaluation of Operational Data

7 Michael Jordan, Deputy Team Leader, Office of Nuclear
8 Reactor Regulation

9 Richard Conte, Region I, Boiling Water Reactor Section

10 Walton Jensen, Office of Nuclear Reactor Regulation

11 Jose Ibarra, Office of Nuclear Reactor Regulation

12 John Kauffman, Office for Analysis and Evaluation of
13 Operational Data

14 Cherie Siegel, Office for Analysis and Evaluation of
15 Operational Data

16

17 For Niagara Mohawk Power Corporation:

18

19 B. Ralph Sylvia, Executive Vice President

20 Joseph F. Firlit, Vice President, Nuclear Generation

21 Martin J. McCormick, Jr., Plant Manager, Nine Mile
22 Point, Unit Two

23 Richard B. Abbott, Manager, Engineering, Nine Mile
24 Point, Unit Two

25



P R O C E E D I N G S

[3:30 p.m.]

1
2
3 MR. ROSENTHAL: Why don't we start our exit. I
4 don't know all the people in the room, but I assume that
5 they're all NRC or Niagara Mohawk people.

6 [Hand raised in audience.]

7 MR. ROSENTHAL: You're not.

8 MR. FIRLIT: He's a consultant that's working with
9 us from California.

10 MR. ROSENTHAL: He's okay with you.

11 MR. FIRLIT: Yes.

12 MR. ROSENTHAL: Okay.

13 My goal is to spend an hour or less. I know
14 everybody is busy.

15 I would ask that the first time people speak they
16 identify themselves by name -- my name is Jack Rosenthal --
17 so that the transcriber can recognize us.

18 First, let me say thank you for the cooperation
19 that you've given us and support in conducting our
20 investigation. We have completed this stage of our field
21 work, and we'll now be going back to Washington and
22 interviewing NRC people to try to see where we should or
23 shouldn't go.


24 I think our minds are just plain not made up about
25 generic actions. I'll give you an example. Clearly, the



1 rod position indicator in the control room is non-1E. All
2 the indicators, I guess, come off UPS 1A, and then there's a
3 backup from 1B, but there's only one stack of read switches,
4 which come off 1A again. I'm sure that every other boiler
5 in the nation is exactly that way.

6 Reg guide 197, which you conform you to, does not
7 require anything of that instrument; in fact, your
8 installation is above the minimum requirements in that area.
9 Nevertheless, the operators really do use that instrument,
10 and in this case it puts them into a tight little box on
11 their ATWS procedure. By following that procedure, they
12 want to know rod position indication and move on, but from
13 the APRMs, LPRMs, they think that they're scrambled. They
14 know that they're subcritical; in fact, the rationale at the
15 time was that the direct indication that you've turned off
16 the reaction is that you monitor the neutron flux, and
17 that's the direct indication, rather than the indirect one
18 that the rods are in. That's a glitch, and I think all
19 boilers would have the same problem.

20 We also said to the owner's groups developing the
21 emergency procedures, Hey, put everything into those
22 procedures that you realistically need to run the plant, no
23 matter what their qualification was. We knew that, if we
24 didn't say that, we'd have two sets of procedures: the real
25 procedures and our hokey procedure, one to satisfy a



1 regulation and another one that's really used. We didn't
2 want that, so we're between a -- that's clearly a generic
3 thing that I'm going to worry about. I don't know what's
4 going to come out.

5 That probably crosses a half dozen branches in the
6 NRC in terms of responsibility, so now we're going to have
7 to go back to them and say, What was the rationale? Why did
8 you do it this way? I think I know. Okay. So we've still
9 got a lot of our work cut out for us.

10 Depending on how this circuit board analysis comes
11 out, I may want to send somebody out to California, so I
12 need you to keep us informed. I doubt if you'll be cutting
13 apart the transformer in the next month, but if you are I'll
14 send somebody out to McGraw-Edison. Okay.

15 In the course of our trying to construct a
16 sequence of events and causal factors, we found a number of
17 hardware issues. During the event, there was always a work-
18 around for those hardware issues. I have shared those with
19 Region I, and they've told me that you are already working
20 on all of them, so there's nothing in the pocket.

21 MR. SYLVIA: Ralph Sylvia.

22 We will give them a status of each of those
23 tomorrow, when we meet with the region. A number of those
24 were due to the UPS failure.

25 MR. ROSENTHAL: Right. That was a challenge to



1 us, to figure out which were random -- which were
2 independent and which were consequential. I think we've got
3 it down about right now. I think it was a learning process
4 for everybody.

5 I don't think we have to go over these one by one,
6 but I do want to pick some examples, okay?

7 MR. SYLVIA: Okay.

8 MR. ROSENTHAL: Let's take MOV-84. I think that,
9 in regulatory space, the '85 generic letter and the '89
10 generic letter pertain to safety-related equipment; that's
11 my memory.

12 MR. SYLVIA: Are you talking about MOV?

13 MR. ROSENTHAL: MOVs.

14 Do you have valves like MOV-84 in your -- do you
15 routinely them? I mean when you work on them.

16 MR. McCORMICK: This is Marty McCormick.

17 There is a very extensive MOVATS program.

18 Unfortunately, those particular valves, as I understand it
19 now, are butterfly-type valves, and the MOVATS device
20 doesn't work to test those. You test them with a torque-
21 level arm. We're confirming that they were set the way they
22 should have been set, and we'll confirm and continue to test
23 those valves to see why they didn't come open.

24 There is a very extensive MOVATS program, and it
25 covers just about everything that's motor-operated in the



1 plant; it was done from startup, and it's very well
2 maintained. We have the equipment, and we have expertise on
3 site to keep those in proper preventive maintenance.

4 MR. ABBOTT: Rick Abbott.

5 Just a couple things. As of the latest
6 information this afternoon, we went and further inspected
7 one of the operators. We found the operator somewhat loose,
8 and that would have affected the applied torque that that
9 operator could do, so we're going to continue our hardware
10 investigation of those three valves.

11 We've also learned that the VOTE company has a
12 tool, a device, that can measure rotational torque, and
13 we're looking into using that for our butterfly valves, that
14 rotate, rather than the standard thrust equipment that
15 MOVATS supplies.

16 MR. ROSENTHAL: And you can talk to Millstone
17 about that. They have VOTES equipment.

18 MR. ABBOTT: We can talk to FitzPatrick about
19 that, right.

20 MR. ROSENTHAL: There clearly is not a regulatory
21 requirement in terms of what's loaded on what UPS, but we
22 all in this room know that, if UPS 1A fails or the cable
23 outside -- you know, the mythical copper-rat scenario -- if
24 that goes, you end up with a plant trip, loss of the
25 feedwater system, loss of the control rods, and loss of some



1 but not all annunciators, and you're back in virtually the
2 same event. I think you ought to think about that, about
3 how you might choose bus loadings.

4 MR. SYLVIA: We are doing that.

5 MR. ROSENTHAL: I think at this point I believe
6 that, in terms of communications, loss of one of the UPS's
7 does not take out all. That's my impression.

8 I was surprised that you didn't have load lists.
9 Maybe I'm naive.

10 MR. ABBOTT: There was a request to engineering
11 during our refueling outage, because we wanted to take one
12 of the UPS's out. A request went in, and it has not been
13 acted on yet, but, as you're aware, we did that for the B
14 unit while you were here; we're now working on the A unit,
15 to develop that list.

16 MR. SYLVIA: It's desirable, clearly, to have
17 them.

18 MR. ROSENTHAL: At the press conference, as we
19 rolled through this exercise, I did tell them that you had
20 planned to replace two of them that were running hot and
21 that that had begun prior to the event, to your credit.

22 I'm still concerned over just temperature
23 degradation within the UPS's. The room temperature may be
24 okay, but it's hot in there, and you may have to run down
25 just what they mean by environmental temperature. Do they



1 . mean the room temperature a nominal foot from the surface of
2 the box, or do they mean the air that's inside of it. I
3 think we have a fair amount of operational experience that
4 says that a lot of these have been heat-related failures.

5 Now, I'm not saying that that is what killed it
6 this time, but it can precondition equipment -- just heat
7 and aging -- such that it runs it down. Again, this is non-
8 IE stuff. I know that I'm not talking in regulatory space
9 now.

10 MR. McCORMICK: Based on our knowledge of the
11 environment, we were well within that criteria for the
12 manufacturer's specification.

13 MR. ROSENTHAL: But it is hot in there.

14 MR. McCORMICK: No question.

15 MR. SYLVIA: We are concerned about the
16 temperature, and that's one of the reasons for our
17 replacement program. We're going beyond what just meets
18 specifications, because we had the same concern.


19 MR. ROSENTHAL: I'll even say my own experience is
20 that it's not unique to this plant that that sort of
21 equipment tends to run hot. I know I've been in more than
22 one plant where they floor fans blowing on breakers during
23 an outage to try to keep stuff cool, but heat does kill
24 electronics, and we all know that. And heat may have killed
25 these batteries, whose significance we're arguing over but



1 would be a contributing factor.

2 We did a lot of interviewing, and we wanted to
3 satisfy ourselves that you didn't luck out. I think that
4 that's our impression -- that is, in terms of who was around
5 at the time. It was important to us to know that lots of
6 people knew how to flip the breaker and get that into
7 maintenance mode, and we believe that lots of your people
8 knew, so it wasn't just the luck of the draw of who was
9 there. I guess you were fortunate that the system engineer
10 was present, but my overall impression is that you would
11 have coped successfully with the event had he not been
12 there. That was an important thing for us to find out, and
13 enough interviewing of operators to assess general
14 knowledge.

15 I guess what you say is that you do the training
16 to impart knowledge, and then they use that knowledge for
17 the event that comes along, and the event that comes along
18 is never going to be exactly what they were trained for. I
19 understand that you were trained for loss of instrument air,
20 which I think is a good one, because a lot of stuff goes on
21 at that time -- you know, simultaneously. You hadn't given
22 specific training on, let's say, loss of all annunciators;
23 you had given training on loss of specific annunciators and
24 specific instruments. That's something that you might
25 consider.



1 Similarly, you're going to have to at least brief
2 the operators -- have some sort of training -- on loss of
3 UPS's, I think -- without my saying what the extent is and
4 what not.


5 MR. MCCORMICK: Certainly we'll plan on the event.

6 [Laughter.]

7 MR. ROSENTHAL: On this one, knowing it'll never
8 come again.

9 Let me give an example, just to belabor it. What
10 they had here, if I just take the feedwater side, is a loss
11 of feedwater and the loss of the associated instruments, as
12 distinct from a loss of feedwater, where you could see the
13 other indicators on that very board. It is, in that sense,
14 different.

15 We looked at the pump head curves. I'm not ready
16 to swear to it, but I think that the condensate booster pump
17 bypass valve opening runs back the water to the feedwater
18 pumps, and the feedwater pumps trip out consequential on the
19 condensate booster. It's a relay race, except that it's
20 important to know which one if you're thinking about doing
21 something about it. We believe that it's the condensate
22 booster pumps, when you opened up the bypass valve -- when
23 that failed to open -- that didn't provide enough flow. I
24 don't know what you want to do about that. Maybe you don't
25 want that to fail full open.



1 MR. McCORMICK: That will be looked at. That's
2 one of the items we've identified as a review, to say, Do we
3 want those valves to fail open; they protect the equipment,
4 but they do some other things. It will be part of our
5 follow-up review.

6 MR. ROSENTHAL: While it looked like, when you
7 opened up the dump off the feedwater pumps, you just run
8 back on the curve a little bit more. At least that's what
9 the first shot was.

10 It wasn't clear in our minds for a few days about
11 whether you had a monitored release. We knew that you had
12 the area rad monitors. We knew that you had lost GEMS. I
13 think that we now have it resolved that you did have a stack
14 monitor on one of the safety divisions from the stack.

15 MR. McCORMICK: Yes.

16 MR. ROSENTHAL: People running around are really
17 taking particulate samples rather than gaseous effluent that
18 goes up the stack, so I think that it's very good that you
19 had it. I don't know that the people who were running the
20 plant at the time knew that they knew that they had it, and,
21 when you put the hoppers on, if they understood that they
22 still had a monitored release, as distinct from -- I mean,
23 they had lots of other indicators -- you know, the high-rad
24 alarms, the area monitors, et cetera -- to believe that they
25 weren't having a release, but I don't know about



1 specifically monitoring the stack, because your general
2 knowledge would say, Hey, that's off the GEMS system, which
3 is down. That's like knowledge-based performance.

4 MR. ABBOTT: My understanding is that we had a
5 chem tech at the stack; he was able to read locally the
6 stack GEMS output at the skid out at the stack, and he was
7 placed there intentionally and in communication with the
8 control room prior to the starting of the hoggers, the
9 mechanical vacuum pumps. That was a pre-planned evolution.

10 MR. ROSENTHAL: Fantastic.

11 MR. ABBOTT: If you need more than that, I'm sure
12 I could get you some more.

13 MR. ROSENTHAL: We know that now. Okay. By the
14 hour I'm learning. Okay.

15 In terms of the report that I intend to right, I
16 really pretty much plan to stick to the event and not all
17 these peripheral issues, as distinct from communicating some
18 of the stuff to Region I.

19 What else?

20 Okay. There's a general area that I just wanted
21 to mention to you. That is that it seems to us that, for
22 the feedwater condensate system and the UPS, as examples,
23 they are really using startup procedures to do what is
24 essentially a restoration task.

25 There may be a million ways that it goes down, so



1 I'm not quite sure how to do it, but it's something that it
2 may be very appropriate to think of. I don't think the UPS
3 goes out on you all the time, but restoring feedwater
4 shouldn't be that unusual -- I think from hot conditions
5 rather than from cold.

6 MR. SYLVIA: Are there some features of a startup
7 test procedure that didn't apply, or you just don't think
8 we're calling it the right thing?

9 MR. ROSENTHAL: Well, I don't know that you would
10 have necessarily wanted to close MOV-84 in the first place,
11 and then have to reopen it, but I don't know that.

12 MR. ABBOTT: What he's talking about is, system
13 startup procedures inside the FOPs presume that the system
14 has been shut down and idle for some plant maintenance.

15 MR. SYLVIA: Right.

16 MR. ABBOTT: We were using sections like these for
17 the UPS and feedwater, to restore it, in this time frame.
18 The procedures don't have a restoration section in them.


19 MR. SYLVIA: The initial conditions are different.

20 MR. ABBOTT: Yes.

21 MR. ROSENTHAL: The problem there, I recognize, is
22 that it becomes almost an infinite set.

23 MR. SYLVIA: Right. That's the problem.

24 MR. McCORMICK: We have to make some judgement,
25 and we'll look at that to see, bound it a little bit, but



1 the dilemma is, if I write it for this emergency, it isn't
2 the emergency I have, any more than the one that says, I
3 know how to start the equipment, so, if I have an emergency,
4 I should know how to operate to contend with the emergency.
5 I mean, it's, where do you go with that. We'll look at
6 that.

7 MR. SYLVIA: I understand what you're getting at.

8 MR. ROSENTHAL: We flipped it to what went
9 right -- We had symptom-oriented emergency procedures,
10 followed the procedures. You had put in the post-accident
11 monitoring system, and I guess in terms of pressure and
12 level that's what you were down to, but it was there, and
13 there are two of them. I mean, there are lessons learned
14 from prior events that were learned here. The operators
15 clearly coped, and I said things like that at this press
16 conference.

17 There are ways of looking at this event in terms
18 of it also being the success, in terms of having put in
19 systems, which were then used to cope -- half full, half
20 empty.

21 Let me give the floor to you.

22 [Pause.]

23 MR. SYLVIA: Are you through, Jack?

24 MR. ROSENTHAL: Yes.

25 MR. SYLVIA: The main thing I'd like to say is



1 that we've tried to give you everything you need. If you
2 get back to White Flint and you need anything else, we'll be
3 happy to give you whatever you need. As new developments
4 come up, we will make the point to share those with you,
5 because I think there are a lot of things yet that we don't
6 know. As I mentioned to you, I'm not at all satisfied that
7 we know exactly what tripped the UPS's or how they tripped.
8 We still want to do more to try to find out.

9 I think, as far as anything that we know, you
10 know, and vice versa, but if there's something that you may
11 not know that we discover, we will share that with you, too.

12 MR. ROSENTHAL: Good.

13 I need a point of contact for this document flow.

14 MS. SIEGEL: We've got it, Jack.

15 MR. ROSENTHAL: We have it.

16 [Pause.]

17 MR. ROSENTHAL: Our plan would be to fax up a
18 list, rather than doing it over the phone, and do it in a
19 more systematic fashion, because I know it was pretty
20 diverse early on.

21 I think that's it.

22 MR. JORDAN: Your report, when can we expect that?

23 MR. McCORMICK: The report of the team that
24 reviewed the event?

25 MR. JORDAN: Yes.



1 MR. McCORMICK: I would say that we should have
2 that in a reasonable form to pass on by the end of the week.
3 This is the summary. We'll be going to the region tomorrow,
4 and much of that detail will be included in that. We'll get
5 that to you post haste.

6 It's still being put in final form, as we speak.
7 We of course reviewed all the incidents typical of a scram.
8 What we're doing would be part of the routine before we
9 would return the plant to service, so we identify those
10 things which were anomalies in the scram. They have to be
11 cleared, understood, approved by SORC, and then justified so
12 we can go back. That process is under way, and it's part of
13 the evolution of this report.

14 I think in that process we've covered all the
15 items which we have shared from your review, along with our
16 own.

17 [Pause.]

18 MR. ROSENTHAL: Meeting adjourned.

19 MR. SYLVIA: Thank you.

20 MR. ROSENTHAL: Thank you.

21 [Whereupon, at 4:00 p.m., the meeting was
22 concluded.]

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: IIT Exit Meeting

DOCKET NUMBER:

PLACE OF PROCEEDING: Scriba, New York

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



MARK HANDY
Official Reporter
Ann Riley & Associates, Ltd.

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U.S. Nuclear Regulatory Commission
Incident Investigation Team

Title: IIT Exit Meeting Nine
Mile Point, Unit Two

Docket No.

LOCATION: Scriba, New York

DATE: Tuesday, August 27, 1991 PAGES: 1 - 17

ANN RILEY & ASSOCIATES, LTD.


1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

Dupe of

9305070058



UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
INCIDENT INVESTIGATION TEAM

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

In the Matter of: :
:
IIT Exit Meeting :
Nine Mile Point, Unit Two :

Security Conference Room
Unit One Security Building
Nine Mile Point Nuclear
Power Station
Lake Road
Scriba, New York 13093
Tuesday, August 27, 1991

The meeting convened, pursuant to notice,
at 3:30 p.m.



1 PARTICIPANTS:

2

3 For the Incident Investigation Team:

4

5 Jack Rosenthal, Team Leader, Office for Analysis and
6 Evaluation of Operational Data7 Michael Jordan, Deputy Team Leader, Office of Nuclear
8 Reactor Regulation

9 Richard Conte, Region I, Boiling Water Reactor Section

10 Walton Jensen, Office of Nuclear Reactor Regulation

11 Jose Ibarra, Office of Nuclear Reactor Regulation

12 John Kauffman, Office for Analysis and Evaluation of
13 Operational Data14 Cherie Siegel, Office for Analysis and Evaluation of
15 Operational Data

16

17 For Niagara Mohawk Power Corporation:

18

19 B. Ralph Sylvia, Executive Vice President

20 Joseph F. Firlit, Vice President, Nuclear Generation

21 Martin J. McCormick, Jr., Plant Manager, Nine Mile
22 Point, Unit Two23 Richard B. Abbott, Manager, Engineering, Nine Mile
24 Point, Unit Two

25



P R O C E E D I N G S

[3:30 p.m.]

1
2
3 MR. ROSENTHAL: Why don't we start our exit. I
4 don't know all the people in the room, but I assume that
5 they're all NRC or Niagara Mohawk people.

6 [Hand raised in audience.]

7 MR. ROSENTHAL: You're not.

8 MR. FIRLIT: He's a consultant that's working with
9 us from California.

10 MR. ROSENTHAL: He's okay with you.

11 MR. FIRLIT: Yes.


12 MR. ROSENTHAL: Okay.

13 My goal is to spend an hour or less. I know
14 everybody is busy.

15 I would ask that the first time people speak they
16 identify themselves by name -- my name is Jack Rosenthal --
17 so that the transcriber can recognize us.

18 First, let me say thank you for the cooperation
19 that you've given us and support in conducting our
20 investigation. We have completed this stage of our field
21 work, and we'll now be going back to Washington and
22 interviewing NRC people to try to see where we should or
23 shouldn't go.


24 I think our minds are just plain not made up about
25 generic actions. I'll give you an example. Clearly, the



1 rod position indicator in the control room is non-1E. All
2 the indicators, I guess, come off UPS 1A, and then there's a
3 backup from 1B, but there's only one stack of read switches,
4 which come off 1A again. I'm sure that every other boiler
5 in the nation is exactly that way.

6 Reg guide 197, which you conform you to, does not
7 require anything of that instrument; in fact, your
8 installation is above the minimum requirements in that area.
9 Nevertheless, the operators really do use that instrument,
10 and in this case it puts them into a tight little box on
11 their ATWS procedure. By following that procedure, they
12 want to know rod position indication and move on, but from
13 the APRMs, LPRMs, they think that they're scrambled. They
14 know that they're subcritical; in fact, the rationale at the
15 time was that the direct indication that you've turned off
16 the reaction is that you monitor the neutron flux, and
17 that's the direct indication, rather than the indirect one
18 that the rods are in. That's a glitch, and I think all
19 boilers would have the same problem.

20 We also said to the owner's groups developing the
21 emergency procedures, Hey, put everything into those
22 procedures that you realistically need to run the plant, no
23 matter what their qualification was. We knew that, if we
24 didn't say that, we'd have two sets of procedures: the real
25 procedures and our hokey procedure, one to satisfy a



1 regulation and another one that's really used. We didn't
2 want that, so we're between a -- that's clearly a generic
3 thing that I'm going to worry about. I don't know what's
4 going to come out.

5 That probably crosses a half dozen branches in the
6 NRC in terms of responsibility, so now we're going to have
7 to go back to them and say, What was the rationale? Why did
8 you do it this way? I think I know. Okay. So we've still
9 got a lot of our work cut out for us.


10 Depending on how this circuit board analysis comes
11 out, I may want to send somebody out to California, so I
12 need you to keep us informed. I doubt if you'll be cutting
13 apart the transformer in the next month, but if you are I'll
14 send somebody out to McGraw-Edison. Okay.

15 In the course of our trying to construct a
16 sequence of events and causal factors, we found a number of
17 hardware issues. During the event, there was always a work-
18 around for those hardware issues. I have shared those with
19 Region I, and they've told me that you are already working
20 on all of them, so there's nothing in the pocket.

21 MR. SYLVIA: Ralph Sylvia.

22 We will give them a status of each of those
23 tomorrow, when we meet with the region. A number of those
24 were due to the UPS failure.

25 MR. ROSENTHAL: Right. That was a challenge to



1 us, to figure out which were random -- which were
2 independent and which were consequential. I think we've got
3 it down about right now. I think it was a learning process
4 for everybody.

5 I don't think we have to go over these one by one,
6 but I do want to pick some examples, okay?

7 MR. SYLVIA: Okay.

8 MR. ROSENTHAL: Let's take MOV-84. I think that,
9 in regulatory space, the '85 generic letter and the '89
10 generic letter pertain to safety-related equipment; that's
11 my memory.

12 MR. SYLVIA: Are you talking about MOV?


13 MR. ROSENTHAL: MOVs.

14 Do you have valves like MOV-84 in your -- do you
15 routinely them? I mean when you work on them.

16 MR. McCORMICK: This is Marty McCormick.

17 There is a very extensive MOVATS program.
18 Unfortunately, those particular valves, as I understand it
19 now, are butterfly-type valves, and the MOVATS device
20 doesn't work to test those. You test them with a torque-
21 level arm. We're confirming that they were set the way they
22 should have been set, and we'll confirm and continue to test
23 those valves to see why they didn't come open.

24 There is a very extensive MOVATS program, and it
25 covers just about everything that's motor-operated in the



1 plant; it was done from startup, and it's very well
2 maintained. We have the equipment, and we have expertise on
3 site to keep those in proper preventive maintenance.

4 MR. ABBOTT: Rick Abbott.

5 Just a couple things. As of the latest
6 information this afternoon, we went and further inspected
7 one of the operators. We found the operator somewhat loose,
8 and that would have affected the applied torque that that
9 operator could do, so we're going to continue our hardware
10 investigation of those three valves.

11 We've also learned that the VOTE company has a
12 tool, a device, that can measure rotational torque, and
13 we're looking into using that for our butterfly valves, that
14 rotate, rather than the standard thrust equipment that
15 MOVATS supplies.

16 MR. ROSENTHAL: And you can talk to Millstone
17 about that. They have VOTES equipment.

18 MR. ABBOTT: We can talk to FitzPatrick about
19 that, right.

20 MR. ROSENTHAL: There clearly is not a regulatory
21 requirement in terms of what's loaded on what UPS, but we
22 all in this room know that, if UPS 1A fails or the cable
23 outside -- you know, the mythical copper-rat scenario -- if
24 that goes, you end up with a plant trip, loss of the
25 feedwater system, loss of the control rods, and loss of some



1 but not all annunciators, and you're back in virtually the
2 same event. I think you ought to think about that, about
3 how you might choose bus loadings.

4 MR. SYLVIA: We are doing that.

5 MR. ROSENTHAL: I think at this point I believe
6 that, in terms of communications, loss of one of the UPS's
7 does not take out all. That's my impression.


8 I was surprised that you didn't have load lists.
9 Maybe I'm naive.

10 MR. ABBOTT: There was a request to engineering
11 during our refueling outage, because we wanted to take one
12 of the UPS's out. A request went in, and it has not been
13 acted on yet, but, as you're aware, we did that for the B
14 unit while you were here; we're now working on the A unit,
15 to develop that list.

16 MR. SYLVIA: It's desirable, clearly, to have
17 them.

18 MR. ROSENTHAL: At the press conference, as we
19 rolled through this exercise, I did tell them that you had
20 planned to replace two of them that were running hot and
21 that that had begun prior to the event, to your credit.

22 I'm still concerned over just temperature
23 degradation within the UPS's. The room temperature may be
24 okay, but it's hot in there, and you may have to run down
25 just what they mean by environmental temperature. Do they



1 mean the room temperature a nominal foot from the surface of
2 the box, or do they mean the air that's inside of it. I
3 think we have a fair amount of operational experience that
4 says that a lot of these have been heat-related failures.

5 Now, I'm not saying that that is what killed it
6 this time, but it can precondition equipment -- just heat
7 and aging -- such that it runs it down. Again, this is non-
8 IE stuff. I know that I'm not talking in regulatory space
9 now.


10 MR. McCORMICK: Based on our knowledge of the
11 environment, we were well within that criteria for the
12 manufacturer's specification.

13 MR. ROSENTHAL: But it is hot in there.

14 MR. McCORMICK: No question.

15 MR. SYLVIA: We are concerned about the
16 temperature, and that's one of the reasons for our
17 replacement program. We're going beyond what just meets
18 specifications, because we had the same concern.

19 MR. ROSENTHAL: I'll even say my own experience is
20 that it's not unique to this plant that that sort of
21 equipment tends to run hot. I know I've been in more than
22 one plant where they floor fans blowing on breakers during
23 an outage to try to keep stuff cool, but heat does kill
24 electronics, and we all know that. And heat may have killed
25 these batteries, whose significance we're arguing over but



1 would be a contributing factor.

2 We did a lot of interviewing, and we wanted to
3 satisfy ourselves that you didn't luck out. I think that
4 that's our impression -- that is, in terms of who was around
5 at the time. It was important to us to know that lots of
6 people knew how to flip the breaker and get that into
7 maintenance mode, and we believe that lots of your people
8 knew, so it wasn't just the luck of the draw of who was
9 there. I guess you were fortunate that the system engineer
10 was present, but my overall impression is that you would
11 have coped successfully with the event had he not been
12 there. That was an important thing for us to find out, and
13 enough interviewing of operators to assess general
14 knowledge.

15 I guess what you say is that you do the training
16 to impart knowledge, and then they use that knowledge for
17 the event that comes along, and the event that comes along
18 is never going to be exactly what they were trained for. I
19 understand that you were trained for loss of instrument air,
20 which I think is a good one, because a lot of stuff goes on
21 at that time -- you know, simultaneously. You hadn't given
22 specific training on, let's say, loss of all annunciators;
23 you had given training on loss of specific annunciators and
24 specific instruments. That's something that you might
25 consider.



1 Similarly, you're going to have to at least brief
2 the operators -- have some sort of training -- on loss of
3 UPS's, I think -- without my saying what the extent is and
4 what not.

5 MR. McCORMICK: Certainly we'll plan on the event.

6 [Laughter.]

7 MR. ROSENTHAL: On this one, knowing it'll never
8 come again.

9 Let me give an example, just to belabor it. What
10 they had here, if I just take the feedwater side, is a loss
11 of feedwater and the loss of the associated instruments, as
12 distinct from a loss of feedwater, where you could see the
13 other indicators on that very board. It is, in that sense,
14 different.

15 We looked at the pump head curves. I'm not ready
16 to swear to it, but I think that the condensate booster pump
17 bypass valve opening runs back the water to the feedwater
18 pumps, and the feedwater pumps trip out consequential on the
19 condensate booster. It's a relay race, except that it's
20 important to know which one if you're thinking about doing
21 something about it. We believe that it's the condensate
22 booster pumps, when you opened up the bypass valve -- when
23 that failed to open -- that didn't provide enough flow. I
24 don't know what you want to do about that. Maybe you don't
25 want that to fail full open.




1 MR. McCORMICK: That will be looked at. That's
2 one of the items we've identified as a review, to say, Do we
3 want those valves to fail open; they protect the equipment,
4 but they do some other things. It will be part of our
5 follow-up review.

6 MR. ROSENTHAL: While it looked like, when you
7 opened up the dump off the feedwater pumps, you just run
8 back on the curve a little bit more. At least that's what
9 the first shot was.

10 It wasn't clear in our minds for a few days about
11 whether you had a monitored release. We knew that you had
12 the area rad monitors. We knew that you had lost GEMS. I
13 think that we now have it resolved that you did have a stack
14 monitor on one of the safety divisions from the stack.

15 MR. McCORMICK: Yes.

16 MR. ROSENTHAL: People running around are really
17 taking particulate samples rather than gaseous effluent that
18 goes up the stack, so I think that it's very good that you
19 had it. I don't know that the people who were running the
20 plant at the time knew that they knew that they had it, and,
21 when you put the hoppers on, if they understood that they
22 still had a monitored release, as distinct from -- I mean,
23 they had lots of other indicators -- you know, the high-rad
24 alarms, the area monitors, et cetera -- to believe that they
25 weren't having a release, but I don't know about



1 specifically monitoring the stack, because your general
2 knowledge would say, Hey, that's off the GEMS system, which
3 is down. That's like knowledge-based performance.

4 MR. ABBOTT: My understanding is that we had a
5 chem tech at the stack; he was able to read locally the
6 stack GEMS output at the skid out at the stack, and he was
7 placed there intentionally and in communication with the
8 control room prior to the starting of the hoppers, the
9 mechanical vacuum pumps. That was a pre-planned evolution.

10 MR. ROSENTHAL: Fantastic.

11 MR. ABBOTT: If you need more than that, I'm sure
12 I could get you some more.

13 MR. ROSENTHAL: We know that now. Okay. By the
14 hour I'm learning. Okay.

15 In terms of the report that I intend to right, I
16 really pretty much plan to stick to the event and not all
17 these peripheral issues, as distinct from communicating some
18 of the stuff to Region I.

19 What else?

20 Okay. There's a general area that I just wanted
21 to mention to you. That is that it seems to us that, for
22 the feedwater condensate system and the UPS, as examples,
23 they are really using startup procedures to do what is
24 essentially a restoration task.

25 There may be a million ways that it goes down, so



1 I'm not quite sure how to do it, but it's something that it
2 may be very appropriate to think of. I don't think the UPS
3 goes out on you all the time, but restoring feedwater
4 shouldn't be that unusual -- I think from hot conditions
5 rather than from cold.

6 MR. SYLVIA: Are there some features of a startup
7 test procedure that didn't apply, or you just don't think
8 we're calling it the right thing?

9 MR. ROSENTHAL: Well, I don't know that you would
10 have necessarily wanted to close MOV-84 in the first place,
11 and then have to reopen it, but I don't know that.

12 MR. ABBOTT: What he's talking about is, system
13 startup procedures inside the FOPs presume that the system
14 has been shut down and idle for some plant maintenance.

15 MR. SYLVIA: Right.

16 MR. ABBOTT: We were using sections like these for
17 the UPS and feedwater, to restore it, in this time frame.
18 The procedures don't have a restoration section in them.


19 MR. SYLVIA: The initial conditions are different.

20 MR. ABBOTT: Yes.

21 MR. ROSENTHAL: The problem there, I recognize, is
22 that it becomes almost an infinite set.

23 MR. SYLVIA: Right. That's the problem.

24 MR. McCORMICK: We have to make some judgement,
25 and we'll look at that to see, bound it a little bit, but



1 the dilemma is, if I write it for this emergency, it isn't
2 the emergency I have, any more than the one that says, I
3 know how to start the equipment, so, if I have an emergency,
4 I should know how to operate to contend with the emergency.
5 I mean, it's, where do you go with that. We'll look at
6 that.

7 MR. SYLVIA: I understand what you're getting at.

8 MR. ROSENTHAL: We flipped it to what went
9 right -- We had symptom-oriented emergency procedures,
10 followed the procedures. You had put in the post-accident
11 monitoring system, and I guess in terms of pressure and
12 level that's what you were down to, but it was there, and
13 there are two of them. I mean, there are lessons learned
14 from prior events that were learned here. The operators
15 clearly coped, and I said things like that at this press
16 conference.

17 There are ways of looking at this event in terms
18 of it also being the success, in terms of having put in
19 systems, which were then used to cope -- half full, half
20 empty.


21 Let me give the floor to you.

22 [Pause.]

23 MR. SYLVIA: Are you through, Jack?

24 MR. ROSENTHAL: Yes.

25 MR. SYLVIA: The main thing I'd like to say is



1 that we've tried to give you everything you need. If you
2 get back to White Flint and you need anything else, we'll be
3 happy to give you whatever you need. As new developments
4 come up, we will make the point to share those with you,
5 because I think there are a lot of things yet that we don't
6 know. As I mentioned to you, I'm not at all satisfied that
7 we know exactly what tripped the UPS's or how they tripped.
8 We still want to do more to try to find out.

9 I think, as far as anything that we know, you
10 know, and vice versa, but if there's something that you may
11 not know that we discover, we will share that with you, too.

12 MR. ROSENTHAL: Good.

13 I need a point of contact for this document flow.

14 MS. SIEGEL: We've got it, Jack.

15 MR. ROSENTHAL: We have it.

16 [Pause.]

17 MR. ROSENTHAL: Our plan would be to fax up a
18 list, rather than doing it over the phone, and do it in a
19 more systematic fashion, because I know it was pretty
20 diverse early on.

21 I think that's it.

22 MR. JORDAN: Your report, when can we expect that?

23 MR. McCORMICK: The report of the team that
24 reviewed the event?

25 MR. JORDAN: Yes.



1 MR. McCORMICK: I would say that we should have
2 that in a reasonable form to pass on by the end of the week.
3 This is the summary. We'll be going to the region tomorrow,
4 and much of that detail will be included in that. We'll get
5 that to you post haste.

6 It's still being put in final form, as we speak.
7 We of course reviewed all the incidents typical of a scram.
8 What we're doing would be part of the routine before we
9 would return the plant to service, so we identify those
10 things which were anomalies in the scram. They have to be
11 cleared, understood, approved by SORC, and then justified so
12 we can go back. That process is under way, and it's part of
13 the evolution of this report.

14 I think in that process we've covered all the
15 items which we have shared from your review, along with our
16 own.

17 [Pause.]

18 MR. ROSENTHAL: Meeting adjourned.

19 MR. SYLVIA: Thank you.

20 MR. ROSENTHAL: Thank you.

21 [Whereupon, at 4:00 p.m., the meeting was
22 concluded.]

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: IIT Exit Meeting

DOCKET NUMBER:

PLACE OF PROCEEDING: Scriba, New York

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



MARK HANDY

Official Reporter

Ann Riley & Associates, Ltd.

