

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Incident Investigation Team

Title: Interview of Bob Jones


Docket No.

LOCATION: Bethesda, Maryland

DATE: Friday, August 30, 1991 PAGES: 1 - 29

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950




ADDENDUM

Page      Line      Correction and Reason for Correction

Do not wish  
To Review  
9/23/91 - Telephone call  
To Karahelm

Date \_\_\_\_\_ Signature \_\_\_\_\_

5-2



UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

INTERVIEW OF )  
 )  
BOB JONES )  
 )

Nuclear Regulatory Commission  
The Woodmont Building  
8120 Woodmont Avenue  
Bethesda, Maryland

Friday, August 30, 1991

The above-entitled interview convened, pursuant to  
notice, in closed session at 2:05 p.m.

PARTICIPANTS:

JOHN KAUFFMAN, NRC/IIT Team  
WALTER JENSEN, NRC/IIT Team

1 - 2



## P R O C E E D I N G S

1  
2 MR. KAUFFMAN: It is August 30th, 1991, at  
3 approximately 2:05 in the afternoon. We're in the Woodmont  
4 Building, Bethesda, Maryland, conducting an interview of Bob  
5 Jones as part of our incident investigation of a Nine Mile  
6 Point Unit 2 event of August 13th, 1991.

7 I'm John Kauffman out of NRC Headquarters, AEOD.


8 MR. JENSEN: I'm Walt Jensen out of NRC  
9 Headquarters, plant assessment branch.

10 MR. JONES: I am Bob Jones, chief of the reactor  
11 systems branch.

12 MR. KAUFFMAN: Bob, at this time will you tell us  
13 a little bit about your previous background and work  
14 experience and education?

15 MR. JONES: I graduated from the Pennsylvania  
16 State University with a bachelors of science in nuclear  
17 engineering in 1971. From there I went on to the Babcock  
18 and Wilcox Company in Lynchburg, Virginia, where I worked  
19 until October of 1983, culminating my career there as the  
20 unit manager of the transient and accident analysis section.

21 I came to NRC in October of '83 in the reactor  
22 systems branch as an engineer, have progressed through three  
23 organizations or reorganizations to become now the chief of  
24 the reactor systems branch in the division of systems  
25 technology and I've been in that position for approximately





1 two years.

2 MR. JENSEN: Okay, Bob. Can you tell us about any  
3 involvement you've had in the review of the Nine Mile 2  
4 event of August 13th?

5 MR. JONES: I have had no involvement in the Nine  
6 Mile 2 event of August 13th other than seeing the morning  
7 reports that come out and those types of general items.

8 MR. JENSEN: Okay, and you've have had no  
9 involvement in the original licensing of Nine Mile 2?

10 MR. JONES: That's correct.

11 MR. JENSEN: What about the review of the  
12 instrumentation that's included on Reg Guide 1.97, the  
13 instrumentation that's important to diagnosing severe  
14 accidents?

15 MR. JONES: I don't remember anything specifically  
16 for Nine Mile 2 in the last few years. About the only item  
17 that's come that would be arguably applicable to Nine Mile 2  
18 would be neutron flux monitoring instrumentation which the  
19 BWR owners group appealed within the last -- I'm not sure  
20 exactly when this came in but we went through an appeal  
21 process on that, both my branch and the instrumentation and  
22 control system branch reviewed and prepared material for the  
23 appeal process.

24 MR. KAUFFMAN: And what was that issue?

25 MR. JONES: The basic issue was, as I try to



1 paraphrase it, when Reg Guide 1.97 was issued one of the  
2 instrumentation items that was listed to be safety grade  
3 class one or category one instrumentation for Reg Guide 1.97  
4 -- I'm not that familiar with the categorizations but the  
5 highest level of instrumentation. That's an instrumentation  
6 issue.

7           That instrumentation, one of them was the neutron  
8 flux monitoring instrumentation and part of that included  
9 capability to detect neutron flux down to one times ten to  
10 the minus six count, one times ten to the minus six power  
11 range, need to be environmentally qualified and such items  
12 as that.

13           As just generically as instrumentation came  
14 through on the Reg Guide 1.97 for the boilers, it was  
15 recognized that there was no qualified neutron flux  
16 monitoring instrument generically available.

17           As a result, essentially all of the SERs that were  
18 issued blessed the adequacy of the existing instrumentation  
19 that was in the plants with a statement that should such  
20 instrumentation become available or they were to continue to  
21 pursue the development of such instrumentation capability  
22 and then would subsequently place that in their plants.

23           The owners group appeal basically came about  
24 because such instrumentation has become available in recent  
25 years by two companies and we were starting to impose that



1 back on the industry, the GE industry, the boilers, to start  
2 pursuing that, putting in that instrumentation and they were  
3 arguing that the existing instrumentation was effective.

4 We put together arguments for our management on  
5 it. It was a very tough issue to resolve because you do  
6 have flux monitoring instrumentation. The biggest issue was  
7 what do you qualify it to.


8 We went through the appeal process and the  
9 director issued a decision which was that they did not need  
10 to upgrade such instrumentation, that the instrumentation in  
11 place was adequate, that the current source ranges were at  
12 normal power.

13 MR. KAUFFMAN: Were adequate or could be backfit  
14 justified or --

15 MR. JONES: That it was adequate for Reg Guide  
16 1.97 purposes and we were given directions for future plants  
17 to have them use such instrumentation.

18 We are still working through the mechanics of how  
19 to implement the director's decision because there is some  
20 guidance that we have to put together about severe accident  
21 mitigation and following severe accidents, core melt type  
22 events or accident management issues.

23 MR. JENSEN: Was the issue more as to whether the  
24 environmental qualification of the instrument or as to the  
25 quality of the power supply?



1           MR. JONES: It was a combination, I believe.  
2 There were arguments made about the environmental  
3 qualifications of the instrument, but one of the issues was  
4 the power supply because you have to drive in, at least  
5 generically in most boilers, the SRMs into the core using  
6 your -- because they were retractable so you would have to  
7 drive them in so therefore you had an electrical power  
8 supply issue as one of the issues.

9           MR. JENSEN: Do you know which nuclear  
10 instrumentation is supplied with vital power as opposed to  
11 that which is supplied with control grade power?

12           MR. JONES: I believe it's the APRMs, which is  
13 some combination of the LPRMs, so those must also have some  
14 -- I'm not sure about the classification of those but the  
15 APRMs must be because they provide trip signals for the  
16 reactor. I'm not that well versed in the power supply  
17 issues.

18           MR. JENSEN: What about the rod position  
19 indication? Was there any discussion over whether or not  
20 the rod position indication should be supplied with vital  
21 power?

22           MR. JONES: That was one of the arguments as I  
23 remember it in the owners group appeal, that you had that  
24 available to you generally speaking to monitor whether or  
25 not the rods were -- one of the issues was to use the reed





1 switches for the rod position indicators.

2           Again, when we put together our arguments, we  
3 recognized that it was a qualified safety grade type  
4 instrumentation, a recognized position but, as I said, we  
5 lost our appeal.

6           We argued to upgrade and when we went through the  
7 appeal process and we revisited the issue, we continued to  
8 push to upgrade the instrumentation.


9           MR. JENSEN: Did that include the rod position  
10 instrumentation for vital power as well as --

11           MR. JONES: No, we did not. We were looking at  
12 it primarily from the standpoint of just putting in the  
13 available instruments which were on the street, which were  
14 the Gammametrics in-core system and somebody had an ex-core  
15 system. We were not looking at specifically upgrading the  
16 position indication system.

17           MR. JENSEN: In the EOPs, one of the vital safety  
18 functions is to have the reactor shut down.

19           Do you remember which -- what kinds of  
20 instrumentation are required to assure reactor safe  
21 shutdown, the neutrons being absorbed?

22           MR. JONES: Well, you would have the APRMs, LPRMs  
23 go off scale, down scale. You would then drive in your  
24 SRMs. You would monitor through that whether or not you were  
25 at decay. You would also have your reed switches for your



1 rods, whether they were in or not. You would look at those  
2 indications. If they were bottomed out you would push them  
3 in, so to speak.

4 MR. KAUFFMAN: May I interrupt?

5 MR. JENSEN: Sure.

6 MR. KAUFFMAN: How would you feel if I said I had  
7 an event where I lost my reed switches, I lost my rod  
8 minimizer, I lost my rod sequence control system indications  
9 on rods and I couldn't tell the position of control rods  
10 although I did have APRM flux indication.

11 Would you think that's a significant event or  
12 would you say that's something that's covered by our guide -  
13 - our guidance recognized that that might happen and that's  
14 okay, or would you say that's reason to go back and  
15 reconsider our decision on upgrading our detectors and maybe  
16 making safety grade some of these power supplies?

17 MR. JONES: My reaction is one of I would feel  
18 uncomfortable in such a situation. I clearly would like to  
19 know that the reactor is fully shut down and be able to  
20 monitor it.

21 There are varied ways you could operate so I'm not  
22 sure whether I would say you would necessarily have to go  
23 back and look at it from the Reg Guide 1.97 point of view we  
24 were using when we looked at the appeal because we were  
25 looking for full-range environmental qualified for LOCA and



1 non LOCA transients, et cetera, going to a fairly extensive  
2 upgrade of the monitoring capability.

3 Arguably, you could upgrade power supplies, for  
4 example,, through reed switches would be one way of taking  
5 care of that.

6 MR. KAUFFMAN: Do you think that would be a hard  
7 fix, an expensive fix, or is that something that you think  
8 would be easy to do? I don't know, that's why --


9 MR. JONES: I don't know, either, and I would  
10 suggest you ask an instrumentation type on that.

11 Again, I think there are various options available  
12 to you. There are fixed core neutron systems, for example,  
13 that you could put in as one possibility, fixed core source  
14 range system which is similar to what we are looking at as  
15 one of the systems for the upgrade of the flux monitoring  
16 system. Limited capability there could be of use. What its  
17 relative cost is, I don't know.

18 MR. KAUFFMAN: I'm not familiar with what fixed  
19 core means.

20 MR. JONES: Unlike the APRMs which are in-core and  
21 stay in-core at all kinds, unlike the SRMs which are  
22 inserted and withdrawn. One of the neutron flux systems  
23 which we're looking at was a fixed in-core system. There  
24 are probably various ways of getting such information.

25 MR. JENSEN: So under the condition that the APRMs




1 and the LPRMs were both indicating that reactor power had  
2 been shut down but control rod indication was not available  
3 or indicated that some or all of the rods may be still out  
4 of the core, should an operator go to his ATWS EOPs or  
5 should he believe his nuclear instrumentation and believe  
6 the reactor is shut down, being that the nuclear information  
7 may be safety grade and the rod position --

8 MR. KAUFFMAN: Also considering you may be shut  
9 down now but if you cool down on Xenon fills in and burns  
10 out you may get positive reactivity.

11 MR. JONES: I'm not sure what you get necessarily  
12 by going to the ATWS procedures. One of the problems you  
13 end up with in the ATWS procedures which basically I think  
14 asks do you inject SLCS -- standby liquid control system --  
15 which is really what you're looking for when you go to the  
16 ATWS procedure and initiate a short shutdown.

17 The ATWS procedures do not necessarily require you  
18 to initiate SLCS, depending on whether you are isolated or  
19 not isolated event. If you haven't isolated during this  
20 IVs, for example, then you would not be injecting SLCS and  
21 I'm not sure what the circumstances were at Nine Mile.

22 So if you went to the ATWS procedures, depending  
23 on the circumstances of the event, you may or may not -- it  
24 may or may not have helped you. You're not coming up  
25 tomorrow so cleanup is not a problem.






1           MR. KAUFFMAN: We may revisit that but at Nine  
2 Mile they did not get to their SLCS injection criteria which  
3 comes up suppression full temperature. They got hung up in  
4 the loop on procedure telling them to stay where they are,  
5 not depressurize and in the meantime they have to maintain  
6 level, they're running RCIC so they are depressurizing.

7           They basically got into one step said don't  
8 depressurize, the other one said if you can stay shut down  
9 while you're depressurizing then you can depressurize and  
10 there were some contradictions and some confusions in the  
11 EOPs so we're going to want to talk about EOPs.

12           We can start that now just generally on what your  
13 branch, what your involvement is in EOPs.

14           MR. JONES: Generally in the EOPs, and I'll go  
15 back a step.

16           We start at the EPGs or the emergency procedure  
17 guideline stage, which is the generic stage, the vendor  
18 generic guidelines, and we would review technically those  
19 procedures, the analyses that form the basis for those  
20 procedures and in conjunction with other branches would look  
21 at the overall accident mitigation strategies and approach  
22 steps, appropriateness of the steps to assure that it could  
23 deal with wide contingencies, wide range of events that we  
24 could postulate, and that means not just the standard design  
25 basis but also beyond design basis multiple failure events.



1           Typically, the branch we interface with especially  
2 on the boilers would be the plant systems branch which is  
3 the containment functions so we're very heavily intertwined  
4 with them.

5           We have overall control of that review. That is,  
6 we have the lead role.

7           Now from there, in the implementation and the  
8 EOPs, our role diminishes. The process to turn them into  
9 EOPs is each utility has their own plant specific technical  
10 guidelines and other processes, writers guides, et cetera,  
11 that they go through to develop their own EOPs, which  
12 accounts for the plant-unique conditions and such.

13           We get involved at times in deviations taken from  
14 the generic guidelines to come up with the plant-specific  
15 procedures. That would come about when we would have either  
16 an EOP inspection, which we may or may not be involved in  
17 that inspection program. We've done so with the boilers, I  
18 don't remember which ones anymore. We went through a few of  
19 them. We did not go on all of them but we have been  
20 involved in EOP deviations which have popped out of several  
21 of those reviews.

22           MR. JENSEN: Would the generic EOPs that you  
23 reviewed be specific enough to tell the operator as to  
24 whether he's allowed to cool the plant down without rod  
25 position indication, or require him to inject boron before




1 he cooled down? Would they give general guidance?

2 MR. JONES: It's difficult for me to answer that  
3 on the specifics on the rod position indication. I would  
4 say that generally though I know there are lots of steps  
5 within the guidelines and I don't know the ins and outs and  
6 all the details of the boiler guidelines but I know there  
7 are several areas in the boiler guidelines where you look at  
8 things like is the reactor shut down, do you believe you  
9 will maintain it shut down as you go through with  
10 depressurization, those kinds of steps are in the guidelines  
11 and have been discussed in our SERs.

12 Whether it specifically says by rod position  
13 indicators, I'm not sure it gets necessarily that specific,  
14 but it will probably lay out a series of options available  
15 to you, by rod positions or by flux or by this or by that so  
16 they will lay out several options and each utility can use a  
17 combination thereof.

18 MR. JENSEN: So it would be up to the utility to  
19 decide which instrumentation he would use to determine  
20 whether he would shut down the nuclear reaction or not and  
21 cold cool safely down to cold shutdown?

22 MR. JONES: I would say generally he would already  
23 have known probably through the guidelines which  
24 instrumentation should be used because there is a lot of  
25 that that we do specify or that we do look at.



1 I would have to go back and look to see in  
2 specific cases or steps whether or not it's identified but  
3 generally speaking there is a priority in many of the steps  
4 in the guidelines and I would expect to find the guidelines  
5 would say he would use this or this and go right down the  
6 list and it's usually not an either/or, it's usually all of  
7 them to account for contingencies if things are not  
8 available. Specific, I'm not sure I would expect it to be  
9 there.


10 MR. JENSEN: Is there any inference in certain EOP  
11 steps as to requiring safety grade or class 1-E  
12 instrumentation be utilized?

13 MR. JONES: Not that I'm aware of. Not that we  
14 would only require use of class one, no.

15 MR. JENSEN: Well, is there any inference that  
16 class 1-E instrumentation be used for any steps in the EOPs?

17 MR. JONES: I would say no. Generally the EOPs or  
18 EPGs are much broader. It uses all available  
19 instrumentation. It uses all available systems to respond  
20 so I would not expect it to necessarily make the  
21 distinction.

22 What I would expect to find, and part of the  
23 reason I say this is because we're involved in a similar  
24 issue on another plant, is the consideration of  
25 instrumentation accuracies in various environments, for





1 example, when you implement the procedures.

2 So I would expect that there would be some  
3 distinction in the development of that kind of information  
4 as to what is qualified, what isn't, what you may have to be  
5 careful with using in certain environmental conditions that  
6 that would be covered in training.

7 There is also usually a general -- you have to  
8 crosscheck instrumentation and never rely on one single  
9 piece of instrumentation to make a decision.


10 MR. JENSEN: Are there decisions so important that  
11 the operator should make in the EOPs that it would require  
12 instrumentation providing class 1-E power?

13 MR. JONES: Not that I can say right off the bat  
14 yes or no. I would rather take the following premise.

15 The operator should have enough instrumentation to  
16 follow the course of an accident based on 1-E power  
17 consistent with the Reg Guide 1.97 approach, that he has  
18 enough instrumentation, safety grade type instrumentation,  
19 available to monitor the course of an accident.

20 If he is ever to that situation, I expect it would  
21 not be ideal, anyway, if he's just down to the safety grade  
22 instrumentation and displays.

23 Clearly one of the reasons for development of Reg  
24 Guide 1.97 was to develop safety functions and assure that  
25 there would be safety grade available instrumentation for



1 the operator for monitoring the course of an accident. That  
2 is how you get your highest level of instrumentation and  
3 that is why I understand it's also referred to in the  
4 equipment qualification rule, 50.49, as being required to be  
5 qualified.

6 MR. JENSEN: How significant is the safety  
7 parameter display system, the SPDS, in the EOPs?


8 MR. JONES: Let me back up and make sure when I  
9 answer these questions on EOPs I want it clear that I can't  
10 answer from a Nine Mile 2 EOP.

11 MR. JENSEN: Sure.

12 MR. JONES: In fact, not even anybody's EOP. I  
13 would rather answer from an EPG perspective.

14 MR. JENSEN: Okay.

15 MR. JONES: So that's clear. The safety  
16 parameter display system is an operator aid. It is not  
17 safety grade and its reliability targets, as I understand  
18 it, clearly we place importance on the SPDS as an agency, I  
19 would say, given how the thing is put together, but I'm not  
20 sure from an EOP perspective that the SPDS is specifically  
21 called out in a way that makes it particularly important  
22 because there are various levels or differences in SPDS  
23 designs across the industry so it would be difficult in a  
24 generic guideline to call that out other than to talk about  
25 the functions and general instrumentation.



1 MR. KAUFFMAN: You call SPDS an operator aid. If  
2 SPDS is lost, how big of an impact do you think it would  
3 have, say, in an emergency with technical support centers  
4 EOPs and their ability to gather information?

5 MR. JONES: I don't know. That's beyond my scope.  
6 To the extent that it's tied to an SPDS, obviously  
7 significantly.

8 To the operator running the plant, assuming he  
9 hasn't lost all his control board instrumentation, which is  
10 my understanding of Nine Mile, under that circumstance  
11 arguably he should have enough information otherwise.

12 I mean there are ties with the SPDS which clearly  
13 you could say that has a bearing on the ability of other  
14 functions to perform if it's tied to it and it's lost.

15 MR. KAUFFMAN: Do you know how it was decided that  
16 SPDS wouldn't be safety grade, wouldn't be 1-E powered?


17 MR. JONES: No, beyond my -- That was before my  
18 time at the agency.

19 MR. KAUFFMAN: Do you know who was involved in  
20 that decision?

21 MR. JONES: No.

22 MR. JENSEN: It seems like the operators and the  
23 BWRs are very hesitant to inject boric acid into the SLCS  
24 system in the core.

25 Do you know of any safety problems or operational



1 problems that suggest boric acid played out in the core that  
2 might occur from boric acid injection subsequent boiling?

3 MR. JONES: No, I'm not aware of any particular  
4 reasons why you should not be able to inject SLCS. In fact,  
5 as I remember discussions we've had with the BWR owners  
6 group concerning ATWS mitigation recently.

7 One of the options that we were looking at related  
8 to the so-called stability issue, is earlier injection of  
9 SLCS for such transients -- that was transients with  
10 oscillations.


11 One of our questions very early on over the last  
12 two years of involvement on this was why can't you inject it  
13 earlier and we have never been given a good reason that  
14 sticks in my mind that says it's a bad thing to do.

15 Obviously it has cleanup implications and that's  
16 the only thing I have ever heard.

17 I'm sure there are some chemical issues that would  
18 need to be addressed from a material standpoint but at this  
19 point nobody has given me any good reason not to.

20 MR. JENSEN: To what extent is the RSB branch  
21 reviewing emergency procedures at this time or emergency  
22 guidelines?

23 MR. JONES: With respect to the boilers, we are  
24 effectively done for Rev.4 of the guidelines, and in fact we  
25 have taken the position that we are absolutely finished with





1 the boiler guidelines with respect to normal transient and  
2 accident mitigation and we are letting the industry carry  
3 forth from there.

4 With respect to accident management or extension  
5 into the severe accident area, we have kept our foot in the  
6 door and we have said when those happen we want to review it  
7 again.

8 However, we do get involved, as I've noted  
9 earlier, with plant-specific exceptions to the guidelines.  
10 We're involved in issues at WNP-2 right now. We've done  
11 some EOP issues at one of the Millstone units in the recent  
12 past.

13 We also have had ongoing discussions over the last  
14 two years with respect to some deviations, particularly ATWS  
15 deviation, taken by Susquehanna relative to the owners  
16 group, primarily related to whether or not you need to lower  
17 water level during an ATWS event.

18 We are also involved with ongoing discussions with  
19 the owners group related to implementation of the EPGs vis-  
20 a-vis the design basis of the plant because the EOPs and  
21 EPGs as written in such a broad-brush treatment of accident  
22 strategy for the entire fleet of BWRs makes it difficult to  
23 say whether following these steps assure you meet your  
24 design basis and we've asked them to review that as part of  
25 the implementation.



1           This has formed up with a few problems that we're  
2 still discussing and we don't have a resolution path yet on  
3 some of those.

4           Last has been the issue of ATWS instability which  
5 I mentioned earlier and the fix that is likely to come out  
6 of that issue will be a procedurally PG modification. That  
7 is not a resolved issue but we have had discussions as to  
8 the types of changes that may be made.

9           Although we said we're close, we still have a lot  
10 of work that we do in the area.


11           MR. KAUFFMAN: Are you expending any efforts  
12 toward the advance of BWR and looking at EPGs for those or  
13 is that just too far away?

14           MR. JONES: I'm trying -- I don't remember right  
15 now whether we have them or we've asked the question on  
16 them. We are going to do it so it's just a matter of I'm  
17 not sure where it is in the process, but clearly one of the  
18 steps is we are going to look at the EPGs for the ABWR as  
19 part of the licensing effort. I'm just not sure where it is  
20 right now.

21           MR. JENSEN: I believe you mentioned the issue of  
22 ATWS stability. I'm not sure I understand what that is.

23           MR. JONES: I was hoping you wouldn't ask that.

24           If you are aware of the LaSalle event of '87, '88,  
25 somewhere in there.



1 MR. KAUFFMAN: March 1988.

2 MR. JONES: That's where you get neutron flux  
3 instabilities, where you have large power oscillations due  
4 to void collapse and development. It's a thermal hydraulic  
5 instability.

6 Basically cold water comes in, gives you a  
7 reactivity surge, then you create a void which shuts it  
8 down, the cold water comes back in. It's a thermal  
9 hydraulic instability which feeds back to the nuclear  
10 calculations.

11 Similar things can happen in ATWS and the issue is  
12 what -- it appears to be mostly dominated by system effects.

13 The other is primarily dominated by core design,  
14 that is, pressure drops across the core, two-phase pressure  
15 drops, single-phase pressure drops in that relationship.

16 In ATWS what seems to really give you a large  
17 power oscillation is cold water insertion, so if you isolate  
18 it and have cold feedwater coming in because you've isolated  
19 the steam, extraction steam, and you're trying to maintain  
20 level in the vessel and now you get very cold water in you  
21 get power spikes. We have seen numbers as high as 3500  
22 percent.

23 MR. KAUFFMAN: Walt, there's a large industry  
24 effort in the owners group in Brookhaven looking into this.

25 MR. JENSEN: What would the operator's response



1 be? Would it be to inject boric acid with the SLCS system?

2 MR. JONES: What we're looking at right now is --

3 As I mentioned earlier, there are basically two --

4 When you talk ATWS procedures and SLCS injection,  
5 you really start looking at two classes of ATWS. You look  
6 at the class of ATWS where you isolate the vessel which  
7 leads to a heatup of the suppression pool which leads you  
8 into SLCS actuation and leads you into lowering vessel water  
9 level.

10 There's the other class of ATWS and there is also  
11 the preferred ATWS mitigation scheme which is to simply dump  
12 steam to the condenser, an unisolated ATWS, and that's the  
13 one that can come back and feed back through the system with  
14 cold feedwater.

15 What we're talking about is -- I don't want to  
16 call it a simplification of the procedures but in my mind it  
17 is in the sense that what we do is you have an ATWS,  
18 isolated or unisolated, you would basically hit the SLCS  
19 system, the boron injection, early and then you would deal  
20 with the issue of do you still lower power level or not is  
21 still one of the fuzzy areas.

22 We will probably in coupling it with the  
23 oscillation issue would be you get indications that your  
24 oscillator is not shutting down you might start lowering the  
25 water level early.





1 MR. JENSEN: What will you do -- suppose you were  
2 an operator at Nine Mile 2 and the reactor had tripped and  
3 the neutron instrumentation indicated that the reactor was  
4 so critical and had no rod position indication, how long  
5 would you set at hot standby before you cooled down?

6 Would you inject boric acid before you cooled  
7 down? What would you do?

8 MR. KAUFFMAN: We are talking strategies here,  
9 obviously, not plant-specific.

10 MR. JONES: I understand that.

11 That was really in a sense part of what the  
12 position was in this owners group neutron flux monitoring  
13 thing. They would basically say you don't need to bother.  
14 You don't need to inject SLCS. You can shut down. You've  
15 got adequate rods in and if you shut down and try to come  
16 down the appropriate decay --

17 You seemed to imply in your question that you had  
18 neutron flux monitoring. If you have ---

19 MR. KAUFFMAN: The APRMs, LPRMs, were  
20 depressurizing.

21 MR. JONES: But I don't know how far and whether  
22 you continue and follow the decay -- Your LPRMs are going  
23 to drop off scale fairly fast and the transients, you don't  
24 know where they are, arguably.

25 Gut reaction is I would inject SLCS. That's my



1 reaction to it.

2 MR. JENSEN: One concern if you cool down and  
3 maybe you were subcritical but if you cool down then you  
4 might go critical because in the cooldown perhaps all of the  
5 rods weren't inserted or only partially inserted.

6 MR. JONES: If you have feedwater and you have  
7 level control and all that happened was you just came back  
8 up on power with your turbine available to dump steam in  
9 your condenser, you just sit there and no big deal.

10 It's a very difficult call to make because if you  
11 look at it from certain eyes you could say the plant just  
12 sits there and you sit at power level and then you ask  
13 yourself what do I do from here and if you really want to  
14 get down at that point, you know you're not fully shut down,  
15 your rods are not fully in because that should not be  
16 happening to you and that could be a good enough indication  
17 to go back and inject SLCS at that point.

18 MR. JENSEN: But if you did go critical, it  
19 wouldn't be a major safety problem?

20 MR. JONES: I don't believe it would be a major  
21 safety problem. The boiler is inherently -- from that  
22 sense, they appear to be inherently safe.

23 As I said, my reaction is I would prefer to inject  
24 SLCS but that's a very personal reaction.

25 MR. KAUFFMAN: Walt is assuming that when you



1 depressurized you had control of your condensate booster  
2 system, for example.

3 MR. JONES: So you should just stabilize out.  
4 From a pure safety standpoint it's not clear that anything  
5 is actually necessary.

6 MR. JENSEN: So an operator just might choose to  
7 cool down and if it did go critical he might wait and inject  
8 the boric acid then.

9 MR. JONES: That's correct, and that would clearly  
10 be, I think, through the procedures what he would then be  
11 directed to do because he is obviously not shut down.

12 MR. JENSEN: In your recent review of the GE EOPs,  
13 what other branches did RSB work with and interface with?

14 MR. JONES: Clearly plant systems. I am sure we  
15 worked somewhat with the human factors people but only --  
16 not to a very large extent I'm sure because a lot of human  
17 factors issues have already been addressed in the earlier  
18 reviews. We may have touched base with instrumentation and  
19 control.

20 Again, you drew a rev of the report which was a  
21 fairly -- Well, it's a fairly major modification and a few  
22 of the strategies but it was mostly dealing with very  
23 specific items so the nature of the review is different that  
24 if you were starting from scratch.

25 We were looking primarily at things like



1 containment flooding as opposed to core spray as a final  
2 accident mitigation step, level control and venting the  
3 containment and a lot of that stuff was a lot of the  
4 emphasis in Rev 4.

5 MR. JENSEN: What kind of things did  
6 instrumentation and control branch look at?

7 MR. JONES: I don't remember. I'm not sure we  
8 interfaced very extensively with them except we probably if  
9 anything just touched on it.

10 MR. KAUFFMAN: I'm going to try this question. It  
11 might be too hard to answer but I'm going to try it.

12 Could you run me through the differences between  
13 the BWR EPG Revs 0 through 4 of the evolution and why those  
14 changes were made? If that's too hard --

15 MR. JONES: I can absolutely not do that because I  
16 am not that familiar with the early revisions at all. That  
17 was before my time.

18 MR. KAUFFMAN: It's a nagging question I have, are  
19 these just small refinements or are they major improvements  
20 as they have gone along.

21 MR. JONES: I can't speak for earlier. I can  
22 speak Rev 3 and Rev 4 and my expectations are Rev 0 and Rev  
23 1 a lot of that is likely to be upgrade in response to staff  
24 questions, comments or open items, which was common for many  
25 of the emergency procedure guidelines we looked at in that





1 stage of their life.

2           Between Rev 3 and Rev 4 there were some very  
3 significant things that were changed. Containment venting  
4 is one of them. It's a much more detailed treatment of  
5 containment venting in the why and the when and how you  
6 calculate the various limits that you need to impose, et  
7 cetera.

8           Another big deviation step was there was a  
9 reliance in the old EPG on core spray. If you uncovered the  
10 core but you could maintain the core level at about two-  
11 thirds core height you would continue -- if you had spray  
12 available to you, you would just sit in that mode and cool  
13 in that fashion.

14           Rev 4, if you're in that mode and you're down to  
15 one pump, from a reliability standpoint if you're really  
16 down to one pump you are probably in pretty fairly strange  
17 territory and I'm not sure you know the reliability of your  
18 system as a whole any more so at that point you take so  
19 steps to start flooding containment so the ultimate path  
20 then, instead of cooling mode, would be in containment -- be  
21 in core spray or spray cooling as a whole different strategy  
22 of flooding and flooding has other implications associated  
23 with it. You have to vent the flood but it is much more  
24 stable and assured.

25           That's a fairly major change. There are some



1 minor rearrangements of a few cautions or elimination of a  
2 few cautions which were not considered significant. Those  
3 are probably the major changes.


4 MR. JENSEN: As far as your branch looks at PWR  
5 EOPs, as well as BWR EOPs, I wonder if you know of any  
6 significant difference in philosophy that operators could  
7 use in entering the ATWS procedures as far as indication  
8 that an ATWS had occurred between the EOPs for PWRs and  
9 BWRs.

10 MR. JONES: Actually I would say there are a  
11 couple of differences. Number one, there is obviously no  
12 distinction between a nonisolated and isolated ATWS in a  
13 PWR. An ATWS is an ATWS is an ATWS. There is no deviation  
14 associated with the actions due to other system conditions.

15 Generally speaking, the PWR, if you have  
16 indications that you're not shut down, you start injecting  
17 your boron systems. Well, your drive rods first and inject  
18 boron and that type of stuff, but it's pretty much a fairly  
19 immediate step to confirm the shutdown reactor and take  
20 those actions.

21 From an indication standpoint, other than the type  
22 of instrumentation that you may be using, it's very similar,  
23 position indicators or rod bottom lights, same thing, you're  
24 talking neutron flux monitoring instrumentation, etc cetera.

25 To the best of my knowledge, all of the Ps have



1 qualified neutron flux monitoring systems down to the ten to  
2 the minus six type range so from that standpoint they should  
3 be in better shape as a whole from the monitoring  
4 standpoint.

5 I think there is a very clear recognition that in  
6 a boiler you're talking a machine that doesn't really have  
7 tremendous reactivity type problems inherently because of  
8 the way feedback, et cetera, the rods go in and you actually  
9 go subcritical on rods in a boiler.

10 That's not true in a PWR, period. A PWR is not  
11 inherently shut down just because the rods are in so you  
12 have to inject boron, for example, before you depressurize  
13 so I think there's more sensitivity to that issue from that  
14 standpoint.

15 I think there are -- From a pure indication  
16 standpoint the distinctions are small. I think there is a  
17 level of sensitivity that's much higher and the quality of  
18 the instrumentation is different and certainly the actions  
19 are arguably simplified because you don't have the same  
20 system feedback to deal with.


21 MR. JENSEN: Okay, good.

22 MR. KAUFFMAN: That's it. We're off the record.

23 (Whereupon the matter concluded at 2:56 p.m.)

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: IIT Interview of Bob Jones


DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Marilyn Estep

Official Reporter  
Ann Riley & Associates, Ltd.





# OFFICIAL TRANSCRIPT OF PROCEEDINGS

**Agency:** Nuclear Regulatory Commission  
Incident Investigation Team

**Title:** Interview of Bob Jones

**Docket No.**

**LOCATION:** Bethesda, Maryland


**DATE:** Friday, August 30, 1991 **PAGES:** 1 - 29

**ANN RILEY & ASSOCIATES, LTD.**


1612 K St. N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950

*Dupe of*

~~73050700-95~~







UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

INTERVIEW OF )  
 )  
BOB JONES )  
 )

Nuclear Regulatory Commission  
The Woodmont Building  
8120 Woodmont Avenue  
Bethesda, Maryland

Friday, August 30, 1991

The above-entitled interview convened, pursuant to  
notice, in closed session at 2:05 p.m.

PARTICIPANTS:

JOHN KAUFFMAN, NRC/IIT Team  
WALTER JENSEN, NRC/IIT Team

1-2



## P R O C E E D I N G S

1  
2 MR. KAUFFMAN: It is August 30th, 1991, at  
3 approximately 2:05 in the afternoon. We're in the Woodmont  
4 Building, Bethesda, Maryland, conducting an interview of Bob  
5 Jones as part of our incident investigation of a Nine Mile  
6 Point Unit 2 event of August 13th, 1991.

7 I'm John Kauffman out of NRC Headquarters, AEOD.

8 MR. JENSEN: I'm Walt Jensen out of NRC  
9 Headquarters, plant assessment branch.

10 MR. JONES: I am Bob Jones, chief of the reactor  
11 systems branch.

12 MR. KAUFFMAN: Bob, at this time will you tell us  
13 a little bit about your previous background and work  
14 experience and education?

15 MR. JONES: I graduated from the Pennsylvania  
16 State University with a bachelors of science in nuclear  
17 engineering in 1971. From there I went on to the Babcock  
18 and Wilcox Company in Lynchburg, Virginia, where I worked  
19 until October of 1983, culminating my career there as the  
20 unit manager of the transient and accident analysis section.

21 I came to NRC in October of '83 in the reactor  
22 systems branch as an engineer, have progressed through three  
23 organizations or reorganizations to become now the chief of  
24 the reactor systems branch in the division of systems  
25 technology and I've been in that position for approximately





1 two years.

2 MR. JENSEN: Okay, Bob. Can you tell us about any  
3 involvement you've had in the review of the Nine Mile 2  
4 event of August 13th?

5 MR. JONES: I have had no involvement in the Nine  
6 Mile 2 event of August 13th other than seeing the morning  
7 reports that come out and those types of general items.

8 MR. JENSEN: Okay, and you've have had no  
9 involvement in the original licensing of Nine Mile 2?

10 MR. JONES: That's correct.

11 MR. JENSEN: What about the review of the  
12 instrumentation that's included on Reg Guide 1.97, the  
13 instrumentation that's important to diagnosing severe  
14 accidents?

15 MR. JONES: I don't remember anything specifically  
16 for Nine Mile 2 in the last few years. About the only item  
17 that's come that would be arguably applicable to Nine Mile 2  
18 would be neutron flux monitoring instrumentation which the  
19 BWR owners group appealed within the last -- I'm not sure  
20 exactly when this came in but we went through an appeal  
21 process on that, both my branch and the instrumentation and  
22 control system branch reviewed and prepared material for the  
23 appeal process.

24 MR. KAUFFMAN: And what was that issue?

25 MR. JONES: The basic issue was, as I try to



1 paraphrase it, when Reg Guide 1.97 was issued one of the  
2 instrumentation items that was listed to be safety grade  
3 class one or category one instrumentation for Reg Guide 1.97  
4 -- I'm not that familiar with the categorizations but the  
5 highest level of instrumentation. That's an instrumentation  
6 issue.

7           That instrumentation, one of them was the neutron  
8 flux monitoring instrumentation and part of that included  
9 capability to detect neutron flux down to one times ten to  
10 the minus six count, one times ten to the minus six power  
11 range, need to be environmentally qualified and such items  
12 as that.

13           As just generically as instrumentation came  
14 through on the Reg Guide 1.97 for the boilers, it was  
15 recognized that there was no qualified neutron flux  
16 monitoring instrument generically available.

17           As a result, essentially all of the SERs that were  
18 issued blessed the adequacy of the existing instrumentation  
19 that was in the plants with a statement that should such  
20 instrumentation become available or they were to continue to  
21 pursue the development of such instrumentation capability  
22 and then would subsequently place that in their plants.

23           The owners group appeal basically came about  
24 because such instrumentation has become available in recent  
25 years by two companies and we were starting to impose that



1 back on the industry, the GE industry, the boilers, to start  
2 pursuing that, putting in that instrumentation and they were  
3 arguing that the existing instrumentation was effective.

4 We put together arguments for our management on  
5 it. It was a very tough issue to resolve because you do  
6 have flux monitoring instrumentation. The biggest issue was  
7 what do you qualify it to.


8 We went through the appeal process and the  
9 director issued a decision which was that they did not need  
10 to upgrade such instrumentation, that the instrumentation in  
11 place was adequate, that the current source ranges were at  
12 normal power.

13 MR. KAUFFMAN: Were adequate or could be backfit  
14 justified or --

15 MR. JONES: That it was adequate for Reg Guide  
16 1.97 purposes and we were given directions for future plants  
17 to have them use such instrumentation.

18 We are still working through the mechanics of how  
19 to implement the director's decision because there is some  
20 guidance that we have to put together about severe accident  
21 mitigation and following severe accidents, core melt type  
22 events or accident management issues.

23 MR. JENSEN: Was the issue more as to whether the  
24 environmental qualification of the instrument or as to the  
25 quality of the power supply?



1 MR. JONES: It was a combination, I believe.  
2 There were arguments made about the environmental  
3 qualifications of the instrument, but one of the issues was  
4 the power supply because you have to drive in, at least  
5 generically in most boilers, the SRMs into the core using  
6 your -- because they were retractable so you would have to  
7 drive them in so therefore you had an electrical power  
8 supply issue as one of the issues.

9 MR. JENSEN: Do you know which nuclear  
10 instrumentation is supplied with vital power as opposed to  
11 that which is supplied with control grade power?

12 MR. JONES: I believe it's the APRMs, which is  
13 some combination of the LPRMs, so those must also have some  
14 -- I'm not sure about the classification of those but the  
15 APRMs must be because they provide trip signals for the  
16 reactor. I'm not that well versed in the power supply  
17 issues.

18 MR. JENSEN: What about the rod position  
19 indication? Was there any discussion over whether or not  
20 the rod position indication should be supplied with vital  
21 power?

22 MR. JONES: That was one of the arguments as I  
23 remember it in the owners group appeal, that you had that  
24 available to you generally speaking to monitor whether or  
25 not the rods were -- one of the issues was to use the reed





1 switches for the rod position indicators.

2 Again, when we put together our arguments, we  
3 recognized that it was a qualified safety grade type  
4 instrumentation, a recognized position but, as I said, we  
5 lost our appeal.

6 We argued to upgrade and when we went through the  
7 appeal process and we revisited the issue, we continued to  
8 push to upgrade the instrumentation.

9 MR. JENSEN: Did that include the rod position  
10 instrumentation for vital power as well as --

11 MR. JONES: No, we did not. We were looking at  
12 it primarily from the standpoint of just putting in the  
13 available instruments which were on the street, which were  
14 the Gammametrics in-core system and somebody had an ex-core  
15 system. We were not looking at specifically upgrading the  
16 position indication system.

17 MR. JENSEN: In the EOPs, one of the vital safety  
18 functions is to have the reactor shut down.

19 Do you remember which -- what kinds of  
20 instrumentation are required to assure reactor safe  
21 shutdown, the neutrons being absorbed?

22 MR. JONES: Well, you would have the APRMs, LPRMs  
23 go off scale, down scale. You would then drive in your  
24 SRMs. You would monitor through that whether or not you were  
25 at decay. You would also have your reed switches for your



1 rods, whether they were in or not. You would look at those  
2 indications. If they were bottomed out you would push them  
3 in, so to speak.

4 MR. KAUFFMAN: May I interrupt?

5 MR. JENSEN: Sure.

6 MR. KAUFFMAN: How would you feel if I said I had  
7 an event where I lost my reed switches, I lost my rod  
8 minimizer, I lost my rod sequence control system indications  
9 on rods and I couldn't tell the position of control rods  
10 although I did have APRM flux indication.

11 Would you think that's a significant event or  
12 would you say that's something that's covered by our guide -  
13 - our guidance recognized that that might happen and that's  
14 okay, or would you say that's reason to go back and  
15 reconsider our decision on upgrading our detectors and maybe  
16 making safety grade some of these power supplies?

17 MR. JONES: My reaction is one of I would feel  
18 uncomfortable in such a situation. I clearly would like to  
19 know that the reactor is fully shut down and be able to  
20 monitor it.

21 There are varied ways you could operate so I'm not  
22 sure whether I would say you would necessarily have to go  
23 back and look at it from the Reg Guide 1.97 point of view we  
24 were using when we looked at the appeal because we were  
25 looking for full-range environmental qualified for LOCA and



1 non LOCA transients, et cetera, going to a fairly extensive  
2 upgrade of the monitoring capability.

3 Arguably, you could upgrade power supplies, for  
4 example,, through reed switches would be one way of taking  
5 care of that.

6 MR. KAUFFMAN: Do you think that would be a hard  
7 fix, an expensive fix, or is that something that you think  
8 would be easy to do? I don't know, that's why --


9 MR. JONES: I don't know, either, and I would  
10 suggest you ask an instrumentation type on that.

11 Again, I think there are various options available  
12 to you. There are fixed core neutron systems, for example,  
13 that you could put in as one possibility, fixed core source  
14 range system which is similar to what we are looking at as  
15 one of the systems for the upgrade of the flux monitoring  
16 system. Limited capability there could be of use. What its  
17 relative cost is, I don't know.

18 MR. KAUFFMAN: I'm not familiar with what fixed  
19 core means.

20 MR. JONES: Unlike the APRMs which are in-core and  
21 stay in-core at all kinds, unlike the SRMs which are  
22 inserted and withdrawn. One of the neutron flux systems  
23 which we're looking at was a fixed in-core system. There  
24 are probably various ways of getting such information.

25 MR. JENSEN: So under the condition that the APRMs



1 and the LPRMs were both indicating that reactor power had  
2 been shut down but control rod indication was not available  
3 or indicated that some or all of the rods may be still out  
4 of the core, should an operator go to his ATWS EOPs or  
5 should he believe his nuclear instrumentation and believe  
6 the reactor is shut down, being that the nuclear information  
7 may be safety grade and the rod position --

8 MR. KAUFFMAN: Also considering you may be shut  
9 down now but if you cool down on Xenon fills in and burns  
10 out you may get positive reactivity.

11 MR. JONES: I'm not sure what you get necessarily  
12 by going to the ATWS procedures. One of the problems you  
13 end up with in the ATWS procedures which basically I think  
14 asks do you inject SLCS -- standby liquid control system --  
15 which is really what you're looking for when you go to the  
16 ATWS procedure and initiate a short shutdown.

17 The ATWS procedures do not necessarily require you  
18 to initiate SLCS, depending on whether you are isolated or  
19 not isolated event. If you haven't isolated during this  
20 IVs, for example, then you would not be injecting SLCS and  
21 I'm not sure what the circumstances were at Nine Mile.

22 So if you went to the ATWS procedures, depending  
23 on the circumstances of the event, you may or may not -- it  
24 may or may not have helped you. You're not coming up  
25 tomorrow so cleanup is not a problem.





1 MR. KAUFFMAN: We may revisit that but at Nine  
2 Mile they did not get to their SLCS injection criteria which  
3 comes up suppression full temperature. They got hung up in  
4 the loop on procedure telling them to stay where they are,  
5 not depressurize and in the meantime they have to maintain  
6 level, they're running RCIC so they are depressurizing.

7 They basically got into one step said don't  
8 depressurize, the other one said if you can stay shut down  
9 while you're depressurizing then you can depressurize and  
10 there were some contradictions and some confusions in the  
11 EOPs so we're going to want to talk about EOPs.

12 We can start that now just generally on what your  
13 branch, what your involvement is in EOPs.

14 MR. JONES: Generally in the EOPs, and I'll go  
15 back a step.

16 We start at the EPGs or the emergency procedure  
17 guideline stage, which is the generic stage, the vendor  
18 generic guidelines, and we would review technically those  
19 procedures, the analyses that form the basis for those  
20 procedures and in conjunction with other branches would look  
21 at the overall accident mitigation strategies and approach  
22 steps, appropriateness of the steps to assure that it could  
23 deal with wide contingencies, wide range of events that we  
24 could postulate, and that means not just the standard design  
25 basis but also beyond design basis multiple failure events.



1           Typically, the branch we interface with especially  
2 on the boilers would be the plant systems branch which is  
3 the containment functions so we're very heavily intertwined  
4 with them.

5           We have overall control of that review. That is,  
6 we have the lead role.

7           Now from there, in the implementation and the  
8 EOPs, our role diminishes. The process to turn them into  
9 EOPs is each utility has their own plant specific technical  
10 guidelines and other processes, writers guides, et cetera,  
11 that they go through to develop their own EOPs, which  
12 accounts for the plant-unique conditions and such.

13           We get involved at times in deviations taken from  
14 the generic guidelines to come up with the plant-specific  
15 procedures. That would come about when we would have either  
16 an EOP inspection, which we may or may not be involved in  
17 that inspection program. We've done so with the boilers, I  
18 don't remember which ones anymore. We went through a few of  
19 them. We did not go on all of them but we have been  
20 involved in EOP deviations which have popped out of several  
21 of those reviews.

22           MR. JENSEN: Would the generic EOPs that you  
23 reviewed be specific enough to tell the operator as to  
24 whether he's allowed to cool the plant down without rod  
25 position indication, or require him to inject boron before



1 he cooled down? Would they give general guidance?

2 MR. JONES: It's difficult for me to answer that  
3 on the specifics on the rod position indication. I would  
4 say that generally though I know there are lots of steps  
5 within the guidelines and I don't know the ins and outs and  
6 all the details of the boiler guidelines but I know there  
7 are several areas in the boiler guidelines where you look at  
8 things like is the reactor shut down, do you believe you  
9 will maintain it shut down as you go through with  
10 depressurization, those kinds of steps are in the guidelines  
11 and have been discussed in our SERs.

12 Whether it specifically says by rod position  
13 indicators, I'm not sure it gets necessarily that specific,  
14 but it will probably lay out a series of options available  
15 to you, by rod positions or by flux or by this or by that so  
16 they will lay out several options and each utility can use a  
17 combination thereof.

18 MR. JENSEN: So it would be up to the utility to  
19 decide which instrumentation he would use to determine  
20 whether he would shut down the nuclear reaction or not and  
21 cold cool safely down to cold shutdown?

22 MR. JONES: I would say generally he would already  
23 have known probably through the guidelines which  
24 instrumentation should be used because there is a lot of  
25 that that we do specify or that we do look at.



1 I would have to go back and look to see in  
2 specific cases or steps whether or not it's identified but  
3 generally speaking there is a priority in many of the steps  
4 in the guidelines and I would expect to find the guidelines  
5 would say he would use this or this and go right down the  
6 list and it's usually not an either/or, it's usually all of  
7 them to account for contingencies if things are not  
8 available. Specific, I'm not sure I would expect it to be  
9 there.


10 MR. JENSEN: Is there any inference in certain EOP  
11 steps as to requiring safety grade or class 1-E  
12 instrumentation be utilized?

13 MR. JONES: Not that I'm aware of. Not that we  
14 would only require use of class one, no.

15 MR. JENSEN: Well, is there any inference that  
16 class 1-E instrumentation be used for any steps in the EOPs?

17 MR. JONES: I would say no. Generally the EOPs or  
18 EPGs are much broader. It uses all available  
19 instrumentation. It uses all available systems to respond  
20 so I would not expect it to necessarily make the  
21 distinction.

22 What I would expect to find, and part of the  
23 reason I say this is because we're involved in a similar  
24 issue on another plant, is the consideration of  
25 instrumentation accuracies in various environments, for





1 example, when you implement the procedures.

2 So I would expect that there would be some  
3 distinction in the development of that kind of information  
4 as to what is qualified, what isn't, what you may have to be  
5 careful with using in certain environmental conditions that  
6 that would be covered in training.

7 There is also usually a general -- you have to  
8 crosscheck instrumentation and never rely on one single  
9 piece of instrumentation to make a decision.


10 MR. JENSEN: Are there decisions so important that  
11 the operator should make in the EOPs that it would require  
12 instrumentation providing class 1-E power?

13 MR. JONES: Not that I can say right off the bat  
14 yes or no. I would rather take the following premise.

15 The operator should have enough instrumentation to  
16 follow the course of an accident based on 1-E power  
17 consistent with the Reg Guide 1.97 approach, that he has  
18 enough instrumentation, safety grade type instrumentation,  
19 available to monitor the course of an accident.

20 If he is ever to that situation, I expect it would  
21 not be ideal, anyway, if he's just down to the safety grade  
22 instrumentation and displays.

23 Clearly one of the reasons for development of Reg  
24 Guide 1.97 was to develop safety functions and assure that  
25 there would be safety grade available instrumentation for



1 the operator for monitoring the course of an accident. That  
2 is how you get your highest level of instrumentation and  
3 that is why I understand it's also referred to in the  
4 equipment qualification rule, 50.49, as being required to be  
5 qualified.

6 MR. JENSEN: How significant is the safety  
7 parameter display system, the SPDS, in the EOPs?

8 MR. JONES: Let me back up and make sure when I  
9 answer these questions on EOPs I want it clear that I can't  
10 answer from a Nine Mile 2 EOP.

11 MR. JENSEN: Sure.

12 MR. JONES: In fact, not even anybody's EOP. I  
13 would rather answer from an EPG perspective.

14 MR. JENSEN: Okay.

15 MR. JONES: So that's clear. The safety  
16 parameter display system is an operator aid. It is not  
17 safety grade and its reliability targets, as I understand  
18 it, clearly we place importance on the SPDS as an agency, I  
19 would say, given how the thing is put together, but I'm not  
20 sure from an EOP perspective that the SPDS is specifically  
21 called out in a way that makes it particularly important  
22 because there are various levels or differences in SPDS  
23 designs across the industry so it would be difficult in a  
24 generic guideline to call that out other than to talk about  
25 the functions and general instrumentation.



1 MR. KAUFFMAN: You call SPDS an operator aid. If  
2 SPDS is lost, how big of an impact do you think it would  
3 have, say, in an emergency with technical support centers  
4 EOPs and their ability to gather information?

5 MR. JONES: I don't know. That's beyond my scope.  
6 To the extent that it's tied to an SPDS, obviously  
7 significantly.

8 To the operator running the plant, assuming he  
9 hasn't lost all his control board instrumentation, which is  
10 my understanding of Nine Mile, under that circumstance  
11 arguably he should have enough information otherwise.

12 I mean there are ties with the SPDS which clearly  
13 you could say that has a bearing on the ability of other  
14 functions to perform if it's tied to it and it's lost.

15 MR. KAUFFMAN: Do you know how it was decided that  
16 SPDS wouldn't be safety grade, wouldn't be 1-E powered?

17 MR. JONES: No, beyond my -- That was before my  
18 time at the agency.

19 MR. KAUFFMAN: Do you know who was involved in  
20 that decision?

21 MR. JONES: No.

22 MR. JENSEN: It seems like the operators and the  
23 BWRs are very hesitant to inject boric acid into the SLCS  
24 system in the core.

25 Do you know of any safety problems or operational



1 problems that suggest boric acid played out in the core that  
2 might occur from boric acid injection subsequent boiling?

3 MR. JONES: No, I'm not aware of any particular  
4 reasons why you should not be able to inject SLCS. In fact,  
5 as I remember discussions we've had with the BWR owners  
6 group concerning ATWS mitigation recently.

7 One of the options that we were looking at related  
8 to the so-called stability issue, is earlier injection of  
9 SLCS for such transients -- that was transients with  
10 oscillations.


11 One of our questions very early on over the last  
12 two years of involvement on this was why can't you inject it  
13 earlier and we have never been given a good reason that  
14 sticks in my mind that says it's a bad thing to do.

15 Obviously it has cleanup implications and that's  
16 the only thing I have ever heard.

17 I'm sure there are some chemical issues that would  
18 need to be addressed from a material standpoint but at this  
19 point nobody has given me any good reason not to.

20 MR. JENSEN: To what extent is the RSB branch  
21 reviewing emergency procedures at this time or emergency  
22 guidelines?

23 MR. JONES: With respect to the boilers, we are  
24 effectively done for Rev.4 of the guidelines, and in fact we  
25 have taken the position that we are absolutely finished with






1 the boiler guidelines with respect to normal transient and  
2 accident mitigation and we are letting the industry carry  
3 forth from there.

4 With respect to accident management or extension  
5 into the severe accident area, we have kept our foot in the  
6 door and we have said when those happen we want to review it  
7 again.

8 However, we do get involved, as I've noted  
9 earlier, with plant-specific exceptions to the guidelines.  
10 We're involved in issues at WNP-2 right now. We've done  
11 some EOP issues at one of the Millstone units in the recent  
12 past.

13 We also have had ongoing discussions over the last  
14 two years with respect to some deviations, particularly ATWS  
15 deviation, taken by Susquehanna relative to the owners  
16 group, primarily related to whether or not you need to lower  
17 water level during an ATWS event.

18 We are also involved with ongoing discussions with  
19 the owners group related to implementation of the EPGs vis-  
20 a-vis the design basis of the plant because the EOPs and  
21 EPGs as written in such a broad-brush treatment of accident  
22 strategy for the entire fleet of BWRs makes it difficult to  
23 say whether following these steps assure you meet your  
24 design basis and we've asked them to review that as part of  
25 the implementation.



1           This has formed up with a few problems that we're  
2 still discussing and we don't have a resolution path yet on  
3 some of those.

4           Last has been the issue of ATWS instability which  
5 I mentioned earlier and the fix that is likely to come out  
6 of that issue will be a procedurally PG modification. That  
7 is not a resolved issue but we have had discussions as to  
8 the types of changes that may be made.

9           Although we said we're close, we still have a lot  
10 of work that we do in the area.


11           MR. KAUFFMAN: Are you expending any efforts  
12 toward the advance of BWR and looking at EPGs for those or  
13 is that just too far away?

14           MR. JONES: I'm trying -- I don't remember right  
15 now whether we have them or we've asked the question on  
16 them. We are going to do it so it's just a matter of I'm  
17 not sure where it is in the process, but clearly one of the  
18 steps is we are going to look at the EPGs for the ABWR as  
19 part of the licensing effort. I'm just not sure where it is  
20 right now.

21           MR. JENSEN: I believe you mentioned the issue of  
22 ATWS stability. I'm not sure I understand what that is.

23           MR. JONES: I was hoping you wouldn't ask that.

24           If you are aware of the LaSalle event of '87, '88,  
25 somewhere in there.



1 MR. KAUFFMAN: March 1988.

2 MR. JONES: That's where you get neutron flux  
3 instabilities, where you have large power oscillations due  
4 to void collapse and development. It's a thermal hydraulic  
5 instability.

6 Basically cold water comes in, gives you a  
7 reactivity surge, then you create a void which shuts it  
8 down, the cold water comes back in. It's a thermal  
9 hydraulic instability which feeds back to the nuclear  
10 calculations.

11 Similar things can happen in ATWS and the issue is  
12 what -- it appears to be mostly dominated by system effects.

13 The other is primarily dominated by core design,  
14 that is, pressure drops across the core, two-phase pressure  
15 drops, single-phase pressure drops in that relationship.

16 In ATWS what seems to really give you a large  
17 power oscillation is cold water insertion, so if you isolate  
18 it and have cold feedwater coming in because you've isolated  
19 the steam, extraction steam, and you're trying to maintain  
20 level in the vessel and now you get very cold water in you  
21 get power spikes. We have seen numbers as high as 3500  
22 percent.

23 MR. KAUFFMAN: Walt, there's a large industry  
24 effort in the owners group in Brookhaven looking into this.

25 MR. JENSEN: What would the operator's response



1 be? Would it be to inject boric acid with the SLCS system?

2 MR. JONES: What we're looking at right now is --  
3 As I mentioned earlier, there are basically two --

4 When you talk ATWS procedures and SLCS injection,  
5 you really start looking at two classes of ATWS. You look  
6 at the class of ATWS where you isolate the vessel which  
7 leads to a heatup of the suppression pool which leads you  
8 into SLCS actuation and leads you into lowering vessel water  
9 level.

10 There's the other class of ATWS and there is also  
11 the preferred ATWS mitigation scheme which is to simply dump  
12 steam to the condenser, an unisolated ATWS, and that's the  
13 one that can come back and feed back through the system with  
14 cold feedwater.

15 What we're talking about is -- I don't want to  
16 call it a simplification of the procedures but in my mind it  
17 is in the sense that what we do is you have an ATWS,  
18 isolated or unisolated, you would basically hit the SLCS  
19 system, the boron injection, early and then you would deal  
20 with the issue of do you still lower power level or not is  
21 still one of the fuzzy areas.

22 We will probably in coupling it with the  
23 oscillation issue, would be you get indications that your  
24 oscillator is not shutting down you might start lowering the  
25 water level early.





1 MR. JENSEN: What will you do -- suppose you were  
2 an operator at Nine Mile 2 and the reactor had tripped and  
3 the neutron instrumentation indicated that the reactor was  
4 so critical and had no rod position indication, how long  
5 would you set at hot standby before you cooled down?

6 Would you inject boric acid before you cooled  
7 down? What would you do?

8 MR. KAUFFMAN: We are talking strategies here,  
9 obviously, not plant-specific.

10 MR. JONES: I understand that.

11 That was really in a sense part of what the  
12 position was in this owners group neutron flux monitoring  
13 thing. They would basically say you don't need to bother.  
14 You don't need to inject SLCS. You can shut down. You've  
15 got adequate rods in and if you shut down and try to come  
16 down the appropriate decay --

17 You seemed to imply in your question that you had  
18 neutron flux monitoring. If you have ---

19 MR. KAUFFMAN: The APRMs, LPRMs, were  
20 depressurizing.

21 MR. JONES: But I don't know how far and whether  
22 you continue and follow the decay -- Your LPRMs are going  
23 to drop off scale fairly fast and the transients, you don't  
24 know where they are, arguably.

25 Gut reaction is I would inject SLCS. That's my



1 reaction to it.

2 MR. JENSEN: One concern if you cool down and  
3 maybe you were subcritical but if you cool down then you  
4 might go critical because in the cooldown perhaps all of the  
5 rods weren't inserted or only partially inserted.

6 MR. JONES: If you have feedwater and you have  
7 level control and all that happened was you just came back  
8 up on power with your turbine available to dump steam in  
9 your condenser, you just sit there and no big deal.


10 It's a very difficult call to make because if you  
11 look at it from certain eyes you could say the plant just  
12 sits there and you sit at power level and then you ask  
13 yourself what do I do from here and if you really want to  
14 get down at that point, you know you're not fully shut down,  
15 your rods are not fully in because that should not be  
16 happening to you and that could be a good enough indication  
17 to go back and inject SLCS at that point.

18 MR. JENSEN: But if you did go critical, it  
19 wouldn't be a major safety problem?

20 MR. JONES: I don't believe it would be a major  
21 safety problem. The boiler is inherently -- from that  
22 sense, they appear to be inherently safe.

23 As I said, my reaction is I would prefer to inject  
24 SLCS but that's a very personal reaction.

25 MR. KAUFFMAN: Walt is assuming that when you



1 depressurized you had control of your condensate booster  
2 system, for example.

3 MR. JONES: So you should just stabilize out.  
4 From a pure safety standpoint it's not clear that anything  
5 is actually necessary.

6 MR. JENSEN: So an operator just might choose to  
7 cool down and if it did go critical he might wait and inject  
8 the boric acid then.


9 MR. JONES: That's correct, and that would clearly  
10 be, I think, through the procedures what he would then be  
11 directed to do because he is obviously not shut down.

12 MR. JENSEN: In your recent review of the GE EOPs,  
13 what other branches did RSB work with and interface with?

14 MR. JONES: Clearly plant systems. I am sure we  
15 worked somewhat with the human factors people but only --  
16 not to a very large extent I'm sure because a lot of human  
17 factors issues have already been addressed in the earlier  
18 reviews. We may have touched base with instrumentation and  
19 control.

20 Again, you drew a rev of the report which was a  
21 fairly -- Well, it's a fairly major modification and a few  
22 of the strategies but it was mostly dealing with very  
23 specific items so the nature of the review is different that  
24 if you were starting from scratch.

25 We were looking primarily at things like



1 containment flooding as opposed to core spray as a final  
2 accident mitigation step, level control and venting the  
3 containment and a lot of that stuff was a lot of the  
4 emphasis in Rev 4.

5 MR. JENSEN: What kind of things did  
6 instrumentation and control branch look at?

7 MR. JONES: I don't remember. I'm not sure we  
8 interfaced very extensively with them except we probably if  
9 anything just touched on it.

10 MR. KAUFFMAN: I'm going to try this question. It  
11 might be too hard to answer but I'm going to try it.

12 Could you run me through the differences between  
13 the BWR EPG Revs 0 through 4 of the evolution and why those  
14 changes were made? If that's too hard --

15 MR. JONES: I can absolutely not do that because I  
16 am not that familiar with the early revisions at all. That  
17 was before my time.

18 MR. KAUFFMAN: It's a nagging question I have, are  
19 these just small refinements or are they major improvements  
20 as they have gone along.

21 MR. JONES: I can't speak for earlier. I can  
22 speak Rev 3 and Rev 4 and my expectations are Rev 0 and Rev  
23 1 a lot of that is likely to be upgrade in response to staff  
24 questions, comments or open items, which was common for many  
25 of the emergency procedure guidelines we looked at in that






1 stage of their life.

2           Between Rev 3 and Rev 4 there were some very  
3 significant things that were changed. Containment venting  
4 is one of them. It's a much more detailed treatment of  
5 containment venting in the why and the when and how you  
6 calculate the various limits that you need to impose, et  
7 cetera.

8           Another big deviation step was there was a  
9 reliance in the old EPG on core spray. If you uncovered the  
10 core but you could maintain the core level at about two-  
11 thirds core height you would continue -- if you had spray  
12 available to you, you would just sit in that mode and cool  
13 in that fashion.

14           Rev 4, if you're in that mode and you're down to  
15 one pump, from a reliability standpoint if you're really  
16 down to one pump you are probably in pretty fairly strange  
17 territory and I'm not sure you know the reliability of your  
18 system as a whole any more so at that point you take so  
19 steps to start flooding containment so the ultimate path  
20 then, instead of cooling mode, would be in containment -- be  
21 in core spray or spray cooling as a whole different strategy  
22 of flooding and flooding has other implications associated  
23 with it. You have to vent the flood but it is much more  
24 stable and assured.

25           That's a fairly major change. There are some



1 minor rearrangements of a few cautions or elimination of a  
2 few cautions which were not considered significant. Those  
3 are probably the major changes.

4 MR. JENSEN: As far as your branch looks at PWR  
5 EOPs, as well as BWR EOPs, I wonder if you know of any  
6 significant difference in philosophy that operators could  
7 use in entering the ATWS procedures as far as indication  
8 that an ATWS had occurred between the EOPs for PWRs and  
9 BWRs.

10 MR. JONES: Actually I would say there are a  
11 couple of differences. Number one, there is obviously no  
12 distinction between a nonisolated and isolated ATWS in a  
13 PWR. An ATWS is an ATWS is an ATWS. There is no deviation  
14 associated with the actions due to other system conditions.

15 Generally speaking, the PWR, if you have  
16 indications that you're not shut down, you start injecting  
17 your boron systems. Well, your drive rods first and inject  
18 boron and that type of stuff, but it's pretty much a fairly  
19 immediate step to confirm the shutdown reactor and take  
20 those actions.

21 From an indication standpoint, other than the type  
22 of instrumentation that you may be using, it's very similar,  
23 position indicators or rod bottom lights, same thing, you're  
24 talking neutron flux monitoring instrumentation, etc cetera.

25 To the best of my knowledge, all of the Ps have



1 qualified neutron flux monitoring systems down to the ten to  
2 the minus six type range so from that standpoint they should  
3 be in better shape as a whole from the monitoring  
4 standpoint.

5 I think there is a very clear recognition that in  
6 a boiler you're talking a machine that doesn't really have  
7 tremendous reactivity type problems inherently because of  
8 the way feedback, et cetera, the rods go in and you actually  
9 go subcritical on rods in a boiler.

10 That's not true in a PWR, period. A PWR is not  
11 inherently shut down just because the rods are in so you  
12 have to inject boron, for example, before you depressurize  
13 so I think there's more sensitivity to that issue from that  
14 standpoint.

15 I think there are -- From a pure indication  
16 standpoint the distinctions are small. I think there is a  
17 level of sensitivity that's much higher and the quality of  
18 the instrumentation is different and certainly the actions  
19 are arguably simplified because you don't have the same  
20 system feedback to deal with.

21 MR. JENSEN: Okay, good.

22 MR. KAUFFMAN: That's it. We're off the record.

23 (Whereupon the matter concluded at 2:56 p.m.)

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: IIT Interview of Bob Jones

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Marilyn Estep

Official Reporter  
Ann Riley & Associates, Ltd.

