

ORIGINAL

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Incident Investigation Team

Title: Interview of Jared Wermiel

Docket No.

LOCATION: Bethesda, Maryland

DATE: Friday, August 30, 1991 PAGES: 1 - 46

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

9305070121 911031
PDR ADDCK 05000410
S PDR



ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
6	14	"outside" power" should be "offsite power"
18	3	"implementation and control" should be "instrumentation and control"
21	9	Add the word "it" prior to "an awful lot..."
29	3	Add the word "I" prior to "don't know..."
29	6	Change "enough" to "too much"
33	23	Change to read "The analysis for the design basis events which the ..."
40	21	Add the word "is" prior to "an ATWS..."
41	4	Add the word "in" prior to "or not."
42	17	Change to read "If he shuts the MSIV's he ..."
44	3	Change the word "go" to "going"

Date 9-20-91 Signature /s/

2

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The goal is to ensure that the information is both reliable and up-to-date.

The third part of the report focuses on the results of the analysis. It shows a clear trend of growth over the period studied. This is attributed to several key factors, including improved operational efficiency and increased market demand.

Finally, the document concludes with a series of recommendations for future actions. These are based on the findings of the analysis and aim to further optimize the current processes. The author believes that these steps will lead to continued success and profitability.

1

2

3

4

5

6

7

INTERVIEW OF)

8

)

9

JARED WERMIEL)

10

)

11

12

Nuclear Regulatory Commission

13

The Woodmont Building

14

8120 Woodmont Avenue

15

Bethesda, Maryland

16

Friday, August 30, 1991

17

18

The above-entitled interview convened, pursuant to

19

notice, in closed session at 12:15 p.m.

20

21

PARTICIPANTS:

22

MICHAEL JORDAN, NRC/IIT TEAM

23

BILL VATTER, NRC/IIT TEAM

24

JOSE IBARRA, NRC/IIT TEAM

25

JOHN KAUFFMAN, NRC/IIT TEAM



P R O C E E D I N G S

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. JORDAN: Good morning. This is August 30th at approximately 12:15. We are here talking and having a discussion about an event that happened on August 13th at Nine Mile Unit 2.

Jerry, why don't you go ahead and tell us what your background is, what your experience right now is and what your current position is and the type of activities of and responsibilities of that position.

MR. WERMIEL: Sure. I'm currently the branch chief of the human factors assessment branch in the division of licensee performance and quality evaluation, Office of Nuclear Reactor Regulation.

As such, we are responsible for those regulatory activities that deal with human performance, emergency operating procedures, training, man-machine interface questions, questions of staffing, all issues that relate to proper performance of the operations staff at a nuclear power plant.

I have been in this position now since May of 1990. Prior to that I was in the plant systems area as a section chief and prior to that as a reviewer.

My background is primarily in the support, reactor support systems area and in balance of plant systems area.

I am an engineer. I'm not a psychologist and my



1 background is primarily in fluid systems.

2 I joined the NRC in March of 1978 and have been
3 with the agency since that point.

4 MR. JORDAN: I guess we should at least introduce
5 for the record who we are. My name is Michael Jordan. I'm
6 with the USNRC out of Region 3. I'm a section chief for
7 boiling water reactors and operator licensing.

8 MR. VATTER: I'm Bill Vatter and I'm on loan to
9 the IIT from INPO.

10 MR. KAUFFMAN: John Kauffman out of NRC
11 headquarters.

12 MR. IBARRA: Jose Ibarra from the instrument
13 controls systems branch of NRR.

14 MR. WERMIEL: Does anybody have a particular
15 question they want to start out with?

16 MR. IBARRA: Jerry, who reviewed the EOPs in the
17 agency, the EOPs coming out of Three Mile Island, or after
18 Three Mile Island?

19 MR. WERMIEL: By who you mean what individual?

20 MR. IBARRA: What branch.

21 MR. WERMIEL: Programmatic responsibility for the
22 review of the emergency operating procedures is with the
23 human factors assessment branch and that would have been the
24 responsibility that they had. The actual review was
25 conducted as part of the emergency operating procedure



1 inspection program.

2 In other words, the region was responsible for
3 conducting an EOP inspection that was supported by
4 headquarters of the procedures at the plant. That review
5 was primarily to confirm implementation of commitments that
6 were made after TMI with regard to incorporation of the new
7 emergency procedure guidelines, the writer's guide, the
8 proper verification and validation of the procedures, all
9 those sorts of things.

10 That's all included in this emergency operating
11 procedure inspection program. I believe it's Manual Chapter
12 41500, I think is the actual inspection module that's
13 involved here.

14 MR. IBARRA: In that review, who would be the
15 technical contact? Who would look at instrumentation and
16 controls and electrical systems?

17 MR. WERMIEL: There would be members on that team
18 that would have expertise in the technical areas and I
19 believe there should have been some expertise on the team in
20 I&C, although that may not have been a specific area that's
21 called out, and there is also expertise on the team in the
22 human factors area so we have both technical experts and
23 human factors people on those teams.

24 There isn't, as I recall, a specific requirement
25 that there be an electrical -- a person with electrical



1 background on that inspection team. There usually is
2 somebody with systems understanding or systems experience,
3 mostly reactor systems experience.

4 MR. IBARRA: How about as far as computer systems,
5 SPDS and so forth, as they relate to the EOP?

6 MR. WERMIEL: A human factors person may have some
7 knowledge of SPDS, of the DCRDR review, but the review from
8 the human factors perspective is primarily a verification of
9 the usability of the procedure -- is the procedure laid out
10 in a way that the operator can appropriately implement it,
11 does it have all the information the operator needs to take
12 the actions he needs to take, is it sequenced in a way where
13 if he follows it he'll be doing the right thing, that kind
14 of a look.

15 We don't do that I'm aware of any kind of a direct
16 check of how the SPDS was incorporated in the procedures or
17 that sort of thing. It's more -- at least from the human
18 factors perspective, it's more a verification that the
19 writers guide which provide guidance on how to make these a
20 user-friendly procedure, has it been implemented properly
21 and are these indeed procedures that the operator if he
22 follows successfully will lead him down the right path, will
23 work right.

24 MR. IBARRA: If we were looking at the
25 instrumentation that the operator is using to carry out his



1 task, how do we link up that with the qualification of that
2 instrument being able to know that it does survive under the
3 conditions that he would be using it?

4 MR. WERMIEL: Okay. That would not be done
5 procedurally, not in the EOP procedure per se. It's the --
6 I would assume and it is my understanding that the people
7 writing the procedures know what instrumentation is
8 qualified and what can be relied on for the various
9 scenarios so when they develop the procedures they will know
10 that whatever indications or controls that they are asking
11 the operator to utilize to conduct the necessary steps are
12 indeed available -- in other words, they are powered from an
13 available power source if the procedure involves a loss of
14 outside power, they are environmentally qualified if the
15 procedure is steamline break or a LOCA procedure so the
16 operator doesn't have to concern himself with that.

17 In other words, the basis for the procedure and
18 the equipment that's being called out has already been
19 checked. It's been verified and validated that this is
20 equipment that's available and can be used for the
21 particular accident or transient situation that he's in.

22 MR. JORDAN: When you say procedure, you're saying
23 the utility's procedure review of it or our guidelines or
24 the industry's guidelines?

25 MR. WERMIEL: We call for that. It's up to the



1 utility to make sure that the procedure writer is doing
2 that.

3 MR. JORDAN: Do we identify what instrumentation
4 we expect to be qualified?

5 MR. WERMIEL: Sure.

6 MR. JORDAN: Do we tell them which instrumentation
7 we expect to have on 1-E course of power and --

8 MR. WERMIEL: As far as I know. I&C isn't my
9 area. I would hope that Scott Newberry could help you out
10 there but it's my understanding is absolutely. Reg Guide
11 1.97, for example, is a set of instrumentation that's
12 supposed to be available to follow the course of an accident
13 and that instrumentation has certain power supply criteria
14 associated with it.

15 MR. JORDAN: So your group relies on the I&C's
16 people to identify what instrumentation will be available
17 for use in the EOP?

18 MR. WERMIEL: Right. That's correct, and then we
19 would assume that once the utility knows what
20 instrumentation they are taking credit for to satisfy the
21 criteria, that the procedure writer then incorporated it in
22 the procedure and doesn't tell the operator to rely on
23 something that isn't appropriately qualified for the event
24 that he's to deal with.

25 MR. JORDAN: So we leave that up to the utility.



1 MR. WERMIEL: Right. Sometimes we will identify
2 circumstances where we will question the instrumentation or
3 the -- we don't deal with the word "instrumentation" as much
4 as "indications."

5 The indications that the operator is to rely on,
6 we may question it. We may say you're telling him to rely
7 on this, is this something that he can rely on, is it going
8 to be available, and even if it is, is it something that's
9 been appropriately qualified.

10 During the inspection we may catch that. We may
11 ask about that as part of our -- it comes out of the
12 verification and validation work. It may come out of that.

13 MR. IBARRA: But it is part of the EOP program,
14 right?

15 MR. WERMIEL: It may, yes, may come out.

16 MR. IBARRA: Other than the inspection program, do
17 we have other mechanisms within the agency that would look -
18 - other than that inspection?

19 MR. WERMIEL: We do periodically under certain
20 circumstances look at operating procedures, yes, for other
21 reasons.

22 The EOP inspection program I'm speaking of is a
23 generic program that went on for several years but on a
24 periodic basis we're asked to look at certain aspects of
25 procedures or procedural steps to verify that they are



1 appropriate and they'll do what the utility claims they'll
2 do.

3 We're doing that right now, for example, for
4 Yankee Rowe and this question of the embrittled reactor
5 vessel. The utility was asked to modify their procedures to
6 do some things that would reduce the likelihood of a
7 pressurized thermal shock incident and they made some
8 procedural changes and we are now looking at those changes
9 to confirm that they will indeed -- first of all, that they
10 make sense for the intended purpose and that they can indeed
11 be accomplished the way the utility intends them to be
12 accomplished.

13 We don't do that very often but we do get requests
14 to do that sort of thing in certain cases.

15 MR. IBARRA: Do you supply support to the DCRDR
16 audits and the SPDS audits? Is that within your group?

17 MR. WERMIEL: Absolutely, yes. Yes. That was a
18 big push for quite a few years within this branch that I'm
19 in now.

20 When I got into the branch, those two programs
21 were nearly complete and since the time I've been there we
22 have completed the DCRDR reviews and the SPDS reviews but
23 that was an ongoing program for many, many years within the
24 human factors assessment branch.

25 MR. VATTER: Jerry, can you tell us how you go



1 about doing a human factors inspection for procedures?

2 MR. WERMIEL: Sure. Typically the region will --
3 Let me use the last plant as an example.

4 We just right now as a matter of fact, as we speak
5 they are completing the final inspection of Perry, the last
6 plant that's to undergo the full EOP inspection -- emergency
7 operating procedure inspection.


8 The region will identify the schedule for
9 completion of those inspections. They will identify the
10 people that they believe they need to accomplish the
11 inspection in accordance with the inspection module that I
12 mentioned.

13 If they need expertise from headquarters or
14 support they will contact us and we will provide them either
15 contractor technical assistance or somebody from my staff.

16 In certain cases, people from my staff have
17 actually gone on inspections but generally we'll provide a
18 contractor assistance from one of our contractors.

19 Then the team goes out and conducts the inspection
20 and in the course of conducting the inspection I'll get
21 feedback or the section chief who works for me will get
22 feedback from the team.

23 When the inspection is completed and the report is
24 written, we'll get copies of the report and if there's any
25 additional followup, either a followup inspection or



1 followup of closing out certain open items, we may again be
2 contacted by the region for assistance.

3 Often on an EOP followup inspection, we will again
4 be asked to provide contractor assistance, not usually for
5 closing out open items but sometimes we are asked to help
6 out for that, too.

7 MR. VATTER: What sort of techniques do the
8 inspectors use to make sure that the human factors are okay?

9 MR. WERMIEL: I'm not real familiar with the
10 details because I haven't been involved in an actual
11 inspection and my staff has been doing this for many more
12 years than I've been involved.

13 Generally, we have guidance. It's in a NUREG and
14 I wish I could think of the number. We have guidance on how
15 to conduct a human factors assessment of EOPs, what to look
16 for in the writers guide, what to look for in a V&V program,
17 what to look for in a walkthrough, what to look for when we
18 ask the utility to simulate the procedures by a simulator
19 scenario evaluation. It's all pretty well spelled out.

20 MR. VATTER: So you do observe some simulator
21 scenarios --

22 MR. WERMIEL: Yes, we do.

23 MR. VATTER: -- and procedures?

24 MR. WERMIEL: Yes. That's called out in the EOP
25 inspection module that we actually have them exercise the



1 EOPs in the simulator so that we can get some firsthand
2 knowledge of how the operators do using them.

3 We usually leave it up to the utility to select
4 what crew or what teams they want to put in the simulator to
5 run it through for us and we often get some pretty
6 substantial feedback from that, some pretty good insights
7 from that.

8 MR. JORDAN: Do you have any guidance -- You
9 mentioned 1.97 Reg Guide.

10 MR. WERMIEL: Yes.

11 MR. JORDAN: Do you have any guidance that says in
12 order to perform the EOPs, in order to get through any
13 particular step in the EOP that you've got to have something
14 that's qualified to 1.97, or is it just --

15 MR. WERMIEL: I don't know that we get that
16 specific, Mike. I believe it really is more a check on
17 whether or not the utility was aware that they needed to
18 make sure that when they wrote the procedure, as part of
19 that, the person who did it knows that he can't be asking an
20 operator to use equipment that isn't qualified.

21 If he's writing a LOCA procedure or a LOCA
22 recovery, the equipment has got to be environmentally
23 qualified and he can't be asking the operator to rely on
24 indications that are not because he'll get --

25 MR. JORDAN: Is that in the guidelines or is that



1 in -- where have we transmitted that to the utility?

2 MR. WERMIEL: I don't know that that is
3 specifically spelled out in the guidelines. I would have to
4 go back and look for you. We could do that. I don't know
5 that I've ever seen that.

6 What I think is called out is a more general
7 statement that the procedure writer as part of his V&V
8 verifies the availability of indications and controls, that
9 kind of thing.

10 MR. JORDAN: That's in the guidelines?

11 MR. WERMIEL: I believe it's in the guidelines on
12 V&V, yes.

13 MR. JORDAN: And the guidelines come from us or
14 from the industry?

15 MR. WERMIEL: From us.

16 MR. JORDAN: From us?

17 MR. WERMIEL: Yes.

18 MR. JORDAN: Our guidelines to the industry on how
19 to write EOPs?

20 MR. WERMIEL: That's correct.

21 MR. JORDAN: And in there you think there's a
22 section that says make sure that they have --

23 MR. WERMIEL: I sure do think so because I know
24 it's part of what we consider. I just don't know how
25 explicit it is.



1 MR. IBARRA: The team member on this inspection
2 team, would he be knowledgeable in all the programs to be
3 able to make that assessment?

4 MR. WERMIEL: He would -- The human factors person
5 may not be but somebody on the team would know what
6 environmental qualification means and ought to be able to
7 judge, yes, that when the utility tells him we are utilizing
8 1.97 instrumentation that indeed they are using 1.97
9 instrumentation.

10 In other words, he would be familiar enough with
11 what that means to at least be able to judge that, yeah, the
12 utility was doing it right. I would think so, yes.

13 MR. IBARRA: What does the term important to
14 safety as far as EOP tasks are concerned, what does that
15 mean to you? Does that carry any significance whatsoever?

16 MR. WERMIEL: It certainly did from a hardware
17 perspective in my previous life, but when you deal with
18 people it doesn't mean a thing.

19 All the old terminology that I'm familiar with --
20 important to safety, safety-related, safety grade -- doesn't
21 mean a thing when we talk about people. We throw out all
22 that stuff -- single-failure criterion -- doesn't mean a
23 thing.

24 We basically rely on the operating procedures and
25 the operator's training to ensure that he'll do the right



1 thing. We don't I guess grade his performance. We just
2 assume he's going to do the right thing if his procedure is
3 okay and his training supports it.

4 MR. IBARRA: Every time there is a revision to the
5 procedure, how do they take care of it? Do they re-review
6 it?

7 MR. WERMIEL: Not as a general rule. We do not,
8 no. Once we've confirmed that the writers guide and the
9 program, the V&V program and all that kind of thing, is
10 acceptable, we would assume that any subsequent revisions
11 would be done in accordance with their procedure revision
12 program that we looked at and therefore we would expect that
13 it would be okay.

14 The questions may come up but again they would be
15 isolated. Unless it was part of an EOP followup, we
16 wouldn't get involved. We wouldn't oversee frequent changes
17 to th emergency operating procedures.

18 MR. JORDAN: How do vendors propose changes?
19 You're talking about the site changes. What about the --

20 MR. WERMIEL: If the emergency procedure
21 guidelines are changed, and particularly if there is a
22 substantial change, then I would expect that we would be
23 reviewing that, yes.

24 MR. IBARRA: Things like three years ago, four
25 years ago, when CE changed their philosophy on the number of



1 reactor coolant pumps?

2 MR. WERMIEL: That would be reviewed. No question
3 in my mind those kind of things because they go to the --

4 MR. JORDAN: Do you review those things?

5 MR. WERMIEL: Not the thermal hydraulic or the
6 technical adequacy of that but if there is anything that
7 results from that that changes the operator's indications or
8 the actions the operator takes, yes, we might get involved.


9 From a thermal hydraulic standpoint, though, and
10 the technical adequacy of that, the reactor systems branch
11 would do that.

12 MR. JORDAN: Do you then look at whether or not
13 performance of the steps and the actions that you would
14 expect from the operators is adequate?

15 MR. WERMIEL: That's right. We sure would,
16 particularly if there were new indications involved or new
17 actions the operator was to take, then we would probably get
18 involved.

19 MR. IBARRA: In your normal review, whatever your
20 group function would be as far as procedure is concerned,
21 does the electrical systems branch and the I&C branch, are
22 they all in concurrence on those?

23 MR. WERMIEL: If -- On almost everything we do
24 that involves EOPs from a technical adequacy standpoint, we
25 get the reactor systems branch involved. I can't think of a



1 case where we've gotten instrumentation and control or
2 electrical involved and that may be only because the kinds
3 of changes that we're talking about didn't affect the power
4 supply or the instrumentation.

5 Usually the process works that the request or the
6 need for the change goes through reactor systems branch and
7 they farm it out to us and the other review branches and I'm
8 trying to think whether --

9 I would assume that if there's a change in
10 instrumentation that would affect them that I&C would be
11 involved or a power supply question that the electrical
12 branch would be involved. I just can't think of an
13 instance where that's happened.

14 MR. IBARRA: Who makes that determination of who's
15 going to be on concurrence and who will be supporting whom?

16 MR. WERMIEL: If it's a licensing change, it goes
17 to the project manager and then the project manager would
18 parcel it out to the appropriate technical branches for
19 review.

20 MR. IBARRA: Okay, and the branches themselves
21 might ask for additional support and then it will be up to
22 them?

23 MR. WERMIEL: Absolutely, and oftentimes when we
24 get a request, if we're not confident that reactor systems
25 branch has seen it, because they need to, we'll make sure



1 they do see it.

2 Those are the examples I can think of. I can't
3 think of cases where implementation and control or
4 electrical were ever involved because we needed them to be
5 involved.

6 MR. IBARRA: We see that Reg Guide 1.97 is an
7 instrumentation issue but have you all supported -- Did you
8 all have any input whatsoever into --

9 MR. WERMIEL: The review of Reg Guide 1.97? No.
10 No, we didn't.

11 MR. IBARRA: How about any other instrumentation
12 dealing with, let's say the tech specs instrumentation
13 that's in there as far as they relate to the procedures, is
14 there a link there somewhere?

15 MR. WERMIEL: Not that I can think of, no.

16 MR. IBARRA: When you review SPDS, do you
17 typically ask for I&C support?

18 MR. WERMIEL: Yes. Typically those reviews had
19 both an I&C input and a human factors input, yes,
20 particularly from the standpoint of isolation of the power
21 supply to the SPDS. Since it was not on a 1-E bus there was
22 some concern about making sure that if SPDS should fail that
23 other instrumentation that the operator would rely on would
24 not fail.

25 Since a lot of the indications on SPDS are the



!



1 same indications that you would rely based on Reg Guide
2 1.97, a lot of them are the same, whereas the one that's a
3 non qualified component, the other should be.

4 MR. IBARRA: Would your group be concerned that,
5 for instance, SPDS is not safety-related and it would go
6 down in an emergency?

7 MR. WERMIEL: We are not concerned so long as we
8 are confident that there's a backup, a reliable backup. We
9 think from a standpoint of the high level display that the
10 SPDS is a real good operator aid and as long as it's
11 available it will probably be easier for him to do a lot of
12 things and get a lot of information from SPDS, but if it
13 goes down we're confident that there are other indications
14 that the operator would have to allow him to get through the
15 EOPs just fine.

16 MR. IBARRA: Is there a concern when the operators
17 lose annunciators and a lot of the backup instrumentation,
18 not necessarily the safety-related?

19 MR. WERMIEL: Sure. There is always a concern
20 where -- at least in our minds -- where if the operator has
21 only, say, one indication of something or one channel of
22 indication of something, that he may feel more hesitant to
23 rely on it because he can't verify it by looking at
24 something else.

25 There is always the desire to be able to confirm



1 an indication by looking at something else or even inferring
2 that he's doing the right thing by some indication so the
3 more you lose, oh, yes, definitely we would be a little more
4 concerned that the operator may be more apprehensive about
5 what he's doing because he has to rely so much on a single
6 indication or a much smaller set of indications. Sure
7 that's a concern, no question.

8 MR. JORDAN: SPDS usage, do you expect the
9 operators to use it or is that more of a transition aid for
10 those that are external to the control room to know what's
11 going on?

12 MR. WERMIEL: We expect the operators to use it.

13 MR. JORDAN: So the loss of it is more of an
14 operational, control and operational problem than a TSC or
15 offsite management control of the event?

16 MR. WERMIEL: Yeah, I would say so.

17 MR. JORDAN: Is that what we would expect?

18 MR. WERMIEL: That's what I would expect. I would
19 also expect, though, that the training the operator gets
20 would be conducive or he would know what to do if he loses
21 SPDS. I mean he ought to be relying on it. It's there for
22 him.

23 MR. JORDAN: Do we find in our inspections that
24 most operators rely on SPDS or do they go -- in an event or
25 their training in their scenarios, do the normally go



1 directly to the indication rather than the SPDS?

2 MR. WERMIEL: No. Certain plants in particular
3 really do rely on their SPDS. They really like it because
4 they've tailored it the way they want it to be and they
5 really like it the way it is and they want their operators
6 to use it because they've gone out of their way to design it
7 to be a real aid to the operator.

8 Some of the plants over the years have relied on
9 an awful lot less than we think they ought to. I think in
10 general, and this is based strictly on hearsay that I've
11 heard from other people, I think in general industry is
12 relying on it a lot more than they used to and a lot more
13 than they thought they would originally.

14 MR. JORDAN: And you're talking about the control
15 room operators, not just external to the control room.

16 MR. WERMIEL: Control room operators. No, I'm not
17 talking about the guy, the plant superintendent who comes in
18 during the event and wants to get a picture of what's going
19 on and looks at the panel, no. I'm talking about the
20 operating crew.

21 MR. VATTER: Is there one or more reactor types
22 that are more that way, where the SPDS is used more?

23 MR. WERMIEL: I don't think it's a function of
24 reactor type so much as it's more utility philosophy.

25 I got in, remember, on SPDS reviews at the very



1 end and I wasn't really a large part of a lot of that review
2 effort. There is a person on my staff who was involved
3 intimately with all the SPDS reviews for many, many, many
4 years. That's Dick Eckenrode, one of my two section chiefs.
5 He knows an awful lot about what happened during those
6 inspections.

7 MR. IBARRA: Would it concern you if a lot of the
8 indications or reliance on indications on instruments that
9 would be off of UPS?

10 MR. WERMIEL: Nonsafety UPS?


11 MR. IBARRA: Yes.

12 MR. WERMIEL: Would it concern me? As long as the
13 reliance was for situations where UPS was available, I
14 wouldn't be overly concerned about it. I would be more
15 concerned if they were relying on it for cases where they
16 couldn't rely on it or they shouldn't be relying on it.

17 I think in general that's a pretty good system.
18 It's got a lot of information on it that the operator could
19 use.

20 Once again, it gets back to what I was saying
21 before, as long as we're confident there's a backup and the
22 operator knows what to do for those situations where the
23 guidance tells him he shouldn't be relying on it, I don't
24 know that I'm too worried.

25 MR. JORDAN: Have we as an agency checked to make



1 sure there is a backup? For all the parameters that are
2 required either by the EOPs or by the SPDS, that there is
3 some type of 1-E instrumentation that would be available to
4 the operators to rely on?

5 MR. WERMIEL: It was my understanding that that's
6 what Reg Guide 1.97 was supposed to be doing. It was
7 supposed to be that minimum set that we could be confident
8 would be available for -- I guess I should say it, for
9 design basis events.

10 I don't know that we really have concentrated much
11 on what to do if you're in a scenario that goes beyond the
12 design basis, but for design basis events, that's what I
13 thought that 1.97 instrumentation was all about.


14 MR. IBARRA: The work that was done after TMI's
15 CRGR included a task analysis, functional task analysis,
16 where they actually broke down the procedures and the
17 instrumentation that would be used.

18 MR. WERMIEL: Yes.

19 MR. IBARRA: A lot of good work went into that.
20 Has the industry kept up with that?

21 MR. WERMIEL: Yes, they have. As part of the
22 DCRDR reviews that we do, we make sure that there is a
23 program in place for subsequent upgrades to the panels and
24 that kind of thing.

25 As far as I know, the industry in general is



1 pretty good about utilizing the same human factors
2 principles when they go in and modify panels after the
3 initial DCRDR review is done.

4 MR. IBARRA: So you would expect that as they do
5 an EOP revision they would go and look at it?


6 MR. WERMIEL: Absolutely. Oh, yeah. They would
7 go back and make sure that there is nothing that is missed
8 with regard to changes on the panel and this kind of thing.

9 One thing I will point out, though. When it comes
10 to modifications to control rooms, many plants are unable to
11 get a lot of the old analog equipment that they had been
12 used to and it had to buy newer digital technology and they
13 are starting to mix some of the digital technology with the
14 old analog equipment.

15 That has become a bit of a concern to us and we
16 are trying to develop some criteria to deal with that now,
17 but in general I don't know that I see a problem in the way
18 they've been upgrading control rooms. We think in general
19 they've been doing a pretty good job.

20 MR. VATTER: Jerry, you said something about
21 instrumentation necessary to support the EOPs was supposed
22 to be 1-E.

23 MR. WERMIEL: No, not necessarily. I think you
24 heard it wrong. Instrumentation to support the EOPs should
25 be geared to the particular scenario that you're in.



1 The EOPs deal with a spectrum of events. Some are
2 relatively minor and they go all the way to core melt. You
3 can get to core melt in some of the emergency procedure
4 guidance that's out there.

5 The instrumentation needs to be geared to the
6 particular set of circumstances and the EOP should be -- the
7 guy writing the EOP needs to know that if he's dealing with
8 a set of circumstances that's a result of loss of outside
9 power, the instrumentation he's asking the operator to rely
10 on has to be powered from an onsite source.

11 So you may start off with a certain set of
12 indications that are powered from offsite sources and then
13 you may end up with having to go back and check or verify
14 plant status with different instrumentation because the
15 symptom-based procedure has progressed to the point where
16 the old stuff is no longer available and the procedure
17 writer needs to know that.

18 He's telling the operator, hey, when you're
19 verifying pressurizing level and you're using this
20 instrumentation, it's the right stuff, it's powered from an
21 onsite source and you shouldn't care whether or not you've
22 lost outside power or not because I know you have and I've
23 made sure that the instrumentation you're going to rely on
24 is available.

25 Are you following me?



1 MR. VATTER: Yes. This time I am.

2 MR. IBARRA: Would you expect if you went to
3 Newberry's group, the instrument control section, that their
4 knowledge of the EOPs -- how would you characterize it --
5 good, bad?

6 MR. WERMIEL: Knowledge of the EOPs themselves?

7 MR. IBARRA: For instance, a question comes up on
8 the right -- the use of some instrumentation, would they
9 understand what the operator would be using it for? Would
10 they have enough knowledge to understand?

11 MR. WERMIEL: Yes, sure. In other words, you're
12 asking do they just concern themselves with the fact that
13 there is an instrument and its power supply or what that
14 instrument is used for?

15 MR. IBARRA: Both.

16 MR. WERMIEL: I think they do know both. I think
17 they not only know what their criteria are for the
18 qualification of that instrumentation but also what it's to
19 be used for. They understand enough of the thermal
20 hydraulics I believe to know why that instrumentation is
21 important.

22 MR. IBARRA: What branch within the agency would
23 look after the total integration procedures, qualification,
24 instrumentation, human factors?

25 MR. WERMIEL: I don't know that there is an



1 overall integration. We all have our areas of specialty and
2 then we would all write our evaluations based on our areas
3 of expertise and then it would all get folded into one
4 evaluation, usually by the project manager.

5 MR. IBARRA: If you are reviewing a procedure that
6 unknowingly might call for some electrical expertise or I&C
7 expertise, who would be able to catch that?

8 MR. WERMIEL: I would expect the human factors
9 people in my branch would know if there was some question
10 about the instrumentation that was being relied on because
11 their experience would tell them that for the particular set
12 of circumstances.


13 If the operator is being told to rely on something
14 that's unfamiliar to them I think they would question it and
15 then we would maybe ask the I&C people, hey, is this right,
16 is this really, say, Reg Guide 1.97 indication or is it not,
17 is it something that really shouldn't be there.

18 We have noted situations like that from EOP
19 inspections.

20 MR. IBARRA: It's a little bit -- It's not
21 heartening to know that sometimes you go into a control room
22 and ask the operator what that label means and they don't
23 understand what it means, especially Reg Guide 1.9.

24 MR. WERMIEL: Oh, yeah.

25 MR. IBARRA: Does that concern you?



1 MR. WERMIEL: It sure does.

2 MR. IBARRA: Is it typical?

3 MR. WERMIEL: Is it typical? I don't believe so,
4 no. I believe from what we know of operator training that,
5 particularly the training now being done with the newer
6 certified simulators that the operators are very familiar
7 with what's on the panel and what it means.

8 I would be very concerned if I was actually
9 talking to a reactor operator and he told me that. I would
10 be very concerned.

11 MR. IBARRA: The 1-E instruments they know very
12 well and in fact the labeling there, but the Reg Guide 1.97
13 instruments which is a subset of all this has another label.

14 Do you find that operators do not understand what
15 that extra label is or what that Reg Guide 1.9 indication
16 means? Would that surprise you for them not to know?

17 MR. WERMIEL: It would surprise me for them not to
18 know, absolutely. I can't say directly because I haven't
19 asked operators and I really haven't heard any feedback on
20 that. I would be surprised and it would bother my
21 confidence if I heard that. Knowing the importance we
22 placed on Reg Guide 1.97 instrumentation, that would bother
23 me.

24 MR. IBARRA: Is there too much labeling in the
25 control room?



1 MR. WERMIEL: As a general rule, no, I don't think
2 so. There may be an isolated case where a utility has gone
3 overboard perhaps but don't know of any. No.

4 I'm not a human factors person, but from my
5 limited exposure to it, I don't think you can provide the
6 operator with enough information on what things are.

7 Too often it's not that there's too much but that
8 there is too little. He just doesn't have enough
9 information to tell what him what this particular thing is
10 or isn't.

11 That was a big part of what the DCRDR review was
12 all about, to make sure that there were appropriate labels
13 and that things were arranged in a kind of systematic way so
14 that he could follow indications and controls in a more
15 concerted manner without having to go over here and go over
16 there and get lost, this kind of thing.

17 MR. IBARRA: From a human performance issue, is
18 communications in an emergency very important or what is
19 your thoughts on this?

20 We have situations where people lost
21 communication.

22 MR. WERMIEL: Communication in an emergency is
23 absolutely essential and I think it's one of the most
24 important areas, if not the most important thing that we do
25 is concern ourselves with crew communication.



1 MR. IBARRA: What are the regulations and the
2 guidelines for that?

3 MR. WERMIEL: I don't know that there are any.
4 I'm certainly not aware of any regulations.

5 The real test of crew communication is during
6 requal examinations when we put the crews in the simulator
7 and we run them through the EOPs, exercise them on the EOPs.
8 That's where we find problems and that's where we deal with
9 those kind of issues.

10 Inter-crew communication is a major part of what
11 we do when we conduct requal. It's a large part of it. If
12 they're not communicating, they probably won't get through
13 the scenarios very well and we'll end up with failures as a
14 result.

15 I don't believe there is any specific regulation
16 or criteria at all on how to communicate or what to
17 communicate.

18 I know there are techniques that improve
19 communication. My guys tell me all the time about how you
20 can better communicate during emergency situations and the
21 kinds of things that work better when we do run these crews
22 through requal and why certain crews have trouble with
23 communications.

24 It's a subjective thing and it is extremely
25 important because you've got to be able to tell everybody on



1 the crew what you know so that they all know.

2 MR. JORDAN: How about the communications systems,
3 not the ability to communicate but in-plant communication
4 systems?

5 MR. WERMIEL: In-plant communication systems? I
6 don't know a whole lot about them. They are very important.
7 There is no question about that.

8 MR. JORDAN: Do we have anything out to the
9 industry as far as the need for them?

10 MR. WERMIEL: We do. There's an SRP section on
11 communication systems. It's section 9.5.2, I think,
12 something like that, and there is guidance in there on the
13 kind of communications systems that ought to be in the
14 plant.

15 It's also extremely important because oftentimes
16 when you're in an emergency situation, particularly say if
17 there's a fire or some external threat, you need to have
18 somebody outside the control room communicating with the
19 control room, or when you're going to take a recovery action
20 or take some LOCA actions as called out in your procedures,
21 you've got to be able to communicate effectively with the
22 control room and there is guidance on the design of those
23 systems, power supplies and all that kind of stuff but
24 that's not my area. I'm not real familiar with what that
25 criteria says.



1 MR. JORDAN: How about some specifics on the EOPs,
2 such as rod position indication particularly for boilers?
3 Do we have any guidance or direction to the utility other
4 than 1.97 that requires them to have any type of a
5 reliability backup on those?

6 MR. WERMIEL: Not that I'm aware of. Not that I
7 know of.

8 MR. JORDAN: Loss of rod position indication?

9 MR. WERMIEL: That should have been accounted for
10 in the emergency procedure guidelines and it should have
11 been factored into the appropriate emergency procedures.

12 MR. JORDAN: Do you know if it was?

13 MR. WERMIEL: Not offhand, no, not specifically.

14 MR. KAUFFMAN: Would you be concerned if there is
15 an event and a loss of RPIS or RSCS and basically no way to
16 tell rod positions other than the APRMs, source range
17 monitors?

18 MR. WERMIEL: That's right. I wouldn't be
19 concerned about rod position as long as I had some
20 indication of flux within the core.

21 If I had source range or if I had intermediate
22 range and it was working and I could rely on it, I wouldn't
23 be as concerned. I'm never as concerned if I have a backup
24 indication of some sort that I can rely on.

25 MR. JORDAN: And those backups, you expect those



1 backups to be backed up by a class 1-E type of
2 instrumentation?

3 MR. WERMIEL: I would -- I hope our criteria for
4 those backups counts for that kind of thing and again Reg
5 Guide 1.97 I believe should have some guidance in there.
6 which would tell us that, yes, we can -- it's appropriately
7 powered and we can rely on it.

8 I would have hoped -- I don't know that we thought
9 about these things when we developed the criteria for what
10 the power supply should be for that instrumentation but I
11 would hope we did.

12 MR. JORDAN: Is that your section that does that,
13 or your branch?

14 MR. WERMIEL: No.


15 MR. JORDAN: That's electrical?

16 MR. WERMIEL: Actually I&C I think,
17 instrumentation and controls systems branch would definitely
18 have looked at that.

19 MR. JORDAN: You expect them to look at the
20 backup?

21 MR. WERMIEL: I expect -- maybe I should clarify
22 that.

23 The analysis for the design basis of that which
24 the reactor systems branch looked at should have identified
25 the kinds of indications that the operator would need to



1 cope with the event.

2 Then the instrumentation and controls systems
3 branch should have made judgments in their criteria about,
4 because of the importance in working with reactor systems
5 branch, what should be the backup power supply.

6 If this is a backup to another indication, then
7 that backup ought to be on a reliable power source and I
8 thought that's how the process worked when Reg Guide 1.97
9 was developed.


10 MR. JORDAN: When you defined reliable power
11 source, are you talking about 1-E or are you just talking
12 about UPS in general? What does your group consider are
13 adequate backup power supply?

14 MR. WERMIEL: It depends but for the most
15 significant events it should be 1-E. It should be a reliable
16 onsite source 1-E, fully safety-related.

17 There ought to be -- I ought to make one more
18 statement. There ought to be 1-E indication of a minimum
19 set that reactor systems branch says has got to be there for
20 the operator to deal with that particular scenario, bottom
21 line.

22 MR. JORDAN: Do we expect them to have indications
23 down to cold shutdown, hot shutdown? Do we establish a
24 position where --

25 MR. WERMIEL: I'm sure that for hot shutdown we



1 have established a position that there ought to be 1-E
2 indication of everything that they need.

3 For cold shutdown, I don't know that I would be
4 quite as concerned because probably I could take some
5 actions, recovery actions, to recover power supplies for
6 cold shutdown instrumentation.

7 Again, I don't know what the criteria says. I
8 don't know that you need to have 1-E, though, all the way
9 down to cold shutdown necessarily. I don't know what we
10 call for.

11 MR. JORDAN: You do not know what's called for in
12 the EOPs?

13 MR. WERMIEL: In the EOPs I don't believe it is
14 called for. I don't know that 1-E indications of cold
15 shutdown are called for.


16 MR. JORDAN: But for hot shutdown?

17 MR. WERMIEL: Hot shutdown, I believe so. I think
18 so. That's my recollection, anyway.

19 MR. IBARRA: The EQ program, environmental
20 qualification program, how did it affect your group as far
21 as procedures are concerned?

22 MR. WERMIEL: I don't believe it affected -- A lot
23 of that was done before I got to the branch but it shouldn't
24 have had any impact at all.

25 Once again, back to what I was saying before, if



1 you're going to rely on instrumentation for an event where
2 you have a harsh environment, the program calls for that
3 instrumentation to be qualified and it was always that way
4 and we would in our audits make sure the plant is not asking
5 the operator to use equipment to cope with a LOCA that's not
6 LOCA qualified.

7 We would hopefully, if there was a question we
8 would try to pick that thing up. We would try to pick up
9 situations where you can't rely on those indications because
10 they're not LOCA qualified.

11 MR. IBARRA: Do you think there is adequate
12 integration of all disciplines within the EOP as it stands
13 today within the agency?

14 MR. WERMIEL: I think so. I think the EOP
15 inspection program was very useful and was very successful.
16 As a matter of fact, we've learned so much from those
17 inspections that we are going to publish a revision to the
18 previous lessons learned document from the EOP inspections
19 and it's going to cover a wide variety of lessons learned, a
20 wide spectrum of things.

21 We're working on that right now and we've met with
22 the regions to discuss issues and findings from the EOP
23 inspection program. I wish I could think of the reg number
24 of the previous lessons learned document but I can't.

25 I think it was, as I say, quite a successful



1 program.

2 MR. JORDAN: Do you know of any indication or
3 instrumentation or equipment in which we as an agency at the
4 staff level or at your level felt should have been 1-E
5 qualified and the industry took exception to it which then
6 caused some type of interface between the two that said now
7 it's got to be resolved at a higher level than yourself?

8 MR. WERMIEL: I'm not aware of any, no. It
9 wouldn't surprise me if there were some but I don't know of
10 any circumstances that came up like that because I was never
11 involved in those reviews.


12 I hope you ask Joe Joyce about some of this
13 because I know he was a big part of Reg Guide 1.97
14 implementation.

15 MR. IBARRA: What would be your involvement let's
16 say in the licensing of Nine Mile Point? Can you just tell
17 me typically on opening a new plant what your group would
18 do?

19 MR. WERMIEL: What we would typically do with any
20 new plant?

21 MR. IBARRA: Any new plant.

22 MR. WERMIEL: Sure. We're responsible for two
23 sections of the standard review plan, a large part of
24 Chapter 13.0 of the standard review plan, and Chapter 18 of
25 the standard review plan.



1 Chapter 13 has in it the review of the applicant's
2 procedures and training, management and organization and
3 staffing questions. Chapter 18 is the review of the man-
4 machine interface, specifically the SPDS and the control
5 room design review.

6 That would be the bulk of human factors assessment
7 branch review for a new plant. That's the kind of thing
8 we're doing right now in our review of the proposed standard
9 designs, the new standard designs.

10 MR. JORDAN: When you do your design review, is it
11 strictly just how it's laid out, availability, access to the
12 equipment, instrumentation?

13 Can you give me an idea of what all you people
14 look at, or do you look in depth and say where the
15 instrumentation is powered from, how many pieces of
16 instruments are powered off of the same, so if you lost one
17 source of power this group of instruments are going to be
18 gone and now they're going to have to rely on something
19 separate from that?

20 MR. WERMIEL: It's the former, not the latter. We
21 don't get into these questions of backups and power supply
22 availability and that kind of thing. It's what I'll call a
23 classical human factors type review.

24 We look to see that there are some analyses that
25 have been done to confirm that the indications are in the



1 right place and that the operator can utilize them and that
2 there is good labeling and good identification of controls
3 and that they are laid out in a systematic way, that kind of
4 thing.

5 We don't really get into what I would
6 characterize, I guess, as review of the backup capability
7 and backup sources of power, that kind of thing. We don't
8 do that.

9 MR. IBARRA: In our review of training, do you
10 envision them losing annunciators?

11 MR. WERMIEL: Oh, yes.

12 MR. IBARRA: Balance of plant equipment?

13 MR. WERMIEL: Absolutely. The procedures
14 themselves provide guidance for those kind of situations an
15 the training is supposed to be on those emergency operating
16 procedures so the training should cover those kind of
17 eventualities. Oh, yeah. Sure.

18 Those are also situations that are easy to
19 simulate in the simulator. You can turn off the
20 annunciators very easily and see how the operator copes with
21 that in the simulator.

22 MR. KAUFFMAN: I just have one more EOP question.
23 In a BWR if you're in the EOP for pressure control and the
24 operators are running RCIC, would you expect reactor
25 pressure to remain stable there while they're running RCIC



1 for level control?

2 My own expectation is that it depends on the decay
3 heat.

4 MR. WERMIEL: Yeah. If decay heat is going down,
5 sure, then he's going to have to cut back or he's going to
6 over-cool.

7 You're speaking of initially in the --

8 MR. KAUFFMAN: Yes.

9 MR. WERMIEL: Yeah, initially it should stay
10 stable, sure, but as he gets further down he's going to have
11 to cut back on his flow or he's going to over-fill or over-
12 cool.

13 MR. KAUFFMAN: Okay. If we're in the ATWS
14 mitigation parts of the procedures and are using RCIC to
15 inject and not depressurize until we have rods in, I guess
16 what would you expect the operator to do? Do you expect him
17 to shut down his IVs to keep from cooling down, terminate
18 RCIC injections?

19 MR. WERMIEL: Oh, no. I expect him to keep RCIC
20 on but he does not have -- He's not confident that he's got
21 the rods in. Are you saying this an ATWS scenario?

22 MR. KAUFFMAN: Yes.

23 MR. WERMIEL: He's already initiated standby
24 liquid control.

25 MR. KAUFFMAN: He has not at that point because he



1 hasn't reached high suppression pool temperature.

2 MR. WERMIEL: Okay, so he's not quite there yet
3 and he doesn't know whether he's going to be able to get the
4 rods or not.

5 MR. KAUFFMAN: Right.


6 MR. WERMIEL: Okay, so what would I expect him to
7 do?

8 MR. KAUFFMAN: I guess we're saying what we
9 reviewed when we reviewed this event is we have different
10 steps that basically one is keep water in, the other one is
11 saying don't decompressurize, and I guess our question is
12 which one overrides, which one is most important and should
13 there be contingencies there that tell him what to do.

14 MR. WERMIEL: I think there should have been some
15 contingencies to tell him what to do. If there aren't,
16 maybe that's something that was missed. Frankly, I would
17 think it would be more important that he continue to
18 maintain flow, RCIC, particularly under those situations if
19 the rods are not in.

20 If he's not confident the rods are in, then he's
21 still with power so he needs to have the flow. That would
22 be my judgment, although I'm not an operator.

23 You're saying though that he really wasn't clear
24 what he should be doing, huh? He shouldn't be
25 depressurizing yet?



1 MR. KAUFFMAN: They had APRM downscaling it and
2 SRMs upscale.

3 MR. WERMIEL: He was getting conflicting
4 information?

5 MR. JORDAN: He had no rod indications, none.

6 MR. WERMIEL: So he didn't know that they were in.

7 MR. JORDAN: All he had was flux indications.

8 MR. WERMIEL: And flux was telling him --

9 MR. KAUFFMAN: Source range monitors were reading.
10 He had maintained level and he uses RCIC. The question is
11 if he loses RCIC he's going to decompressurize, he's going
12 to cool down.

13 MR. WERMIEL: He's got to right at that point.

14 MR. KAUFFMAN: If he doesn't use RCIC the options
15 are he closes the MSIVs to stop any type of flow and he's
16 still making cooldown.

17 MR. WERMIEL: Yeah. If he shuts down his IVs he
18 will collapse the voids.

19 MR. JORDAN: We don't know if we looked into that
20 area or if the vendor has even looked into that area when
21 they did their EOP design.

22 MR. WERMIEL: I'm not sure that they did. I don't
23 know. I would be surprised if the emergency procedure
24 guidance didn't account for this kind of a situation. Maybe
25 not --



1 MR. JORDAN: It's not clear.

2 MR. WERMIEL: It's not clear that it did.

3 MR. JORDAN: It's not clear. It may have subtly
4 by the direction that it gave but it's not clear looking at
5 the EOPs that that is there.

6 MR. WERMIEL: I see.

7 MR. JORDAN: That if you are now subcritical but
8 if you continue to cool down you may go critical, do you go
9 ahead and continue to cool down if you don't know --

10 MR. WERMIEL: If you don't know that the rods are
11 in. It strikes me if I didn't know the rods were in, I
12 would want to maintain flow at all costs.

13 MR. JORDAN: That's the thing. If that's in
14 there, it's in there very subtly.

15 MR. WERMIEL: I see.

16 MR. JORDAN: It's not clear that says this is why
17 you want to do this even if you have the ATWS and it's
18 subcritical you may go critical again but go ahead and use
19 RCIC anyway even if you do cool down. That's not clear in
20 the EOPs.

21 MR. WERMIEL: I see. It should have been.

22 MR. JORDAN: Using RCIC without sufficient decay
23 heat or without having a critical reactor, you're probably
24 not going to get heat out of it, so therefore the question
25 is with the EOPs would you expect him to go ahead and use



1 RCIC anyway and continue to cool down and maintain flow?

2 MR. WERMIEL: I would say so. What would be wrong,
3 even if decay heat is go down, with continuing to use RCIC.
4 So it over-cooled a little bit. What's the --

5 MR. JORDAN: It's not allowed by the EOPs.

6 MR. KAUFFMAN: It says don't depressurize until
7 all the rods are in.

8 MR. WERMIEL: It says make sure rods are in.
9 There is kind of a conflict here so he's in kind of a
10 quandary is what you're saying.

11 MR. JORDAN: Which is more important -- don't cool
12 down or maintain level?

13 MR. WERMIEL: Maintain level. I don't know if I
14 would be that concerned about over-cooling a little or over-
15 filling a little. Over-filling, maybe, but not over-
16 cooling. I could still maintain level. I would do that.

17 MR. KAUFFMAN: There's a concern with over-
18 cooling in that that adds positive reactivity.

19 MR. WERMIEL: That's true, too, but that's a minor
20 concern, isn't it? I mean that comes farther down. That
21 would be pretty far down in decay heat before that becomes a
22 problem, doesn't it?

23 MR. JORDAN: I don't know.

24 MR. WERMIEL: I don't know, either, but I would
25 think so.



1 MR. JORDAN: Not being a systems engineer, all I
2 know is what the EOPs say.

3 MR. WERMIEL: I can see where you would be
4 concerned but I think I would be more worried about damaging
5 the fuel. Maintain level is what I would do.

6 MR. JORDAN: But you don't have any problem where
7 that's been identified before, either?

8 MR. WERMIEL: Not that I'm aware of, not as a
9 specific technical issue. Somebody from reactor systems
10 branch would be a better person to ask about that, somebody
11 from Bob Jones' shop.

12 How did they resolve the dilemma, incidentally?
13 They just kept going? Good.

14 MR. JORDAN: Do you know if the IRM -- maybe
15 you're the person or maybe not -- Do you know if the IRM,
16 the drive mechanisms, are 1-E qualified?

17 MR. WERMIEL: I don't think so, no. I don't
18 believe they are. Just the -- I don't know for sure but I
19 don't think they are. Somebody else would be a much better
20 source of information on that. I don't think they are.

21 MR. JORDAN: I think 1.97 qualified I guess is the
22 proper terminology.

23 MR. WERMIEL: There's a lot of strange terminology
24 in 1.97, this and that.

25 MR. JORDAN: I don't have any more questions.



1 Does anybody have any more?

2 We'll go off the record.

3 (Whereupon the matter concluded at 1:18 p.m.)

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: IIT Interview of Jared Wermiel

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Marilynn Estep

Official Reporter
Ann Riley & Associates, Ltd.



OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Incident Investigation Team

Title: Interview of Jared Wermiel

Docket No.

LOCATION: Bethesda, Maryland

DATE: Friday, August 30, 1991 PAGES: 1 - 46

ANN RILEY & ASSOCIATES, LTD.
1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950.

Dupe of


~~930507012-1~~



ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
6	14	"outside" power" should be "offsite power"
18	3	"implementation and control" should be "instrumentation and control"
21	9	Add the word "it" prior to "an awful lot..."
29	3	Add the word "I" prior to "don't know..."
29	6	Change "enough" to "too much"
33	23	Change to read " The analysis for the design basis events which the ..."
40	21	Add the word "is" prior to "an ATWS..."
41	4	Add the word "in" prior to "or not."
42	17	Change to read " If he shuts the MSIV's he ..."
44	3	Change the word "go" to "going"

Date 9.20.91 Signature JS



1
2 UNITED STATES OF AMERICA
3 NUCLEAR REGULATORY COMMISSION
4 INCIDENT INVESTIGATION TEAM
5
6

7 INTERVIEW OF)
8)
9 JARED WERMIEL)
10)

11
12 Nuclear Regulatory Commission
13 The Woodmont Building
14 8120 Woodmont Avenue
15 Bethesda, Maryland
16 Friday, August 30, 1991
17

18 The above-entitled interview convened, pursuant to
19 notice, in closed session at 12:15 p.m.
20

21 PARTICIPANTS:

- 22 MICHAEL JORDAN, NRC/IIT TEAM
23 BILL VATTER, NRC/IIT TEAM
24 JOSE IBARRA, NRC/IIT TEAM
25 JOHN KAUFFMAN, NRC/IIT TEAM

11



P R O C E E D I N G S

1
2 MR. JORDAN: Good morning. This is August 30th at
3 approximately 12:15. We are here talking and having a
4 discussion about an event that happened on August 13th at
5 Nine Mile Unit 2.

6 Jerry, why don't you go ahead and tell us what
7 your background is, what your experience right now is and
8 what your current position is and the type of activities of
9 and responsibilities of that position.

10 MR. WERMIEL: Sure. I'm currently the branch
11 chief of the human factors assessment branch in the division
12 of licensee performance and quality evaluation, Office of
13 Nuclear Reactor Regulation.

14 As such, we are responsible for those regulatory
15 activities that deal with human performance, emergency
16 operating procedures, training, man-machine interface
17 questions, questions of staffing, all issues that relate to
18 proper performance of the operations staff at a nuclear
19 power plant.

20 I have been in this position now since May of
21 1990. Prior to that I was in the plant systems area as a
22 section chief and prior to that as a reviewer.

23 My background is primarily in the support, reactor
24 support systems area and in balance of plant systems area.

25 I am an engineer. I'm not a psychologist and my



12

13

14

15



16

17

18

19

20

21



1 background is primarily in fluid systems.

2 I joined the NRC in March of 1978 and have been
3 with the agency since that point.

4 MR. JORDAN: I guess we should at least introduce
5 for the record who we are. My name is Michael Jordan. I'm
6 with the USNRC out of Region 3. I'm a section chief for
7 boiling water reactors and operator licensing.

8 MR. VATTER: I'm Bill Vatter and I'm on loan to
9 the IIT from INPO.

10 MR. KAUFFMAN: John Kauffman out of NRC
11 headquarters.

12 MR. IBARRA: Jose Ibarra from the instrument
13 controls systems branch of NRR.

14 MR. WERMIEL: Does anybody have a particular
15 question they want to start out with?

16 MR. IBARRA: Jerry, who reviewed the EOPs in the
17 agency, the EOPs coming out of Three Mile Island, or after
18 Three Mile Island?

19 MR. WERMIEL: By who you mean what individual?

20 MR. IBARRA: What branch.

21 MR. WERMIEL: Programmatic responsibility for the
22 review of the emergency operating procedures is with the
23 human factors assessment branch and that would have been the
24 responsibility that they had. The actual review was
25 conducted as part of the emergency operating procedure

8



1 inspection program.

2 In other words, the region was responsible for
3 conducting an EOP inspection that was supported by
4 headquarters of the procedures at the plant. That review
5 was primarily to confirm implementation of commitments that
6 were made after TMI with regard to incorporation of the new
7 emergency procedure guidelines, the writer's guide, the
8 proper verification and validation of the procedures, all
9 those sorts of things.

10 That's all included in this emergency operating
11 procedure inspection program. I believe it's Manual Chapter
12 41500, I think is the actual inspection module that's
13 involved here.

14 MR. IBARRA: In that review, who would be the
15 technical contact? Who would look at instrumentation and
16 controls and electrical systems?

17 MR. WERMIEL: There would be members on that team
18 that would have expertise in the technical areas and I
19 believe there should have been some expertise on the team in
20 I&C, although that may not have been a specific area that's
21 called out, and there is also expertise on the team in the
22 human factors area so we have both technical experts and
23 human factors people on those teams.

24 There isn't, as I recall, a specific requirement
25 that there be an electrical -- a person with electrical



10

11

12

13



14

15

16

17

18

19



1 background on that inspection team. There usually is
2 somebody with systems understanding or systems experience,
3 mostly reactor systems experience.

4 MR. IBARRA: How about as far as computer systems,
5 SPDS and so forth, as they relate to the EOP?

6 MR. WERMIEL: A human factors person may have some
7 knowledge of SPDS, of the DCRDR review, but the review from
8 the human factors perspective is primarily a verification of
9 the usability of the procedure -- is the procedure laid out
10 in a way that the operator can appropriately implement it,
11 does it have all the information the operator needs to take
12 the actions he needs to take, is it sequenced in a way where
13 if he follows it he'll be doing the right thing, that kind
14 of a look.

15 We don't do that I'm aware of any kind of a direct
16 check of how the SPDS was incorporated in the procedures or
17 that sort of thing. It's more -- at least from the human
18 factors perspective, it's more a verification that the
19 writers guide which provide guidance on how to make these a
20 user-friendly procedure, has it been implemented properly
21 and are these indeed procedures that the operator if he
22 follows successfully will lead him down the right path, will
23 work right.

24 MR. IBARRA: If we were looking at the
25 instrumentation that the operator is using to carry out his



12

13

14

15

16



17

18

19

20

21

22

23

24



1 task, how do we link up that with the qualification of that
2 instrument being able to know that it does survive under the
3 conditions that he would be using it?

4 MR. WERMIEL: Okay. That would not be done
5 procedurally, not in the EOP procedure per se. It's the --
6 I would assume and it is my understanding that the people
7 writing the procedures know what instrumentation is
8 qualified and what can be relied on for the various
9 scenarios so when they develop the procedures they will know
10 that whatever indications or controls that they are asking
11 the operator to utilize to conduct the necessary steps are
12 indeed available -- in other words, they are powered from an
13 available power source if the procedure involves a loss of
14 outside power, they are environmentally qualified if the
15 procedure is steamline break or a LOCA procedure so the
16 operator doesn't have to concern himself with that.

17 In other words, the basis for the procedure and
18 the equipment that's being called out has already been
19 checked. It's been verified and validated that this is
20 equipment that's available and can be used for the
21 particular accident or transient situation that he's in.

22 MR. JORDAN: When you say procedure, you're saying
23 the utility's procedure review of it or our guidelines or
24 the industry's guidelines?

25 MR. WERMIEL: We call for that. It's up to the



1 utility to make sure that the procedure writer is doing
2 that.

3 MR. JORDAN: Do we identify what instrumentation
4 we expect to be qualified?

5 MR. WERMIEL: Sure.


6 MR. JORDAN: Do we tell them which instrumentation
7 we expect to have on 1-E course of power and --

8 MR. WERMIEL: As far as I know. I&C isn't my
9 area. I would hope that Scott Newberry could help you out
10 there but it's my understanding is absolutely. Reg Guide
11 1.97, for example, is a set of instrumentation that's
12 supposed to be available to follow the course of an accident
13 and that instrumentation has certain power supply criteria
14 associated with it.

15 MR. JORDAN: So your group relies on the I&C's
16 people to identify what instrumentation will be available
17 for use in the EOP?

18 MR. WERMIEL: Right. That's correct, and then we
19 would assume that once the utility knows what
20 instrumentation they are taking credit for to satisfy the
21 criteria, that the procedure writer then incorporated it in
22 the procedure and doesn't tell the operator to rely on
23 something that isn't appropriately qualified for the event
24 that he's to deal with.

25 MR. JORDAN: So we leave that up to the utility.



1 MR. WERMIEL: Right. Sometimes we will identify
2 circumstances where we will question the instrumentation or
3 the -- we don't deal with the word "instrumentation" as much
4 as "indications."

5 The indications that the operator is to rely on,
6 we may question it. We may say you're telling him to rely
7 on this, is this something that he can rely on, is it going
8 to be available, and even if it is, is it something that's
9 been appropriately qualified.

10 During the inspection we may catch that. We may
11 ask about that as part of our -- it comes out of the
12 verification and validation work. It may come out of that.


13 MR. IBARRA: But it is part of the EOP program,
14 right?

15 MR. WERMIEL: It may, yes, may come out.

16 MR. IBARRA: Other than the inspection program, do
17 we have other mechanisms within the agency that would look -
18 - other than that inspection?

19 MR. WERMIEL: We do periodically under certain
20 circumstances look at operating procedures, yes, for other
21 reasons.

22 The EOP inspection program I'm speaking of is a
23 generic program that went on for several years but on a
24 periodic basis we're asked to look at certain aspects of
25 procedures or procedural steps to verify that they are



1 appropriate and they'll do what the utility claims they'll
2 do.

3 We're doing that right now, for example, for
4 Yankee Rowe and this question of the embrittled reactor
5 vessel. The utility was asked to modify their procedures to
6 do some things that would reduce the likelihood of a
7 pressurized thermal shock incident and they made some
8 procedural changes and we are now looking at those changes
9 to confirm that they will indeed -- first of all, that they
10 make sense for the intended purpose and that they can indeed
11 be accomplished the way the utility intends them to be
12 accomplished.

13 We don't do that very often but we do get requests
14 to do that sort of thing in certain cases.

15 MR. IBARRA: Do you supply support to the DCRDR
16 audits and the SPDS audits? Is that within your group?

17 MR. WERMIEL: Absolutely, yes. Yes. That was a
18 big push for quite a few years within this branch that I'm
19 in now.

20 When I got into the branch, those two programs
21 were nearly complete and since the time I've been there we
22 have completed the DCRDR reviews and the SPDS reviews but
23 that was an ongoing program for many, many years within the
24 human factors assessment branch.

25 MR. VATTER: Jerry, can you tell us how you go



10



12

14



16

1 about doing a human factors inspection for procedures?

2 MR. WERMIEL: Sure. Typically the region will --
3 Let me use the last plant as an example.

4 We just right now as a matter of fact, as we speak
5 they are completing the final inspection of Perry, the last
6 plant that's to undergo the full EOP inspection -- emergency
7 operating procedure inspection.


8 The region will identify the schedule for
9 completion of those inspections. They will identify the
10 people that they believe they need to accomplish the
11 inspection in accordance with the inspection module that I
12 mentioned.

13 If they need expertise from headquarters or
14 support they will contact us and we will provide them either
15 contractor technical assistance or somebody from my staff.

16 In certain cases, people from my staff have
17 actually gone on inspections but generally we'll provide a
18 contractor assistance from one of our contractors.

19 Then the team goes out and conducts the inspection
20 and in the course of conducting the inspection I'll get
21 feedback or the section chief who works for me will get
22 feedback from the team.

23 When the inspection is completed and the report is
24 written, we'll get copies of the report and if there's any
25 additional followup, either a followup inspection or



1 followup of closing out certain open items, we may again be
2 contacted by the region for assistance.

3 Often on an EOP followup inspection, we will again
4 be asked to provide contractor assistance, not usually for
5 closing out open items but sometimes we are asked to help
6 out for that, too.

7 MR. VATTER: What sort of techniques do the
8 inspectors use to make sure that the human factors are okay?

9 MR. WERMIEL: I'm not real familiar with the
10 details because I haven't been involved in an actual
11 inspection and my staff has been doing this for many more
12 years than I've been involved.

13 Generally, we have guidance. It's in a NUREG and
14 I wish I could think of the number. We have guidance on how
15 to conduct a human factors assessment of EOPs, what to look
16 for in the writers guide, what to look for in a V&V program,
17 what to look for in a walkthrough, what to look for when we
18 ask the utility to simulate the procedures by a simulator
19 scenario evaluation. It's all pretty well spelled out.

20 MR. VATTER: So you do observe some simulator
21 scenarios --

22 MR. WERMIEL: Yes, we do.

23 MR. VATTER: -- and procedures?

24 MR. WERMIEL: Yes. That's called out in the EOP
25 inspection module that we actually have them exercise the



1 EOPs in the simulator so that we can get some firsthand
2 knowledge of how the operators do using them.

3 We usually leave it up to the utility to select
4 what crew or what teams they want to put in the simulator to
5 run it through for us and we often get some pretty
6 substantial feedback from that, some pretty good insights
7 from that.

8 MR. JORDAN: Do you have any guidance -- You
9 mentioned 1.97 Reg Guide.


10 MR. WERMIEL: Yes.

11 MR. JORDAN: Do you have any guidance that says in
12 order to perform the EOPs, in order to get through any
13 particular step in the EOP that you've got to have something
14 that's qualified to 1.97, or is it just --

15 MR. WERMIEL: I don't know that we get that
16 specific, Mike. I believe it really is more a check on
17 whether or not the utility was aware that they needed to
18 make sure that when they wrote the procedure, as part of
19 that, the person who did it knows that he can't be asking an
20 operator to use equipment that isn't qualified.

21 If he's writing a LOCA procedure or a LOCA
22 recovery, the equipment has got to be environmentally
23 qualified and he can't be asking the operator to rely on
24 indications that are not because he'll get --

25 MR. JORDAN: Is that in the guidelines or is that



1 in--- where have we transmitted that to the utility?

2 MR. WERMIEL: I don't know that that is
3 specifically spelled out in the guidelines. I would have to
4 go back and look for you. We could do that. I don't know
5 that I've ever seen that.

6 What I think is called out is a more general
7 statement that the procedure writer as part of his V&V
8 verifies the availability of indications and controls, that
9 kind of thing.

10 MR. JORDAN: That's in the guidelines?

11 MR. WERMIEL: I believe it's in the guidelines on
12 V&V, yes.

13 MR. JORDAN: And the guidelines come from us or
14 from the industry?

15 MR. WERMIEL: From us.

16 MR. JORDAN: From us?

17 MR. WERMIEL: Yes.

18 MR. JORDAN: Our guidelines to the industry on how
19 to write EOPs?

20 MR. WERMIEL: That's correct.

21 MR. JORDAN: And in there you think there's a
22 section that says make sure that they have --

23 MR. WERMIEL: I sure do think so because I know
24 it's part of what we consider. I just don't know how
25 explicit it is.

64

41

42

43

44

45

46

47



1 MR. IBARRA: The team member on this inspection
2 team, would he be knowledgeable in all the programs to be
3 able to make that assessment?

4 MR. WERMIEL: He would -- The human factors person
5 may not be but somebody on the team would know what
6 environmental qualification means and ought to be able to
7 judge, yes, that when the utility tells him we are utilizing
8 1.97 instrumentation that indeed they are using 1.97
9 instrumentation.

10 In other words, he would be familiar enough with
11 what that means to at least be able to judge that, yeah, the
12 utility was doing it right. I would think so, yes.

13 MR. IBARRA: What does the term important to
14 safety as far as EOP tasks are concerned, what does that
15 mean to you? Does that carry any significance whatsoever?

16 MR. WERMIEL: It certainly did from a hardware
17 perspective in my previous life, but when you deal with
18 people it doesn't mean a thing.

19 All the old terminology that I'm familiar with --
20 important to safety, safety-related, safety grade -- doesn't
21 mean a thing when we talk about people. We throw out all
22 that stuff -- single-failure criterion -- doesn't mean a
23 thing.

24 We basically rely on the operating procedures and
25 the operator's training to ensure that he'll do the right



4



2

3

7

1

1

4

2

2



1 thing. We don't I guess grade his performance. We just
2 assume he's going to do the right thing if his procedure is
3 okay and his training supports it.

4 MR. IBARRA: Every time there is a revision to the
5 procedure, how do they take care of it? Do they re-review
6 it?

7 MR. WERMIEL: Not as a general rule. We do not,
8 no. Once we've confirmed that the writers guide and the
9 program, the V&V program and all that kind of thing, is
10 acceptable, we would assume that any subsequent revisions
11 would be done in accordance with their procedure revision
12 program that we looked at and therefore we would expect that
13 it would be okay.

14 The questions may come up but again they would be
15 isolated. Unless it was part of an EOP followup, we
16 wouldn't get involved. We wouldn't oversee frequent changes
17 to th emergency operating procedures.

18 MR. JORDAN: How do vendors propose changes?
19 You're talking about the site changes. What about the --

20 MR. WERMIEL: If the emergency procedure
21 guidelines are changed, and particularly if there is a
22 substantial change, then I would expect that we would be
23 reviewing that, yes.

24 MR. IBARRA: Things like three years ago, four
25 years ago, when CE changed their philosophy on the number of



11

11

11

11



11

11

11

11

11



11

1 reactor coolant pumps?

2 MR. WERMIEL: That would be reviewed. No question
3 in my mind those kind of things because they go to the --

4 MR. JORDAN: Do you review those things?

5 MR. WERMIEL: Not the thermal hydraulic or the
6 technical adequacy of that but if there is anything that
7 results from that that changes the operator's indications or
8 the actions the operator takes, yes, we might get involved.


9 From a thermal hydraulic standpoint, though, and
10 the technical adequacy of that, the reactor systems branch
11 would do that.

12 MR. JORDAN: Do you then look at whether or not
13 performance of the steps and the actions that you would
14 expect from the operators is adequate?

15 MR. WERMIEL: That's right. We sure would,
16 particularly if there were new indications involved or new
17 actions the operator was to take, then we would probably get
18 involved.

19 MR. IBARRA: In your normal review, whatever your
20 group function would be as far as procedure is concerned,
21 does the electrical systems branch and the I&C branch, are
22 they all in concurrence on those?

23 MR. WERMIEL: If -- On almost everything we do
24 that involves EOPs from a technical adequacy standpoint, we
25 get the reactor systems branch involved. I can't think of a



1 case where we've gotten instrumentation and control or
2 electrical involved and that may be only because the kinds
3 of changes that we're talking about didn't affect the power
4 supply or the instrumentation.

5 Usually the process works that the request or the
6 need for the change goes through reactor systems branch and
7 they farm it out to us and the other review branches and I'm
8 trying to think whether --


9 I would assume that if there's a change in
10 instrumentation that would affect them that I&C would be
11 involved or a power supply question that the electrical
12 branch would be involved. I just can't think of an
13 instance where that's happened.

14 MR. IBARRA: Who makes that determination of who's
15 going to be on concurrence and who will be supporting whom?

16 MR. WERMIEL: If it's a licensing change, it goes
17 to the project manager and then the project manager would
18 parcel it out to the appropriate technical branches for
19 review.

20 MR. IBARRA: Okay, and the branches themselves
21 might ask for additional support and then it will be up to
22 them?

23 MR. WERMIEL: Absolutely, and oftentimes when we
24 get a request, if we're not confident that reactor systems
25 branch has seen it, because they need to, we'll make sure



1 they do see it.

2 Those are the examples I can think of. I can't
3 think of cases where implementation and control or
4 electrical were ever involved because we needed them to be
5 involved.

6 MR. IBARRA: We see that Reg Guide 1.97 is an
7 instrumentation issue but have you all supported -- Did you
8 all have any input whatsoever into --

9 MR. WERMIEL: The review of Reg Guide 1.97? No.
10 No, we didn't.

11 MR. IBARRA: How about any other instrumentation
12 dealing with, let's say the tech specs instrumentation
13 that's in there as far as they relate to the procedures, is
14 there a link there somewhere?

15 MR. WERMIEL: Not that I can think of, no.

16 MR. IBARRA: When you review SPDS, do you
17 typically ask for I&C support?

18 MR. WERMIEL: Yes. Typically those reviews had
19 both an I&C input and a human factors input, yes,
20 particularly from the standpoint of isolation of the power
21 supply to the SPDS. Since it was not on a 1-E bus there was
22 some concern about making sure that if SPDS should fail that
23 other instrumentation that the operator would rely on would
24 not fail.

25 Since a lot of the indications on SPDS are the



1 same indications that you would rely based on Reg Guide
2 1.97, a lot of them are the same, whereas the one that's a
3 non qualified component, the other should be.

4 MR. IBARRA: Would your group be concerned that,
5 for instance, SPDS is not safety-related and it would go
6 down in an emergency?

7 MR. WERMIEL: We are not concerned so long as we
8 are confident that there's a backup, a reliable backup. We
9 think from a standpoint of the high level display that the
10 SPDS is a real good operator aid and as long as it's
11 available it will probably be easier for him to do a lot of
12 things and get a lot of information from SPDS, but if it
13 goes down we're confident that there are other indications
14 that the operator would have to allow him to get through the
15 EOPs just fine.

16 MR. IBARRA: Is there a concern when the operators
17 lose annunciators and a lot of the backup instrumentation,
18 not necessarily the safety-related?

19 MR. WERMIEL: Sure. There is always a concern
20 where -- at least in our minds -- where if the operator has
21 only, say, one indication of something or one channel of
22 indication of something, that he may feel more hesitant to
23 rely on it because he can't verify it by looking at
24 something else.

25 There is always the desire to be able to confirm



11

2

12



13

14



1 an indication by looking at something else or even inferring
2 that he's doing the right thing by some indication so the
3 more you lose, oh, yes, definitely we would be a little more
4 concerned that the operator may be more apprehensive about
5 what he's doing because he has to rely so much on a single
6 indication or a much smaller set of indications. Sure
7 that's a concern, no question.

8 MR. JORDAN: SPDS usage, do you expect the
9 operators to use it or is that more of a transition aid for
10 those that are external to the control room to know what's
11 going on?

12 MR. WERMIEL: We expect the operators to use it.

13 MR. JORDAN: So the loss of it is more of an
14 operational, control and operational problem than a TSC or
15 offsite management control of the event?

16 MR. WERMIEL: Yeah, I would say so.

17 MR. JORDAN: Is that what we would expect?

18 MR. WERMIEL: That's what I would expect. I would
19 also expect, though, that the training the operator gets
20 would be conducive or he would know what to do if he loses
21 SPDS. I mean he ought to be relying on it. It's there for
22 him.

23 MR. JORDAN: Do we find in our inspections that
24 most operators rely on SPDS or do they go -- in an event or
25 their training in their scenarios, do they normally go



1 directly to the indication rather than the SPDS?

2 MR. WERMIEL: No. Certain plants in particular
3 really do rely on their SPDS. They really like it because
4 they've tailored it the way they want it to be and they
5 really like it the way it is and they want their operators
6 to use it because they've gone out of their way to design it
7 to be a real aid to the operator.

8 Some of the plants over the years have relied on
9 an awful lot less than we think they ought to. I think in
10 general, and this is based strictly on hearsay that I've
11 heard from other people, I think in general industry is
12 relying on it a lot more than they used to and a lot more
13 than they thought they would originally.


14 MR. JORDAN: And you're talking about the control
15 room operators, not just external to the control room.

16 MR. WERMIEL: Control room operators. No, I'm not
17 talking about the guy, the plant superintendent who comes in
18 during the event and wants to get a picture of what's going
19 on and looks at the panel, no. I'm talking about the
20 operating crew.

21 MR. VATTER: Is there one or more reactor types
22 that are more that way, where the SPDS is used more?

23 MR. WERMIEL: I don't think it's a function of
24 reactor type so much as it's more utility philosophy.

25 I got in, remember, on SPDS reviews at the very



1 end and I wasn't really a large part of a lot of that review
2 effort. There is a person on my staff who was involved
3 intimately with all the SPDS reviews for many, many, many
4 years. That's Dick Eckenrode, one of my two section chiefs.
5 He knows an awful lot about what happened during those
6 inspections.

7 MR. IBARRA: Would it concern you if a lot of the
8 indications or reliance on indications on instruments that
9 would be off of UPS?

10 MR. WERMIEL: Nonsafety UPS?

11 MR. IBARRA: Yes.

12 MR. WERMIEL: Would it concern me? As long as the
13 reliance was for situations where UPS was available, I
14 wouldn't be overly concerned about it. I would be more
15 concerned if they were relying on it for cases where they
16 couldn't rely on it or they shouldn't be relying on it.

17 I think in general that's a pretty good system.
18 It's got a lot of information on it that the operator could
19 use.

20 Once again, it gets back to what I was saying
21 before, as long as we're confident there's a backup and the
22 operator knows what to do for those situations where the
23 guidance tells him he shouldn't be relying on it, I don't
24 know that I'm too worried.

25 MR. JORDAN: Have we as an agency checked to make



1 sure there is a backup? For all the parameters that are
2 required either by the EOPs or by the SPDS, that there is
3 some type of 1-E instrumentation that would be available to
4 the operators to rely on?

5 MR. WERMIEL: It was my understanding that that's
6 what Reg Guide 1.97 was supposed to be doing. It was
7 supposed to be that minimum set that we could be confident
8 would be available for -- I guess I should say it, for
9 design basis events.

10 I don't know that we really have concentrated much
11 on what to do if you're in a scenario that goes beyond the
12 design basis, but for design basis events, that's what I
13 thought that 1.97 instrumentation was all about.

14 MR. IBARRA: The work that was done after TMI's
15 CRGR included a task analysis, functional task analysis,
16 where they actually broke down the procedures and the
17 instrumentation that would be used.

18 MR. WERMIEL: Yes.

19 MR. IBARRA: A lot of good work went into that.
20 Has the industry kept up with that?

21 MR. WERMIEL: Yes, they have. As part of the
22 DCRDR reviews that we do, we make sure that there is a
23 program in place for subsequent upgrades to the panels and
24 that kind of thing.

25 As far as I know, the industry in general is



1

100

2



3

4

5



6

7

1 pretty good about utilizing the same human factors
2 principles when they go in and modify panels after the
3 initial DCRDR review is done.

4 MR. IBARRA: So you would expect that as they do
5 an EOP revision they would go and look at it?

6 MR. WERMIEL: Absolutely. Oh, yeah. They would
7 go back and make sure that there is nothing that is missed
8 with regard to changes on the panel and this kind of thing.

9 One thing I will point out, though. When it comes
10 to modifications to control rooms, many plants are unable to
11 get a lot of the old analog equipment that they had been
12 used to and it had to buy newer digital technology and they
13 are starting to mix some of the digital technology with the
14 old analog equipment.

15 That has become a bit of a concern to us and we
16 are trying to develop some criteria to deal with that now,
17 but in general I don't know that I see a problem in the way
18 they've been upgrading control rooms. We think in general
19 they've been doing a pretty good job.

20 MR. VATTER: Jerry, you said something about
21 instrumentation necessary to support the EOPs was supposed
22 to be 1-E.

23 MR. WERMIEL: No, not necessarily. I think you
24 heard it wrong. Instrumentation to support the EOPs should
25 be geared to the particular scenario that you're in.



1 The EOPs deal with a spectrum of events. Some are
2 relatively minor and they go all the way to core melt. You
3 can get to core melt in some of the emergency procedure
4 guidance that's out there.

5 The instrumentation needs to be geared to the
6 particular set of circumstances and the EOP should be -- the
7 guy writing the EOP needs to know that if he's dealing with
8 a set of circumstances that's a result of loss of outside
9 power, the instrumentation he's asking the operator to rely
10 on has to be powered from an onsite source.

11 So you may start off with a certain set of
12 indications that are powered from offsite sources and then
13 you may end up with having to go back and check or verify
14 plant status with different instrumentation because the
15 symptom-based procedure has progressed to the point where
16 the old stuff is no longer available and the procedure
17 writer needs to know that.

18 He's telling the operator, hey, when you're
19 verifying pressurizing level and you're using this
20 instrumentation, it's the right stuff, it's powered from an
21 onsite source and you shouldn't care whether or not you've
22 lost outside power or not because I know you have and I've
23 made sure that the instrumentation you're going to rely on
24 is available.

25 Are you following me?

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



1 MR. VATTER: Yes. This time I am.

2 MR. IBARRA: Would you expect if you went to
3 Newberry's group, the instrument control section, that their
4 knowledge of the EOPs -- how would you characterize it --
5 good, bad?

6 MR. WERMIEL: Knowledge of the EOPs themselves?

7 MR. IBARRA: For instance, a question comes up on
8 the right -- the use of some instrumentation, would they
9 understand what the operator would be using it for? Would
10 they have enough knowledge to understand?

11 MR. WERMIEL: Yes, sure. In other words, you're
12 asking do they just concern themselves with the fact that
13 there is an instrument and its power supply or what that
14 instrument is used for?

15 MR. IBARRA: Both.

16 MR. WERMIEL: I think they do know both. I think
17 they not only know what their criteria are for the
18 qualification of that instrumentation but also what it's to
19 be used for. They understand enough of the thermal
20 hydraulics I believe to know why that instrumentation is
21 important.

22 MR. IBARRA: What branch within the agency would
23 look after the total integration procedures, qualification,
24 instrumentation, human factors?

25 MR. WERMIEL: I don't know that there is an



1 overall integration. We all have our areas of specialty and
2 then we would all write our evaluations based on our areas
3 of expertise and then it would all get folded into one
4 evaluation, usually by the project manager.

5 MR. IBARRA: If you are reviewing a procedure that
6 unknowingly might call for some electrical expertise or I&C
7 expertise, who would be able to catch that?

8 MR. WERMIEL: I would expect the human factors
9 people in my branch would know if there was some question
10 about the instrumentation that was being relied on because
11 their experience would tell them that for the particular set
12 of circumstances.

13 If the operator is being told to rely on something
14 that's unfamiliar to them I think they would question it and
15 then we would maybe ask the I&C people, hey, is this right,
16 is this really, say, Reg Guide 1.97 indication or is it not,
17 is it something that really shouldn't be there.

18 We have noted situations like that from EOP
19 inspections.

20 MR. IBARRA: It's a little bit -- It's not
21 heartening to know that sometimes you go into a control room
22 and ask the operator what that label means and they don't
23 understand what it means, especially Reg Guide 1.9.

24 MR. WERMIEL: Oh, yeah.

25 MR. IBARRA: Does that concern you?



1 MR. WERMIEL: It sure does.

2 MR. IBARRA: Is it typical?

3 MR. WERMIEL: Is it typical? I don't believe so,
4 no. I believe from what we know of operator training that,
5 particularly the training now being done with the newer
6 certified simulators that the operators are very familiar
7 with what's on the panel and what it means.

8 I would be very concerned if I was actually
9 talking to a reactor operator and he told me that. I would
10 be very concerned.

11 MR. IBARRA: The 1-E instruments they know very
12 well and in fact the labeling there, but the Reg Guide 1.97
13 instruments which is a subset of all this has another label.

14 Do you find that operators do not understand what
15 that extra label is or what that Reg Guide 1.9 indication
16 means? Would that surprise you for them not to know?

17 MR. WERMIEL: It would surprise me for them not to
18 know, absolutely. I can't say directly because I haven't
19 asked operators and I really haven't heard any feedback on
20 that. I would be surprised and it would bother my
21 confidence if I heard that. Knowing the importance we
22 placed on Reg Guide 1.97 instrumentation, that would bother
23 me.

24 MR. IBARRA: Is there too much labeling in the
25 control room?



1 MR. WERMIEL: As a general rule, no, I don't think
2 so. There may be an isolated case where a utility has gone
3 overboard perhaps but don't know of any. No.

4 I'm not a human factors person, but from my
5 limited exposure to it, I don't think you can provide the
6 operator with enough information on what things are.

7 Too often it's not that there's too much but that
8 there is too little. He just doesn't have enough
9 information to tell what him what this particular thing is
10 or isn't.

11 That was a big part of what the DCRDR review was
12 all about, to make sure that there were appropriate labels
13 and that things were arranged in a kind of systematic way so
14 that he could follow indications and controls in a more
15 concerted manner without having to go over here and go over
16 there and get lost, this kind of thing.

17 MR. IBARRA: From a human performance issue, is
18 communications in an emergency very important or what is
19 your thoughts on this?

20 We have situations where people lost
21 communication.

22 MR. WERMIEL: Communication in an emergency is
23 absolutely essential and I think it's one of the most
24 important areas, if not the most important thing that we do
25 is concern ourselves with crew communication.



Vertical line of small characters or marks on the right side of the page.

1. MR. IBARRA: What are the regulations and the
2 guidelines for that?

3 MR. WERMIEL: I don't know that there are any.
4 I'm certainly not aware of any regulations.


5 The real test of crew communication is during
6 requal examinations when we put the crews in the simulator
7 and we run them through the EOPs, exercise them on the EOPs.
8 That's where we find problems and that's where we deal with
9 those kind of issues.

10 Inter-crew communication is a major part of what
11 we do when we conduct requal. It's a large part of it. If
12 they're not communicating, they probably won't get through
13 the scenarios very well and we'll end up with failures as a
14 result.

15 I don't believe there is any specific regulation
16 or criteria at all on how to communicate or what to
17 communicate.

18 I know there are techniques that improve
19 communication. My guys tell me all the time about how you
20 can better communicate during emergency situations and the
21 kinds of things that work better when we do run these crews
22 through requal and why certain crews have trouble with
23 communications.

24 It's a subjective thing and it is extremely
25 important because you've got to be able to tell everybody on



1 . the crew what you know so that they all know.

2 MR. JORDAN: How about the communications systems,
3 not the ability to communicate but in-plant communication
4 systems?

5 MR. WERMIEL: In-plant communication systems? I
6 don't know a whole lot about them. They are very important.
7 There is no question about that.

8 MR. JORDAN: Do we have anything out to the
9 industry as far as the need for them?

10 MR. WERMIEL: We do. There's an SRP section on
11 communication systems. It's section 9.5.2, I think,
12 something like that, and there is guidance in there on the
13 kind of communications systems that ought to be in the
14 plant.

15 It's also extremely important because oftentimes
16 when you're in an emergency situation, particularly say if
17 there's a fire or some external threat, you need to have
18 somebody outside the control room communicating with the
19 control room, or when you're going to take a recovery action
20 or take some LOCA actions as called out in your procedures,
21 you've got to be able to communicate effectively with the
22 control room and there is guidance on the design of those
23 systems, power supplies and all that kind of stuff but
24 that's not my area. I'm not real familiar with what that
25 criteria says.



201



202

203



204

1 MR. JORDAN: How about some specifics on the EOPs,
2 such as rod position indication particularly for boilers?
3 Do we have any guidance or direction to the utility other
4 than 1.97 that requires them to have any type of a
5 reliability backup on those?

6 MR. WERMIEL: Not that I'm aware of. Not that I
7 know of.

8 MR. JORDAN: Loss of rod position indication?

9 MR. WERMIEL: That should have been accounted for
10 in the emergency procedure guidelines and it should have
11 been factored into the appropriate emergency procedures.

12 MR. JORDAN: Do you know if it was?

13 MR. WERMIEL: Not offhand, no, not specifically.

14 MR. KAUFFMAN: Would you be concerned if there is
15 an event and a loss of RPIS or RSCS and basically no way to
16 tell rod positions other than the APRMs, source range
17 monitors?

18 MR. WERMIEL: That's right. I wouldn't be
19 concerned about rod position as long as I had some
20 indication of flux within the core.

21 If I had source range or if I had intermediate
22 range and it was working and I could rely on it, I wouldn't
23 be as concerned. I'm never as concerned if I have a backup
24 indication of some sort that I can rely on.

25 MR. JORDAN: And those backups, you expect those



11

1 backups to be backed up by a class 1-E type of
2 instrumentation?

3 MR. WERMIEL: I would -- I hope our criteria for
4 those backups counts for that kind of thing and again Reg
5 Guide 1.97 I believe should have some guidance in there
6 which would tell us that, yes, we can -- it's appropriately
7 powered and we can rely on it.

8 I would have hoped -- I don't know that we thought
9 about these things when we developed the criteria for what
10 the power supply should be for that instrumentation but I
11 would hope we did.

12 MR. JORDAN: Is that your section that does that,
13 or your branch?

14 MR. WERMIEL: No.

15 MR. JORDAN: That's electrical?

16 MR. WERMIEL: Actually I&C I think,
17 instrumentation and controls systems branch would definitely
18 have looked at that.

19 MR. JORDAN: You expect them to look at the
20 backup?

21 MR. WERMIEL: I expect -- maybe I should clarify
22 that.

23 The analysis for the design basis of that which
24 the reactor systems branch looked at should have identified
25 the kinds of indications that the operator would need to



9.

4.

1. 2. 3. 4. 5.

2.

5.



1.

6. 7.

3.

8.

4.

9.

5.



1 cope with the event.

2 Then the instrumentation and controls systems
3 branch should have made judgments in their criteria about,
4 because of the importance in working with reactor systems
5 branch, what should be the backup power supply.

6 If this is a backup to another indication, then
7 that backup ought to be on a reliable power source and I
8 thought that's how the process worked when Reg Guide 1.97
9 was developed.

10 MR. JORDAN: When you defined reliable power
11 source, are you talking about 1-E or are you just talking
12 about UPS in general? What does your group consider an
13 adequate backup power supply?

14 MR. WERMIEL: It depends but for the most
15 significant events it should be 1-E. It should be a reliable
16 onsite source 1-E, fully safety-related.

17 There ought to be -- I ought to make one more
18 statement. There ought to be 1-E indication of a minimum
19 set that reactor systems branch says has got to be there for
20 the operator to deal with that particular scenario, bottom
21 line.

22 MR. JORDAN: Do we expect them to have indications
23 down to cold shutdown, hot shutdown? Do we establish a
24 position where --

25 MR. WERMIEL: I'm sure that for hot shutdown we



1 have established a position that there ought to be 1-E
2 indication of everything that they need.

3 For cold shutdown, I don't know that I would be
4 quite as concerned because probably I could take some
5 actions, recovery actions, to recover power supplies for
6 cold shutdown instrumentation.

7 Again, I don't know what the criteria says. I
8 don't know that you need to have 1-E, though, all the way
9 down to cold shutdown necessarily. I don't know what we
10 call for.

11 MR. JORDAN: You do not know what's called for in
12 the EOPs?

13 MR. WERMIEL: In the EOPs I don't believe it is
14 called for. I don't know that 1-E indications of cold
15 shutdown are called for.

16 MR. JORDAN: But for hot shutdown?

17 MR. WERMIEL: Hot shutdown, I believe so. I think
18 so. That's my recollection, anyway.

19 MR. IBARRA: The EQ program, environmental
20 qualification program, how did it affect your group as far
21 as procedures are concerned?

22 MR. WERMIEL: I don't believe it affected -- A lot
23 of that was done before I got to the branch but it shouldn't
24 have had any impact at all.

25 Once again, back to what I was saying before, if



2

2

2

2



2

2

2

2

2

2

2

2

2

2

2

2

2



1 you're going to rely on instrumentation for an event where
2 you have a harsh environment, the program calls for that
3 instrumentation to be qualified and it was always that way
4 and we would in our audits make sure the plant is not asking
5 the operator to use equipment to cope with a LOCA that's not
6 LOCA qualified.

7 We would hopefully, if there was a question we
8 would try to pick that thing up. We would try to pick up
9 situations where you can't rely on those indications because
10 they're not LOCA qualified.

11 MR. IBARRA: Do you think there is adequate
12 integration of all disciplines within the EOP as it stands
13 today within the agency?

14 MR. WERMIEL: I think so. I think the EOP
15 inspection program was very useful and was very successful.
16 As a matter of fact, we've learned so much from those
17 inspections that we are going to publish a revision to the
18 previous lessons learned document from the EOP inspections
19 and it's going to cover a wide variety of lessons learned, a
20 wide spectrum of things.

21 We're working on that right now and we've met with
22 the regions to discuss issues and findings from the EOP
23 inspection program. I wish I could think of the reg number
24 of the previous lessons learned document but I can't.

25 I think it was, as I say, quite a successful



1 program.

2 MR. JORDAN: Do you know of any indication or
3 instrumentation or equipment in which we as an agency at the
4 staff level or at your level felt should have been 1-E
5 qualified and the industry took exception to it which then
6 caused some type of interface between the two that said now
7 it's got to be resolved at a higher level than yourself?

8 MR. WERMIEL: I'm not aware of any, no. It
9 wouldn't surprise me if there were some but I don't know of
10 any circumstances that came up like that because I was never
11 involved in those reviews.

12 I hope you ask Joe Joyce about some of this
13 because I know he was a big part of Reg Guide 1.97
14 implementation.

15 MR. IBARRA: What would be your involvement let's
16 say in the licensing of Nine Mile Point? Can you just tell
17 me typically on opening a new plant what your group would
18 do?

19 MR. WERMIEL: What we would typically do with any
20 new plant?

21 MR. IBARRA: Any new plant.

22 MR. WERMIEL: Sure. We're responsible for two
23 sections of the standard review plan, a large part of
24 Chapter 13.0 of the standard review plan, and Chapter 18 of
25 the standard review plan.



4

Q

1

2

3

1 Chapter 13 has in it the review of the applicant's
2 procedures and training, management and organization and
3 staffing questions. Chapter 18 is the review of the man-
4 machine interface, specifically the SPDS and the control
5 room design review.

6 That would be the bulk of human factors assessment
7 branch review for a new plant. That's the kind of thing
8 we're doing right now in our review of the proposed standard
9 designs, the new standard designs.

10 MR. JORDAN: When you do your design review, is it
11 strictly just how it's laid out, availability, access to the
12 equipment, instrumentation?

13 Can you give me an idea of what all you people
14 look at, or do you look in depth and say where the
15 instrumentation is powered from, how many pieces of
16 instruments are powered off of the same, so if you lost one
17 source of power this group of instruments are going to be
18 gone and now they're going to have to rely on something
19 separate from that?

20 MR. WERMIEL: It's the former, not the latter. We
21 don't get into these questions of backups and power supply
22 availability and that kind of thing. It's what I'll call a
23 classical human factors type review.

24 We look to see that there are some analyses that
25 have been done to confirm that the indications are in the



1 right place and that the operator can utilize them and that
2 there is good labeling and good identification of controls
3 and that they are laid out in a systematic way, that kind of
4 thing.

5 We don't really get into what I would
6 characterize, I guess, as review of the backup capability
7 and backup sources of power, that kind of thing. We don't
8 do that.

9 MR. IBARRA: In our review of training, do you
10 envision them losing annunciators?

11 MR. WERMIEL: Oh, yes.

12 MR. IBARRA: Balance of plant equipment?

13 MR. WERMIEL: Absolutely. The procedures
14 themselves provide guidance for those kind of situations and
15 the training is supposed to be on those emergency operating
16 procedures so the training should cover those kind of
17 eventualities. Oh, yeah. Sure.

18 Those are also situations that are easy to
19 simulate in the simulator. You can turn off the
20 annunciators very easily and see how the operator copes with
21 that in the simulator.

22 MR. KAUFFMAN: I just have one more EOP question.
23 In a BWR if you're in the EOP for pressure control and the
24 operators are running RCIC, would you expect reactor
25 pressure to remain stable there while they're running RCIC



1 for level control?

2 My own expectation is that it depends on the decay
3 heat.

4 MR. WERMIEL: Yeah. If decay heat is going down,
5 sure, then he's going to have to cut back or he's going to
6 over-cool.

7 You're speaking of initially in the --

8 MR. KAUFFMAN: Yes.

9 MR. WERMIEL: Yeah, initially it should stay
10 stable, sure, but as he gets further down he's going to have
11 to cut back on his flow or he's going to over-fill or over-
12 cool.

13 MR. KAUFFMAN: Okay. If we're in the ATWS
14 mitigation parts of the procedures and are using RCIC to
15 inject and not depressurize until we have rods in, I guess
16 what would you expect the operator to do? Do you expect him
17 to shut down his IVs to keep from cooling down, terminate
18 RCIC injections?

19 MR. WERMIEL: Oh, no. I expect him to keep RCIC
20 on but he does not have -- He's not confident that he's got
21 the rods in. Are you saying this an ATWS scenario?

22 MR. KAUFFMAN: Yes.

23 MR. WERMIEL: He's already initiated standby
24 liquid control.

25 MR. KAUFFMAN: He has not at that point because he



1 hasn't reached high suppression pool temperature.

2 MR. WERMIEL: Okay, so he's not quite there yet
3 and he doesn't know whether he's going to be able to get the
4 rods or not.

5 MR. KAUFFMAN: Right.

6 MR. WERMIEL: Okay, so what would I expect him to
7 do?

8 MR. KAUFFMAN: I guess we're saying what we
9 reviewed when we reviewed this event is we have different
10 steps that basically one is keep water in, the other one is
11 saying don't decompressurize, and I guess our question is
12 which one overrides, which one is most important and should
13 there be contingencies there that tell him what to do.

14 MR. WERMIEL: I think there should have been some
15 contingencies to tell him what to do. If there aren't,
16 maybe that's something that was missed. Frankly, I would
17 think it would be more important that he continue to
18 maintain flow, RCIC, particularly under those situations if
19 the rods are not in.

20 If he's not confident the rods are in, then he's
21 still with power so he needs to have the flow. That would
22 be my judgment, although I'm not an operator.

23 You're saying though that he really wasn't clear
24 what he should be doing, huh? He shouldn't be
25 depressurizing yet?



1 MR. KAUFFMAN: They had APRM downscaling it and
2 SRMs upscale.

3 MR. WERMIEL: He was getting conflicting
4 information?

5 MR. JORDAN: He had no rod indications, none.

6 MR. WERMIEL: So he didn't know that they were in.

7 MR. JORDAN: All he had was flux indications.

8 MR. WERMIEL: And flux was telling him --

9 MR. KAUFFMAN: Source range monitors were reading.
10 He had maintained level and he uses RCIC. The question is
11 if he loses RCIC he's going to decompressurize, he's going
12 to cool down.

13 MR. WERMIEL: He's got to right at that point.

14 MR. KAUFFMAN: If he doesn't use RCIC the options
15 are he closes the MSIVs to stop any type of flow and he's
16 still making cooldown.

17 MR. WERMIEL: Yeah. If he shuts down his IVs he
18 will collapse the voids.

19 MR. JORDAN: We don't know if we looked into that
20 area or if the vendor has even looked into that area when
21 they did their EOP design.

22 MR. WERMIEL: I'm not sure that they did. I don't
23 know. I would be surprised if the emergency procedure
24 guidance didn't account for this kind of a situation. Maybe
25 not --



1 MR. JORDAN: It's not clear.

2 MR. WERMIEL: It's not clear that it did.

3 MR. JORDAN: It's not clear. It may have subtly
4 by the direction that it gave but it's not clear looking at
5 the EOPs that that is there.

6 MR. WERMIEL: I see.

7 MR. JORDAN: That if you are now subcritical but
8 if you continue to cool down you may go critical, do you go
9 ahead and continue to cool down if you don't know --

10 MR. WERMIEL: If you don't know that the rods are
11 in. It strikes me if I didn't know the rods were in, I
12 would want to maintain flow at all costs.

13 MR. JORDAN: That's the thing. If that's in
14 there, it's in there very subtly.

15 MR. WERMIEL: I see.

16 MR. JORDAN: It's not clear that says this is why
17 you want to do this even if you have the ATWS and it's
18 subcritical you may go critical again but go ahead and use
19 RCIC anyway even if you do cool down. That's not clear in
20 the EOPs.

21 MR. WERMIEL: I see. It should have been.

22 MR. JORDAN: Using RCIC without sufficient decay
23 heat or without having a critical reactor, you're probably
24 not going to get heat out of it, so therefore the question
25 is with the EOPs would you expect him to go ahead and use



1 RCIC anyway and continue to cool down and maintain flow?

2 MR. WERMIEL: I would say so. What would be wrong,
3 even if decay heat is go down, with continuing to use RCIC.
4 So it over-cooled a little bit. What's the --

5 MR. JORDAN: It's not allowed by the EOPs.

6 MR. KAUFFMAN: It says don't depressurize until
7 all the rods are in.

8 MR. WERMIEL: It says make sure rods are in.
9 There is kind of a conflict here so he's in kind of a
10 quandary is what you're saying.

11 MR. JORDAN: Which is more important -- don't cool
12 down or maintain level?

13 MR. WERMIEL: Maintain level. I don't know if I
14 would be that concerned about over-cooling a little or over-
15 filling a little. Over-filling, maybe, but not over-
16 cooling. I could still maintain level. I would do that.

17 MR. KAUFFMAN: There's a concern with over-
18 cooling in that that adds positive reactivity.

19 MR. WERMIEL: That's true, too, but that's a minor
20 concern, isn't it? I mean that comes farther down. That
21 would be pretty far down in decay heat before that becomes a
22 problem, doesn't it?

23 MR. JORDAN: I don't know.

24 MR. WERMIEL: I don't know, either, but I would
25 think so.



1 MR. JORDAN: Not being a systems engineer, all I
2 know is what the EOPs say.

3 MR. WERMIEL: I can see where you would be
4 concerned but I think I would be more worried about damaging
5 the fuel. Maintain level is what I would do.

6 MR. JORDAN: But you don't have any problem where
7 that's been identified before, either?

8 MR. WERMIEL: Not that I'm aware of, not as a
9 specific technical issue. Somebody from reactor systems
10 branch would be a better person to ask about that, somebody
11 from Bob Jones' shop.

12 How did they resolve the dilemma, incidentally?
13 They just kept going? Good.

14 MR. JORDAN: Do you know if the IRM -- maybe
15 you're the person or maybe not -- Do you know if the IRM,
16 the drive mechanisms, are 1-E qualified?

17 MR. WERMIEL: I don't think so, no. I don't
18 believe they are. Just the -- I don't know for sure but I
19 don't think they are. Somebody else would be a much better
20 source of information on that. I don't think they are.

21 MR. JORDAN: I think 1.97 qualified I guess is the
22 proper terminology.

23 MR. WERMIEL: There's a lot of strange terminology
24 in 1.97, this and that.

25 MR. JORDAN: I don't have any more questions.



1 Does anybody have any more?

2 We'll go off the record.

3 (Whereupon the matter concluded at 1:18 p.m.)

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: IIT Interview of Jared Wermiel

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Marilynn Estep

Official Reporter
Ann Riley & Associates, Ltd.

