

ORIGINAL

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U.S. Nuclear Regulatory Commission
Incident Investigation Team

Title: Interview of: Wayne Hodges
(Closed)

Docket No.

LOCATION: Bethesda, Maryland

DATE: Thursday, September 5, 1991 PAGES: 1 - 59

ANN RILEY & ASSOCIATES, LTD.
1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

9305070258 911031
PDR ADDCK 05000410
S PDR



ADDENDUM

| <u>Page</u> | <u>Line</u> | <u>Correction and Reason for Correction</u> |
|-------------|-------------|---|
| 5 | 14 | change short to source |
| 6 | 4 | change imposition to position |
| 18 | 5 | change course route to core shroud |
| 20 | 4 | change weight to wait |
| 22 | 12 | change AEOPs to EOPs |
| 23 | 13 | change incurssion to excursion |
| 23 | 14 | change section L to scenario |
| 31 | 13 | change SIVs to SRVs |
| 38 | 10 | change Sham to shame |
| 38 | 18 | change Ms. Herbert to Mr. Hodges |
| 40 | 6&7 | change Conrad to Conran |
| 40 | 13 | change Conrad. to Conran |
| 40 | 13 | change Dennis Peace to Themis Speis |

Note: There are several instances where words are not transcribed accurately but the errors are obvious. I have not attempted to alter these.

Date 9/26/91

Signature

M. Wayne Hodges

11

11

11

11

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
INCIDENT INVESTIGATION TEAM

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

-----X
In the Matter of: :
INTERVIEW OF: :
WAYNE HODGES :
(CLOSED) :
-----X

Nuclear Regulatory Commission
Interview Room
Woodmont Building
8120 Woodmont Ave.
Bethesda, Maryland
Thursday, September 5, 1991

The above-entitled matter commenced at 12:22
o'clock p.m.

...



1 On behalf of the Incident Investigation Team:

2

3 JOHN ROSENTHAL, II Team Leader

4 MICHAEL JORDAN, NRC Region III, II Team Member

5 WILLIAM VATTER, INPO, II Team Member

6 WALTON JENSEN, Events Assessment Branch, II Team
7 Member

8 JOHN KAUFFMAN, AEOD, II Team Member

9

10 Interviewee:

11

12 WAYNE HODGES

13 Deputy Director for Reactor Safety

14 U.S. Nuclear Regulatory Commission

15 Division I

16 Philadelphia, Pennsylvania

17

18 [Mr. Hodges was interviewed via telephone from

19 Charlottesville, Virginia.]

20

21

22

23

24

25



P R O C E E D I N G S

[12:22 p.m.]

1
2
3 MR. JORDAN: Okay, Wayne, why don't we start?

4 I'll introduce myself. My name is Michael Jordan.
5 I'm out of Region III, Wayne. I'm a Section Chief in Region
6 III for Operating Licensing, and also in the room is also --

7 MR. KAUFFMAN: John Kauffman. I'm a Director of
8 Systems Engineering in AEOD.

9 MR. JENSEN: Walton Jensen. I work in the Events
10 Assessment Branch, but I used to work in Reactor Systems
11 across the hall from you, Wayne.

12 MR. HODGES: Yes, I know you did, Walt.

13 MR. VATTER: I'm Bill Vatter. I'm from INPO,
14 Wayne. You'll remember that we met in that IIT School
15 earlier this year.

16 MR. HODGES: Right, right. I remember you.

17 MR. JORDAN: Okay. The event we're going to talk
18 about, Wayne, happened on August the 13th at Nine Mile
19 Point, Unit II, involving a site emergency because of a
20 transient coupled with a loss of power of annunciators.
21 That's why they had the site emergency. They lost a lot of
22 balance-of-plant equipment, and they lost their full core
23 display.

24 The reason why we're talking to you is, we're
25 looking for information having to do with the development



1 and review of the BWR's EOPs.

2 And why don't we start out with the first we've
3 got here, and we'll work our way through this thing. If you
4 have any questions along the way, stop us and ask us.

5 MR. HODGES: Okay.

6 MR. JORDAN: Since we can't see you, we don't know
7 what you're -- if you're having a problem or not.

8 With respect to the EOP parameters and
9 instrumentation used during the operator implementation of
10 the EOPs, how were the parameters related to the Reg Guide
11 197 instrumentation?

12 MR. HODGES: I didn't understand the question.

13 MR. JORDAN: Okay. 197 has got the list of
14 instrumentation that's required to be operable EQ'd, et
15 cetera, after an event -- EOP development.

16 Do you know of any -- how those 197
17 instrumentation were related to the EOP development?

18 MR. HODGES: Not directly. I mean, as far as the
19 development of the list, the EOP was being developed
20 concurrent with 197, and I know that Jack Rosenthal tried to
21 incorporate EOP issues, but it was strictly 197, and which
22 ones were required by 197, I don't know.

23 MR. JORDAN: Okay. So you don't know of any in
24 the EOPs where portions of the EOPs require 197 in order to
25 get through them?



1 MR. HODGES: Well, I would answer the question a
2 little bit differently. Was there adequate instrumentation
3 available with what they lost to make it through the event?
4 And in this case, there was. And that was at least my
5 opinion at the time the event was going on, and then that
6 was later confirmed by Carl -- uh-oh.

7 MR. JORDAN: Sisco.

8 MR. HODGES: Carl Sisco when he looked at it up
9 there as part of the AI team.

10 Recognize that you can use, you know, a myriad of
11 things, and in this particular instance, they did have
12 indications on the back panel that they APRMs were
13 downscale. The power was down for most of the plant, but it
14 was down in the short range.

15 MR. JORDAN: Well, they knew they were off 4
16 percent.

17 MR. HODGES: Right.

18 MR. JORDAN: And I guess the question is, is that
19 is there any instrumentation that's EQ qualified to verify
20 below the 4 percent, so they get out of that do loop that
21 was part of the EOPs.

22 Are you familiar with the section of the EOPs that
23 got them into a holding pattern?

24 MR. HODGES: I'm trying to recall. No, I'm not
25 right off the top of my head, because you don't need -- if



1 the power instrumentation is not available, the power
2 instrumentation is not available, there are steps in the EOP
3 to determine where you are without using that
4 instrumentation. It relies upon pressure or imposition of
5 SRVs and those types of things.

6 So you can determine not the absolute power level,
7 but you can tell -- you can determine that the reactor is
8 shut down based upon the reactor pressure and the status of
9 SRVs.

10 MR. JORDAN: Yes, but the problem is there is a
11 section here that talks about you have to wait until all
12 control rods are inserted to at least the O2 position.

13 MR. HODGES: Right.

14 MR. JORDAN: Okay. And do you know of any 1.97
15 material that allows them to go through that?

16 MR. HODGES: Again, I don't recall which is 197
17 and which is not. I haven't looked at a list of 197
18 instrumentation in a long time.

19 MR. JORDAN: Okay. Well, the reason I'm asking,
20 Wayne, is that, you know, I'm looking at what they had, and
21 since they didn't have the full core display -- they said
22 they didn't have that. All rods are inserted to at least
23 the O2 position. They felt the only way --

24 MR. HODGES: They did not have the rod position
25 indication, is my understanding.



1 MR. JORDAN: That's correct. So they couldn't do
2 that.

3 MR. HODGES: Right.

4 MR. JORDAN: And it says: Or the reactor will
5 remain shut down without boron.

6 MR. HODGES: Right.

7 MR. JORDAN: Okay. What instrumentation would you
8 expect them to use to verify that the reactor remained shut
9 down?

10 MR. HODGES: I would use several things. One, I
11 would use the back panel and see that the APRMs were
12 downscale. That's an indication that they're down.

13 MR. JORDAN: Yes.

14 MR. HODGES: They also got the status of the SRVs
15 and the pressure, and those would indicate the reactor was
16 shut down. So there's adequate instrumentation from what
17 they had to deduce that the reactor was shut down.

18 MR. JORDAN: But how do they know it's going to
19 remain shut down, because the step was "will remain shut
20 down without boron"?

21 MR. HODGES: Right. All that says is before you
22 start to depressurize, you may have to worry about, for
23 example, if you don't have rod position indication and you
24 don't know -- all you know is that it's below a certain
25 point, now you've got to -- you have to worry about some



1 rods being out, and you have to have some means of verifying
2 the rod position. Otherwise you shouldn't cool down. That
3 does not say you cannot maintain the plant in a stable
4 condition.

5 And that's all the EOPs is trying to do, is keep
6 you in a safe, stable condition. And a hot shutdown at full
7 pressure but zero decay heat power is a safe, stable
8 condition.

9 MR. KAUFFMAN: Okay. But if they were cooling
10 down by, say, using RCIC to inject, that wouldn't meet the
11 intent of that step there to not depressurize if they, in
12 fact, did depressurize?

13 MR. HODGES: Well, I don't think they started that
14 until after they got some instrumentation back. They got
15 the instrumentation back in about 20 minutes.

16 I mean, if you're sitting there with, you know,
17 the pressure between 800 and 1000 pounds, you're not
18 depressurizing.

19 MR. JORDAN: Yes, but what they did, Wayne, in
20 order to put water into the vessel --

21 MR. HODGES: Right.

22 MR. JORDAN: -- they used RCIC.

23 MR. HODGES: And that's going introduce some cold
24 water, and that's going to drop the pressure a little bit.

25 MR. JORDAN: Right. And that dropped the



1 pressure.

2 MR. HODGES: But it's going to operate, is what's
3 going to happen. Initially, RCIC won't be enough to take
4 out the decay heat, and so it will maintain pressure. After
5 a period of time, then RCIC will keep up with it. So it's
6 an energy balance game.

7 MR. JORDAN: Yes, but I think what really
8 happened, Wayne, is they didn't maintain the pressure. The
9 RCIC drawing the steam off on the RCIC --

10 MR. HODGES: Right.

11 MR. JORDAN: -- actually reduced pressure.

12 MR. HODGES: Okay.

13 MR. JORDAN: You know.

14 MR. HODGES: But they also went to Level 8, which
15 they didn't have to do, but it is routine to do that. But
16 how far down did the pressure bring them?

17 MR. JORDAN: Down to about -- I think it was
18 around, Walt, 500 pounds.

19 MR. JENSEN: Around 700. They went down to around
20 700 pounds, so that the condensate booster pumps started
21 injecting into the vessel.

22 MR. HODGES: Okay.

23 MR. JENSEN: And that's when it went up to Level
24 8, when they dropped down below the booster pump pressure,
25 and the booster pump started injecting into the reactor --



1 MR. HODGES: Okay.

2 MR. JENSEN: -- and brought the level up.

3 MR. HODGES: All right.

4 MR. JENSEN: It was about a little less than 700.

5 MR. HODGES: Did they see anything that would have
6 indicated an increase in power while they were doing that,
7 an increase in pressure or anything like that?

8 MR. JENSEN: No. The pressure was going down all
9 the time they were having RCIC injection, and the --

10 MR. HODGES: The only thing you don't know is --
11 during that first 20 minutes until they got some power
12 restored, is the absolute position of the rods.

13 MR. JENSEN: That's right.

14 MR. HODGES: You know the reactor was essentially
15 shut down where you are.

16 MR. JORDAN: You know -- right. At each pressure
17 point, you know you're shut down.

18 MR. HODGES: You don't know what will happen if
19 you go lower.

20 MR. JORDAN: You don't know what will happen if
21 you go lower.

22 MR. HODGES: That's the only concern there.

23 MR. JORDAN: But that says -- that's what that --
24 maybe understanding what the step is, but that, I thought,
25 was what the wait step is for is so that you don't --



1 MR. HODGES: Yes. The step says that you should
2 not, you know -- you should try to hold it in safe, stable
3 condition until you can make that determination, basically
4 is what that's saying.

5 MR. JORDAN: And the question I have is that other
6 than the pressure, which is the 197 pressure, the PAM, the
7 post-accident monitor records, and the APRMs and the back
8 panels, did we look at any other method by which they could
9 go through that step prior to depressurization using RCIC.

10 MR. HODGES: Well, be careful, because most of us
11 did not even get to the Response Center until after they had
12 restored power. So we were looking at everything after the
13 fact at that point.

14 MR. JORDAN: No, but I'm looking at -- I'm
15 questioning back on EOP development.

16 MR. HODGES: Right, right.

17 MR. JORDAN: Not when we showed up, not when we,
18 the NRC, responded to the event.

19 MR. HODGES: When we were developing the EOPs, we
20 did not say: Is this 197 or not 197? That was not a
21 consideration in the development of EOPs.

22 The consideration is; do you have an instrument
23 that will do that? And if you lose that instrument, do you
24 have a backup? And there was no consideration of; is it
25 safety related, is it 197? That was not part of the



1

1 discussion.

2 MR. KAUFFMAN: Was there a consideration given
3 that at least instrument for that function would be, as you
4 seemed to indicate before, not considered at all?

5 MR. HODGES: I'm sorry, the question again?

6 MR. KAUFFMAN: I guess you said it wasn't
7 considered whether the instrument was Reg Guide 197 or not.
8 My further question is, was there consideration given to the
9 idea that for some functions, you would make sure you at
10 least had one safety grade or one 197 instrument to look at
11 that function?

12 MR. HODGES: There was no consideration of whether
13 or not the instrumentation was safety grade of 197. The
14 question was; did you have an instrument that, given the
15 conditions that you had, you could have confidence in?

16 And you verified that by several means: one is,
17 if you had similar instruments reading the same kind of
18 thing, or if you had other parameters that were consistent
19 with the reading that you have. But, I mean, whether it's a
20 safety grade instrument or a non-safety grade instrument,
21 you may have a problem.

22 Therefore, the EOPs do not consider whether it's a
23 197 or a safety related or anything else. They basically
24 say, do you have an instrument you can rely upon to do the
25 job? Well, the purpose of the 197 and the safety grade is



1 to try to assure a high level of reliability for a certain
2 set of instruments. But that does not mean necessarily that
3 those instruments are more reliable than some other
4 instrument.

5 In fact, because of some of the criteria we put on
6 them, they may, for some circumstances, be less reliable.
7 But the point is that the operator should have some
8 instrumentation that he can rely upon to draw his
9 conclusions.

10 Now, beyond that, if, on a BWR, you lose all
11 power indication, there are still -- I mean, power not
12 reading, whether from the APRMs or source ranges or
13 whatever, and you don't have a power reading, you can still
14 deduce the power rating from the pressure and status of SRVs
15 and MSIIVs.

16 The EOPs allow that to occur. For example, if the
17 pressure was going down -- you say down to 700 pounds --

18 MR. JORDAN: Right.

19 MR. HODGES: Then you're not at power, not with
20 the kind of flow that you've got with RCIC, because RCIC can
21 -- is a low capacity system that will, if my memory is
22 right, is that it is equivalent to roughly five percent of
23 power -- no, it's less than that 3 percent of power, which
24 is identical to decay heat range and until -- and for the
25 first five minutes or so, RCIC can't even keep up with decay



1 heat.

2 After that, it will start to do a little bit and
3 could depressurize you. But RCIC is a low capacity system,
4 and if that's what you're using and the pressure is going
5 down, you can have a high confidence, even though you've got
6 no direct power instrumentation, that the reactor is shut
7 down.

8 MR. VATTER: Wayne, let me postulate for you --

9 MR. HODGES: Sorry. That was part of the
10 philosophy in developing the EOPs.

11 MR. VATTER: Wayne, I'd like to postulate for you,
12 a little bit different scenario.

13 MR. HODGES: Okay.

14 MR. VATTER: And perhaps you can tell me whether
15 it's realistic or whether it's been considered.

16 MR. HODGES: Okay.

17 MR. VATTER: You get the scram but you don't get
18 all the rods going in.

19 MR. HODGES: Right.

20 MR. VATTER: However, the operator doesn't know
21 this.

22 MR. HODGES: Right.

23 MR. VATTER: And he is able to see that the
24 reactor is shut down, but he doesn't know how much it's shut
25 down.



1 MR. HODGES: Right.

2 MR. VATTER: And then, as he cools down, he has
3 re-criticality.

4 MR. HODGES: Right.

5 MR. VATTER: And because of the rate of the
6 cooldown, either through cold water addition or by
7 depressurizing, the reactivity is added quick enough that
8 before you get Doppler, or voids or something that could
9 turn it, you get the reactor going on a power increase
10 that's unacceptable. Maybe you get not prompt critical, but
11 you get close enough to it that you have such a high power
12 spike that you hurt the fuel?

13 MR. HODGES: Right. You can't do that with that
14 kind of a cooldown. In fact, as you cool down and
15 depressurize, if you start to generate some power, what you
16 will do is, you will get some voiding and that will -- the
17 voids that you depressurize will have a stronger effect than
18 the cooldown. That was considered.

19 MR. VATTER: But you might shoot some cold water
20 in there like condensate booster pumps. You might be
21 cooling down real slowly or depressurizing real slowly.

22 MR. HODGES: If you get to the point where you --
23 and you get to a situation similar to what you're talking
24 about, but you can't do it without boron in there. You
25 can't have it both ways.



1 Either you're going to have -- as far as -- I
2 suppose you could go -- you could go recritical. But you're
3 not going to go on a prompt critical that's going to become
4 exponential on you.

5 MR. VATTER: Is there some kind of analysis that's
6 been done in that that we could study?

7 MR. HODGES: There were some analyses done. I
8 don't have them. GE may have them. I'm not sure where they
9 are right now.

10 MR. VATTER: Who is the person that we ought to
11 talk to to find out more about that analysis?

12 MR. HODGES: Probably what I would do is go
13 through the BWR Owners Group chairman and have him contact
14 GE. The EOPs belong to the BWR Owners Group, not GE. They
15 had some analyses done by GE and they had some analyses done
16 by contractors. I think I would go through the BWR Owners
17 Group and see what they've got.

18 MR. JORDAN: But you think there's analysis to
19 show that with using -- without boron in the vessel, as long
20 as you have a cooldown, that you can't go prompt critical
21 and cause --

22 MR. HODGES: Well, I think that's true. Now, we
23 even did some calculations at Brookhaven with boron in there
24 that tended to show that that couldn't happen, but that
25 tended -- that was where you were smearing the effects over



1 the whole core. I'm not so sure that if you localized it,
2 you couldn't do something with it if you had boron in there.

3 But even that showed that if you -- as long as you
4 weren't localizing -- and these were from calculations that
5 were done under contract at Brookhaven by Dave Diamond --
6 again, I don't have any contract -- any reports on that, but
7 they're probably retrievable from Brookhaven somehow.

8 MR. JENSEN: Wayne, would somebody in the Reactor
9 Systems Branch maybe have those reports or be familiar with
10 the calculations?

11 MR. HODGES: Well, we did at one time when I was
12 down there. I don't know where they are now, Walt. Chuck
13 Graves was involved with some of that. Whether he still has
14 some, I don't know. It might wind up having to go back to
15 the Brookhaven or someplace to try to get them, because they
16 did the analysis.

17 MR. JORDAN: Did they do that for us or for
18 somebody else?

19 MR. HODGES: They did that for us.

20 MR. KAUFFMAN: Who on our staff reviewed those
21 types analysis?

22 MR. HODGES: I said Chuck Graves and I looked at
23 that from the Brookhaven analyses. We were trying -- we
24 were asking a slight different question. We were looking at
25 it with boron in there, and we were concerned -- my concern



1 was at that time that if you had the reactor shut down and
2 you injected, un-borated water, but it was shut down
3 strictly on boron -- and we were looking at a BWR-5 or BWR-6
4 design where you injected the low pressure cooling injection
5 system directly into the course route, could you get, you
6 know, an excursion?

7 And their calculation showed no. My concern was,
8 their model was not good enough to look at the local jetting
9 effect of the cold water, the localized effect rather than
10 the smeared effect across the core.

11 But for the kinds of things you're talking about
12 where you're just injecting it in the feedwater lines and
13 coming on down that way, that analysis would say, even with
14 boron in there, you're not going to get that.

15 MR. KAUFFMAN: Did that analysis assume that you
16 got, I guess we'll say, full rated condensate booster pumps?
17 Because, what happened in this --

18 MR. HODGES: That analysis assumes all LPCI flow
19 coming in cold. Basically, I think it assumed full LPCI
20 flow coming in.

21 MR. JENSEN: Now, when you say that there was
22 boron, is that assuming that the operator has injected the
23 system?

24 MR. HODGES: That was taken as an assumption that
25 you had an ATWS where no rods went in. You had shut the



1 reactor down using boron from the standby liquid control
2 system. You had depressurized down to, you know, a low
3 pressure system and then you got an inadvertent actuation of
4 your LPCI to inject the full -- the LPCI flow which is like
5 going to be roughly 20,000 gallons per minute -- 15-20,000
6 gallons per minute injected into a core that's shut down
7 strictly with the boron which I think is probably a more
8 valuable analysis than what you were asking for.

9 MR. JORDAN: Okay. Let me ask another question.

10 MR. HODGES: Okay.

11 MR. JORDAN: This is to the -- the previous
12 questions were more generic with the EOPs. This is back to
13 the specific event.

14 MR. HODGES: Okay.

15 MR. JORDAN: Okay, when the operators got to the
16 point in their ATWS procedure that says wait until all rods
17 are inserted at least the 02 position in the reactor or the
18 reactor remains shut down without boron. I think they got
19 into a stop statement, that they couldn't get through that,
20 okay?

21 MR. HODGES: Okay.

22 MR. JORDAN: Now on the other one for the normal
23 reactor vessel level control under pressure control, it says
24 you don't start cooling down until all rods are inserted.
25 The reactor remains shut down without boron, if boron is



1 being injected but a slick level is dropped to 900 gallons
2 or the reactor is shut down and no boron has been injected.

3 MR. HODGES: All right.

4 MR. JORDAN: Okay. That's another weight
5 statement.

6 MR. HODGES: Okay.

7 MR. JORDAN: Both of those are -- but they were in
8 a situation that while they were using RCIC they were
9 depressurizing.

10 MR. HODGES: Okay.

11 MR. JORDAN: And RCIC is allowed by the ATWS
12 procedure as an injection source. By injecting with RCIC
13 they reduce pressure.

14 MR. HODGES: Right.


15 MR. JORDAN: So is --

16 MR. HODGES: Well, that says the power is at least
17 less than what RCIC is capable of.

18 MR. JORDAN: Okay.

19 MR. HODGES: And RCIC because they can take out
20 and it's all between 2 and 3 percent power so you know it's
21 less than that.

22 MR. JORDAN: Okay, so as far as the cooldown
23 depressurization using RCIC, that's not allowed by the
24 pressure -- you feel it's okay because it's allowed by the
25 RCIC ATWS? You have a problem with --



1 MR. HODGES: Wait, let's back up a minute.

2 MR. JORDAN: Okay.

3 MR. HODGES: RCIC is maintained core covered.

4 MR. JORDAN: Right.

5 MR. HODGES: And that has got to be the first
6 priority is that you maintain adequate coverage of the core.

7 MR. JORDAN: Okay.

8 MR. HODGES: All right? Now if in the process of
9 doing that you have some depressurization, if it could be
10 avoided you probably should, but if it is needed in order to
11 maintain the core covered and adequate core cooling, the
12 choice has got to be to go for the core cooling. There has
13 to be a priority there.

14 MR. JORDAN: Okay. Okay, would you expect the
15 reactor operators to close the MSIVs in order to maintain
16 pressure up?

17 MR. HODGES: I would expect that they might want
18 to try to control pressure with MSIVs so as not to cycle the
19 SRVs and dump heat to the -- but I would expect them if the
20 pressure is dropping to try to close them to let it come
21 back up but I would expect they might try to use an MSIV as
22 a pressure control mechanism.

23 MR. JORDAN: MSIVs are to control with pressure.

24 MR. HODGES: I understand that.

25 MR. JORDAN: They're either opened or closed.



1 MR. HODGES: It's either open or closed -- but
2 MSIV is open and using a bypass or something to --

3 MR. JORDAN: -- need a bypass? By just using RCIC
4 they were depressurizing.

5 MR. HODGES: Right.

6 MR. KAUFFMAN: Then there's steam auxiliaries.

7 MR. JORDAN: Then there are steam auxiliaries.

8 Okay, the question I have is that would you have -- the EOPs
9 don't tell them to do that --

10 MR. HODGES: Right.

11 MR. JORDAN: -- it just says you can't cool down--

12 MR. HODGES: But in fact I think the AEOPs would
13 encourage them to keep the MSIVs open as a means of removing
14 heat, particularly if there's a concern for an ATWS, because
15 it is preferable to dump the heat to the condenser if you
16 are going to have an ATWS going on than to dump it to the
17 pool, where you start challenging your containment.

18 MR. VATTER: That's if you got power below 4
19 percent and you're concerned about recriticality, then maybe
20 pressure control might come in.

21 MR. HODGES: The only thing -- what is the concern
22 with recriticality? The concern is that if you've got a
23 real skewed rod pattern that you might get boiling
24 transition on a few rods and even though that would be a
25 violation of the safety limit and it's something we'd



1 probably slap their hands for from a strict safety
2 standpoint that ain't a big deal.

3 MR. VATTER: The other possibility is like we were
4 talking that you get some power spike due to the reactivity
5 going in there too quick.

6 MR. JENSEN: Like when you injected the condensate
7 booster pumps pretty fast like they did at Nine Mile and
8 then have some of the rods stuck out or they didn't know
9 they weren't out --

10 MR. HODGES: Right.

11 MR. JENSEN: -- they weren't of course but they --

12 MR. HODGES: There is a possibility they would
13 have gone critical but as far as an incursion I think it's a
14 high unto impossibility for that kind of a Section L and
15 part of that is based upon the Brookhaven analyses where we
16 looked at roughly half the flow rate for that system with
17 all the rods out and replacing -- see, you got, when the BWR
18 is operating you have roughly eleven dollars of reactivity
19 in the void, the steam, so if you shut the thing down and if
20 you still have got some boiling going on, you have got some
21 of that negative reactivity already.

22 When you shut down on boron and so that you've got
23 the thing shut down basically we're saying in this case you
24 have got all of the eleven dollars of that negative
25 reactivity offset plus whatever else you need in order to



1 keep the thing shut down.

2 Now what you are talking about is as soon as you
3 start to inject to this cold water, if you start generating
4 power you also start generating void again and that's a very
5 strong negative feedback and at low pressure the void offset
6 the temperature effect, the void effects is much larger than
7 the temperature effect and so we tend to shut the plant
8 down, or at least not let it run away.

9 MR. JORDAN: Okay. Do you agree that the
10 operators did correctly, by the weight statement?

11 MR. HODGES: I think that if I were in this
12 situation -- until I got some indication back, I would try
13 not to go all the way down. I would try to maintain some
14 pressure there and wait. I think I would try to play it
15 cautiously, yes.

16 Now, to me, the depressurizing the 700 pounds with
17 RCIC is not going through a depressurization for cooldown.
18 In a normal control, even for ATWS and other things like
19 that, they talk about controlling it at 800 to a thousand or
20 800 to 1,100, something like that. They're supposed to
21 specify a band. If you're a little bit outside the band
22 they would specify. And so that may be a bit of no-no, but
23 is it a safety problem? No.

24 MR. JORDAN: Okay.

25 MR. HODGES: Again, putting the priority on



1 maintaining the cooling.

2 MR. JORDAN: Maintaining water on the core?

3 MR. HODGES: Right.

4 MR. JORDAN: That's the priority?

5 MR. HODGES: Yes.

6 MR. JENSEN: Wayne?

7 MR. HODGES: Yes?

8 MR. JENSEN: Just after your reviewing the BWR
9 guidelines, I was looking at the PWR guidelines. It seems
10 like they were listing as their most critical safety
11 function the shutdown of the reactor. They had their ATWS
12 functional restoration -- they had a red line. They had
13 that as the reddest most important thing they could do in a
14 PWR.

15 MR. HODGES: Right.

16 MR. JENSEN: And then after that was core cooling.

17 MR. HODGES: If you look at the PRAs for BWR, ATWS
18 is one of the big challengers. It's very critical, yes.

19 MR. JENSEN: Well, I was thinking -- I was
20 wondering if you knew why they would have the -- the most
21 critical safety function for a PWR being the ATWS, as
22 opposed to core cooling, wherein BWR, the core cooling would
23 take precedence over the ATWS?

24 MR. HODGES: I don't think that the PWR would tell
25 you that ATWS takes precedent over core cooling. If you



1 don't keep the core cool, you've lost it. That's got to be
2 your first priority -- one of the -- well, up to a point,
3 that's got to be your first priority. If you decide, well,
4 there ain't no way you're going to keep the core cooling
5 anyhow, then you've got to go worry about the containment
6 and try to protect it. But, otherwise, core cooling has got
7 to be your first priority. If you can keep that core cool,
8 then you can commit a lot of other sins and it won't catch
9 up with you.

10 MR. JENSEN: Okay.

11 MR. JORDAN: Wayne, we've got a question here.

12 What was the scope of the ATWS analyses, were
13 there different events, and what different events were
14 considered?

15 On the ATWS, I guess what we're looking for, is
16 that considered anywhere from, I guess, 4 percent power up
17 to 100 percent power, or was it only considered at power in
18 which it exceeded the decay heat such that the addition of
19 RCIC would not depressurize the core?

20 MR. HODGES: It's going to test my memory a bit.

21 I know what was discussed. Now, how much analysis
22 we had may be part of the problem. They did not have
23 analyses for every situation. A lot of it was, given some
24 limited analyses, now what could you extrapolate from and
25 do?



1 So, did the BWR owners group have an analysis for
2 an ATWS at, say, 10 percent power or 5 percent power or 3
3 percent power? My honest answer is no.

4 They analyses that we looked at for limiting
5 things and then went back and tried to use some physics
6 reasoning on some of the other stuff.

7 MR. JORDAN: Do you know, did we consider their
8 analysis all-encompassing as far as the lower powers, as
9 well as the upper powers?

10 MR. HODGES: I think, with the analyses, plus the
11 discussions of the logic and the physics, I think we
12 considered it covered the full range, yes.

13 I'm trying to think for a minute while we talk,
14 too. There was -- that's still going to be fairly high
15 power.

16 There were some analyses that were done in the
17 last, oh, three or four years, again from the BWR owners
18 group, looking at BWR stability, that got into some ATWS
19 considerations, but they're starting from about the 40- to
20 50-percent power range.

21 Larry Phillips could probably tell you more about
22 those.

23 MR. JORDAN: Okay. I'm just reading through some
24 of these questions. I think you've answered some of these.

25 What happens if partial ATWS is followed by a



1 maximum credible reactivity addition from depressurization
2 or cold water addition at a very low power?

3 You're saying -- in the source range level, you're
4 saying you don't think that that -- that, if that happened,
5 the core would go critical, but it would not cause fuel
6 damage.

7 MR. HODGES: If you're talking about from -- you
8 may have said a little bit more than I want to say.

9 MR. JORDAN: Okay.

10 MR. HODGES: If you're talking about a situation
11 where you're not borated --

12 MR. JORDAN: Correct.

13 MR. HODGES: -- then the addition of the cold
14 water won't result in what I would characterize as
15 significant fuel damage.

16 The reason I hedge a bit is I think it's possible
17 to get a localized relatively high power so that you might
18 have some local clad failure on a few pins. I don't think
19 that is a big safety issue.

20 It means you may get a little bit of radioactivity
21 in the water, and if you've got a valve open that's going to
22 go to the outside, you may release a little radioactivity.
23 That's not a major fuel failure, though.

24 That's a localized fuel failure, as opposed to a
25 core melt or something like a Chernobyl or something like



1 that.

2 So, you may, with that large cold water addition
3 from low power, get -- for a PWR, you would call it DNB, and
4 basically, you go to film boiling.

5 Then you have to say will that film boiling result
6 in fuel failure? And there, it's possible but not
7 necessary.

8 If we were doing a licensing analysis, we would
9 assume it did. In real world, it doesn't necessary happen
10 that way..

11 As a an example, there was a case in Sweden about
12 four or five years ago where they made some mistakes in
13 correlating and a few other things like that, and they
14 actually operated the plant at full power with several
15 bundles -- rods in several bundles in film boiling for
16 periods of up to two weeks, and what they got was they
17 failed a few pins, other pins has discoloration and didn't
18 fail, and they didn't really even know they had that problem
19 until they shut down.

20 You can damage the pins as far as some damage to
21 the cladding, but not the extent you're talking about a
22 massive safety problem. It's not something I would want to
23 evacuate people for.

24 MR. JORDAN: Okay. You answered some of these
25 questions we've got here. Let me run through them.



1 What would be the safety significance on an
2 inadvertent criticality? While clearing down the plant, an
3 analytical analysis, you say that as long as there is no
4 boron, that you think it's going to have low safety
5 significance.

6 MR. HODGES: Yes. I think there is some
7 possibility -- I can't rule it out -- that you will have
8 film boiling on some pins.

9 MR. JORDAN: And we've got some analytical
10 analysis on, if the plant is boron, the consequences of a
11 cold water injection.

12 MR. HODGES: Yes. And there again, you might get
13 some film boiling on some pins, but you don't have massive
14 fuel damage.

15 MR. JORDAN: Okay.

16 [Pause.]

17 MR. JENSEN: Wayne,


18 MR. HODGES: Yes.

19 MR. JENSEN: This comes from RSB days. Remember
20 the Branch Technical Position 51?

21 MR. HODGES: Uh-huh.

22 MR. JENSEN: And that requires that plants be
23 capable of achieving cold shutdown with safety-related
24 equipment.

25 MR. HODGES: Right.



1 MR. JENSEN: And we were wondering how BWRs would
2 show that, and if they needed to have safety-related
3 equipment showing that either the rods were in or else they
4 were in a shutdown condition. How was that done? How were
5 they brought to cold shutdown with safety-related equipment,
6 and would Nine Mile meet that?


7 MR. HODGES: Okay. I don't recall any analyses
8 with that, considering a loss of all your power indication.
9 That was really looking at -- could you cool the plant down
10 and go on to shutdown cooling, using only safety-related
11 equipment?

12 Typically, they demonstrated that they could do
13 that they could do that by opening up the SIVs and
14 depressurizing it in an injection through the LPSI system
15 and providing cooling with the LPSI heat exchanger.

16 That was the method they used as a safety-related
17 path to do that. That's not a path they would normally
18 choose, in the few instances where I know of where they
19 haven't been able to cooldown by the normal means, but
20 that's not the path they've chosen.

21 MR. JENSEN: So, are you saying that they didn't
22 look at the instrumentation when they did that? Are you
23 just --

24 MR. HODGES: I did not look at the instrumentation
25 when we did that. I don't think the question of the



1 instrumentation even came up at that point. I think single
2 failure would limit you on that.

3 MR. JENSEN: Well that's nonsafety
4 instrumentation.

5 MR. HODGES: Right.

6 MR. JENSEN: Did the instrument -- ICSB Branch
7 help us review RSV51 and get into cold shutdown with safety-
8 related equipment?

9 MR. HODGES: Not to my knowledge.

10 MR. JENSEN: Okay.

11 MR. JORDAN: Are we saying that the only thing
12 that they looked at was the equipment, not the
13 instrumentation?

14 MR. HODGES: I think that's probably true. I
15 think that's probably true.

16 MR. JORDAN: Okay. All right. Let's go on and
17 review the OPs in discussion with GE and licensee. Did they
18 express a reservation about using SLC or implementation of
19 the ELPs, and I do something contract -- do you know what
20 that's asking?

21 MR. JENSEN: This next one was -- involves your
22 discussions with General Electric and developing the
23 emergency operating procedures.

24 MR. HODGES: Right.

25 MR. JENSEN: And probably applied those under



1 certain conditions they would inject SLC. I wondered if in
2 any of these discussions did they mention any reservations
3 to injecting SLC -- worry about getting the boron out or
4 worrying about long-term effects on the plant? Did they
5 express that they might be hesitant -- operators might be
6 hesitant to inject SLC?

7 MR. HODGES: When we asked that question on
8 numerous occasions, we always got the answer that they would
9 not be hesitant to inject SLC. We never fully believed it.
10 But that was usually -- that was always the answer they gave
11 us.

12 MR. JORDAN: Do you know, Wayne, is SLC injection
13 for reactivity or is SLC injection for containment
14 protection? In other words, would you expect them, if they
15 had an ATWS and they entered the ATWS procedure, would you
16 expect them, even if they were in cold conditions, to
17 initiate SLC as a precautionary measure?

18 MR. HODGES: Not necessarily.

19 MR. JORDAN: Okay. They --

20 MR. HODGES: Basically, the main reason -- well,
21 SLC is there to satisfy two purposes. One is that you've
22 got a regulation or the GDC that says that they've got to
23 have diverse means of shutting the plant down. One is rods
24 and the other is SLC, okay? So, it's there to satisfy that
25 requirement.



1 From the ATWS world, it says if your MSIVs are
2 closing and you're dumping all your heat into the
3 suppression pool, you've got to get your power down and
4 you've got to get it down in a hurry. The only thing you've
5 got left at that point is SLC, in a worse case.

6 If you've got -- but the EOPs are specifically
7 written that if they're not cycling the SRVs; in other
8 words, if they're controlling pressure with the second SI by
9 dumping heat to the condenser --


10 MR. JORDAN: Yes.

11 MR. HODGES: They don't have to inject it.

12 MR. JORDAN: Right. And that's so -- the EOPs
13 looked at the containment, not at the first one, the
14 diversification -- diversified method of shutting down?

15 MR. HODGES: That's right. It's there if you need
16 it, and you can use it. But, basically, they really felt
17 that you want an opportunity for the other means to work, if
18 you don't have an urgency. If you're dumping the heat to
19 the condenser, rather than to the suppression pool, you
20 don't have the urgency, as I said, you've got to start the
21 SLC right away.

22 Now, if you've tried everything else, driving the
23 individual rods and resetting the scram, been doing all
24 those other actions that are in there and nothing works,
25 you're going to have to inject SLC to get the plant down.



1 But the idea was, if you can maintain the pressure below the
2 SRVs so they're not cycling, that means one of several
3 things. Either that you power down so that you don't have
4 to worry about it, or that you're controlling pressure by
5 another means, you're dumping the heat in the condenser, and
6 you have the time to take -- which, from the plant
7 standpoint, is a preferable action and safety is not
8 threatened.

9 MR. JORDAN: Okay.

10 I guess I'm on to 15, unless there is some
11 question you guys had earlier than that.

12 The next question, Wayne, we have is there has
13 been a lot of loss of power to control room annunciators
14 instrumentation.

15 MR. HODGES: Yes.

16 MR. JORDAN: Okay. And in fact, I guess there is
17 an Information Notice 88-05 stating the lack of specific
18 emergency procedures to address complete loss of annunciator
19 systems.

20 Is NRC reviewing its position on power supplies to
21 these equipments being non-safety-related grade? Do you
22 know if there is an re-review of annunciator power?

23 MR. HODGES: Do I know if there is any?

24 MR. JORDAN: Yes.

25 MR. HODGES: Somebody at headquarters would be



1 better to answer that.

2 MR. JORDAN: That's probably an acceptable answer.

3 The question, I guess, then, also, is what do you
4 feel -- based on your knowledge of the EOPs, do you think
5 there's a need for a more reliable source of power to
6 annunciators and instrumentation?

7 MR. HODGES: "Need" is a strong word. Is it
8 desireable? Absolutely.

9 MR. JORDAN: Desireable. Okay.

10 MR. HODGES: Needed, that's debatable, and you
11 would probably have to get into a cost-benefit argument that
12 would -- it's hard to answer off the top of my head, but --
13 because you can shut the plant down without it, basically.

14 As long as you can do that, the cost-benefit
15 argument gets to be a little bit harder to answer, and
16 you've just got to go to the hard numbers.

17 MR. JORDAN: Maybe you can run through for me, on
18 an ATWS, what instrumentation would we expect to be
19 available for the operators to look at that's safety-related
20 to validate that they are shut down?

21 MR. HODGES: That is safety-related?

22 MR. JORDAN: Yes.

23 MR. HODGES: Well, you would have -- I'm not sure
24 whether the position indication on the SRVs is safety-
25 related or not.



1 That is 197, I think, so it may be, but I'm not
2 certain of that, but that's something you would need to
3 know, and you need the reactor pressure, and that's really
4 all you need if you don't have the power information.

5 MR. JORDAN: SRV positions?

6 MR. HODGES: How many are open or closed, and
7 let's just assume that your secondary side is closed.

8 MR. JORDAN: Yes.

9 MR. HODGES: You also need to know whether your
10 MSIVs or your bypass circuit is closed. If your top valve
11 and bypass are closed, then you just roll back the SRVs, but
12 again, you're relying upon some non-safety-related
13 instrumentation there.

14 You're relying upon, for example, the -- if you
15 assumed that the MSIV's are open, you're relying upon the
16 position of the -- the bypass valve, which would be non-
17 safety, I would think.

18 I think, almost any way you do it, you're going to
19 have to bring in some non-safety instrumentation.

20 MR. JORDAN: What training requirements did we
21 impose on the licensees dealing with loss of annunciators,
22 or balance-of-plant instrumentation, in order to accomplish
23 EOPs. Do you know of any?

24 MR. HODGES: On training requirement?

25 MR. JORDAN: Yes.



1 MR. HODGES: I think the answer there is none.

2 We have, first off, loss of annunciator is not
3 necessarily covered by the EOPs. It could be covered by an
4 normal shutdown procedure. And I think most utilities will
5 have some training on loss of that. But I don't know of any
6 particular event that we prescribe and say you have to have
7 training on that event.

8 Now, we will go and test them on a wide range of
9 events, and if they don't have some training on it, then
10 sham on them. But I don't know if any, I don't know that we
11 require them, for example, to have training on an ATWS. But
12 they sure as hell know we're going to come test them on it.

13 MR. JORDAN: Yes. Being from the operator
14 licensing examining section, you're right, that's what we
15 do. I just wondered if we had any guidelines to them
16 saying, other than a comment that we would come out and
17 examine them in those areas.

18 MS. HERBERT: We have, the supplement to the NUREG
19 0737 I think it was, that talked about they had to have
20 procedures dealing with a range of events, including
21 multiple failures and operator errors. And we expect them
22 to have procedures to deal with that stuff.

23 MR. JORDAN: Beyond the EOPs --

24 MR. HODGES: And we expect them to have a training
25 program. But we don't require training on any specific



1 issues.

2 MR. JORDAN: Beyond the EOPs, are they required to
3 have procedures, for multiple event failures?

4 MR. HODGES: We don't tell them what they've got
5 to call them. We don't tell them they got to call them
6 EOPs.

7 MR. JORDAN: Okay. But I mean, besides the EOPs,
8 we would expect them to have additional procedures for like
9 loss of annunciators; would we expect them to have them --

10 MR. HODGES: We would expect -- you're getting
11 into a difference whether we require or expect.

12 MR. JORDAN: Okay.

13 MR. HODGES: Yes, I expect them to have that. Do
14 we have a requirement that says they've got to have a loss
15 of annunciator procedure? No, we do not have such a
16 requirement. Do I expect that? Yes.

17 MR. JORDAN: Okay. Shortly after the TMI
18 accident, the NRC staff encouraged the licensees to create a
19 third classification scheme for equipment called "important
20 to safety."

21 Can you identify any internal or external NRC
22 document associated with that position? In particular, was
23 there a generic letter issued in 1983 or '85 providing a
24 legal group's challenge to the agency's position on
25 "important to safety"? Do you know of any?



1 MR. HODGES: Yes. There was lots of stuff on
2 that. I can't quote you documents and dates and stuff like
3 that, but there was an old paper that was put together on
4 that, and then what's his name that used to be on the staff
5 for the CRGR, blonde guy?

6 MR. JORDAN: Conrad?

7 MR. HODGES: Yes, Conrad had written a position
8 for --

9 MR. JORDAN: "Important to safety"?

10 MR. HODGES: Yes. He had written a thing on
11 "important to safety" paper that was sent out. There was a
12 lot of discussion of that at the hearings. We even had a
13 panel composed of Conrad and Dennis Peace and Ashok Thadani
14 and myself, and several others. I think there was a total
15 of seven of us dealing with that particular issue. And then
16 there was, I think there was an industry paper on it. So
17 there's a lot of stuff. But I'll have trouble trying to
18 quote you documents off the top of my head.

19 MR. JORDAN: Do you know if we had any regulatory
20 basis for the "important to safety" classification?

21 MR. HODGES: Well, the concern, the problem was
22 we've got conflicting uses of those terms. One part of our
23 regulations will use "important to safety," another part
24 will use "safety-related," and use those terms
25 interchangeably. And the industry contention is they mean



1 the same thing, because we use them one way in one case, and
2 basically we use both terms to mean essentially the same
3 thing in our regulations. And I think that's true. But
4 what we were trying to do is say there is a "safety-related"
5 case and then there's "important to safety," which might be
6 things like in a feedwater system that are not safety-
7 related but are still important. And that's what we were
8 trying to set up. But I think we finally gave up, because
9 we were using the two terms too interchangeably in our
10 regulations.

11 MR. JORDAN: Did we put something out to the
12 industry telling them that they were synonymous, or did we
13 just let it moot?

14 MR. HODGES: I think we finally let it mute. I
15 don't know for sure, but I think we finally let it moot. I
16 think we finally threw our hands up.

17 MR. JORDAN: Okay. I think that answers the next
18 question there.

19 Were you in the region when this happened, Wayne?

20 MR. HODGES: Yes, I was.

21 MR. JORDAN: You were in the IRC when it happened?

22 MR. HODGES: Well, I came into the office about 20
23 after 7:00 and immediately went down there. So by the time
24 I got there, they had restored power.

25 MR. JORDAN: Okay.



1 MR. HODGES: But after 7:00 in the morning until
2 sometime much later, I was in there.

3 MR. JORDAN: Okay. So you're familiar with the
4 event, then?

5 MR. HODGES: Yes.

6 MR. JORDAN: Okay. Are you familiar with the
7 equipment that they did not have available to them?

8 MR. HODGES: Yes.

9 MR. JORDAN: Okay. Can we ask your opinion on
10 equipment that they did not have available to them and
11 whether or not you think it should be safety-related or not,
12 or should it be non-safety-related, one of which is all
13 control rod instrumentation in their power supplies?

14 MR. HODGES: My personal opinion is that should be
15 safety-related. But you have to be a bit careful here,
16 because it's also not safety-related on PWRs, you know.

17 MR. JORDAN: Okay.

18 MR. HODGES: But I am amazed that we have let that
19 go by as not being safety-related. But there's a long
20 history of it not being safety-related, and we would, I
21 think, have a significant backfit issue to deal with that we
22 probably couldn't justify on a cost-benefit basis to try to
23 make it safety-related. But I think that's a shame on us.

24 MR. JORDAN: Okay. You're thinking that thee
25 backup to the control room instrumentation and their power



1 supplies, particularly for, I guess it says all control room
2 instrumentation and their power supplies. You think of it
3 that, just that broad sense --

4 MR. HODGES: No, I think that's too broad.

5 MR. JORDAN: That's too broad. You feel that
6 there's some instrumentation in the control room that should
7 not be safety-related?

8 MR. HODGES: Yes. Yes.

9 MR. JORDAN: Okay. The rod position sensing
10 elements, an indication in their power supplies, you feel
11 maybe should be safety-related?

12 MR. HODGES: My personal opinion is we should make
13 it safety-related.

14 MR. JORDAN: Okay. And you agree that this
15 plant's having them non-safety-related --

16 MR. HODGES: I'm sorry. I was talking. I didn't
17 hear you.

18 MR. JORDAN: This plant being, in other words,
19 non-safety-related, you feel met what the industry
20 requirements are?

21 MR. HODGES: I think it met what the NRC
22 requirements were.

23 MR. JORDAN: But your own personal opinion is, you
24 think it should be safety related?

25 MR. HODGES: My own personal opinion is it should



1 be safety related. I think there's a long history of NRC
2 position that it does not have to be safety related.

3 MR. KAUFFMAN: What is your reason for thinking it
4 should be safety related? Just good practice?

5 MR. HODGES: Yes, I take it -- yes, you've got
6 basically, in a BWR in particular, about three pieces of
7 instrumentation you really have to worry about, and one is
8 water level. Another is power and another is pressure.

9 And I think those are the three major parameters
10 and those ought to be safety related. Those ought to be
11 gold-plated. That's my personal opinion.

12 MR. JORDAN: Okay, how about the APRM, IRM, SRM
13 sensing elements, indicators including their drive motors?
14 Do you want it broken up or whole?

15 MR. HODGES: The instrumentation, yes; the drive
16 motors, I'm not so sure of.

17 MR. JORDAN: Why do you feel that the
18 instrumentation should be, but the driver motors may not be?

19 MR. HODGES: I -- well, you've got to go in and
20 say, what do you mean by safety related and what are you
21 trying to do with it? You know, you want to put them in
22 there and drive them in right away if you get a scram
23 signal. And if you do that, then it's going to be doing
24 that in the normal kind of environment because this stuff is
25 outside of containment. You're not going to have to worry



1 about a harsh environment and a lot of other things with it.

2 Once it's in there, it's going to -- it may have
3 to clear re-criticality, so it should be a very robust
4 instrumentation. So, I think the challenges are different.

5 MR. JORDAN: Okay, but what happens if loss of
6 offsite power -- if the drive motors are not safety related,
7 they may not come off of the diesels and you may not be able
8 to drive them in. They may be sensing external to the core,
9 okay, but they may not be able to get them in.

10 I'm just asking you.

11 MR. HODGES: That's right, you have --

12 MR. JORDAN: You mentioned the fact that the
13 indicators should be, but the drive motors may not be.
14 Could you postulate, as a result of the indicators reading
15 external to the core, what the core power is? Do we have
16 the ability to do that?

17 MR. HODGES: I wouldn't want to try to do that.
18 That would be too wild.

19 MR. JORDAN: Okay, how about all instrumentation
20 used to verify reactor shutdown; do you feel that should be
21 safety related, non-safety related or do you think the mix
22 they have right now is okay?

23 MR. HODGES: Well, I'm not sure. When you say
24 all, I just put the drive motors back in there. You know, I
25 have trouble any time you want to try to use, "all" on me.



1 But I think, in general, the instrumentation used
2 to verify shutdown should be safety related.

3 MR. JORDAN: You think they should have at least
4 one system that's safety related to verify shutdown? If you
5 don't say "all," should you have a system, whether it be rod
6 positions or --

7 MR. HODGES: Yes.

8 MR. JORDAN: Or APRMs or IRMs or something?

9 MR. HODGES: Right, right.

10 MR. JORDAN: How about -- I guess shutdown is also
11 a question. We're talking about here, cold shutdown versus
12 hot shutdown.

13 MR. HODGES: Well, for example, the source range
14 and the APRMs are not going to tell you much about whether
15 you can be in cold shutdown if you're still in hot shutdown,
16 and that's the question you need to answer. There, you're
17 going to need rod position.

18 MR. JORDAN: So you feel they need some type of a
19 rod position, and that should be some type of safety related
20 backfit?

21 MR. HODGES: If I had my druthers, that's the way
22 I would do it because if I have to justify it on a
23 cost/benefit basis as a backfit, I doubt it.

24 MR. JORDAN: Okay. How about the plant computers,
25 SPDS and their power supplies?



1 MR. HODGES: Plant computer, not necessarily;
2 SPDS, yes.

3 MR. JORDAN: Why SPDS?

4 MR. HODGES: Because I think that you need --
5 again, highly desirable, need is probably the strongest.

6 MR. JORDAN: Okay.

7 MR. HODGES: Highly desirable for accident
8 purposes. If you've got that, there are other things you
9 could do without.

10 MR. JORDAN: Okay.

11 MR. HODGES: Again, this is my personal opinion.

12 MR. JORDAN: I understand.

13 Based on your knowledge of the EOPs for boilers
14 and how they're developed and the use of the instrumentation
15 in order to accomplish the EOPs is --

16 MR. HODGES: You can do the shutdown without the
17 SPDS and all this other stuff --

18 THE REPORTER: Without these other things, and
19 then you said what?

20 MR. HODGES: I say you could get the plant shut
21 down to the safe condition with all of this other stuff but
22 it's tough if you don't have it.

23 MR. JORDAN: It's tough if you don't have it,
24 okay.

25 THE REPORTER: Thank you.



1 MR. JORDAN: Okay, how about safety-related for
2 all EOP use parameters and indicators and equipment?

3 MR. HODGES: Nope.

4 MR. JORDAN: Okay. Should a black box for
5 transient analysis be required and be classified safety-
6 related?

7 What we're looking at, Wayne, is should they have
8 some type of a -- like the airlines do, that no matter what
9 happens when you're all done you can go back and via this
10 black box evaluate the transient and what happened?

11 In this case with loss of the computer and loss of
12 the alarm printer and loss of indication, it was hard to
13 recreate with just level and pressure exactly what happened.

14 Do you think we should require the utilities to
15 have some type of a black box transmitted analysis be
16 required and be classified as safety-related, non-safety-
17 related and if you say yes or no, why not?

18 Why or why not?

19 MR. HODGES: I don't think we can -- cost/benefit
20 basis again.

21 I mean it would be a nice thing to have. We
22 always like to be able to know what happened, but -- and
23 because you want to apply that lesson to other plants or
24 even this plant in the future, but I think what we have to
25 focus on is if from a safety standpoint if we're able to get



1 through the event safely without that part in this case at
2 this time there is a fair chance if it occurs again -- we're
3 going to learn something about what happened during the
4 event. We won't be totally ignorant, so I think if you look
5 at the cost of such an instrument versus the benefits that
6 we get from it, we may have a hard time justifying it but it
7 would be a very nice thing to have.

8 MR. JORDAN: Okay, on redundancy and diversity, do
9 we expect, would you expect the utility to have diversity as
10 well as redundancy in non-safety related applications?

11 MR. HODGES: Nice, but not necessary.

12 MR. JORDAN: Nice, but not necessary.

13 MR. HODGES: Right.

14 MR. JORDAN: And you are saying because of cost
15 benefit or you just don't think as a regulator requirement
16 we should be requiring that?

17 MR. HODGES: Well, if it is non-safety-related,
18 we're already saying we don't require that it -- we don't
19 have any requirements on them.

20 MR. JORDAN: How about safety-related?

21 MR. HODGES: I think there's some level of
22 diversity we normally want but we don't always get it. All
23 we get is redundancy. I don't think we need it.

24 For example, we have diverse ways of shutting the
25 plant down and we have diverse systems for injecting water



1 and they are redundant among themselves. You need a certain
2 amount of that.

3 MR. JORDAN: How about important to safety
4 equipment?

5 MR. HODGES: I don't think, for example, we'd want
6 to say you need both for example a centrifugal and a
7 positive displacement pump to get diversity in the injection
8 system. I think something like that would be kind of
9 ridiculous.

10 If you got -- I think you have to temper the
11 amount of diversity. I think there are situations where
12 it's great. I think there's other situations where it
13 doesn't buy you a lot.

14 MR. JORDAN: How about manufacturer, model types?

15 MR. HODGES: I think you have to look at again
16 specific -- if I had manufacturer I had a high confidence in
17 making my pumps I might prefer to stay with that rather than
18 trying to split it up just for diversity's sake.

19 I think you have to temper some of that with
20 reason is what I'm saying.

21 Across-the-board diversity is not necessarily good
22 and there are problems with spare parts and other things as
23 well, so a certain amount of diversity, across-the-board
24 diversity may be bad for you.

25 MR. JORDAN: Okay.



1 Can you describe -- I think you already did a
2 little bit -- any interfaces you have had with NRR branches
3 in the review of the above areas?

4 In your experience, have you brought issues like
5 this up, and has it been discussed and developed, and in
6 what areas of NRR did you bring it up with?

7 MR. HODGES: Okay.

8 Well, obviously I was in NRR when I reviewed the
9 EOPs.

10 MR. JORDAN: Okay.

11 MR. HODGES: And when I began, the branch chief
12 was a supervisor, supervising the review of EOPs.

13 MR. KAUFFMAN: What revs were those?

14 MR. HODGES: Well, I actually did the review for
15 Rev 2. Rev 3 was done in another organization, and then I
16 did Rev 4 under my supervision.

17 MR. KAUFFMAN: Do you happen to know who did Rev 0
18 and Rev 1?

19 MR. HODGES: Rev 0 and Rev 1 were never approved
20 by the NRC. We were doing a continual review up through Rev
21 2, and Rev 2 was the first one that an SER was written on.

22 So, I was involved all the way up through the
23 writing of the SER for -- for Rev 2.

24 MR. KAUFFMAN: Okay.

25 MR. JORDAN: In your review of those, did you have



1 any interface with other NRR branches?

2 MR. HODGES: Oh, sure.

3 The -- it was the human factors division, and they
4 -- in fact, they had an individual who did the human factors
5 review while I was doing the systems review, and then I also
6 interfaced with the instrumentation branch and the
7 containment systems branch and -- those were the major ones.

8 Yes, there -- there was -- was interface with
9 other -- other branches.

10 MR. JORDAN: What kind of interface did you have
11 with instrumentation?

12 MR. HODGES: Basically, we talked about the kind
13 of things -- what would be needed in an operator and that
14 kind of stuff.

15 It was more on a consulting basis. They didn't
16 actually do the review.

17 They were used as consultants, and pretty much the
18 same with containment systems, although they were given some
19 parts, say look at this and give me your opinion kind of
20 thing, but I was responsible for the review, and I did the
21 writeup. They acted as consultants to me.

22 MR. JORDAN: Did you ever ask instrumentation, you
23 know, what instrumentation is going to be available or not
24 available and whether or not they felt -- what their
25 feelings were on instrumentation that was going to be needed

1. The first part of the document discusses the importance of maintaining accurate records of all transactions.

2. It is essential to ensure that all data is entered correctly and that the system is regularly updated.

3. The following table provides a summary of the key findings from the study.

4. The results indicate that there is a significant correlation between the variables studied.

5. Further research is needed to explore the underlying causes of these trends.

6. The data suggests that there are several factors that influence the outcome of the process.

7. It is recommended that the organization implement the following measures to improve efficiency.

8. The conclusion of the study is that the current system is effective but requires ongoing monitoring.

1 or they felt was needed?

2 MR. HODGES: We had a lot of discussions on what
3 we would do under various circumstances. Did we ever
4 contemplate something like happened at Nine Mile, where you
5 lose five separate power supplies selectively, I'm not sure
6 we got that detailed.

7 But we looked at loss of all instrumentation and
8 all power or all DC power in the control room and those
9 types of things and tried to say, okay, what do you need to
10 deal with it?

11 But when you've got a mixture, I don't think we
12 got into that kind of detail.

13 MR. JORDAN: Okay.

14 Well, let me go around the room here and see if
15 there's any other questions. Then we'll ask you our final
16 question.

17 You guys got anything else?

18 MR. KAUFFMAN: I had one.

19 Back when we were talking about EOPs and we're in
20 two legs that basically told us to do different things --

21 MR. HODGES: Right.

22 MR. KAUFFMAN: -- we debated amongst ourselves
23 here what should be done. Is that a good position, a fair
24 position to put the operator in, that he has conflicting
25 things and he doesn't have something to say that this one is



1 most important, it takes priority, do this?

2 I guess what I'm asking is the EOPs, was it
3 intended that you would wind up in conflicting spots, or did
4 this event show a glitch?

5 MR. HODGES: I think if you even look at our SER
6 on the Rev 2 -- and I think some of the others were carried
7 forward in our SER on Rev 4 -- it talks about where the
8 priority should be put, and some of that should be in
9 training.

10 You don't want to have everything in the EOPs
11 themselves. Some of it is going to be left to training.

12 Where the focus should be on maintaining core
13 cooling, for example, that's fairly clear that it's a
14 priority, and my memory is a little dim on some of this, but
15 I think the BWR information, the owners group information on
16 that, also --

17 MR. JORDAN: Also what?

18 MR. HODGES: -- also has similar words on where to
19 put the priorities, and also, there is -- see, in addition
20 to just the -- the EOPs, there were appendices to that that
21 got into how to develop these numbers that go into the EOPs
22 and the philosophy behind what was being done, and then,
23 that -- those appendices definitely put precedence on
24 keeping the core cool.

25 MR. KAUFFMAN: So, in this event, the operators



1 really weren't sure which one was more important. They used
2 their judgement and kind of picked one.

3 MR. HODGES: Well, I think their training, if it
4 didn't tell them that the priority was on core cooling,
5 should have.

6 So, there should not have been a big question mark
7 for the operators, in my opinion. If it was, then that may
8 signal a weakness in their training.

9 MR. KAUFFMAN: If I'm looking at this a human
10 factors point of view, I might suggest something like that
11 this leg, the most important leg, be in bigger print or
12 darker or have a big "1" by it. Would something like that
13 make sense?

14 MR. HODGES: I don't know. I'm not a human
15 factors expert.

16 MR. KAUFFMAN: Because it's a stressful situation.

17 MR. HODGES: It's a stressful situation, but
18 you're relying upon several things.

19 You're relying upon the procedures that tell you
20 how to go through and do things.

21 You're relying upon training that tells you where
22 to put your emphasis on things, what's important, how the
23 plant behaves, you know, the physics of the plant, and I
24 think that -- you don't put all that in the procedures
25 either.



1 There's a lot of stuff you don't have in there
2 explicitly. It's expected to be covered in training --
3 whether you should single out because this event happened to
4 do that, I'm not sure.

5 MR. ROSENTHAL: Wayne, this is Jack Rosenthal. I
6 just came in a few minutes ago from another meeting.

7 MR. HODGES: I can't repeat everything I've just
8 said.

9 MR. ROSENTHAL: I don't expect you to. Number
10 one, I wanted to say thank you.

11 MR. HODGES: Uh-huh.

12 MR. ROSENTHAL: But I do want to ask just a couple
13 of questions. If it's been covered, you could just say,
14 hey, it was covered.

15 I think that we, in reviewing the EOPs, we said,
16 go ahead and put all the instruments in that you really
17 need, whether they're safety-related or not, because we
18 didn't want to have one set of EOPs that were the real EOPs,
19 and another one that was just for the regulators. So, we
20 told them that hey, if you put in the stuff, that means we
21 won't turn around and make you make it all safety-related.

22 MR. HODGES: In essence, that's correct.

23 MR. ROSENTHAL: Okay. But I can't find that in
24 writing any place. Do you know where that was ever
25 formalized?



1 MR. HODGES: I don't know if we ever did formalize
2 it.

3 MR. ROSENTHAL: Okay. Another issue that I've
4 heard is that some people believe that if you needed to take
5 action, it ought to be of the highest quality and
6 redundancy, but if you need it for confirmation or
7 verification, it could of a lower quality or level of
8 redundancy. That was like a logic that was used. But I
9 don't know where that's written down. Do you know anyplace
10 where that's written down as a rationale?

11 MR. HODGES: No.

12 MR. ROSENTHAL: That was just the way people
13 worked?

14 MR. HODGES: For the most part. But, again, we
15 have one here like the control rod position, which really
16 need to take an action, not just for confirmation. Because,
17 you know, you need to know that before you could cooldown,
18 and it's not safety-related. So, that's not an across-the-
19 board truism.

20 MR. KAUFFMAN: I guess, in some of the interviews
21 we had people said if it was to take credit for it, like in
22 Chapter 15 FSAR, then it was safety-related.

23 MR. HODGES: That's not even true, sir. There are
24 things that are taken credit for in the Chapter 15 FSARs
25 that are not safety-related.



1 MR. ROSENTHAL: Especially for anticipated
2 transients?

3 MR. HODGES: Oh, yes, absolutely. The only thing
4 -- the only place where it's required to be safety-related
5 is in dealing with LOCAs and such. Now, there you've got to
6 have safety-related equipment to deal with it -- the oldest
7 ECCS stuff. But if you're talking about turbine trips and
8 things like that, you will rely upon nonsafety-related
9 instrumentation, Chapter 15. And that's been common
10 practice for both BWRs and PWRs.

11 MR. ROSENTHAL: Okay. Were you involved in the
12 maintenance rule?

13 MR. HODGES: No.

14 MR. ROSENTHAL: Were you involved in importance of
15 safety versus safety-related?

16 MR. HODGES: Uh, I've been involved with it for
17 the Shoreham hearings. I had numerous discussions with --
18 again, I can't think of his name --

19 MR. ROSENTHAL: Conran?

20 MR. HODGES: -- he's from the CRGR staff.

21 MR. ROSENTHAL: Jim Conran?

22 MR. HODGES: Jim Conran. He and I had lots of
23 discussions. We were on a panel together, on one of the
24 contentions at Shoreham.

25 MR. ROSENTHAL: Well, we've interviewed Conran.



1 So, if we pumped him --

2 MR. HODGES: You've probably got the most
3 knowledgeable person on it then, if you pumped him.

4 MR. ROSENTHAL: Okay. And you guys have been over
5 the emergency procedures, I know.

6 I'm finished.

7 MR. JORDAN: Wayne, I personally thank you.

8 MR. HODGES: Okay.

9 MR. JORDAN: Someday you and I are going to have
10 to meet each other face-to-face.

11 MR. HODGES: Right. I look forward to it.

12 MR. JORDAN: Okay, Wayne.

13 MR. HODGES: Take care.

14 MR. JORDAN: Thank you.

15 MR. ROSENTHAL: Thank you.

16 [Whereupon, at 1:39 o'clock p.m., the above-
17 entitled interview was concluded.]

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: Wayne Hodges

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Official Reporter
Ann Riley & Associates, Ltd.



OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U.S. Nuclear Regulatory Commission
Incident Investigation Team

Title: Interivew of: Wayne Hodges
(Closed)

Docket No.

LOCATION: Bethesda, Maryland

DATE: Thursday, September 5, 1991 **PAGES:** 1 - 59

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

Dupe of

~~9305070258~~



ADDENDUM

| <u>Page</u> | <u>Line</u> | <u>Correction and Reason for Correction</u> |
|-------------|-------------|---|
| 5 | 14 | change short to source |
| 6 | 4 | change imposition to position |
| 18 | 5 | change course route to core shroud |
| 20 | 4 | change weight to wait |
| 22 | 12 | change AEOPs to EOPs |
| 23 | 13 | change incursion to excursion |
| 23 | 14 | change section L to scenario |
| 31 | 13 | change SIVs to SRVs |
| 38 | 10 | change sham to shame |
| 38 | 18 | change Ms. Herbert to Mr. Hodges |
| 40 | 6 & 7 | change Conrad to Conran |
| 40 | 13 | change Conrad to Conran |
| 40 | 13 | change Dennis Peace to Themis Speis |

Note: There are several instances where words are not transcribed accurately but the errors are obvious. I have not attempted to alter these.

Date 9/26/91 Signature M. Wayne Hodges

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 INCIDENT INVESTIGATION TEAM
4
5

6 - - - - -X

7 In the Matter of: :
8 INTERVIEW OF: :
9 WAYNE HODGES :
10 (CLOSED) :

11 - - - - -X

12
13 Nuclear Regulatory Commission
14 Interview Room
15 Woodmont Building
16 8120 Woodmont Ave.
17 Bethesda, Maryland
18 Thursday, September 5, 1991
19

20 The above-entitled matter commenced at 12:22
21 o'clock p.m.
22
23
24
25



1 On behalf of the Incident Investigation Team:

2

3 JOHN ROSENTHAL, II Team Leader

4 MICHAEL JORDAN, NRC Region III, II Team Member

5 WILLIAM VATTER, INPO, II Team Member

6 WALTON JENSEN, Events Assessment Branch, II Team
7 Member

8 JOHN KAUFFMAN, AEOD, II Team Member

9

10 Interviewee:

11

12 WAYNE HODGES

13 Deputy Director for Reactor Safety

14 U.S. Nuclear Regulatory Commission

15 Division I

16 Philadelphia, Pennsylvania

17

18 [Mr. Hodges was interviewed via telephone from
19 Charlottesville, Virginia.]

20

21

22

23

24

25



P R O C E E D I N G S

[12:22 p.m.]

1
2
3 MR. JORDAN: Okay, Wayne, why don't we start?

4 I'll introduce myself. My name is Michael Jordan.
5 I'm out of Region III, Wayne. I'm a Section Chief in Region
6 III for Operating Licensing, and also in the room is also --

7 MR. KAUFFMAN: John Kauffman. I'm a Director of
8 Systems Engineering in AEOD.

9 MR. JENSEN: Walton Jensen. I work in the Events
10 Assessment Branch, but I used to work in Reactor Systems
11 across the hall from you, Wayne.

12 MR. HODGES: Yes, I know you did, Walt.

13 MR. VATTER: I'm Bill Vatter. I'm from INPO,
14 Wayne. You'll remember that we met in that IIT School
15 earlier this year.

16 MR. HODGES: Right, right. I remember you.

17 MR. JORDAN: Okay. The event we're going to talk
18 about, Wayne, happened on August the 13th at Nine Mile
19 Point, Unit II, involving a site emergency because of a
20 transient coupled with a loss of power of annunciators.
21 That's why they had the site emergency. They lost a lot of
22 balance-of-plant equipment, and they lost their full core
23 display.

24 The reason why we're talking to you is, we're
25 looking for information having to do with the development



7

8

9

10

11



12

13

14

15

16

17



1 and review of the BWR's EOPs.

2 And why don't we start out with the first we've
3 got here, and we'll work our way through this thing. If you
4 have any questions along the way, stop us and ask us.

5 MR. HODGES: Okay.

6 MR. JORDAN: Since we can't see you, we don't know
7 what you're -- if you're having a problem or not.

8 With respect to the EOP parameters and
9 instrumentation used during the operator implementation of
10 the EOPs, how were the parameters related to the Reg Guide
11 197 instrumentation?

12 MR. HODGES: I didn't understand the question.

13 MR. JORDAN: Okay. 197 has got the list of
14 instrumentation that's required to be operable EQ'd, et
15 cetera, after an event -- EOP development.

16 Do you know of any -- how those 197
17 instrumentation were related to the EOP development?

18 MR. HODGES: Not directly. I mean, as far as the
19 development of the list, the EOP was being developed
20 concurrent with 197, and I know that Jack Rosenthal tried to
21 incorporate EOP issues, but it was strictly 197, and which
22 ones were required by 197, I don't know.

23 MR. JORDAN: Okay. So you don't know of any in
24 the EOPs where portions of the EOPs require 197 in order to
25 get through them?



34

2

4 4 2



1

4



1 MR. HODGES: Well, I would answer the question a
2 little bit differently. Was there adequate instrumentation
3 available with what they lost to make it through the event?
4 And in this case, there was. And that was at least my
5 opinion at the time the event was going on, and then that
6 was later confirmed by Carl -- uh-oh.

7 MR. JORDAN: Sisco.

8 MR. HODGES: Carl Sisco when he looked at it up
9 there as part of the AI team.

10 Recognize that you can use, you know, a myriad of
11 things, and in this particular instance, they did have
12 indications on the back panel that they APRMs were
13 downscale. The power was down for most of the plant, but it
14 was down in the short range.

15 MR. JORDAN: Well, they knew they were off 4
16 percent.

17 MR. HODGES: Right.

18 MR. JORDAN: And I guess the question is, is that
19 is there any instrumentation that's EQ qualified to verify
20 below the 4 percent, so they get out of that do loop that
21 was part of the EOPs.

22 Are you familiar with the section of the EOPs that
23 got them into a holding pattern?

24 MR. HODGES: I'm trying to recall. No, I'm not
25 right off the top of my head, because you don't need -- if



11

12

13

14

15

16



17

18

19

20

21



1 the power instrumentation is not available, the power
2 instrumentation is not available, there are steps in the EOP
3 to determine where you are without using that
4 instrumentation. It relies upon pressure or imposition of
5 SRVs and those types of things.

6 So you can determine not the absolute power level,
7 but you can tell -- you can determine that the reactor is
8 shut down based upon the reactor pressure and the status of
9 SRVs.

10 MR. JORDAN: Yes, but the problem is there is a
11 section here that talks about you have to wait until all
12 control rods are inserted to at least the O2 position.

13 MR. HODGES: Right.

14 MR. JORDAN: Okay. And do you know of any 1.97
15 material that allows them to go through that?

16 MR. HODGES: Again, I don't recall which is 1.97
17 and which is not. I haven't looked at a list of 1.97
18 instrumentation in a long time.

19 MR. JORDAN: Okay. Well, the reason I'm asking,
20 Wayne, is that, you know, I'm looking at what they had, and
21 since they didn't have the full core display -- they said
22 they didn't have that. All rods are inserted to at least
23 the O2 position. They felt the only way --

24 MR. HODGES: They did not have the rod position
25 indication, is my understanding.



Vertical text or markings along the right edge of the page, possibly bleed-through from the reverse side.



1 MR. JORDAN: That's correct. So they couldn't do
2 that.

3 MR. HODGES: Right.

4 MR. JORDAN: And it says: Or the reactor will
5 remain shut down without boron.

6 MR. HODGES: Right.

7 MR. JORDAN: Okay. What instrumentation would you
8 expect them to use to verify that the reactor remained shut
9 down?

10 MR. HODGES: I would use several things. One, I
11 would use the back panel and see that the APRMs were
12 downscale. That's an indication that they're down.

13 MR. JORDAN: Yes.

14 MR. HODGES: They also got the status of the SRVs
15 and the pressure, and those would indicate the reactor was
16 shut down. So there's adequate instrumentation from what
17 they had to deduce that the reactor was shut down.

18 MR. JORDAN: But how do they know it's going to
19 remain shut down, because the step was "will remain shut
20 down without boron"?

21 MR. HODGES: Right. All that says is before you
22 start to depressurize, you may have to worry about, for
23 example, if you don't have rod position indication and you
24 don't know -- all you know is that it's below a certain
25 point, now you've got to -- you have to worry about some

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



1 rods being out, and you have to have some means of verifying
2 the rod position. Otherwise you shouldn't cool down. That
3 does not say you cannot maintain the plant in a stable
4 condition.

5 And that's all the EOPs is trying to do, is keep
6 you in a safe, stable condition. And a hot shutdown at full
7 pressure but zero decay heat power is a safe, stable
8 condition.

9 MR. KAUFFMAN: Okay. But if they were cooling
10 down by, say, using RCIC to inject, that wouldn't meet the
11 intent of that step there to not depressurize if they, in
12 fact, did depressurize?

13 MR. HODGES: Well, I don't think they started that
14 until after they got some instrumentation back. They got
15 the instrumentation back in about 20 minutes.

16 I mean, if you're sitting there with, you know,
17 the pressure between 800 and 1000 pounds, you're not
18 depressurizing.

19 MR. JORDAN: Yes, but what they did, Wayne, in
20 order to put water into the vessel --

21 MR. HODGES: Right.

22 MR. JORDAN: -- they used RCIC.

23 MR. HODGES: And that's going introduce some cold
24 water, and that's going to drop the pressure a little bit.

25 MR. JORDAN: Right. And that dropped the



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



1 pressure.

2 MR. HODGES: But it's going to operate, is what's
3 going to happen. Initially, RCIC won't be enough to take
4 out the decay heat, and so it will maintain pressure. After
5 a period of time, then RCIC will keep up with it. So it's
6 an energy balance game.

7 MR. JORDAN: Yes, but I think what really
8 happened, Wayne, is they didn't maintain the pressure. The
9 RCIC drawing the steam off on the RCIC --

10 MR. HODGES: Right.

11 MR. JORDAN: -- actually reduced pressure.

12 MR. HODGES: Okay.

13 MR. JORDAN: You know.

14 MR. HODGES: But they also went to Level 8, which
15 they didn't have to do, but it is routine to do that. But
16 how far down did the pressure bring them?

17 MR. JORDAN: Down to about -- I think it was
18 around, Walt, 500 pounds.

19 MR. JENSEN: Around 700. They went down to around
20 700 pounds, so that the condensate booster pumps started
21 injecting into the vessel.

22 MR. HODGES: Okay.

23 MR. JENSEN: And that's when it went up to Level
24 8, when they dropped down below the booster pump pressure,
25 and the booster pump started injecting into the reactor --



1 2 3

1

2

3

4

5

6

7

8

9



1 MR. HODGES: Okay.

2 MR. JENSEN: -- and brought the level up.

3 MR. HODGES: All right.

4 MR. JENSEN: It was about a little less than 700.

5 MR. HODGES: Did they see anything that would have
6 indicated an increase in power while they were doing that,
7 an increase in pressure or anything like that?

8 MR. JENSEN: No. The pressure was going down all
9 the time they were having RCIC injection, and the --

10 MR. HODGES: The only thing you don't know is --
11 during that first 20 minutes until they got some power
12 restored, is the absolute position of the rods.

13 MR. JENSEN: That's right.

14 MR. HODGES: You know the reactor was essentially
15 shut down where you are.

16 MR. JORDAN: You know -- right. At each pressure
17 point, you know you're shut down.

18 MR. HODGES: You don't know what will happen if
19 you go lower.

20 MR. JORDAN: You don't know what will happen if
21 you go lower.

22 MR. HODGES: That's the only concern there.

23 MR. JORDAN: But that says -- that's what that --
24 maybe understanding what the step is, but that, I thought,
25 was what the wait step is for is so that you don't --

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1 MR. HODGES: Yes. The step says that you should
2 not, you know -- you should try to hold it in safe, stable
3 condition until you can make that determination, basically
4 is what that's saying.

5 MR. JORDAN: And the question I have is that other
6 than the pressure, which is the 197 pressure, the PAM, the
7 post-accident monitor records, and the APRMs and the back
8 panels, did we look at any other method by which they could
9 go through that step prior to depressurization using RCIC.

10 MR. HODGES: Well, be careful, because most of us
11 did not even get to the Response Center until after they had
12 restored power. So we were looking at everything after the
13 fact at that point.

14 MR. JORDAN: No, but I'm looking at -- I'm
15 questioning back on EOP development.

16 MR. HODGES: Right, right.

17 MR. JORDAN: Not when we showed up, not when we,
18 the NRC, responded to the event.

19 MR. HODGES: When we were developing the EOPs, we
20 did not say: Is this 197 or not 197? That was not a
21 consideration in the development of EOPs.

22 The consideration is; do you have an instrument
23 that will do that? And if you lose that instrument, do you
24 have a backup? And there was no consideration of; is it
25 safety related, is it 197? That was not part of the



1 discussion.

2 MR. KAUFFMAN: Was there a consideration given
3 that at least instrument for that function would be, as you
4 seemed to indicate before, not considered at all?


5 MR. HODGES: I'm sorry, the question again?

6 MR. KAUFFMAN: I guess you said it wasn't
7 considered whether the instrument was Reg Guide 197 or not.
8 My further question is, was there consideration given to the
9 idea that for some functions, you would make sure you at
10 least had one safety grade or one 197 instrument to look at
11 that function?

12 MR. HODGES: There was no consideration of whether
13 or not the instrumentation was safety grade of 197. The
14 question was; did you have an instrument that, given the
15 conditions that you had, you could have confidence in?

16 And you verified that by several means: one is,
17 if you had similar instruments reading the same kind of
18 thing, or if you had other parameters that were consistent
19 with the reading that you have. But, I mean, whether it's a
20 safety grade instrument or a non-safety grade instrument,
21 you may have a problem.

22 Therefore, the EOPs do not consider whether it's a
23 197 or a safety related or anything else. They basically
24 say, do you have an instrument you can rely upon to do the
25 job? Well, the purpose of the 197 and the safety grade is



1 to try to assure a high level of reliability for a certain
2 set of instruments. But that does not mean necessarily that
3 those instruments are more reliable than some other
4 instrument.


5 In fact, because of some of the criteria we put on
6 them, they may, for some circumstances, be less reliable.
7 But the point is that the operator should have some
8 instrumentation that he can rely upon to draw his
9 conclusions.

10 Now, beyond that, if, on a BWR, you lose all
11 power indication, there are still -- I mean, power not
12 reading, whether from the APRMs or source ranges or
13 whatever, and you don't have a power reading, you can still
14 deduce the power rating from the pressure and status of SRVs
15 and MSIVs.

16 The EOPs allow that to occur. For example, if the
17 pressure was going down -- you say down to 700 pounds --

18 MR. JORDAN: Right.

19 MR. HODGES: Then you're not at power, not with
20 the kind of flow that you've got with RCIC, because RCIC can
21 -- is a low capacity system that will, if my memory is
22 right, is that it is equivalent to roughly five percent of
23 power -- no, it's less than that 3 percent of power, which
24 is identical to decay heat range and until -- and for the
25 first five minutes or so, RCIC can't even keep up with decay



1 heat.

2 After that, it will start to do a little bit and
3 could depressurize you. But RCIC is a low capacity system,
4 and if that's what you're using and the pressure is going
5 down, you can have a high confidence, even though you've got
6 no direct power instrumentation, that the reactor is shut
7 down.

8 MR. VATTER: Wayne, let me postulate for you --

9 MR. HODGES: Sorry. That was part of the
10 philosophy in developing the EOPs.

11 MR. VATTER: Wayne, I'd like to postulate for you,
12 a little bit different scenario.

13 MR. HODGES: Okay.

14 MR. VATTER: And perhaps you can tell me whether
15 it's realistic or whether it's been considered.

16 MR. HODGES: Okay.


17 MR. VATTER: You get the scram but you don't get
18 all the rods going in.

19 MR. HODGES: Right.

20 MR. VATTER: However, the operator doesn't know
21 this.

22 MR. HODGES: Right.

23 MR. VATTER: And he is able to see that the
24 reactor is shut down, but he doesn't know how much it's shut
25 down.



1 MR. HODGES: Right.

2 MR. VATTER: And then, as he cools down, he has
3 re-criticality.


4 MR. HODGES: Right.

5 MR. VATTER: And because of the rate of the
6 cooldown, either through cold water addition or by
7 depressurizing, the reactivity is added quick enough that
8 before you get Doppler, or voids or something that could
9 turn it, you get the reactor going on a power increase
10 that's unacceptable. Maybe you get not prompt critical, but
11 you get close enough to it that you have such a high power
12 spike that you hurt the fuel?

13 MR. HODGES: Right. You can't do that with that
14 kind of a cooldown. In fact, as you cool down and
15 depressurize, if you start to generate some power, what you
16 will do is, you will get some voiding and that will -- the
17 voids that you depressurize will have a stronger effect than
18 the cooldown. That was considered.

19 MR. VATTER: But you might shoot some cold water
20 in there like condensate booster pumps. You might be
21 cooling down real slowly or depressurizing real slowly.

22 MR. HODGES: If you get to the point where you --
23 and you get to a situation similar to what you're talking
24 about, but you can't do it without boron in there. You
25 can't have it both ways.



1 Either you're going to have -- as far as -- I
2 suppose you could go -- you could go recritical. But you're
3 not going to go on a prompt critical that's going to become
4 exponential on you.

5 MR. VATTER: Is there some kind of analysis that's
6 been done in that that we could study?


7 MR. HODGES: There were some analyses done. I
8 don't have them. GE may have them. I'm not sure where they
9 are right now.

10 MR. VATTER: Who is the person that we ought to
11 talk to to find out more about that analysis?

12 MR. HODGES: Probably what I would do is go
13 through the BWR Owners Group chairman and have him contact
14 GE. The EOPs belong to the BWR Owners Group, not GE. They
15 had some analyses done by GE and they had some analyses done
16 by contractors. I think I would go through the BWR Owners
17 Group and see what they've got.

18 MR. JORDAN: But you think there's analysis to
19 show that with using -- without boron in the vessel, as long
20 as you have a cooldown, that you can't go prompt critical
21 and cause --

22 MR. HODGES: Well, I think that's true. Now, we
23 even did some calculations at Brookhaven with boron in there
24 that tended to show that that couldn't happen, but that
25 tended -- that was where you were smearing the effects over



1 the whole core. I'm not so sure that if you localized it,
2 you couldn't do something with it if you had boron in there.

3 But even that showed that if you -- as long as you
4 weren't localizing -- and these were from calculations that
5 were done under contract at Brookhaven by Dave Diamond --
6 again, I don't have any contract -- any reports on that, but
7 they're probably retrievable from Brookhaven somehow.

8 MR. JENSEN: Wayne, would somebody in the Reactor
9 Systems Branch maybe have those reports or be familiar with
10 the calculations?


11 MR. HODGES: Well, we did at one time when I was
12 down there. I don't know where they are now, Walt. Chuck
13 Graves was involved with some of that. Whether he still has
14 some, I don't know. It might wind up having to go back to
15 the Brookhaven or someplace to try to get them, because they
16 did the analysis.

17 MR. JORDAN: Did they do that for us or for
18 somebody else?

19 MR. HODGES: They did that for us.

20 MR. KAUFFMAN: Who on our staff reviewed those
21 types analysis?

22 MR. HODGES: I said Chuck Graves and I looked at
23 that from the Brookhaven analyses. We were trying -- we
24 were asking a slight different question. We were looking at
25 it with boron in there, and we were concerned -- my concern



1 was at that time that if you had the reactor shut down and
2 you injected, un-borated water, but it was shut down
3 strictly on boron -- and we were looking at a BWR-5 or BWR-6
4 design where you injected the low pressure cooling injection
5 system directly into the course route, could you get, you
6 know, an excursion?

7 And their calculation showed no. My concern was,
8 their model was not good enough to look at the local jetting
9 effect of the cold water, the localized effect rather than
10 the smeared effect across the core.

11 But for the kinds of things you're talking about
12 where you're just injecting it in the feedwater lines and
13 coming on down that way, that analysis would say, even with
14 boron in there, you're not going to get that.

15 MR. KAUFFMAN: Did that analysis assume that you
16 got, I guess we'll say, full rated condensate booster pumps?
17 Because, what happened in this --

18 MR. HODGES: That analysis assumes all LPCI flow
19 coming in cold. Basically, I think it assumed full LPCI
20 flow coming in.

21 MR. JENSEN: Now, when you say that there was
22 boron, is that assuming that the operator has injected the
23 system?

24 MR. HODGES: That was taken as an assumption that
25 you had an ATWS where no rods went in. You had shut the



11

20

12



13

14

15

16

17



1 reactor down using boron from the standby liquid control
2 system. You had depressurized down to, you know, a low
3 pressure system and then you got an inadvertent actuation of
4 your LPCI to inject the full -- the LPCI flow which is like
5 going to be roughly 20,000 gallons per minute -- 15-20,000
6 gallons per minute injected into a core that's shut down
7 strictly with the boron which I think is probably a more
8 valuable analysis than what you were asking for.

9 MR. JORDAN: Okay. Let me ask another question.

10 MR. HODGES: Okay.

11 MR. JORDAN: This is to the -- the previous
12 questions were more generic with the EOPs. This is back to
13 the specific event.

14 MR. HODGES: Okay.

15 MR. JORDAN: Okay, when the operators got to the
16 point in their ATWS procedure that says wait until all rods
17 are inserted at least the 02 position in the reactor or the
18 reactor remains shut down without boron. I think they got
19 into a stop statement, that they couldn't get through that,
20 okay?

21 MR. HODGES: Okay.

22 MR. JORDAN: Now on the other one for the normal
23 reactor vessel level control under pressure control, it says
24 you don't start cooling down until all rods are inserted.
25 The reactor remains shut down without boron, if boron is



62



2



1 being injected but a slick level is dropped to 900 gallons
2 or the reactor is shut down and no boron has been injected.

3 MR. HODGES: All right.

4 MR. JORDAN: Okay. That's another weight
5 statement.

6 MR. HODGES: Okay.

7 MR. JORDAN: Both of those are -- but they were in
8 a situation that while they were using RCIC they were
9 depressurizing.

10 MR. HODGES: Okay.

11 MR. JORDAN: And RCIC is allowed by the ATWS
12 procedure as an injection source. By injecting with RCIC
13 they reduce pressure.

14 MR. HODGES: Right.

15 MR. JORDAN: So is --

16 MR. HODGES: Well, that says the power is at least
17 less than what RCIC is capable of.

18 MR. JORDAN: Okay.

19 MR. HODGES: And RCIC because they can take out
20 and it's all between 2 and 3 percent power so you know it's
21 less than that.

22 MR. JORDAN: Okay, so as far as the cooldown
23 depressurization using RCIC, that's not allowed by the
24 pressure -- you feel it's okay because it's allowed by the
25 RCIC ATWS? You have a problem with --



1 MR. HODGES: Wait, let's back up a minute.

2 MR. JORDAN: Okay.

3 MR. HODGES: RCIC is maintained core covered.

4 MR. JORDAN: Right.

5 MR. HODGES: And that has got to be the first
6 priority is that you maintain adequate coverage of the core.

7 MR. JORDAN: Okay.

8 MR. HODGES: All right? Now if in the process of
9 doing that you have some depressurization, if it could be
10 avoided you probably should, but if it is needed in order to
11 maintain the core covered and adequate core cooling, the
12 choice has got to be to go for the core cooling. There has
13 to be a priority there.


14 MR. JORDAN: Okay. Okay, would you expect the
15 reactor operators to close the MSIVs in order to maintain
16 pressure up?

17 MR. HODGES: I would expect that they might want
18 to try to control pressure with MSIVs so as not to cycle the
19 SRVs and dump heat to the -- but I would expect them if the
20 pressure is dropping to try to close them to let it come
21 back up but I would expect they might try to use an MSIV as
22 a pressure control mechanism.

23 MR. JORDAN: MSIVs are to control with pressure.

24 MR. HODGES: I understand that.

25 MR. JORDAN: They're either opened or closed.



1 MR. HODGES: It's either open or closed -- but
2 MSIV is open and using a bypass or something to --

3 MR. JORDAN: -- need a bypass? By just using RCIC
4 they were depressurizing.

5 MR. HODGES: Right.

6 MR. KAUFFMAN: Then there's steam auxiliaries.

7 MR. JORDAN: Then there are steam auxiliaries.

8 Okay, the question I have is that would you have -- the EOPs
9 don't tell them to do that --


10 MR. HODGES: Right.

11 MR. JORDAN: -- it just says you can't cool down--

12 MR. HODGES: But in fact I think the AEOPs would
13 encourage them to keep the MSIVs open as a means of removing
14 heat, particularly if there's a concern for an ATWS, because
15 it is preferable to dump the heat to the condenser if you
16 are going to have an ATWS going on than to dump it to the
17 pool, where you start challenging your containment.

18 MR. VATTER: That's if you got power below 4
19 percent and you're concerned about recriticality, then maybe
20 pressure control might come in.

21 MR. HODGES: The only thing -- what is the concern
22 with recriticality? The concern is that if you've got a
23 real skewed rod pattern that you might get boiling
24 transition on a few rods and even though that would be a
25 violation of the safety limit and it's something we'd



1 probably slap their hands for from a strict safety
2 standpoint that ain't a big deal.

3 MR. VATTER: The other possibility is like we were
4 talking that you get some power spike due to the reactivity
5 going in there too quick.

6 MR. JENSEN: Like when you injected the condensate
7 booster pumps pretty fast like they did at Nine Mile and
8 then have some of the rods stuck out or they didn't know
9 they weren't out --

10 MR. HODGES: Right.

11 MR. JENSEN: -- they weren't of course but they --

12 MR. HODGES: There is a possibility they would
13 have gone critical but as far as an incursion I think it's a
14 nigh unto impossibility for that kind of a Section L and
15 part of that is based upon the Brookhaven analyses where we
16 looked at roughly half the flow rate for that system with
17 all the rods out and replacing -- see, you got, when the BWR
18 is operating you have roughly eleven dollars of reactivity
19 in the void, the steam, so if you shut the thing down and if
20 you still have got some boiling going on, you have got some
21 of that negative reactivity already.

22 When you shut down on boron and so that you've got
23 the thing shut down basically we're saying in this case you
24 have got all of the eleven dollars of that negative
25 reactivity offset plus whatever else you need in order to



1 keep the thing shut down.

2 Now what you are talking about is as soon as you
3 start to inject to this cold water, if you start generating
4 power you also start generating void again and that's a very
5 strong negative feedback and at low pressure the void offset
6 the temperature effect, the void effects is much larger than
7 the temperature effect and so we tend to shut the plant
8 down, or at least not let it run away.

9 MR. JORDAN: Okay. Do you agree that the
10 operators did correctly, by the weight statement?

11 MR. HODGES: I think that if I were in this
12 situation -- until I got some indication back, I would try
13 not to go all the way down. I would try to maintain some
14 pressure there and wait. I think I would try to play it
15 cautiously, yes.

16 Now, to me, the depressurizing the 700 pounds with
17 RCIC is not going through a depressurization for cooldown.
18 In a normal control, even for ATWS and other things like
19 that, they talk about controlling it at 800 to a thousand or
20 800 to 1,100, something like that. They're supposed to
21 specify a band. If you're a little bit outside the band
22 they would specify. And so that may be a bit of no-no, but
23 is it a safety problem? No.

24 MR. JORDAN: Okay.

25 MR. HODGES: Again, putting the priority on



1 maintaining the cooling.

2 MR. JORDAN: Maintaining water on the core?

3 MR. HODGES: Right.

4 MR. JORDAN: That's the priority?

5 MR. HODGES: Yes.

6 MR. JENSEN: Wayne?

7 MR. HODGES: Yes?

8 MR. JENSEN: Just after your reviewing the BWR
9 guidelines, I was looking at the PWR guidelines. It seems
10 like they were listing as their most critical safety
11 function the shutdown of the reactor. They had their ATWS
12 functional restoration -- they had a red line. They had
13 that as the reddest most important thing they could do in a
14 PWR.

15 MR. HODGES: Right.

16 MR. JENSEN: And then after that was core cooling.

17 MR. HODGES: If you look at the PRAs for BWR, ATWS
18 is one of the big challengers. It's very critical, yes.

19 MR. JENSEN: Well, I was thinking -- I was
20 wondering if you knew why they would have the -- the most
21 critical safety function for a PWR being the ATWS, as
22 opposed to core cooling, wherein BWR, the core cooling would
23 take precedence over the ATWS?

24 MR. HODGES: I don't think that the PWR would tell
25 you that ATWS takes precedent over core cooling. If you



1 don't keep the core cool, you've lost it. That's got to be
2 your first priority -- one of the -- well, up to a point,
3 that's got to be your first priority. If you decide, well,
4 there ain't no way you're going to keep the core cooling
5 anyhow, then you've got to go worry about the containment
6 and try to protect it. But, otherwise, core cooling has got
7 to be your first priority. If you can keep that core cool,
8 then you can commit a lot of other sins and it won't catch
9 up with you.

10 MR. JENSEN: Okay.


11 MR. JORDAN: Wayne, we've got a question here.

12 What was the scope of the ATWS analyses, were
13 there different events, and what different events were
14 considered?

15 On the ATWS, I guess what we're looking for, is
16 that considered anywhere from, I guess, 4 percent power up
17 to 100 percent power, or was it only considered at power in
18 which it exceeded the decay heat such that the addition of
19 RCIC would not depressurize the core?

20 MR. HODGES: It's going to test my memory a bit.

21 I know what was discussed. Now, how much analysis
22 we had may be part of the problem. They did not have
23 analyses for every situation. A lot of it was, given some
24 limited analyses, now what could you extrapolate from and
25 do?



1 So, did the BWR owners group have an analysis for
2 an ATWS at, say, 10 percent power or 5 percent power or 3
3 percent power? My honest answer is no.

4 They analyses that we looked at for limiting
5 things and then went back and tried to use some physics
6 reasoning on some of the other stuff.

7 MR. JORDAN: Do you know, did we consider their
8 analysis all-encompassing as far as the lower powers, as
9 well as the upper powers?

10 MR. HODGES: I think, with the analyses, plus the
11 discussions of the logic and the physics, I think we
12 considered it covered the full range, yes.


13 I'm trying to think for a minute while we talk,
14 too. There was -- that's still going to be fairly high
15 power.

16 There were some analyses that were done in the
17 last, oh, three or four years, again from the BWR owners
18 group, looking at BWR stability, that got into some ATWS
19 considerations, but they're starting from about the 40- to
20 50-percent power range.

21 Larry Phillips could probably tell you more about
22 those.

23 MR. JORDAN: Okay. I'm just reading through some
24 of these questions. I think you've answered some of these.

25 What happens if partial ATWS is followed by a



1 maximum credible reactivity addition from depressurization
2 or cold water addition at a very low power?

3 You're saying -- in the source range level, you're
4 saying you don't think that that -- that, if that happened,
5 the core would go critical, but it would not cause fuel
6 damage.

7 MR. HODGES: If you're talking about from -- you
8 may have said a little bit more than I want to say.

9 MR. JORDAN: Okay.

10 MR. HODGES: If you're talking about a situation
11 where you're not borated --


12 MR. JORDAN: Correct.

13 MR. HODGES: -- then the addition of the cold
14 water won't result in what I would characterize as
15 significant fuel damage.

16 The reason I hedge a bit is I think it's possible
17 to get a localized relatively high power so that you might
18 have some local clad failure on a few pins. I don't think
19 that is a big safety issue.

20 It means you may get a little bit of radioactivity
21 in the water, and if you've got a valve open that's going to
22 go to the outside, you may release a little radioactivity.
23 That's not a major fuel failure, though.

24 That's a localized fuel failure, as opposed to a
25 core melt or something like a Chernobyl or something like



1 that.

2 So, you may, with that large cold water addition
3 from low power, get -- for a PWR, you would call it DNB, and
4 basically, you go to film boiling.


5 Then you have to say will that film boiling result
6 in fuel failure? And there, it's possible but not
7 necessary.

8 If we were doing a licensing analysis, we would
9 assume it did. In real world, it doesn't necessary happen
10 that way.

11 As a an example, there was a case in Sweden about
12 four or five years ago where they made some mistakes in
13 correlating and a few other things like that, and they
14 actually operated the plant at full power with several
15 bundles -- rods in several bundles in film boiling for
16 periods of up to two weeks, and what they got was they
17 failed a few pins, other pins has discoloration and didn't
18 fail, and they didn't really even know they had that problem
19 until they shut down.

20 You can damage the pins as far as some damage to
21 the cladding, but not the extent you're talking about a
22 massive safety problem. It's not something I would want to
23 evacuate people for.

24 MR. JORDAN: Okay. You answered some of these
25 questions we've got here. Let me run through them.



1 What would be the safety significance on an
2 inadvertent criticality? While clearing down the plant, an
3 analytical analysis, you say that as long as there is no
4 boron, that you think it's going to have low safety
5 significance.

6 MR. HODGES: Yes. I think there is some
7 possibility -- I can't rule it out -- that you will have
8 film boiling on some pins.

9 MR. JORDAN: And we've got some analytical
10 analysis on, if the plant is boron, the consequences of a
11 cold water injection.

12 MR. HODGES: Yes. And there again, you might get
13 some film boiling on some pins, but you don't have massive
14 fuel damage.

15 MR. JORDAN: Okay.

16 [Pause.]

17 MR. JENSEN: Wayne,

18 MR. HODGES: Yes.

19 MR. JENSEN: This comes from RSB days. Remember
20 the Branch Technical Position 51?

21 MR. HODGES: Uh-huh.

22 MR. JENSEN: And that requires that plants be
23 capable of achieving cold shutdown with safety-related
24 equipment.

25 MR. HODGES: Right.



2

3

4

5



6

7



1 MR. JENSEN: And we were wondering how BWRs would
2 show that, and if they needed to have safety-related
3 equipment showing that either the rods were in or else they
4 were in a shutdown condition. How was that done? How were
5 they brought to cold shutdown with safety-related equipment,
6 and would Nine Mile meet that?


7 MR. HODGES: Okay. I don't recall any analyses
8 with that, considering a loss of all your power indication.
9 That was really looking at -- could you cool the plant down
10 and go on to shutdown cooling, using only safety-related
11 equipment?

12 Typically, they demonstrated that they could do
13 that they could do that by opening up the SIVs and
14 depressurizing it in an injection through the LPSI system
15 and providing cooling with the LPSI heat exchanger.

16 That was the method they used as a safety-related
17 path to do that. That's not a path they would normally
18 choose, in the few instances where I know of where they
19 haven't been able to cooldown by the normal means, but
20 that's not the path they've chosen.

21 MR. JENSEN: So, are you saying that they didn't
22 look at the instrumentation when they did that? Are you
23 just --

24 MR. HODGES: I did not look at the instrumentation
25 when we did that. I don't think the question of the



1 instrumentation even came up at that point. I think single
2 failure would limit you on that.

3 MR. JENSEN: Well that's nonsafety
4 instrumentation.

5 MR. HODGES: Right.

6 MR. JENSEN: Did the instrument -- ICSB Branch
7 help us review RSV51 and get into cold shutdown with safety-
8 related equipment?

9 MR. HODGES: Not to my knowledge.

10 MR. JENSEN: Okay.

11 MR. JORDAN: Are we saying that the only thing
12 that they looked at was the equipment, not the
13 instrumentation?


14 MR. HODGES: I think that's probably true. I
15 think that's probably true.

16 MR. JORDAN: Okay. All right. Let's go on and
17 review the OPs in discussion with GE and licensee. Did they
18 express a reservation about using SLC or implementation of
19 the ELPs, and I do something contract -- do you know what
20 that's asking?

21 MR. JENSEN: This next one was -- involves your
22 discussions with General Electric and developing the
23 emergency operating procedures.

24 MR. HODGES: Right.

25 MR. JENSEN: And probably applied those under



1 certain conditions they would inject SLC. I wondered if in
2 any of these discussions did they mention any reservations
3 to injecting SLC -- worry about getting the boron out or
4 worrying about long-term effects on the plant? Did they
5 express that they might be hesitant -- operators might be
6 hesitant to inject SLC?

7 MR. HODGES: When we asked that question on
8 numerous occasions, we always got the answer that they would
9 not be hesitant to inject SLC. We never fully believed it.
10 But that was usually -- that was always the answer they gave
11 us.

12 MR. JORDAN: Do you know, Wayne, is SLC injection
13 for reactivity or is SLC injection for containment
14 protection? In other words, would you expect them, if they
15 had an ATWS and they entered the ATWS procedure, would you
16 expect them, even if they were in cold conditions, to
17 initiate SLC as a precautionary measure?

18 MR. HODGES: Not necessarily.

19 MR. JORDAN: Okay. They --

20 MR. HODGES: Basically, the main reason -- well,
21 SLC is there to satisfy two purposes. One is that you've
22 got a regulation or the GDC that says that they've got to
23 have diverse means of shutting the plant down. One is rods
24 and the other is SLC, okay? So, it's there to satisfy that
25 requirement.



The first part of the document
 discusses the importance of
 maintaining accurate records
 and the role of the
 management team in
 ensuring compliance with
 applicable laws and
 regulations.

Section 2

This section outlines the
 specific responsibilities of
 the various departments
 involved in the process.



1 From the ATWS world, it says if your MSIVs are
2 closing and you're dumping all your heat into the
3 suppression pool, you've got to get your power down and
4 you've got to get it down in a hurry. The only thing you've
5 got left at that point is SLC, in a worse case.

6 If you've got -- but the EOPs are specifically
7 written that if they're not cycling the SRVs; in other
8 words, if they're controlling pressure with the second SI by
9 dumping heat to the condenser --


10 MR. JORDAN: Yes.

11 MR. HODGES: They don't have to inject it.

12 MR. JORDAN: Right. And that's so -- the EOPs
13 looked at the containment, not at the first one, the
14 diversification -- diversified method of shutting down?

15 MR. HODGES: That's right. It's there if you need
16 it, and you can use it. But, basically, they really felt
17 that you want an opportunity for the other means to work, if
18 you don't have an urgency. If you're dumping the heat to
19 the condenser, rather than to the suppression pool, you
20 don't have the urgency, as I said, you've got to start the
21 SLC right away.

22 Now, if you've tried everything else, driving the
23 individual rods and resetting the scram, been doing all
24 those other actions that are in there and nothing works,
25 you're going to have to inject SLC to get the plant down.



1 But the idea was, if you can maintain the pressure below the
2 SRVs so they're not cycling, that means one of several
3 things. Either that you power down so that you don't have
4 to worry about it, or that you're controlling pressure by
5 another means, you're dumping the heat in the condenser, and
6 you have the time to take -- which, from the plant
7 standpoint, is a preferable action and safety is not
8 threatened.

9 MR. JORDAN: Okay.

10 I guess I'm on to 15, unless there is some
11 question you guys had earlier than that.

12 The next question, Wayne, we have is there has
13 been a lot of loss of power to control room annunciators
14 instrumentation.

15 MR. HODGES: Yes.

16 MR. JORDAN: Okay. And in fact, I guess there is
17 an Information Notice 88-05 stating the lack of specific
18 emergency procedures to address complete loss of annunciator
19 systems.

20 Is NRC reviewing its position on power supplies to
21 these equipments being non-safety-related grade? Do you
22 know if there is an re-review of annunciator power?

23 MR. HODGES: Do I know if there is any?

24 MR. JORDAN: Yes.

25 MR. HODGES: Somebody at headquarters would be



4

5

6

7

8



9

10



11

AY

1 better to answer that.

2 MR. JORDAN: That's probably an acceptable answer.

3 The question, I guess, then, also, is what do you
4 feel -- based on your knowledge of the EOPs, do you think
5 there's a need for a more reliable source of power to
6 annunciators and instrumentation?

7 MR. HODGES: "Need" is a strong word. Is it
8 desireable? Absolutely.

9 MR. JORDAN: Desireable. Okay.

10 MR. HODGES: Needed, that's debatable, and you
11 would probably have to get into a cost-benefit argument that
12 would -- it's hard to answer off the top of my head, but --
13 because you can shut the plant down without it, basically.


14 As long as you can do that, the cost-benefit
15 argument gets to be a little bit harder to answer, and
16 you've just got to go to the hard numbers.

17 MR. JORDAN: Maybe you can run through for me, on
18 an ATWS, what instrumentation would we expect to be
19 available for the operators to look at that's safety-related
20 to validate that they are shut down?

21 MR. HODGES: That is safety-related?

22 MR. JORDAN: Yes.

23 MR. HODGES: Well, you would have -- I'm not sure
24 whether the position indication on the SRVs is safety-
25 related or not.



1 That is 197, I think, so it may be, but I'm not
2 certain of that, but that's something you would need to
3 know, and you need the reactor pressure, and that's really
4 all you need if you don't have the power information.

5 MR. JORDAN: SRV positions?

6 MR. HODGES: How many are open or closed, and
7 let's just assume that your secondary side is closed.

8 MR. JORDAN: Yes.

9 MR. HODGES: You also need to know whether your
10 MSIVs or your bypass circuit is closed. If your top valve
11 and bypass are closed, then you just roll back the SRVs, but
12 again, you're relying upon some non-safety-related
13 instrumentation there.


14 You're relying upon, for example, the -- if you
15 assumed that the MSIV's are open, you're relying upon the
16 position of the -- the bypass valve, which would be non-
17 safety, I would think.

18 I think, almost any way you do it, you're going to
19 have to bring in some non-safety instrumentation.

20 MR. JORDAN: What training requirements did we
21 impose on the licensees dealing with loss of annunciators,
22 or balance-of-plant instrumentation, in order to accomplish
23 EOPs. Do you know of any?

24 MR. HODGES: On training requirement?

25 MR. JORDAN: Yes.



1 MR. HODGES: I think the answer there is none.

2 We have, first off, loss of annunciator is not
3 necessarily covered by the EOPs. It could be covered by an
4 normal shutdown procedure. And I think most utilities will
5 have some training on loss of that. But I don't know of any
6 particular event that we prescribe and say you have to have
7 training on that event.


8 Now, we will go and test them on a wide range of
9 events, and if they don't have some training on it, then
10 sham on them. But I don't know if any, I don't know that we
11 require them, for example, to have training on an ATWS. But
12 they sure as hell know we're going to come test them on it.

13 MR. JORDAN: Yes. Being from the operator
14 licensing examining section, you're right, that's what we
15 do. I just wondered if we had any guidelines to them
16 saying, other than a comment that we would come out and
17 examine them in those areas.

18 MS. HERBERT: We have, the supplement to the NUREG
19 0737 I think it was, that talked about they had to have
20 procedures dealing with a range of events, including
21 multiple failures and operator errors. And we expect them
22 to have procedures to deal with that stuff.

23 MR. JORDAN: Beyond the EOPs --

24 MR. HODGES: And we expect them to have a training
25 program. But we don't require training on any specific



1 issues.

2 MR. JORDAN: Beyond the EOPs, are they required to
3 have procedures, for multiple event failures?

4 MR. HODGES: We don't tell them what they've got
5 to call them. We don't tell them they got to call them
6 EOPs.

7 MR. JORDAN: Okay. But I mean, besides the EOPs,
8 we would expect them to have additional procedures for like
9 loss of annunciators; would we expect them to have them --


10 MR. HODGES: We would expect -- you're getting
11 into a difference whether we require or expect.

12 MR. JORDAN: Okay.

13 MR. HODGES: Yes, I expect them to have that. Do
14 we have a requirement that says they've got to have a loss
15 of annunciator procedure? No, we do not have such a
16 requirement. Do I expect that? Yes.

17 MR. JORDAN: Okay. Shortly after the TMI
18 accident, the NRC staff encouraged the licensees to create a
19 third classification scheme for equipment called "important
20 to safety."

21 Can you identify any internal or external NRC
22 document associated with that position? In particular, was
23 there a generic letter issued in 1983 or '85 providing a
24 legal group's challenge to the agency's position on
25 "important to safety"? Do you know of any?



1 MR. HODGES: Yes. There was lots of stuff on
2 that. I can't quote you documents and dates and stuff like
3 that, but there was an old paper that was put together on
4 that, and then what's his name that used to be on the staff
5 for the CRGR, blonde guy?

6 MR. JORDAN: Conrad?


7 MR. HODGES: Yes, Conrad had written a position
8 for --

9 MR. JORDAN: "Important to safety"?

10 MR. HODGES: Yes. He had written a thing on
11 "important to safety" paper that was sent out. There was a
12 lot of discussion of that at the hearings. We even had a
13 panel composed of Conrad and Dennis Peace and Ashok Thadani
14 and myself, and several others. I think there was a total
15 of seven of us dealing with that particular issue. And then
16 there was, I think there was an industry paper on it. So
17 there's a lot of stuff. But I'll have trouble trying to
18 quote you documents off the top of my head.

19 MR. JORDAN: Do you know if we had any regulatory
20 basis for the "important to safety" classification?

21 MR. HODGES: Well, the concern, the problem was
22 we've got conflicting uses of those terms. One part of our
23 regulations will use "important to safety," another part
24 will use "safety-related," and use those terms
25 interchangeably. And the industry contention is they mean



1 the same thing, because we use them one way in one case, and
2 basically we use both terms to mean essentially the same
3 thing in our regulations. And I think that's true. But
4 what we were trying to do is say there is a "safety-related"
5 case and then there's "important to safety," which might be
6 things like in a feedwater system that are not safety-
7 related but are still important. And that's what we were
8 trying to set up. But I think we finally gave up, because
9 we were using the two terms too interchangeably in our
10 regulations.

11 MR. JORDAN: Did we put something out to the
12 industry telling them that they were synonymous, or did we
13 just let it moot?

14 MR. HODGES: I think we finally let it mute. I
15 don't know for sure, but I think we finally let it moot. I
16 think we finally threw our hands up.

17 MR. JORDAN: Okay. I think that answers the next
18 question there.

19 Were you in the region when this happened, Wayne?

20 MR. HODGES: Yes, I was.

21 MR. JORDAN: You were in the IRC when it happened?

22 MR. HODGES: Well, I came into the office about 20
23 after 7:00 and immediately went down there. So by the time
24 I got there, they had restored power.

25 MR. JORDAN: Okay.



1 MR. HODGES: But after 7:00 in the morning until
2 sometime much later, I was in there.

3 MR. JORDAN: Okay. So you're familiar with the
4 event, then?

5 MR. HODGES: Yes.

6 MR. JORDAN: Okay. Are you familiar with the
7 equipment that they did not have available to them?

8 MR. HODGES: Yes.


9 MR. JORDAN: Okay. Can we ask your opinion on
10 equipment that they did not have available to them and
11 whether or not you think it should be safety-related or not,
12 or should it be non-safety-related, one of which is all
13 control rod instrumentation in their power supplies?

14 MR. HODGES: My personal opinion is that should be
15 safety-related. But you have to be a bit careful here,
16 because it's also not safety-related on PWRs, you know.

17 MR. JORDAN: Okay.

18 MR. HODGES: But I am amazed that we have let that
19 go by as not being safety-related. But there's a long
20 history of it not being safety-related, and we would, I
21 think, have a significant backfit issue to deal with that we
22 probably couldn't justify on a cost-benefit basis to try to
23 make it safety-related. But I think that's a shame on us.

24 MR. JORDAN: Okay. You're thinking that thee
25 backup to the control room instrumentation and their power



1 supplies, particularly for, I guess it says all control room
2 instrumentation and their power supplies. You think of it
3 that, just that broad sense --

4 MR. HODGES: No, I think that's too broad.

5 MR. JORDAN: That's too broad. You feel that
6 there's some instrumentation in the control room that should
7 not be safety-related?

8 MR. HODGES: Yes. Yes.

9 MR. JORDAN: Okay. The rod position sensing
10 elements, an indication in their power supplies, you feel
11 maybe should be safety-related?

12 MR. HODGES: My personal opinion is we should make
13 it safety-related.

14 MR. JORDAN: Okay. And you agree that this
15 plant's having them non-safety-related --

16 MR. HODGES: I'm sorry. I was talking. I didn't
17 hear you.

18 MR. JORDAN: This plant being, in other words,
19 non-safety-related, you feel met what the industry
20 requirements are?

21 MR. HODGES: I think it met what the NRC
22 requirements were.

23 MR. JORDAN: But your own personal opinion is, you
24 think it should be safety related?

25 MR. HODGES: My own personal opinion is it should



1 be safety related. I think there's a long history of NRC
2 position that it does not have to be safety related.

3 MR. KAUFFMAN: What is your reason for thinking it
4 should be safety related? Just good practice?

5 MR. HODGES: Yes, I take it -- yes, you've got
6 basically, in a BWR in particular, about three pieces of
7 instrumentation you really have to worry about, and one is
8 water level. Another is power and another is pressure.

9 And I think those are the three major parameters
10 and those ought to be safety related. Those ought to be
11 gold-plated. That's my personal opinion.

12 MR. JORDAN: Okay, how about the APRM, IRM, SRM
13 sensing elements, indicators including their drive motors?
14 Do you want it broken up or whole?

15 MR. HODGES: The instrumentation, yes; the drive
16 motors, I'm not so sure of.

17 MR. JORDAN: Why do you feel that the
18 instrumentation should be, but the driver motors may not be?

19 MR. HODGES: I -- well, you've got to go in and
20 say, what do you mean by safety related and what are you
21 trying to do with it? You know, you want to put them in
22 there and drive them in right away if you get a scram
23 signal. And if you do that, then it's going to be doing
24 that in the normal kind of environment because this stuff is
25 outside of containment. You're not going to have to worry



1 about a harsh environment and a lot of other things with it.

2 Once it's in there, it's going to -- it may have
3 to clear re-criticality, so it should be a very robust
4 instrumentation. So, I think the challenges are different.

5 MR. JORDAN: Okay, but what happens if loss of
6 offsite power -- if the drive motors are not safety related,
7 they may not come off of the diesels and you may not be able
8 to drive them in. They may be sensing external to the core,
9 okay, but they may not be able to get them in.

10 I'm just asking you.


11 MR. HODGES: That's right, you have --

12 MR. JORDAN: You mentioned the fact that the
13 indicators should be, but the drive motors may not be.
14 Could you postulate, as a result of the indicators reading
15 external to the core, what the core power is? Do we have
16 the ability to do that?

17 MR. HODGES: I wouldn't want to try to do that.
18 That would be too wild.

19 MR. JORDAN: Okay, how about all instrumentation
20 used to verify reactor shutdown; do you feel that should be
21 safety related, non-safety related or do you think the mix
22 they have right now is okay?

23 MR. HODGES: Well, I'm not sure. When you say
24 all, I just put the drive motors back in there. You know, I
25 have trouble any time you want to try to use, "all" on me.



1 But I think, in general, the instrumentation used
2 to verify shutdown should be safety related.

3 MR. JORDAN: You think they should have at least
4 one system that's safety related to verify shutdown? If you
5 don't say "all," should you have a system, whether it be rod
6 positions or --

7 MR. HODGES: Yes.

8 MR. JORDAN: Or APRMs or IRMs or something?

9 MR. HODGES: Right, right.

10 MR. JORDAN: How about -- I guess shutdown is also
11 a question. We're talking about here, cold shutdown versus
12 hot shutdown.

13 MR. HODGES: Well, for example, the source range
14 and the APRMs are not going to tell you much about whether
15 you can be in cold shutdown if you're still in hot shutdown,
16 and that's the question you need to answer. There, you're
17 going to need rod position.

18 MR. JORDAN: So you feel they need some type of a
19 rod position, and that should be some type of safety related
20 backfit?

21 MR. HODGES: If I had my druthers, that's the way
22 I would do it because if I have to justify it on a
23 cost/benefit basis as a backfit, I doubt it.

24 MR. JORDAN: Okay. How about the plant computers,
25 SPDS and their power supplies?



1 MR. HODGES: Plant computer, not necessarily;
2 SPDS, yes.

3 MR. JORDAN: Why SPDS?

4 MR. HODGES: Because I think that you need --
5 again, highly desirable, need is probably the strongest.

6 MR. JORDAN: Okay.

7 MR. HODGES: Highly desirable for accident
8 purposes. If you've got that, there are other things you
9 could do without.

10 MR. JORDAN: Okay.

11 MR. HODGES: Again, this is my personal opinion.

12 MR. JORDAN: I understand.

13 Based on your knowledge of the EOPs for boilers
14 and how they're developed and the use of the instrumentation
15 in order to accomplish the EOPs is --


16 MR. HODGES: You can do the shutdown without the
17 SPDS and all this other stuff --

18 THE REPORTER: Without these other things, and
19 then you said what?

20 MR. HODGES: I say you could get the plant shut
21 down to the safe condition with all of this other stuff but
22 it's tough if you don't have it.

23 MR. JORDAN: It's tough if you don't have it,
24 okay.

25 THE REPORTER: Thank you.



1 MR. JORDAN: Okay, how about safety-related for
2 all EOP use parameters and indicators and equipment?

3 MR. HODGES: Nope.

4 MR. JORDAN: Okay. Should a black box for
5 transient analysis be required and be classified safety-
6 related?

7 What we're looking at, Wayne, is should they have
8 some type of a -- like the airlines do, that no matter what
9 happens when you're all done you can go back and via this
10 black box evaluate the transient and what happened?


11 In this case with loss of the computer and loss of
12 the alarm printer and loss of indication, it was hard to
13 recreate with just level and pressure exactly what happened.

14 Do you think we should require the utilities to
15 have some type of a black box transmitted analysis be
16 required and be classified as safety-related, non-safety-
17 related and if you say yes or no, why not?

18 Why or why not?

19 MR. HODGES: I don't think we can -- cost/benefit
20 basis again.

21 I mean it would be a nice thing to have. We
22 always like to be able to know what happened, but -- and
23 because you want to apply that lesson to other plants or
24 even this plant in the future, but I think what we have to
25 focus on is if from a safety standpoint if we're able to get



1 through the event safely without that part in this case at
2 this time there is a fair chance if it occurs again -- we're
3 going to learn something about what happened during the
4 event. We won't be totally ignorant, so I think if you look
5 at the cost of such an instrument versus the benefits that
6 we get from it, we may have a hard time justifying it but it
7 would be a very nice thing to have.

8 MR. JORDAN: Okay, on redundancy and diversity, do
9 we expect, would you expect the utility to have diversity as
10 well as redundancy in non-safety related applications?

11 MR. HODGES: Nice, but not necessary.

12 MR. JORDAN: Nice, but not necessary.

13 MR. HODGES: Right.


14 MR. JORDAN: And you are saying because of cost
15 benefit or you just don't think as a regulator requirement
16 we should be requiring that?

17 MR. HODGES: Well, if it is non-safety-related,
18 we're already saying we don't require that it -- we don't
19 have any requirements on them.

20 MR. JORDAN: How about safety-related?

21 MR. HODGES: I think there's some level of
22 diversity we normally want but we don't always get it. All
23 we get is redundancy. I don't think we need it.

24 For example, we have diverse ways of shutting the
25 plant down and we have diverse systems for injecting water



1 and they are redundant among themselves. You need a certain
2 amount of that.

3 MR. JORDAN: How about important to safety
4 equipment?

5 MR. HODGES: I don't think, for example, we'd want
6 to say you need both for example a centrifugal and a
7 positive displacement pump to get diversity in the injection
8 system. I think something like that would be kind of
9 ridiculous.

10 If you got -- I think you have to temper the
11 amount of diversity. I think there are situations where
12 it's great. I think there's other situations where it
13 doesn't buy you a lot.

14 MR. JORDAN: How about manufacturer, model types?

15 MR. HODGES: I think you have to look at again
16 specific -- if I had manufacturer I had a high confidence in
17 making my pumps I might prefer to stay with that rather than
18 trying to split it up just for diversity's sake.

19 I think you have to temper some of that with
20 reason is what I'm saying.

21 Across-the-board diversity is not necessarily good
22 and there are problems with spare parts and other things as
23 well, so a certain amount of diversity, across-the-board
24 diversity may be bad for you.

25 MR. JORDAN: Okay.



1 Can you describe -- I think you already did a
2 little bit -- any interfaces you have had with NRR branches
3 in the review of the above areas?

4 In your experience, have you brought issues like
5 this up, and has it been discussed and developed, and in
6 what areas of NRR did you bring it up with?

7 MR. HODGES: Okay.

8 Well, obviously I was in NRR when I reviewed the
9 EOPs.

10 MR. JORDAN: Okay.

11 MR. HODGES: And when I began, the branch chief
12 was a supervisor, supervising the review of EOPs.

13 MR. KAUFFMAN: What revs were those?

14 MR. HODGES: Well, I actually did the review for
15 Rev 2. Rev 3 was done in another organization, and then I
16 did Rev 4 under my supervision.

17 MR. KAUFFMAN: Do you happen to know who did Rev 0
18 and Rev 1?

19 MR. HODGES: Rev 0 and Rev 1 were never approved
20 by the NRC. We were doing a continual review up through Rev
21 2, and Rev 2 was the first one that an SER was written on.

22 So, I was involved all the way up through the
23 writing of the SER for -- for Rev 2.

24 MR. KAUFFMAN: Okay.

25 MR. JORDAN: In your review of those, did you have



1 any interface with other NRR branches?

2 MR. HODGES: Oh, sure.

3 The -- it was the human factors division, and they
4 -- in fact, they had an individual who did the human factors
5 review while I was doing the systems review, and then I also
6 interfaced with the instrumentation branch and the
7 containment systems branch and -- those were the major ones.

8 Yes, there -- there was -- was interface with
9 other -- other branches.


10 MR. JORDAN: What kind of interface did you have
11 with instrumentation?

12 MR. HODGES: Basically, we talked about the kind
13 of things -- what would be needed in an operator and that
14 kind of stuff.

15 It was more on a consulting basis. They didn't
16 actually do the review.

17 They were used as consultants, and pretty much the
18 same with containment systems, although they were given some
19 parts, say look at this and give me your opinion kind of
20 thing, but I was responsible for the review, and I did the
21 writeup. They acted as consultants to me.

22 MR. JORDAN: Did you ever ask instrumentation, you
23 know, what instrumentation is going to be available or not
24 available and whether or not they felt -- what their
25 feelings were on instrumentation that was going to be needed



1 or they felt was needed?

2 MR. HODGES: We had a lot of discussions on what
3 we would do under various circumstances. Did we ever
4 contemplate something like happened at Nine Mile, where you
5 lose five separate power supplies selectively, I'm not sure
6 we got that detailed.

7 But we looked at loss of all instrumentation and
8 all power or all DC power in the control room and those
9 types of things and tried to say, okay, what do you need to
10 deal with it?

11 But when you've got a mixture, I don't think we
12 got into that kind of detail.

13 MR. JORDAN: Okay.

14 Well, let me go around the room here and see if
15 there's any other questions. Then we'll ask you our final
16 question.


17 You guys got anything else?

18 MR. KAUFFMAN: I had one.

19 Back when we were talking about EOPs and we're in
20 two legs that basically told us to do different things --

21 MR. HODGES: Right.

22 MR. KAUFFMAN: -- we debated amongst ourselves
23 here what should be done. Is that a good position, a fair
24 position to put the operator in, that he has conflicting
25 things and he doesn't have something to say that this one is



1 most important, it takes priority, do this?

2 I guess what I'm asking is the EOPs, was it
3 intended that you would wind up in conflicting spots, or did
4 this event show a glitch?

5 MR. HODGES: I think if you even look at our SER
6 on the Rev 2 -- and I think some of the others were carried
7 forward in our SER on Rev 4 -- it talks about where the
8 priority should be put, and some of that should be in
9 training.

10 You don't want to have everything in the EOPs
11 themselves. Some of it is going to be left to training.

12 Where the focus should be on maintaining core
13 cooling, for example, that's fairly clear that it's a
14 priority, and my memory is a little dim on some of this, but
15 I think the BWR information, the owners group information on
16 that, also --

17 MR. JORDAN: Also what?

18 MR. HODGES: -- also has similar words on where to
19 put the priorities, and also, there is -- see, in addition
20 to just the -- the EOPs, there were appendices to that that
21 got into how to develop these numbers that go into the EOPs
22 and the philosophy behind what was being done, and then,
23 that -- those appendices definitely put precedence on
24 keeping the core cool.

25 MR. KAUFFMAN: So, in this event, the operators



1 really weren't sure which one was more important. They used
2 their judgement and kind of picked one.

3 MR. HODGES: Well, I think their training, if it
4 didn't tell them that the priority was on core cooling,
5 should have.

6 So, there should not have been a big question mark
7 for the operators, in my opinion. If it was, then that may
8 signal a weakness in their training.

9 MR. KAUFFMAN: If I'm looking at this a human
10 factors point of view, I might suggest something like that
11 this leg, the most important leg, be in bigger print or
12 darker or have a big "1" by it. Would something like that
13 make sense?

14 MR. HODGES: I don't know. I'm not a human
15 factors expert.

16 MR. KAUFFMAN: Because it's a stressful situation.

17 MR. HODGES: It's a stressful situation, but
18 you're relying upon several things.

19 You're relying upon the procedures that tell you
20 how to go through and do things.

21 You're relying upon training that tells you where
22 to put your emphasis on things, what's important, how the
23 plant behaves, you know, the physics of the plant, and I
24 think that -- you don't put all that in the procedures
25 either.



1 There's a lot of stuff you don't have in there
2 explicitly. It's expected to be covered in training --
3 whether you should single out because this event happened to
4 do that, I'm not sure.

5 MR. ROSENTHAL: Wayne, this is Jack Rosenthal. I
6 just came in a few minutes ago from another meeting.

7 MR. HODGES: I can't repeat everything I've just
8 said.

9 MR. ROSENTHAL: I don't expect you to. Number
10 one, I wanted to say thank you.

11 MR. HODGES: Uh-huh.

12 MR. ROSENTHAL: But I do want to ask just a couple
13 of questions. If it's been covered, you could just say,
14 hey, it was covered.

15 I think that we, in reviewing the EOPs, we said,
16 go ahead and put all the instruments in that you really
17 need, whether they're safety-related or not, because we
18 didn't want to have one set of EOPs that were the real EOPs,
19 and another one that was just for the regulators. So, we
20 told them that hey, if you put in the stuff, that means we
21 won't turn around and make you make it all safety-related.

22 MR. HODGES: In essence, that's correct.

23 MR. ROSENTHAL: Okay. But I can't find that in
24 writing any place. Do you know where that was ever
25 formalized?



1 MR. HODGES: I don't know if we ever did formalize
2 it.

3 MR. ROSENTHAL: Okay. Another issue that I've
4 heard is that some people believe that if you needed to take
5 action, it ought to be of the highest quality and
6 redundancy, but if you need it for confirmation or
7 verification, it could of a lower quality or level of
8 redundancy. That was like a logic that was used. But I
9 don't know where that's written down. Do you know anyplace
10 where that's written down as a rationale?

11 MR. HODGES: No.

12 MR. ROSENTHAL: That was just the way people
13 worked?

14 MR. HODGES: For the most part. But, again, we
15 have one here like the control rod position, which really
16 need to take an action, not just for confirmation. Because,
17 you know, you need to know that before you could cooldown,
18 and it's not safety-related. So, that's not an across-the-
19 board truism.

20 MR. KAUFFMAN: I guess, in some of the interviews
21 we had people said if it was to take credit for it, like in
22 Chapter 15 FSAR, then it was safety-related.

23 MR. HODGES: That's not even true, sir. There are
24 things that are taken credit for in the Chapter 15 FSARS
25 that are not safety-related.



10 2



1 MR. ROSENTHAL: Especially for anticipated
2 transients?

3 MR. HODGES: Oh, yes, absolutely. The only thing
4 -- the only place where it's required to be safety-related
5 is in dealing with LOCAs and such. Now, there you've got to
6 have safety-related equipment to deal with it -- the oldest
7 ECCS stuff. But if you're talking about turbine trips and
8 things like that, you will rely upon nonsafety-related
9 instrumentation, Chapter 15. And that's been common
10 practice for both BWRs and PWRs.

11 MR. ROSENTHAL: Okay. Were you involved in the
12 maintenance rule?

13 MR. HODGES: No.

14 MR. ROSENTHAL: Were you involved in importance of
15 safety versus safety-related?

16 MR. HODGES: Uh, I've been involved with it for
17 the Shoreham hearings. I had numerous discussions with --
18 again, I can't think of his name --


19 MR. ROSENTHAL: Conran?

20 MR. HODGES: -- he's from the CRGR staff.

21 MR. ROSENTHAL: Jim Conran?

22 MR. HODGES: Jim Conran. He and I had lots of
23 discussions. We were on a panel together, on one of the
24 contentions at Shoreham.

25 MR. ROSENTHAL: Well, we've interviewed Conran.



1 So, if we pumped him --

2 MR. HODGES: You've probably got the most
3 knowledgeable person on it then, if you pumped him.

4 MR. ROSENTHAL: Okay. And you guys have been over
5 the emergency procedures, I know.

6 I'm finished.

7 MR. JORDAN: Wayne, I personally thank you.

8 MR. HODGES: Okay.

9 MR. JORDAN: Someday you and I are going to have
10 to meet each other face-to-face.

11 MR. HODGES: Right. I look forward to it.

12 MR. JORDAN: Okay, Wayne.

13 MR. HODGES: Take care.

14 MR. JORDAN: Thank you.

15 MR. ROSENTHAL: Thank you.

16 [Whereupon, at 1:39 o'clock p.m., the above-
17 entitled interview was concluded.]

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: Wayne Hodges

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Official Reporter
Ann Riley & Associates, Ltd.

