

ORIGINAL

07-102A-91

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Incident Investigation Team

Title: Nine Mile Point Nuclear Power Plant  
Interview of: BRIAN J. MOORE

Docket No.

LOCATION: Scriba, New York

DATE: Wednesday, August 21, 1991


PAGES: 1 - 27

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950.

9305070281 911031  
PDR ADDCK 05000410  
S PDR

10305070281



UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

-----  
Interview of :  
BRIAN J. MOORE :  
(Closed) :  
-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Wednesday, August 21, 1991

The interview commenced, pursuant to notice,  
at 4:25 p.m.

PRESENT FOR THE IIT:  
John Kauffman, NRC  
Michael Jordan, NRC



## P R O C E E D I N G S

[4:25 p.m.]

1  
2  
3  
4 MR. JORDAN: It's August the 21st, 1991 at 4:25  
5 p.m. We are at the Nine Mile Point, Unit Two in the P  
6 Building. We're conducting interviews concerning a  
7 transient that occurred on August 13th, 1991.

8 My name is Michael Jordan, I'm with the NRC. I'm  
9 out of Region III.


10 MR. KAUFFMAN: I'm John Kauffman, NRC  
11 headquarters.

12 MR. MOORE: Brian Moore, reactor operator at Unit  
13 Two.

14 MR. JORDAN: Okay, Brian, why don't you give us a  
15 background of what your experience is?

16 MR. MOORE: I've been a reactor operator almost  
17 three years at Unit Two. Prior to that I was a non-LOT for  
18 five years at Unit Two. Prior to that I was in the Navy as  
19 a boiler technician -- conventional Navy for four years. I  
20 got out as a Petty Officer, Second Class, if that helps.  
21 Prior to that I was a machinist in an instrument and control  
22 type place. We made thermometers, pressure gauges and  
23 before that I was in high school.

24 MR. JORDAN: That's fine. We don't go back to  
25 when you were born.



1 MR. MOORE: No.

2 MR. JORDAN: Not that far back, anyway.

3 MR. KAUFFMAN: That's fine. But we could find  
4 out.

5 MR. MOORE: Oh yeah, right.

6 [Laughter.]

7 MR. JORDAN: Okay. Why don't you -- let's see,  
8 you were on day shift, what shift, mid-shift?

9 MR. MOORE: I was coming in on surveillance shift.


10 MR. JORDAN: Okay, why don't you tell us, as you  
11 come through the gate what you saw and what happened?

12 MR. MOORE: At -- I got to work about 6:15 because  
13 I wasn't shift-of-record and I didn't have to be in until  
14 6:30, so I was early, but --

15 MR. KAUFFMAN: Did you have any problems with the  
16 traffic?

17 MR. MOORE: I didn't have any problems at 6:15  
18 coming in, however, when I got to security, they wouldn't  
19 let me in because they weren't sure what was going on and  
20 the initial thing is to prevent anybody from coming inside.  
21 I was out in security, I'm going to say tops, 10 minutes.

22 George Moyer, one of the SSS's -- of course, they  
23 know him on sight, they said, "You, in." And as he was  
24 passing through the gate the first goal is to get through  
25 the explosives meters. We had all requested, there was





1 probably six or seven of us, to call back down so that we  
2 could get on site.


3 After that, there was a phone call, probably ten  
4 minutes later and we were coming in. I then came in and got  
5 my hardhat and my keys, flashlight, and headed upstairs.

6 MR. JORDAN: Any lighting problems or anything  
7 like that?

8 MR. MOORE: No. Everything was already resolved  
9 by then. As far as I was aware of. I didn't have any  
10 problems coming in, I even used the elevator.

11 MR. JORDAN: And the elevators had lighting?

12 MR. MOORE: Yeah. The elevators were all lit, the  
13 stairways were lit. At least the area I was using. I then  
14 got to the control room, but instead of coming in through  
15 the back door, because I knew there was a problem, coming  
16 through the control room and getting into people's way, I  
17 went through the south door of the control room and I waited  
18 until I was recognized by the on-shift's CSO. He was busy.  
19 Occasionally he would look up and he acknowledged my  
20 presence in the control room by a nod or -- you know, he  
21 realized, I guess, I was there. A few minutes went on  
22 again. He had more than enough hands helping him. So, I  
23 guess probably five minutes in the control room I was  
24 trying to evaluate what had happened to kind of form my own  
25 -- I guess plan of attack to help and wait for some



1 direction to do things.

2 MR. KAUFFMAN: So what do you think happened? Or  
3 what did you see?

4 MR. MOORE: Well, most everything was back to  
5 normal. When I got there it just looked like we scrambled.  
6 We had indications, annunciators, I was like, okay, we took  
7 a scram. And then I heard a lot of this and that and what  
8 happened and what didn't happen.

9 So, I then -- the CSO came over to me and he says  
10 I have enough help, go across the hall and wait in the  
11 staging area which is our break area. I'll call you when I  
12 need you. And I was in there about 10 minutes, maybe 15  
13 minutes and then I was told to come over to the control  
14 room.

15 MR. JORDAN: So this is probably what time? Any  
16 idea?


17 MR. MOORE: 7:15, maybe. On site maybe.

18 MR. KAUFFMAN: We're really trying to establish  
19 time because the alarms and things are gone.

20 MR. MOORE: It's probably around 7:15 by now. He  
21 called me to come over to start flushing -- shutdown  
22 cooling.

23 [Pause as interviewee peruses notebook.]

24 MR. MOORE: And then -- I've got some things wrote  
25 down because I always write what I do. From day-to-day in



1 case something like this ever happens.

2 My first actions were to flush our RHR shutdown  
3 cooling and get shutdown cooling in service.

4 MR. JORDAN: What systems were you using?

5 MR. MOORE: RHR and condensate transfer.

6 MR. JORDAN: Which RHR, A, B, C --

7 MR. MOORE: B. It would have been RHR B. And  
8 condensate transfer would be used for the flush.


9 MR. KAUFFMAN: What pressure can you shut down  
10 cooling and service --

11 MR. MOORE: Huh?

12 MR. KAUFFMAN: What pressure can you put shut down  
13 cooling and service interlocks?

14 MR. MOORE: Yes. It's 128 pounds which we were  
15 well above prior to that. I was also looking around at what  
16 level was and there was some interlocks I still had to  
17 clear. The level was -- at that time just short of  
18 clearing level three and coming back slowly, at least on  
19 the trip units in the back, so that would have been about a  
20 level of 150 coming up.

21 I had two aux operators, Dwayne LeMay and Bob  
22 Pellegrino assist me in the flush, and they had to do a  
23 couple of valve manipulations out in the plant and open the  
24 condensate transfer valve which is a manual valve and  
25 isolate a discharge valve off of the boost -- jockey booster



ADDENDUM TO INTERVIEW OF BRIAN J MOORE NAOE  
(Name/Position)

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
7	13	1CSM@002 (PROCEDURE NUMBER)
9	20	WHEN WE TURNED SWITCH TO ON. (OTHERS WORKING WITH ME. CLINT SMITH ACTUALLY STARTED PUMP WITH SWITCH.)
26	3	3:15 WHEN CLINT SMITH STARTED (WE WERE WORKING TOGETHER)

Page 1 of 1 Signature Brian Moore Date 8/23/91

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both primary and secondary data collection techniques. The analysis focuses on identifying trends and patterns over time, which is crucial for making informed decisions.

The third part of the document provides a detailed breakdown of the results. It shows that there has been a significant increase in sales volume, particularly in the online channel. This is attributed to the implementation of the new marketing strategy and the improved user experience on the website.

—

The final section of the document discusses the implications of the findings and offers recommendations for future actions. It suggests that the current strategy should be continued, but with a focus on further optimizing the online platform. Additionally, it recommends exploring new marketing channels to reach a wider audience.

In conclusion, the data clearly shows that the new marketing strategy has been successful in driving growth. By continuing to invest in digital marketing and customer experience, the company can maintain its competitive edge in the market.



1 pump to keep the system full.

2 I'd say that took almost 40 minutes to do the  
3 flush, so we're looking, probably around -- by something  
4 close to 8:00. Sometime in between there Marty McCormick  
5 took over as SED because there was an announcement made in  
6 the control room that Mike Conway was no longer the SED,  
7 that he was relieved by Marty McCormick. And I kind of  
8 remembered that because it was right around that when I was  
9 finishing up the flush.

10 Then somebody had asked me what I was doing -- was  
11 I in a lull because of pressure and so on and so forth. I  
12 said, "Yes." And they asked me to assist them in doing the  
13 ICS M at 002 which is a vacuum breaker test. Because I  
14 guess they evaluated that they cycled an SRV. So I helped  
15 them do that.

16 MR. KAUFFMAN: Why are you required to do that  
17 test?


18 MR. MOORE: It's to verify that the vacuum  
19 breakers will actually cycle and the DP will not be  
20 excessive across the floor.

21 MR. JORDAN: You do it just for SRV's? Do you do  
22 it if you run RCIC, do you do it for --

23 MR. MOORE: No. It's just SRV's.

24 MR. JORDAN: Just strictly SRV's?

25 MR. MOORE: Yes. As far as I'm aware of.



1 MR. KAUFFMAN: Can you tell us the procedure then,  
2 that you were doing or that that is?


3 MR. MOORE: I was pushing the buttons on the  
4 panel. The actual procedure number is N2OSPICSM, the little  
5 a with the circle around it, it's an AT, 002.

6 And I assisted Jay Lawrence. He had the actual  
7 procedure and I stood at the back panels and he told me  
8 which button to push for which valves and we verified  
9 lights and computer points and so on and so forth.

10 That had to be sometime -- I'm going to have to  
11 say, maybe 8:30 or 9:00, maybe later. I can't remember  
12 exact time when we were doing that. Then most of the rest  
13 of the day I spent putting shutdown cooling in service and  
14 that's a long drawn out process of warming up and heating  
15 up and unisolating and clearing interlocks.

16 MR. KAUFFMAN: How did that process go? Did it go  
17 good?

18 MR. MOORE: Well, it's like any time we put it on  
19 it's very, very long to get it on because you're waiting for  
20 pressure. You don't want to violate cool-down rates. Once  
21 you clear your interlocks you want to make sure that you're  
22 down far enough that it doesn't come back. When you start  
23 opening isolation valves you want to make sure that you have  
24 sufficient inventory so you don't drop level again. And  
25 then once you turn the pump switch to start, it becomes



1 rather quick because you're dealing with a few variables;  
2 heat exchanger, service water, outlet temperature, cool-down  
3 rate in the reactor which is a major concern; flow rate for  
4 pump concerns so you're kind of -- really got to think what  
5 you're doing on each manipulation and in the first 15  
6 minutes it's kind of hectic, but that's the way it is.  
7 We've always learned to accept that and we get positive  
8 control and within minutes -- what -- because of the  
9 increase in flow, both service water and system flow, you're  
10 variables change a lot, especially you're cool down. So, we  
11 cool down quite a bit in the first 15 minutes and then the  
12 next 45 minutes to an hour we almost sit with no cool-down  
13 at all.


14 That's about all I can tell you on this, unless  
15 you've got some questions.

16 MR. JORDAN: So the rest of the day you were in  
17 the shutdown cooling?

18 MR. MOORE: Right, and I didn't get shutdown  
19 cooling running until about 3:15. That's from flushing till  
20 starting the pump; it was probably when I turned the switch  
21 off.

22 MR. JORDAN: After you flush, how long is it good  
23 for before you have to flush again?

24 MR. MOORE: Since the system is closed and we're  
25 not putting any other water in it, it shouldn't be a



1 problem. The chemistry should remain fairly constant.

2 MR. JORDAN: Why do you flush?


3 MR. MOORE: Well, RHR has five modes of operation,  
4 one of them being off the suppression pool. We consider  
5 suppression pool not a clean source of water, so to minimize  
6 the conductivity increase in the vessel, we flush with  
7 condensate transfer water, which is a more clean source of  
8 water.

9 MR. JORDAN: Okay. You flush from the condensate  
10 -- what's the supply?

11 MR. MOORE: Okay. Condensate transfer taps in on  
12 the suction supply on the outboard isolation valves for the  
13 containment. We flush that leg of piping down to the  
14 suction of the pump.

15 MR. JORDAN: Where's the section of the pump  
16 pumping to?

17 MR. MOORE: All right. The reactor, one of the  
18 loops, the A loop of recirc, goes to the shutdown cooling  
19 loop, so we line up the loop for suction, with the section  
20 of the isolation valves, because they're locked out because  
21 of your pressure interlock. So you're lining up your entire  
22 system to put on your shutdown cooling leg, and then you  
23 would open up your condensate transfer to flush out that  
24 water. The suction from the suppression pool has been  
25 closed prior to this.





1 MR. JORDAN: So it comes from the condensate  
2 transfer pump?

3 MR. MOORE: System.

4 MR. JORDAN: System?

5 MR. MOORE: Yes.

6 MR. JORDAN: Okay. You flush the entire RHR  
7 system out?

8 MR. MOORE: Right.

9 MR. JORDAN: Where does it flush back to?

10 MR. MOORE: It's flushed to rad waste.

11 MR. JORDAN: To rad waste?


12 MR. MOORE: Right.

13 MR. JORDAN: So you flush it to rad waste. How do  
14 you know if you've flushed enough?

15 MR. MOORE: There's a computer point that we  
16 monitor for conductivity. Once that computer point clears  
17 .2, I think it is -- I'd have to refer to the procedure for  
18 the exact micromole number, but once that gets below that  
19 point, the sufficient flushing has been done. I usually  
20 wait to make sure that it's not just a flood of water going  
21 through, that the system is completely flushed prior to  
22 securing.

23 MR. JORDAN: Is the transfer from -- what --  
24 transfer from the condenser?

25 MR. MOORE: No, it comes from the condensate



1 storage tanks.

2 MR. JORDAN: It comes from the condensate storage  
3 tanks.

4 MR. MOORE: Right.

5 I'd flush that. If conductivity gets below I  
6 think it's .2, I'd let it sit for at least another minute or  
7 two, flushing, to verify that it's not just a slug of water  
8 that's passing by the element, that it is completely clean  
9 water.

10 MR. JORDAN: The pumps were operating at this  
11 time?

12 MR. MOORE: No. The pump is shut down. Actually,  
13 the pump is in pull-to-lock.

14 MR. JORDAN: What's the driving force for the  
15 water?

16 MR. MOORE: The pressure developed by the  
17 condensate transfer pumps.

18 MR. JORDAN: Okay. I think I understand now how  
19 that works.


20 MR. MOORE: Okay.

21 MR. JORDAN: You say you started shutdown cooling  
22 around 3:15?

23 MR. MOORE: Yes.

24 MR. JORDAN: When did you get relieved?

25 MR. MOORE: I left the control room about quarter



1 to 7.

2 MR. JORDAN: So you were here when they finally  
3 got to the point of shutdown.

4 MR. MOORE: Yes, mode 4.

5 MR. JORDAN: Mode 4?

6 MR. MOORE: Yes.

7 MR. JORDAN: Okay.

8 MR. MOORE: I was relieved earlier than that. We  
9 went to mode 4, if I remember correctly, about 6:30 that  
10 night. That's I guess the best I can remember.


11 MR. JORDAN: You were on shift when that happened?  
12 Were you on the shutdown cooling?

13 MR. MOORE: I had turned everything over at about  
14 quarter after 6.

15 MR. JORDAN: Okay.

16 MR. MOORE: I usually stick around, collect my  
17 belongings, collect my thoughts for the day before I walk  
18 about, because I hate walking out and then saying, Oh, I  
19 forgot, and then come back -- so I usually take the time to  
20 turn over, collect my thoughts, collect my things, go  
21 through the control room one more time before I leave, to  
22 make sure that I haven't forgotten anything, and then I left  
23 at about 6:45.


24 MR. JORDAN: I've got two final questions here,  
25 and we'll combine one of the -- One of the question I want



1 to ask is the good news-bad news. The good news is, give me  
2 an idea of things that you found as a result of the actions  
3 you were assigned to do that you said, Gee, I'm glad I had  
4 this in my possession -- whether it be knowledge, training,  
5 piece of hardware, procedure -- something that was of great  
6 benefit to me to accomplish my tasks. And If there is  
7 anything out there that you say, Gee, I wish I would have  
8 had this available to me -- instrumentation, indication --  
9 you know, Gee, when I'm operating shutdown cooling, I wish  
10 this would be available to me -- that you didn't have that  
11 would have helped you in accomplishing your tasks? Are  
12 there any of those good news, this is great; the bad news  
13 is, we got through this, but it would have made my task  
14 available easier if I would have had this available to me?

15 MR. MOORE: Right. Probably the best thing I had  
16 was the procedure I used. OP-31 was wrote by George Moyer.  
17 He's a very knowledgeable individual. Because the procedure  
18 was written so well, at no time did I feel uncomfortable  
19 prior to doing a step, if there was some kind of a caution -  
20 - You know, it's not do the step and then, oh, by the way,  
21 pay attention to this. It's always, Before you do this, pay  
22 attention to -- because it's coming when you do your next  
23 step. So there was never any guess-work involved.

24 MR. KAUFFMAN: Is that different from -- Is that  
25 unusual, or are most of the procedures set up like that?





1 MR. MOORE: It varies from procedure to procedure.  
2 Again, no procedure can cover everything. There are things  
3 that are unique. We proved that on Tuesday, things being  
4 unique. But in most cases, our procedures are quite  
5 adequate. There are problems here and there.

6 MR. JORDAN: But in this case you found this  
7 procedure adequate.

8 MR. MOORE: Very well.

9 MR. JORDAN: Good for you.

10 MR. MOORE: OP-31 is written quite well.

11 The biggest hindrance, I would say, is the initial  
12 suction piping flush. The condensate transfer valve is  
13 located inside the IV room, which is a no-self-monitor,  
14 because you have shutdown cooling, suction, and reactor  
15 water cleanup suction piping coming both through the room.  
16 It's a high-rad room. In order to get an operator  
17 dispatched to open up the condensate transfer valve, you  
18 need to get a-hold of rad protection, so on and so forth.

19 MR. JORDAN: What's this valve?

20 MR. MOORE: The valve number is RHS-V-38.


21 MR. JORDAN: And it's located where?

22 MR. MOORE: In the IV room, reactor building 240.

23 MR. JORDAN: IV?

24 MR. MOORE: Isolation valve, 240 elevation.

25 MR. JORDAN: And the problem with the location and



1 access? What's the function of that?

2 MR. MOORE: That's the initial suction piping  
3 flush. It's condensate transfer water that is used to flush  
4 the suction piping.

5 MR. KAUFFMAN: Do I understand that's normally not  
6 a problem, but in this event it was a problem getting a rad  
7 tech?


8 MR. MOORE: Well, yes, because --

9 MR. JORDAN: Is it normally a problem, or is it  
10 not normally a problem? It was a problem this time?

11 MR. MOORE: Yes, I think because everybody was  
12 going different directions to man up, and our normal routine  
13 that we normally do was not there. Usually, when we're  
14 running cleanup, we're never in that room, because we're  
15 above 128' -- it's a situation that we don't normally run  
16 into. We're either shut down or the room is open, or we're  
17 running and we don't go in there. The only time we have  
18 problems is in the transient mode, and, when we're in that  
19 mode, we're normally shutting down, and we have an RP tech  
20 to go with us.

21 MR. JORDAN: So access to the room requires RP,  
22 and that's the problem that you had?

23 MR. MOORE: Yes. There were a lot of people doing  
24 a lot of things that were, I guess, more important than what  
25 I was working on at the time. Again, shutdown cooling is a



1 long, drawn out process. That's why they started having me  
2 do it at about 7 o'clock in the morning.

3 MR. JORDAN: I've got one more question.

4 MR. MOORE: Okay.

5 MR. JORDAN: There was some discussion about a  
6 potential water hammer in the RHR system for shutdown  
7 cooling. Do you know of any problem in that area?

8 MR. MOORE: Yes. When we were putting shutdown  
9 cooling on, doing the initial flush, there is a precaution  
10 to close or throttle RHS MOV I think it's 142 -- that's a  
11 throttleable valve -- to less than 50 percent open. The  
12 stroke on the valve is about 15 seconds, normally. I  
13 clocked it out in my head and my wristwatch prior to opening  
14 the other IV.


15 MR. JORDAN: Full stroke?

16 MR. MOORE: Yes. I wanted to find out what the  
17 stroke was.

18 I then, in turn, opened the valve about three to  
19 four seconds to make sure that it was less than 50 percent.  
20 When I started doing the flush, I had a report that there  
21 was some noise coming from the 215, 196 elevation, which is  
22 about the piping goes through to rad waste, and that's how  
23 we would flush.

24 MR. JORDAN: That was 215 --?

25 MR. MOORE: 196 elevation. There's a pipe that



1 runs off --

2 MR. JORDAN: Is that 216 to 196, or is it 215  
3 elevation and the 196 elevation?

4 MR. MOORE: That's two different elevations.

5 MR. JORDAN: At the 215 and 196 elevations you got  
6 reports of --

7 MR. MOORE: Noise or some kind of a hammering  
8 sound. I immediately throttled back on RHS-MOV-142 to  
9 probably minimum open position. I was then told that there  
10 was no further noise. Again the pump was not running. We  
11 were just doing initial flushes.

12 MR. JORDAN: You're saying the transfer pump  
13 wasn't running or the RHR pump was not running?

14 MR. MOORE: RHR pump and at that point you would  
15 not be flushing with condensate transfer.


16 MR. JORDAN: You said your water would not be?

17 MR. MOORE: Would not be.

18 MR. JORDAN: Okay, I'm confused. Opening this  
19 valve, does that thing in condensate transfer the water?

20 MR. MOORE: No, that's RHS-MOV-142 is a discharge  
21 to rad waste and what you are doing at this point to help  
22 you out is you already have, your isolation is cleared. You  
23 are using I guess the height of water from the reactor to  
24 slowly warm up the system.

25 MR. JORDAN: Are the valves to the reactor open?





1 MR. MOORE: Yes.

2 MR. JORDAN: So you are taking water from the  
3 reactor through the RHR pump. Is the RHR pump on it  
4 running?

5 MR. MOORE: No. No, all you are doing is warming  
6 up the system with the height of water that's in the  
7 reactor--

8 MR. JORDAN: To rad waste.

9 MR. MOORE: To rad waste and it is a very slow  
10 amount that you are doing it with.

11 MR. JORDAN: Is the only thing that is the valves  
12 that are open to the reactor, are they full open?

13 MR. MOORE: 113 -- I'd have to refer to the  
14 procedure. I am not sure I think 113 was full open.


15 MR. JORDAN: So the method by which you are  
16 controlling the flow through this system is via the 142  
17 valve?

18 MR. MOORE: Correct, and that is also an  
19 isolation, has an isolation logic built in on it and it will  
20 auto-isolate on Level 3, if that is any help.

21 MR. JORDAN: From the reactor to rad waste?

22 MR. MOORE: Right, and what you are doing there is  
23 to get the pump to within 100 degrees of coolant  
24 temperature.

25 I think -- well, I shouldn't think. I know why



1 the water, why I got a vibration.

2 MR. JORDAN: Is this part of the flushing  
3 procedure or is this part of putting the RHR in shutdown  
4 cooling?

5 MR. MOORE: That is part of the flush, prior to  
6 even getting into shutdown cooling.

7 MR. JORDAN: Within a hundred degrees you say?

8 MR. MOORE: Uh-huh. [Affirmative.]

9 MR. JORDAN: It came from the 100 degrees at what?

10 MR. MOORE: Reactor coolant temperature.

11 MR. JORDAN: Okay. Okay?

12 MR. MOORE: The reason that we got the hammer was  
13 because water that was in the line when you open the valve  
14 slight to rad waste then you start flushing, it's at 90, 80  
15 pounds. You are discharging to an area that is open to  
16 atmosphere and thinks it's water but it's not so it turns  
17 into steam and I think that's what I had.


18 MR. JORDAN: Reactor coolant was at what pressure?

19 MR. MOORE: Oh, I'd say 80, 90 pounds, something  
20 around there.

21 MR. JORDAN: 80, 90 pounds?

22 MR. MOORE: Yes.

23 MR. JORDAN: I am somewhat confused. So you are  
24 saying when you did your flushing around eight o'clock in  
25 the morning --



1 MR. MOORE: Okay, the initial flush is to get rid  
2 of the conductivity --

3 MR. JORDAN: Okay.

4 MR. MOORE: -- on the suction piping.

5 MR. JORDAN: Okay.

6 MR. MOORE: Then there is another point where you  
7 flush the discharge. That's where this comes into. The  
8 discharge piping --

9 MR. JORDAN: This doesn't pick up the discharge  
10 piping?

11 MR. MOORE: No.

12 MR. JORDAN: The flushing that you did in the  
13 morning doesn't pick up the discharge piping?

14 MR. MOORE: Right.

15 MR. JORDAN: It picks up which part of the system?

16 MR. MOORE: The suction piping from the reactor,  
17 because the suction piping was initially --


18 MR. JORDAN: To the pump?

19 MR. MOORE: Right, drawing through the suppression  
20 pool.

21 MR. JORDAN: Was it picked up through the pump?

22 MR. MOORE: Yes.

23 MR. JORDAN: Then discharged from the pump? It  
24 doesn't go through -- after it goes through the pump it  
25 doesn't pick up -- the morning discharge, the morning flush,



1 it picks up the suction to the pump --

2 MR. MOORE: Right.

3 MR. JORDAN: -- through the pump --

4 MR. MOORE: The discharge piping or part of the  
5 discharge piping and then it goes through rad waste.

6 MR. JORDAN: Then it goes to rad waste.

7 MR. MOORE: The afternoon flush is kind of a  
8 flush/warmup together.

9 MR. JORDAN: Okay, so then it takes it from the  
10 reactor --

11 MR. MOORE: Right.

12 MR. JORDAN: Through the pump?

13 MR. MOORE: Right.

14 MR. JORDAN: Okay, and this is in preparation for  
15 shutdown cooling?

16 MR. MOORE: Correct.


17 MR. JORDAN: And reactor pressure is in 80 to 90  
18 bounds?

19 MR. MOORE: Yes.

20 MR. JORDAN: And the discharged rad waste is  
21 atmospheric?

22 MR. MOORE: Right. That's just whatever -- it  
23 goes to one of their tanks, which one I am not sure.

24 MR. JORDAN: And you think you got the water  
25 hammer because --





1 MR. JORDAN:

2 MR. MOORE: The water flashed to steam. When I  
3 heard the noise I reclosed it.

4 MR. JORDAN: Did you hear the noise?

5 MR. MOORE: No. No, they called me on the radio.  
6 They said there is some noise down here, it sounds like a  
7 water hammer, what's going on up in the control room?


8 Of course at that time there was a lot of things  
9 still going on all through the course of the day and I said  
10 where are you? They said 215 or -- and the noise is coming  
11 right near 215 and 196.

12 I said, well, it's probably the warmup so I  
13 throttled back on 142 and about a minute later I got the  
14 call that the noise had stopped. Then I continued on with  
15 my warmup and I also asked the person that called me and I  
16 can't remember which one that was, to walk around and make  
17 sure that there was no leakage or anything was wrong.

18 MR. JORDAN: So they walked down the system?

19 MR. MOORE: I don't know if they completely  
20 walked down the system but they walked down the area that  
21 they heard the noise. They called back five, ten minutes  
22 later. They called five, ten minutes later, said that they  
23 didn't see anything. The noise had stopped. Everything  
24 appeared to be normal and I continued on.

25 MR. KAUFFMAN: Is this unusual, this happening



1 other times, shutdown cooling's been put into service?

2 MR. MOORE: Honestly, I can't give you an answer  
3 on that but nobody is usually out there in this type of  
4 situation. Guys are -- once you do the initial flush in the  
5 a.m., you don't need operating assistance for the rest of  
6 it so unless someone is out actually in the building at that  
7 point in time, they may not hear it and until you take the  
8 pump switch to start, and by that time you are all warmed  
9 up, there is an operator usually locally and then he'll go  
10 down and walk in after the pump starts to make sure that  
11 everything is running fine.

12 MR. JORDAN: When you are flushing, this is just a  
13 natural drain?

14 MR. MOORE: Right.

15 MR. JORDAN: Okay. The pumps aren't running or the  
16 RHR pumps running. Is there a flow indication or how do you  
17 know if you have water flowing through it?

18 MR. MOORE: The meters start indicating 2000 GPM.  
19 You really --

20 MR. JORDAN: During this flush --

21 MR. MOORE: You go by temperature, I guess would  
22 be the easiest way of doing that.

23 MR. JORDAN: Is that how you do it? I was just  
24 curious how you -- when you cut back on the throttle, how do  
25 you know you still have flow through the system?



1 MR. MOORE: Temperature. There is a chart recorder  
2 on Panel 601. Outlet temperatures for the heat exchanger  
3 inlet, you'll start seeing those increase and there is also  
4 a point that measures the temperature for the discharge to  
5 rad waste.

6 Initially when I started I had 75 or 80 degrees.  
7 I started flushing for the warmup. Temperature was going up.  
8 I got the call. I throttled back further. They said it  
9 stopped and I still had a temperature increase. It was  
10 less excessive, I guess you could say. Then someone had  
11 asked me how I was doing on shutdown cooling, getting it  
12 started.

13 I said, well, we got some noise, I wanted to slow  
14 down. They said fine. I think it was Eric Townsend. He  
15 was up in the room asking questions, just kind of seeing how  
16 things were going, see if he could help out.

17 Then they said okay, when you feel comfortable if  
18 you would like to increase the heatup, you can do so.

19 We wound up increasing the rate and then I had, I  
20 can't remember which person I kept calling, because I had  
21 three guys working with me. I asked them to check and  
22 listen for noise again in the area you heard previous. I  
23 increased valve position probably to something less than 50  
24 percent.

25 They said there was no further noise. We had a



1 substantial heat up on the pump and then by that time we  
2 were with 100 degrees of coolant temperature, and that was  
3 about 3:15 when I started the cooling pump, the shut down  
4 cooling in service.

5 MR. JORDAN: Does the procedure step you through  
6 this use of the recorder for temperature indications?

7 MR. MOORE: Yes, it does. It gives you an  
8 actual --

9 MR. JORDAN: -- the rad waste?

10 MR. MOORE: The actual number and it's a 7 --  
11 actually it is a multiple point chart recorder but it gives  
12 you the points that you're supposed to use and they are  
13 labelled right there, which point is what.

14 MR. JORDAN: Anything to watch for as far as  
15 temperature increases goes?

16 MR. MOORE: Right.

17 MR. JORDAN: That's in the procedure?

18 MR. MOORE: Yes.

19 MR. JORDAN: Don't we have that procedure  
20 anywhere?

21 MR. MOORE: OP-31.

22 MR. JORDAN: OP-31. OP, right?

23 MR. MOORE: Yes. That's in N2-OP-31.

24 MR. JORDAN: Anything else you want to tell us?

25 MR. MOORE: No.

100





1 MR. JORDAN: Okay, we can go off the record.

2 [Whereupon, at 5:00 p.m., the taking of the  
3 interview was concluded.]

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: Int. of BRIAN J. MOORE

DOCKET NUMBER:

PLACE OF PROCEEDING: Scriba, N.Y.

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

*Ian Rothrock*

IAN ROTHROCK  
Official Reporter  
Ann Riley & Associates, Ltd.

12345



XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXX



XXXXXXXXXXXXXXXXXXXX



# OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Incident Investigation Team

Title: Nine Mile Point Nuclear Power Plant  
Interview of: BRIAN J. MOORE

Docket No.

LOCATION: Scriba, New York

DATE: Wednesday, August 21, 1991

PAGES: 1<sup>1</sup> - 27

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950.

*9305070281*

1  
2  
3



ADDENDUM TO INTERVIEW OF BRIAN J MOORE NAOE  
(Name/Position)

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
7	13	1CSM@002 (PROCEDURE NUMBER)
9	20	WHEN WE TURNED SWITCH TO ON. (OTHERS WORKING WITH ME CLINT SMITH ACTUALLY STARTED PUMP WITH SWITCH)
26	3	3:15 WHEN CLINT SMITH STARTED (WE WERE WORKING TOGETHER)

Page 1 of 1 Signature Brian J Moore Date 8/23/91

1  
2

1  
2





UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

-----  
Interview of :  
BRIAN J. MOORE :  
(Closed) :  
-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Wednesday, August 21, 1991

The interview commenced, pursuant to notice,  
at 4:25 p.m.

PRESENT FOR THE IIT:  
John Kauffman, NRC  
Michael Jordan, NRC

3  
1

2  
2



## P R O C E E D I N G S

[4:25 p.m.]

1  
2  
3  
4 MR. JORDAN: It's August the 21st, 1991 at 4:25  
5 p.m. We are at the Nine Mile Point, Unit Two in the P  
6 Building. We're conducting interviews concerning a  
7 transient that occurred on August 13th, 1991.

8 My name is Michael Jordan, I'm with the NRC. I'm  
9 out of Region III.

10 MR. KAUFFMAN: I'm John Kauffman, NRC  
11 headquarters.

12 MR. MOORE: Brian Moore, reactor operator at Unit  
13 Two.

14 MR. JORDAN: Okay, Brian, why don't you give us a  
15 background of what your experience is?

16 MR. MOORE: I've been a reactor operator almost  
17 three years at Unit Two. Prior to that I was a non-LOT for  
18 five years at Unit Two. Prior to that I was in the Navy as  
19 a boiler technician -- conventional Navy for four years. I  
20 got out as a Petty Officer, Second Class, if that helps.  
21 Prior to that I was a machinist in an instrument and control  
22 type place. We made thermometers, pressure gauges and  
23 before that I was in high school.

24 MR. JORDAN: That's fine. We don't go back to  
25 when you were born.



1 MR. MOORE: No.

2 MR. JORDAN: Not that far back, anyway.

3 MR. KAUFFMAN: That's fine. But we could find  
4 out.

5 MR. MOORE: Oh yeah, right.

6 [Laughter.]

7 MR. JORDAN: Okay. Why don't you -- let's see,  
8 you were on day shift, what shift, mid-shift?

9 MR. MOORE: I was coming in on surveillance shift.

10 MR. JORDAN: Okay, why don't you tell us, as you  
11 come through the gate what you saw and what happened?

12 MR. MOORE: At -- I got to work about 6:15 because  
13 I wasn't shift-of-record and I didn't have to be in until  
14 6:30, so I was early, but --

15 MR. KAUFFMAN: Did you have any problems with the  
16 traffic?

17 MR. MOORE: I didn't have any problems at 6:15  
18 coming in, however, when I got to security, they wouldn't  
19 let me in because they weren't sure what was going on and  
20 the initial thing is to prevent anybody from coming inside.  
21 I was out in security, I'm going to say tops, 10 minutes.

22 George Moyer, one of the SSS's -- of course, they  
23 know him on sight, they said, "You, in." And as he was  
24 passing through the gate the first goal is to get through  
25 the explosives meters. We had all requested, there was

5 1  
2 4



1 probably six or seven of us, to call back down so that we  
2 could get on site.

3 After that, there was a phone call, probably ten  
4 minutes later and we were coming in. I then came in and got  
5 my hardhat and my keys, flashlight, and headed upstairs.

6 MR. JORDAN: Any lighting problems or anything  
7 like that?

8 MR. MOORE: No. Everything was already resolved  
9 by then. As far as I was aware of. I didn't have any  
10 problems coming in, I even used the elevator.

11 MR. JORDAN: And the elevators had lighting?

12 MR. MOORE: Yeah. The elevators were all lit, the  
13 stairways were lit. At least the area I was using. I then  
14 got to the control room, but instead of coming in through  
15 the back door, because I knew there was a problem, coming  
16 through the control room and getting into people's way, I  
17 went through the south door of the control room and I waited  
18 until I was recognized by the on-shift's CSO. He was busy.  
19 Occasionally he would look up and he acknowledged my  
20 presence in the control room by a nod or -- you know, he  
21 realized, I guess, I was there. A few minutes went on  
22 again. He had more than enough hands helping him. So, I  
23 guess probably five minutes in the control room I was  
24 trying to evaluate what had happened to kind of form my own  
25 -- I guess plan of attack to help and wait for some





1 direction to do things.

2 MR. KAUFFMAN: So what do you think happened? Or  
3 what did you see?

4 MR. MOORE: Well, most everything was back to  
5 normal. When I got there it just looked like we scrambled.  
6 We had indications, annunciators, I was like, okay, we took  
7 a scram. And then I heard a lot of this and that and what  
8 happened and what didn't happen.

9 So, I then -- the CSO came over to me and he says  
10 I have enough help, go across the hall and wait in the  
11 staging area which is our break area. I'll call you when I  
12 need you. And I was in there about 10 minutes, maybe 15  
13 minutes and then I was told to come over to the control  
14 room.

15 MR. JORDAN: So this is probably what time? Any  
16 idea?

17 MR. MOORE: 7:15, maybe. On site maybe.

18 MR. KAUFFMAN: We're really trying to establish  
19 time because the alarms and things are gone.

20 MR. MOORE: It's probably around 7:15 by now. He  
21 called me to come over to start flushing -- shutdown  
22 cooling.

23 [Pause as interviewee peruses notebook.]

24 MR. MOORE: And then -- I've got some things wrote  
25 down because I always write what I do. From day-to-day in



1 case something like this ever happens.

2 My first actions were to flush our RHR shutdown  
3 cooling and get shutdown cooling in service.

4 MR. JORDAN: What systems were you using?

5 MR. MOORE: RHR and condensate transfer.

6 MR. JORDAN: Which RHR, A, B, C --

7 MR. MOORE: B. It would have been RHR B. And  
8 condensate transfer would be used for the flush.


9 MR. KAUFFMAN: What pressure can you shut down  
10 cooling and service --

11 MR. MOORE: Huh?

12 MR. KAUFFMAN: What pressure can you put shut down  
13 cooling and service interlocks?

14 MR. MOORE: Yes. It's 128 pounds which we were  
15 well above prior to that. I was also looking around at what  
16 level was and there was some interlocks I still had to  
17 clear. The level was -- at that time just short of  
18 clearing level three and coming back slowly, at least on  
19 the trip units in the back, so that would have been about a  
20 level of 150 coming up.

21 I had two aux operators, Dwayne LeMay and Bob  
22 Pellegrino assist me in the flush, and they had to do a  
23 couple of valve manipulations out in the plant and open the  
24 condensate transfer valve which is a manual valve and  
25 isolate a discharge valve off of the boost -- jockey booster



1 pump to keep the system full.

2 I'd say that took almost 40 minutes to do the  
3 flush, so we're looking, probably around -- by something  
4 close to 8:00. Sometime in between there Marty McCormick  
5 took over as SED because there was an announcement made in  
6 the control room that Mike Conway was no longer the SED,  
7 that he was relieved by Marty McCormick. And I kind of  
8 remembered that because it was right around that when I was  
9 finishing up the flush.

10 Then somebody had asked me what I was doing -- was  
11 I in a lull because of pressure and so on and so forth. I  
12 said, "Yes." And they asked me to assist them in doing the  
13 ICS M at 002 which is a vacuum breaker test. Because I  
14 guess they evaluated that they cycled an SRV. So I helped  
15 them do that.

16 MR. KAUFFMAN: Why are you required to do that  
17 test?

18 MR. MOORE: It's to verify that the vacuum  
19 breakers will actually cycle and the DP will not be  
20 excessive across the floor.

21 MR. JORDAN: You do it just for SRV's? Do you do  
22 it if you run RCIC, do you do it for --

23 MR. MOORE: No. It's just SRV's.

24 MR. JORDAN: Just strictly SRV's?

25 MR. MOORE: Yes. As far as I'm aware of.

5  
4  
2



1 MR. KAUFFMAN: Can you tell us the procedure then,  
2 that you were doing or that that is?


3 MR. MOORE: I was pushing the buttons on the  
4 panel. The actual procedure number is N2OSPICSM, the little  
5 a with the circle around it, it's an AT, 002.

6 And I assisted Jay Lawrence. He had the actual  
7 procedure and I stood at the back panels and he told me  
8 which button to push for which valves and we verified  
9 lights and computer points and so on and so forth.

10 That had to be sometime -- I'm going to have to  
11 say, maybe 8:30 or 9:00, maybe later. I can't remember  
12 exact time when we were doing that. Then most of the rest  
13 of the day I spent putting shutdown cooling in service and  
14 that's a long drawn out process of warming up and heating  
15 up and unisolating and clearing interlocks.

16 MR. KAUFFMAN: How did that process go? Did it go  
17 good?

18 MR. MOORE: Well, it's like any time we put it on  
19 it's very, very long to get it on because you're waiting for  
20 pressure. You don't want to violate cool-down rates. Once  
21 you clear your interlocks you want to make sure that you're  
22 down far enough that it doesn't come back. When you start  
23 opening isolation valves you want to make sure that you have  
24 sufficient inventory so you don't drop level again. And  
25 then once you turn the pump switch to start, it becomes





1 rather quick because you're dealing with a few variables;  
2 heat exchanger, service water, outlet temperature, cool-down  
3 rate in the reactor which is a major concern; flow rate for  
4 pump concerns so you're kind of -- really got to think what  
5 you're doing on each manipulation and in the first 15  
6 minutes it's kind of hectic, but that's the way it is.  
7 We've always learned to accept that and we get positive  
8 control and within minutes -- what -- because of the  
9 increase in flow, both service water and system flow, you're  
10 variables change a lot, especially you're cool down. So, we  
11 cool down quite a bit in the first 15 minutes and then the  
12 next 45 minutes to an hour we almost sit with no cool-down  
13 at all.


14 That's about all I can tell you on this, unless  
15 you've got some questions.

16 MR. JORDAN: So the rest of the day you were in  
17 the shutdown cooling?

18 MR. MOORE: Right, and I didn't get shutdown  
19 cooling running until about 3:15. That's from flushing till  
20 starting the pump; it was probably when I turned the switch  
21 off.

22 MR. JORDAN: After you flush, how long is it good  
23 for before you have to flush again?

24 MR. MOORE: Since the system is closed and we're  
25 not putting any other water in it, it shouldn't be a



1 problem. The chemistry should remain fairly constant.

2 MR. JORDAN: Why do you flush?


3 MR. MOORE: Well, RHR has five modes of operation,  
4 one of them being off the suppression pool. We consider  
5 suppression pool not a clean source of water, so to minimize  
6 the conductivity increase in the vessel, we flush with  
7 condensate transfer water, which is a more clean source of  
8 water.

9 MR. JORDAN: Okay. You flush from the condensate  
10 -- what's the supply?

11 MR. MOORE: Okay. Condensate transfer taps in on  
12 the suction supply on the outboard isolation valves for the  
13 containment. We flush that leg of piping down to the  
14 suction of the pump.

15 MR. JORDAN: Where's the section of the pump  
16 pumping to?

17 MR. MOORE: All right. The reactor, one of the  
18 loops, the A loop of recirc, goes to the shutdown cooling  
19 loop, so we line up the loop for suction, with the section  
20 of the isolation valves, because they're locked out because  
21 of your pressure interlock. So you're lining up your entire  
22 system to put on your shutdown cooling leg, and then you  
23 would open up your condensate transfer to flush out that  
24 water. The suction from the suppression pool has been  
25 closed prior to this.



1 MR. JORDAN: So it comes from the condensate  
2 transfer pump?

3 MR. MOORE: System.

4 MR. JORDAN: System?

5 MR. MOORE: Yes.

6 MR. JORDAN: Okay. You flush the entire RHR  
7 system out?

8 MR. MOORE: Right.

9 MR. JORDAN: Where does it flush back to?

10 MR. MOORE: It's flushed to rad waste.

11 MR. JORDAN: To rad waste?


12 MR. MOORE: Right.

13 MR. JORDAN: So you flush it to rad waste. How do  
14 you know if you've flushed enough?

15 MR. MOORE: There's a computer point that we  
16 monitor for conductivity. Once that computer point clears  
17 .2, I think it is -- I'd have to refer to the procedure for  
18 the exact micromole number, but once that gets below that  
19 point, the sufficient flushing has been done. I usually  
20 wait to make sure that it's not just a flood of water going  
21 through, that the system is completely flushed prior to  
22 securing.

23 MR. JORDAN: Is the transfer from -- what --  
24 transfer from the condenser?

25 MR. MOORE: No, it comes from the condensate



1 storage tanks.

2 MR. JORDAN: It comes from the condensate storage  
3 tanks.

4 MR. MOORE: Right.

5 I'd flush that. If conductivity gets below I  
6 think it's .2, I'd let it sit for at least another minute or  
7 two, flushing, to verify that it's not just a slug of water  
8 that's passing by the element, that it is completely clean  
9 water.

10 MR. JORDAN: The pumps were operating at this  
11 time?

12 MR. MOORE: No. The pump is shut down. Actually,  
13 the pump is in pull-to-lock.

14 MR. JORDAN: What's the driving force for the  
15 water?

16 MR. MOORE: The pressure developed by the  
17 condensate transfer pumps.

18 MR. JORDAN: Okay. I think I understand now how  
19 that works.


20 MR. MOORE: Okay.

21 MR. JORDAN: You say you started shutdown cooling  
22 around 3:15?

23 MR. MOORE: Yes.

24 MR. JORDAN: When did you get relieved?

25 MR. MOORE: I left the control room about quarter





1 to 7.

2 MR. JORDAN: So you were here when they finally  
3 got to the point of shutdown.

4 MR. MOORE: Yes, mode 4.

5 MR. JORDAN: Mode 4?

6 MR. MOORE: Yes.

7 MR. JORDAN: Okay.

8 MR. MOORE: I was relieved earlier than that. We  
9 went to mode 4, if I remember correctly, about 6:30 that  
10 night. That's I guess the best I can remember.


11 MR. JORDAN: You were on shift when that happened?  
12 Were you on the shutdown cooling?

13 MR. MOORE: I had turned everything over at about  
14 quarter after 6.

15 MR. JORDAN: Okay.

16 MR. MOORE: I usually stick around, collect my  
17 belongings, collect my thoughts for the day before I walk  
18 about, because I hate walking out and then saying, Oh, I  
19 forgot, and then come back -- so I usually take the time to  
20 turn over, collect my thoughts, collect my things, go  
21 through the control room one more time before I leave, to  
22 make sure that I haven't forgotten anything, and then I left  
23 at about 6:45.


24 MR. JORDAN: I've got two final questions here,  
25 and we'll combine one of the -- One of the question I want



1 to ask is the good news-bad news. The good news is, give me  
2 an idea of things that you found as a result of the actions  
3 you were assigned to do that you said, Gee, I'm glad I had  
4 this in my possession -- whether it be knowledge, training,  
5 piece of hardware, procedure -- something that was of great  
6 benefit to me to accomplish my tasks. And If there is  
7 anything out there that you say, Gee, I wish I would have  
8 had this available to me -- instrumentation, indication --  
9 you know, Gee, when I'm operating shutdown cooling, I wish  
10 this would be available to me -- that you didn't have that  
11 would have helped you in accomplishing your tasks? Are  
12 there any of those good news, this is great; the bad news  
13 is, we got through this, but it would have made my task  
14 available easier if I would have had this available to me?

15 MR. MOORE: Right. Probably the best thing I had  
16 was the procedure I used. OP-31 was wrote by George Moyer.  
17 He's a very knowledgeable individual. Because the procedure  
18 was written so well, at no time did I feel uncomfortable  
19 prior to doing a step, if there was some kind of a caution -  
20 - You know, it's not do the step and then, oh, by the way,  
21 pay attention to this. It's always, Before you do this, pay  
22 attention to -- because it's coming when you do your next  
23 step. So there was never any guess-work involved.

24 MR. KAUFFMAN: Is that different from -- Is that  
25 unusual, or are most of the procedures set up like that?



1 MR. MOORE: It varies from procedure to procedure.  
2 Again, no procedure can cover everything. There are things  
3 that are unique. We proved that on Tuesday, things being  
4 unique. But in most cases, our procedures are quite  
5 adequate. There are problems here and there.

6 MR. JORDAN: But in this case you found this  
7 procedure adequate.

8 MR. MOORE: Very well.

9 MR. JORDAN: Good for you.

10 MR. MOORE: OP-31 is written quite well.

11 The biggest hindrance, I would say, is the initial  
12 suction piping flush. The condensate transfer valve is  
13 located inside the IV room, which is a no-self-monitor,  
14 because you have shutdown cooling, suction, and reactor  
15 water cleanup suction piping coming both through the room.  
16 It's a high-rad room. In order to get an operator  
17 dispatched to open up the condensate transfer valve, you  
18 need to get a-hold of rad protection, so on and so forth.

19 MR. JORDAN: What's this valve?

20 MR. MOORE: The valve number is RHS-V-38.

21 MR. JORDAN: And it's located where?

22 MR. MOORE: In the IV room, reactor building 240.

23 MR. JORDAN: IV?

24 MR. MOORE: Isolation valve, 240 elevation.

25 MR. JORDAN: And the problem with the location and



1 access? What's the function of that?

2 MR. MOORE: That's the initial suction piping  
3 flush. It's condensate transfer water that is used to flush  
4 the suction piping.

5 MR. KAUFFMAN: Do I understand that's normally not  
6 a problem, but in this event it was a problem getting a rad  
7 tech?


8 MR. MOORE: Well, yes, because --

9 MR. JORDAN: Is it normally a problem, or is it  
10 not normally a problem? It was a problem this time?

11 MR. MOORE: Yes, I think because everybody was  
12 going different directions to man up, and our normal routine  
13 that we normally do was not there. Usually, when we're  
14 running cleanup, we're never in that room, because we're  
15 above 128 -- it's a situation that we don't normally run  
16 into. We're either shut down or the room is open, or we're  
17 running and we don't go in there. The only time we have  
18 problems is in the transient mode, and, when we're in that  
19 mode, we're normally shutting down, and we have an RP tech  
20 to go with us.

21 MR. JORDAN: So access to the room requires RP,  
22 and that's the problem that you had?

23 MR. MOORE: Yes. There were a lot of people doing  
24 a lot of things that were, I guess, more important than what  
25 I was working on at the time. Again, shutdown cooling is a





1 long, drawn out process. That's why they started having me  
2 do it at about 7 o'clock in the morning.

3 MR. JORDAN: I've got one more question.

4 MR. MOORE: Okay.

5 MR. JORDAN: There was some discussion about a  
6 potential water hammer in the RHR system for shutdown  
7 cooling. Do you know of any problem in that area?

8 MR. MOORE: Yes. When we were putting shutdown  
9 cooling on, doing the initial flush, there is a precaution  
10 to close or throttle RHS MOV I think it's 142 -- that's a  
11 throttleable valve -- to less than 50 percent open. The  
12 stroke on the valve is about 15 seconds, normally. I  
13 clocked it out in my head and my wristwatch prior to opening  
14 the other IV.

15 MR. JORDAN: Full stroke?

16 MR. MOORE: Yes. I wanted to find out what the  
17 stroke was.

18 I then, in turn, opened the valve about three to  
19 four seconds to make sure that it was less than 50 percent.  
20 When I started doing the flush, I had a report that there  
21 was some noise coming from the 215, 196 elevation, which is  
22 about the piping goes through to rad waste, and that's how  
23 we would flush.

24 MR. JORDAN: That was 215 --?

25 MR. MOORE: 196 elevation. There's a pipe that



1 runs off --

2 MR. JORDAN: Is that 216 to 196, or is it 215  
3 elevation and the 196 elevation?

4 MR. MOORE: That's two different elevations.

5 MR. JORDAN: At the 215 and 196 elevations you got  
6 reports of --

7 MR. MOORE: Noise or some kind of a hammering  
8 sound. I immediately throttled back on RHS-MOV-142 to  
9 probably minimum open position. I was then told that there  
10 was no further noise. Again the pump was not running. We  
11 were just doing initial flushes.

12 MR. JORDAN: You're saying the transfer pump  
13 wasn't running or the RHR pump was not running?

14 MR. MOORE: RHR pump and at that point you would  
15 not be flushing with condensate transfer.

16 MR. JORDAN: You said your water would not be?

17 MR. MOORE: Would not be.

18 MR. JORDAN: Okay, I'm confused. Opening this  
19 valve, does that thing in condensate transfer the water?

20 MR. MOORE: No, that's RHS-MOV-142 is a discharge  
21 to rad waste and what you are doing at this point to help  
22 you out is you already have, your isolation is cleared. You  
23 are using I guess the height of water from the reactor to  
24 slowly warm up the system.

25 MR. JORDAN: Are the valves to the reactor open?



1 MR. MOORE: Yes.

2 MR. JORDAN: So you are taking water from the  
3 reactor through the RHR pump. Is the RHR pump on it  
4 running?

5 MR. MOORE: No. No, all you are doing is warming  
6 up the system with the height of water that's in the  
7 reactor--

8 MR. JORDAN: To rad waste.

9 MR. MOORE: To rad waste and it is a very slow  
10 amount that you are doing it with.

11 MR. JORDAN: Is the only thing that is the valves  
12 that are open to the reactor, are they full open?

13 MR. MOORE: 113 -- I'd have to refer to the  
14 procedure. I am not sure I think 113 was full open.


15 MR. JORDAN: So the method by which you are  
16 controlling the flow through this system is via the 142  
17 valve?

18 MR. MOORE: Correct, and that is also an  
19 isolation, has an isolation logic built in on it and it will  
20 auto-isolate on Level 3, if that is any help.

21 MR. JORDAN: From the reactor to rad waste?

22 MR. MOORE: Right, and what you are doing there is  
23 to get the pump to within 100 degrees of coolant  
24 temperature.

25 I think -- well, I shouldn't think. I know why



1 the water, why I got a vibration.

2 MR. JORDAN: Is this part of the flushing  
3 procedure or is this part of putting the RHR in shutdown  
4 cooling?

5 MR. MOORE: That is part of the flush, prior to  
6 even getting into shutdown cooling.

7 MR. JORDAN: Within a hundred degrees you say?

8 MR. MOORE: Uh-huh. [Affirmative.]

9 MR. JORDAN: It came from the 100 degrees at what?

10 MR. MOORE: Reactor coolant temperature.

11 MR. JORDAN: Okay. Okay?

12 MR. MOORE: The reason that we got the hammer was  
13 because water that was in the line when you open the valve  
14 slight to rad waste then you start flushing, it's at 90, 80  
15 pounds. You are discharging to an area that is open to  
16 atmosphere and thinks it's water but it's not so it turns  
17 into steam and I think that's what I had.

18 MR. JORDAN: Reactor coolant was at what pressure?

19 MR. MOORE: Oh, I'd say 80, 90 pounds, something  
20 around there.

21 MR. JORDAN: 80, 90 pounds?

22 MR. MOORE: Yes.

23 MR. JORDAN: I am somewhat confused. So you are  
24 saying when you did your flushing around eight o'clock in  
25 the morning --





1 MR. MOORE: Okay, the initial flush is to get rid  
2 of the conductivity --

3 MR. JORDAN: Okay.

4 MR. MOORE: -- on the suction piping.

5 MR. JORDAN: Okay.

6 MR. MOORE: Then there is another point where you  
7 flush the discharge. That's where this comes into. The  
8 discharge piping --

9 MR. JORDAN: This doesn't pick up the discharge  
10 piping?

11 MR. MOORE: No.

12 MR. JORDAN: The flushing that you did in the  
13 morning doesn't pick up the discharge piping?

14 MR. MOORE: Right.

15 MR. JORDAN: It picks up which part of the system?

16 MR. MOORE: The suction piping from the reactor,  
17 because the suction piping was initially --

18 MR. JORDAN: To the pump?

19 MR. MOORE: Right, drawing through the suppression  
20 pool.

21 MR. JORDAN: Was it picked up through the pump?

22 MR. MOORE: Yes.

23 MR. JORDAN: Then discharged from the pump? It  
24 doesn't go through -- after it goes through the pump it  
25 doesn't pick up -- the morning discharge, the morning flush,

11



1 it picks up the suction to the pump --

2 MR. MOORE: Right.

3 MR. JORDAN: -- through the pump --

4 MR. MOORE: The discharge piping or part of the  
5 discharge piping and then it goes through rad waste.

6 MR. JORDAN: Then it goes to rad waste.

7 MR. MOORE: The afternoon flush is kind of a  
8 flush/warmup together.

9 MR. JORDAN: Okay, so then it takes it from the  
10 reactor --

11 MR. MOORE: Right.

12 MR. JORDAN: Through the pump?

13 MR. MOORE: Right.

14 MR. JORDAN: Okay, and this is in preparation for  
15 shutdown cooling?

16 MR. MOORE: Correct.

17 MR. JORDAN: And reactor pressure is in 80 to 90  
18 bounds?

19 MR. MOORE: Yes.

20 MR. JORDAN: And the discharged rad waste is  
21 atmospheric?

22 MR. MOORE: Right. That's just whatever -- it  
23 goes to one of their tanks, which one I am not sure.

24 MR. JORDAN: And you think you got the water  
25 hammer because --



1 MR. JORDAN:

2 MR. MOORE: The water flashed to steam. When I  
3 heard the noise I reclosed it.

4 MR. JORDAN: Did you hear the noise?

5 MR. MOORE: No. No, they called me on the radio.  
6 They said there is some noise down here, it sounds like a  
7 water hammer, what's going on up in the control room?

8 Of course at that time there was a lot of things  
9 still going on all through the course of the day and I said  
10 where are you? They said 215 or -- and the noise is coming  
11 right near 215 and 196.

12 I said, well, it's probably the warmup so I  
13 throttled back on 142 and about a minute later I got the  
14 call that the noise had stopped. Then I continued on with  
15 my warmup and I also asked the person that called me and I  
16 can't remember which one that was, to walk around and make  
17 sure that there was no leakage or anything was wrong.

18 MR. JORDAN: So they walked down the system?

19 MR. MOORE: I don't know if they completely  
20 walked down the system but they walked down the area that  
21 they heard the noise. They called back five, ten minutes  
22 later. They called five, ten minutes later, said that they  
23 didn't see anything. The noise had stopped. Everything  
24 appeared to be normal and I continued on.

25 MR. KAUFFMAN: Is this unusual, this happening

1 2 3  
4 5 6



1 other times, shutdown cooling's been put into service?

2 MR. MOORE: Honestly, I can't give you an answer  
3 on that but nobody is usually out there in this type of  
4 situation. Guys are -- once you do the initial flush in the  
5 a.m., you don't need operating assistance for the rest of  
6 it so unless someone is out actually in the building at that  
7 point in time, they may not hear it and until you take the  
8 pump switch to start, and by that time you are all warmed  
9 up, there is an operator usually locally and then he'll go  
10 down and walk in after the pump starts to make sure that  
11 everything is running fine.

12 MR. JORDAN: When you are flushing, this is just a  
13 natural drain?

14 MR. MOORE: Right.

15 MR. JORDAN: Okay. The pumps aren't running or the  
16 RHR pumps running. Is there a flow indication or how do you  
17 know if you have water flowing through it?

18 MR. MOORE: The meters start indicating 2000 GPM.  
19 You really --

20 MR. JORDAN: During this flush --

21 MR. MOORE: You go by temperature, I guess would  
22 be the easiest way of doing that.

23 MR. JORDAN: Is that how you do it? I was just  
24 curious how you -- when you cut back on the throttle, how do  
25 you know you still have flow through the system?





1 MR. MOORE: Temperature. There is a chart recorder  
2 on Panel 601. Outlet temperatures for the heat exchanger  
3 inlet, you'll start seeing those increase and there is also  
4 a point that measures the temperature for the discharge to  
5 rad waste.

6 Initially when I started I had 75 or 80 degrees.  
7 I started flushing for the warmup. Temperature was going up.  
8 I got the call. I throttled back further. They said it  
9 stopped and I still had a temperature increase. It was  
10 less excessive, I guess you could say. Then someone had  
11 asked me how I was doing on shutdown cooling, getting it  
12 started.

13 I said, well, we got some noise, I wanted to slow  
14 down. They said fine. I think it was Eric Townsend. He  
15 was up in the room asking questions, just kind of seeing how  
16 things were going, see if he could help out.

17 Then they said okay, when you feel comfortable if  
18 you would like to increase the heatup, you can do so.

19 We wound up increasing the rate and then I had, I  
20 can't remember which person I kept calling, because I had  
21 three guys working with me. I asked them to check and  
22 listen for noise again in the area you heard previous. I  
23 increased valve position probably to something less than 50  
24 percent.

25 They said there was no further noise. We had a



1 substantial heat up on the pump and then by that time we  
2 were with 100 degrees of coolant temperature, and that was  
3 about 3:15 when I started the cooling pump, the shut down  
4 cooling in service.

5 MR. JORDAN: Does the procedure step you through  
6 this use of the recorder for temperature indications?

7 MR. MOORE: Yes, it does. It gives you an  
8 actual --

9 MR. JORDAN: -- the rad waste?

10 MR. MOORE: The actual number and it's a 7 --  
11 actually it is a multiple point chart recorder but it gives  
12 you the points that you're supposed to use and they are  
13 labelled right there, which point is what.

14 MR. JORDAN: Anything to watch for as far as  
15 temperature increases goes?

16 MR. MOORE: Right.

17 MR. JORDAN: That's in the procedure?

18 MR. MOORE: Yes.

19 MR. JORDAN: Don't we have that procedure  
20 anywhere?

21 MR. MOORE: OP-31.

22 MR. JORDAN: OP-31. OP, right?

23 MR. MOORE: Yes. That's in N2-OP-31.

24 MR. JORDAN: Anything else you want to tell us?

25 MR. MOORE: No.

11 11 11  
11 11 11



1 MR. JORDAN: Okay, we can go off the record.

2 [Whereupon, at 5:00 p.m., the taking of the

3 interview was concluded.]

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: Int. of BRIAN J. MOORE

DOCKET NUMBER:

PLACE OF PROCEEDING: Scriba, N.Y.

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



IAN ROTHROCK

Official Reporter  
Ann Riley & Associates, Ltd.

11 2 2  
11 2 2

