

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U.S. Nuclear Regulatory Commission
Incident Investigation Team

Title: Telephone Conference Call
Interview Of Philip Smith

Docket No.


LOCATION: Bethesda, Maryland

DATE: Thursday, September 19, 1991 PAGES: 1 - 36

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

9305070335 911031
PDR ADDOCK 05000410
S PDR



ERRATA SHEET

ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
2	20	Change "Team" to "Senior" transcription error
2	21	Insert "Systems" before "Engineering" transcription error
4	12	Change "read" to "reed" typographical error
5	16	Change "lever" to "level" transcription error
6	14	Change "RPM's" to "APRM's" transcription error
14	21	Change "circulation" to "recirculation" transcription error
21	4	Change "tough" to "touch" transcription error
24	15	Delete "will maintain," transcription/grammatical error
26	9	Insert "the reactor is" before "shutdown" transcription error
32	6	Delete "probably" transcription/grammatical error.
36	11	Delete "-- physically seen" transcription/grammatical error.

Date 13 Oct
1991

Signature Philip S. Smith

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL


1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 INCIDENT INVESTIGATION TEAM
4
5

6 Telephone Conference Call
7

8 Interview of Philip Smith
9

10
11 Nuclear Regulatory Commission
12 The Woodmont Building
13 Room W-102
14 8120 Woodmont Avenue
15 Bethesda, Maryland
16 Thursday, September 19, 1991
17
18

19 The meeting in the above-entitled matter convened,
20 pursuant to notice, in closed session at 10:00 a.m.
21
22
23
24
25



P R O C E E D I N G S

[10:03 a.m.]

1
2
3 MR. CONTE: Good morning. My name is Richard
4 Conte from Region I. I am a member of the Incident
5 Investigation Team investing the event of August 13 at Nine
6 Mile II. We are in a conference call with Mr. Philip Smith
7 from GPU Nuclear. I believe he is at Parsippany, New
8 Jersey. The NRC members are at the Woodmont Building in
9 Bethesda, Maryland. The time is 10:03.

10 We will start out by going around the room here in
11 Bethesda, and then we will ask you to identify yourself,
12 Phil. My name, as I said, is Richard Conte.

13 MR. VATTER: Bill Vatter from INPO.

14 MR. JORDAN: Mike Jordan, member of the NRC IIT
15 Team.

16 MR. KAUFFMAN: John Kauffman, NRC, AEOD.

17 MR. STONER: Jim Stoner, with Duke Power.

18 MR. CONTE: We have a Court Reporter here also.
19 Phil, could you introduce yourself?

20 MR. SMITH: Sure. I am Philip Smith, Team
21 Engineer, Engineering Department at GPU Nuclear. I am also
22 Chairman of the BWR Owners Group Emergency Procedures
23 Guideline Committee.

24 MR. CONTE: Thank you, Phil. We are ready to go
25 around the room and get started. I think Mr. Vatter has one



1 of the first questions.


2 MR. VATTER: Phil, one of the problems that we are
3 most interested in is when the operators did not have any
4 indication of control rod position in this event, what could
5 have been the worst reactivity situation that they would
6 have had to deal with --

7 MR. CONTE: Let me interrupt here. I think we need
8 to establish how much Mr. Smith knows about the Nine Mile II
9 event. Phil, how much do you know; could you tell us?

10 MR. SMITH: I talked to several people at Nine
11 Mile about the event. My understanding of it is that it was
12 a loss of power or load reject out in the turbine, and that
13 ended up causing a loss of off-site power and then failure
14 of some transfer switches to go over to DC power or
15 alternate. That resulted in a loss of some amount of
16 control room indication for 20 to 25 minutes.

17 MR. CONTE: Let me see if we can get you up to
18 speed a little more in terms of how the operators were
19 implementing the EOP's. They are using Rev 4 of the Boiler
20 EOP's. Primarily they were in RP -- when the event
21 happened, as you said, there was a loss of power supplies.
22 They lost all indication of rod position; five
23 uninterruptable power supplies went down simultaneously.

24 That resulted in a lot of front panel information
25 lost except for safety grade instrumentation on reactor



1 pressure and reactor vessel level. Post-accident monitors
2 went in the fast -- recorders went into fast speed.
3 Electrical distribution volt meters and amperages, that was
4 still okay because they were apparently independently
5 powered.

6 APRM readings were gotten from the back panel.
7 The recorders for APRM's and IRM's were lost in the front
8 panel. Are you following me so far?

9 MR. SMITH: Sure.

10 MR. CONTE: Once again, rod position indication,
11 there are multiple ways of finding rod position indication.
12 However, the read switches all come off of one power supply;
13 therefore, that essentially disabled one of those five power
14 supplies and others deal with the rod position indication --
15 rod minimizer, rod sequence control -- those are the things
16 that were basically unavailable for rod position indication.

17 When the event happened the preliminary assessment
18 was they had APRM's down scale less than four percent. No
19 rod position. I guess they diagnosed or assessed that they
20 were in a transient on the reactor besides the electrical
21 transient, so they decided to manually scram. The other key
22 thing here that gets you into the EOP's is that feedwater
23 was lost because of that power supply problem, and that
24 created a low level situation and an entry into the RPV
25 control.



1 Are you with me?

2 MR. SMITH: The volume dropped off, and I can
3 hardly hear you at all.

4 [Disconnected.]

5 MR. CONTE: We are going to call you back.

6 [Reconnected.]

7 MR. CONTE: Back on the record. For the record,
8 we had a phone communication problem. We had to switch
9 phones, so we are back on the record.


10 Phil, I was giving you a run down of equipment
11 that was lost. I got to where there was a loss of feedwater
12 and an entry into the RPV control on level. Did you
13 understand everything up to that point?

14 MR. SMITH: I have it.

15 MR. CONTE: One of the key things in the RPV
16 control and the lever leg was the operators were faced with
17 a question, if all control rods are not inserted into at
18 least position 02 and the reactor will not remain shutdown
19 without boron, exit this section and go into C5 which is the
20 contingency on power level control.

21 MR. SMITH: Correct.

22 MR. CONTE: The operator exited and went to C5,
23 primarily on the information of rod position. He didn't
24 have rod position, he didn't know where he was, and he
25 didn't have a reactor analyst to tell him that the reactor



1 will remain shutdown so he went into the ATWS procedure.


2 Setting that stage, I am going to ask Bill Vatter
3 to ask the question again.

4 MR. VATTER: Thank you, Rich. I am sorry. I sort
5 of jumped in the middle of it, Phil. Basically what they
6 had was a scram with loss of feed and they didn't know where
7 the rod position was.

8 We are trying to postulate different ways that a
9 loss of rod position indication could have been a serious
10 problem. One of the ways that we are postulating is that
11 they also had an ATWS combined with loss of rod position
12 indication. If they did have an ATWS it would have had to
13 have been a partial ATWS because they did know the power was
14 down scale on the RPM's. A little bit later they had the
15 IRM's driven in, and they could see that they were going
16 down in there.

17 If some of the rods did not scram what kind of a
18 reactivity situation might have existed such that if they
19 added cold water that they would have had a recriticality
20 and resultant core damage from the recriticality?

21 MR. SMITH: Let me preface answering the question
22 with, it is my understanding that they could determine that
23 the reactor was indeed shut down, and when you get into
24 Contingency 5 procedure the first statement asks whether the
25 operator can determine that reactor power is above or below



1 the down scale trip.

2 Understanding that the front panel indications of
3 reactor power were unavailable, there are alternate means of
4 determining reactor power, one of which is reactor period
5 looking at steam flow, looking at vessel pressure and level
6 trends, perhaps a number of open SRV's. Suppression pool
7 temperature and temperature trends, all indications to the
8 operator of what reactor power is doing and whether or not
9 he is above or below the down scale trip; i.e., does he have
10 the reactor shut down.

11 MR. CONTE: It seems like the exiting to the ATWS
12 procedure is solely dependent on the rod position alone.

13 MR. SMITH: That is very true. When you get into
14 Contingency 5, as I was trying to say, there is criteria for
15 which the operator makes the decision on whether the reactor
16 is making sufficient power and heating the containment.
17 Under these conditions, as I understand them, he was not
18 getting sufficient heat to the suppression pool and he did
19 not have significant power in the reactor.

20 Therefore, he would have controlled water level in
21 the same manner that you would had you had a normal scram.
22 The level power control procedure, it directs the operator
23 to make an assessment whether or not reactor power is above
24 the down scale trip or cannot be determined. In addition to
25 that, he has to have suppression pool temperature above a



1 curve in the EOP's called boron initiation injection
2 temperature which is criteria for shooting boron into the
3 core. Third he has to have an SRV open or drywall pressure
4 above the high drywall pressure scram set point as an
5 indication of the reactor is still at significant power and
6 is rejecting significant amount of heat to the containment.

7 If that is true, then the operator goes through
8 the steps of lowering reactor water level to suppress the
9 reactor power and wait for the boron to shut the reactor
10 down. In this case, I don't believe that he met those entry
11 conditions to lower reactor water level. Therefore, the
12 next step in the Contingency, Step C5-3, directs the
13 operator to maintain water level within the normal band with
14 his normal injection systems.

15 I believe that the operator would have controlled
16 water level within the normal band.

17 MR. VATTER: That is basically what happened,
18 Phil. He had a little problem with condensate booster pumps
19 started injecting when pressure went down. That is the
20 direction that he was going.

21 MR. SMITH: Okay.

22 MR. VATTER: The focus of my question is, the
23 reactor is shut down but we don't know how much it is shut
24 down. There may have been one or more rods that didn't
25 insert or inserted partway, because he hasn't any position




1 indication.

2 What we would like to know is, if there has been
3 any analysis done to determine what might happen if you had
4 a large amount of cold water injected in that circumstance.
5 We are particularly looking at a caution in Niagra Mohawk's
6 procedure that says in the C5 procedure it says: "Caution.
7 Raising injection flow rapidly may induce a large power
8 excursion and result in substantial core damage."

9 He is in the C5 procedure because the entry
10 condition that is spelled out in the RPV control procedure
11 says that if the rods are not all at 02 and the reactor will
12 not remain shut down without boron, he really didn't know
13 either of those things so he went over to C5. That's where
14 he was. He went past that caution that I just reiterated to
15 you.

16 We don't understand the significance of that
17 caution and what it is based on.

18 MR. SMITH: The significance of the caution is
19 based on having the operator aware that because he cannot be
20 certain that the reactor is shut down then care must be
21 taken in establishing injection flow rates into the reactor.
22 The criteria for systems to be used is systems which inject
23 outside of the reactor shroud, understanding that when they
24 inject in the downcomer that the water as it is transported
25 through the recirculation loops mixes with warmer water in



1 the reactor and, therefore, reduces the cold water addition
2 to the reactor core and hence your reactivity addition.

3 He is directed to go to outside the shroud systems
4 first. He would not try inside the shroud systems unless he
5 could not maintain water level with those outside shroud
6 systems. If he decided he needed to go to inside the shroud
7 systems, he is directed to terminate and prevent all
8 injection from inside the shroud systems and to depressurize
9 the reactor, realizing that as pressure drops down you don't
10 want to have the low pressure ECCS systems injecting at an
11 uncontrolled rate because the reactivity excursion could be
12 significant.

13 There is some work that has been done by General
14 Electric, I think, many years ago which suggested that the
15 reactivity addition due to uncontrolled LPCI injection into
16 the reactor core could be in excess of one dollar of
17 reactivity. There is some debate on how much in excess of
18 one dollar it is, but I think it's sufficient to say that if
19 it is in excess of one dollar that's too much.

20 That was the basis for that caution that was in
21 there, to say that be aware operator that if the reactor is
22 not shut down to be careful on the rate at which you
23 increase flow rates into the reactor because of the cold
24 water effect.

25 MR. VATTER: Phil, do you know if there was any



1 analysis for a partial ATWS that shut the plant down but
2 there was a potential for recriticality with perhaps adverse
3 rod configuration that would cause one region of the core to
4 have maybe some fuel damage. Was there any work on partial
5 ATWS and trying to figure out what the worst case might be?


6 MR. SMITH: I don't recall that there was any
7 specific work on partial ATWS. I know that they looked at
8 all rods out condition. In fact, I think you would agree
9 that the worst case for reactivity addition would be if the
10 reactor was several decades below the heating range when you
11 injected the cold water, because the power and reactivity
12 addition rate and -- power would continue to increase on
13 almost an exponential basis until either Doppler or voids
14 turned it around.

15 I think you would agree that that would be the
16 worst case in terms of depositing energy to the fuel.

17 MR. VATTER: Right. What we would like to know is
18 if anybody has tried to quantify how bad that worst case is?

19 MR. SMITH: As I said, I have seen numbers that
20 have ranged upwards from one dollar up to eight or nine
21 dollars worth of reactivity. I don't know that people have
22 gone and connected the reactivity addition with what sort of
23 fuel damage or fracture or cladding perforations you may
24 expect because of that.

25 MR. VATTER: I think eight or nine dollars worth



1 of reactivity will be a big deal.

2 MR. SMITH: It will certainly get your attention,
3 yes. Understand that the way Contingency 5 is structured
4 that first making the operator aware that uncontrolled or
5 rapidly increasing injection into the reactor core can
6 result in these conditions; that he is sensitized to that,
7 and that he would use systems which inject outside the
8 shroud first to minimize the effect of reactivity addition
9 on to the core.

10 MR. VATTER: I understand that. Of course, the
11 normal feedwater system is outside the shroud.

12 MR. SMITH: True.

13 MR. VATTER: In this event they had an unexpected
14 injection from the condensate booster pumps. The pressure
15 drifted down fairly slowly, and the condensate booster pumps
16 caught them unaware. It put in a large amount of water and
17 they went off scale high. We don't think that they put
18 water in the steam lines, but they got close.

19 MR. CONTE: I would like to emphasize that this
20 was not an ATWS also.

21 MR. SMITH: True.

22 MR. VATTER: Right. All the rods were in, but if
23 all the rods were not all in -- if they were in that sort of
24 an undesirable configuration that we were talking about
25 which, apparently there has not been any analysis done, what



1 do you think might be the worst case reactivity
2 recriticality kind of an event from just condensate booster
3 pumps shooting in water?

4 MR. KAUFFMAN: As an aside here, the feedwater reg
5 valves failed in their 100 percent open position, so they
6 were wide open.

7 MR. SMITH: Again, I can tell you where I would
8 expect reactor power to end up. If reactor water level is
9 up into the normal range or slightly above the normal range,
10 if the rods were completely withdrawn or were significantly
11 out, you might expect to have a steady state power in the
12 range of 40 to 60 percent power.

13 Certainly, the rate at which the condensate
14 booster pumps would slug the water in there and whether or
15 not there was any feedwater heating left would certainly
16 affect the peak power before it steadied out in around the
17 40 to 60 percent range.

18 MR. VATTER: Of course, we started now from below
19 the heating range. The operator knows that reactor is
20 subcritical, he has no APRM indication, but it might be only
21 slightly subcritical.

22 MR. SMITH: I would be hesitant to quote you a
23 number of what the spike could be, because there are just
24 several fairly important variables that would influence how
25 high the peak would be. Certainly, it could twice or three



1 times the average power. Anything above that, I would be
2 hesitant to kind of offer an opinion on.

3 MR. VATTER: I guess one scenario that has been
4 going through our minds is that several rods in a very bad
5 configuration failed to scram but the reactor is
6 subcritical. Then, this power drifts down below the heating
7 range a few decades, and the condensate booster pump
8 injection causes a recriticality with a power peak in that
9 area of the core where the rods didn't scram; and that,
10 maybe the core gets hurt from all of that.

11 Is that a potential concern do you think, or do
12 you think it couldn't happen?

13 MR. SMITH: I would say it wouldn't be a very
14 large concern. Understanding the mixing of the condensate
15 booster pump water with the rest of the water in the
16 reactor, understanding how it would mix as it came through
17 the diffusers from the recirc loops back into the lower
18 plenum of the reactor vessel, and it would kind of
19 homogenize out. I think you need to look at some relative
20 flow rates of the water in the reactor vessel, the
21 circulation flow, versus what you are going to inject from
22 the condensate booster pumps.

23 I would think that the cold water effect would
24 have been reduced significantly by the mixing. Certainly, a
25 way to tell that is to look at recirc loop temperature and



1 to see how far that fell off during the condensate booster
2 pump injection. That would give you a feel for what the
3 temperature of the water was that was going into the core.

4 MR. VATTER: That's a good thought, although we
5 won't get much out of that, Phil. The process computer went
6 down with the event and none of that data is available.

7 MR. CONTE: Phil, how do you expect operators to
8 implement this caution?


9 MR. SMITH: That caution?

10 MR. CONTE: Yes, practically speaking.

11 MR. SMITH: I would expect the operator to
12 understand that injection of the water can have a
13 detrimental effect on his ability to control reactor water
14 level and power. I would expect that in trying to control
15 reactor water level where this caution does appear, that he
16 would be careful in terms of how much he opened up for
17 example the feedwater regulating valves or whatever
18 injection valve on the system he was using and would not
19 just try and open the valve to full position immediately.

20 The EPG's do provide him a fairly wide level
21 control band for this action. It does not necessitate that
22 he take rapid and potentially too rapid operator action
23 which could result in the high reactivity addition rate.

24 MR. CONTE: What I think I am hearing you say is
25 an operator tweaks on whatever controller he has and looks




1 for a level response, it doesn't get a level response and
2 tweaks a little more. Once he gets a level response, he
3 kind of holds it there and makes sure the level is slowly
4 coming up. You really can't put a GPM number on this; is
5 that correct?

6 MR. SMITH: You surely can't, because the state of
7 being in this contingency procedure is that you are unsure
8 first whether the reactor is shut down or what the rod
9 configuration is. Certainly, you just wouldn't want to
10 arbitrarily establish a flow number because it would work
11 for several cases but not for all. It could be that for one
12 of the cases for which it did not work would be the one
13 where that could give you some reactivity addition.

14 As you said, I believe he would look at level
15 response. He would also look at power response if he had
16 power indication available. By tweaking the controller and
17 little bit and saw a little bit of level response and didn't
18 see too much on the power, that may give him an indication
19 that he can tweak it a little bit more until he starts
20 seeing power come up with that.

21 That is my opinion on how the operator would
22 implement that caution.

23 MR. CONTE: Okay. I had another question -- I
24 have two more questions. Let's back up when he exits the RP
25 level control, he exits the C5. What do you think about




1 that situation? Basically rod position, you may or may not
2 know this, but the rod position indication is not considered
3 safety grade. The power supplies for this event were not
4 safety grade.

5 What do you think about the situation where there
6 was no ATWS and the operator was forced into being fooled
7 that he had an ATWS; what do you think about that?

8 MR. SMITH: I would not characterize it that he
9 was fooled into thinking he had an ATWS. I would
10 characterize it as he could not confirm the reactor was shut
11 down. If he could not confirm that, I believe that it is
12 prudent to take actions and precautions that would be
13 sensitive to the fact that the reactor may not be shut down
14 rather than trying to make a determination initially that
15 the reactor is shut down and that a normal reactor level
16 control kind of initiating injection without regard to
17 whether it is inside the shroud or outside shroud, or
18 without regard to the rate of flow increase.

19 I think it is very appropriate that if the
20 operator cannot determine that the reactor is shut down,
21 that he should take precautions and assume that it is not.
22 Understand in this condition that because I believe that the
23 operator could make a determination that really the APRM's
24 were probably down scale and that he was not heating the
25 containment, his actions in terms of controlling reactor



1 water level would not be different than what he would do for
2 normal scram with the exception of this precaution on how
3 fast to increase the flow rate.

4 He is not really doing anything different than he
5 would if he had known that all the rods went in and he was
6 recovering from the scram.

7 MR. CONTE: What I am hearing is that you are
8 supporting the operator actions to enter C5?

9 MR. SMITH: Absolutely.

10 MR. CONTE: You mentioned something earlier, that
11 it is appropriate to go into C5 because it gets the operator
12 to take a look at the situation in the containment and the
13 situation with respect to reactor power. I realize and I
14 wanted to emphasize this point, you are probably talking
15 from your knowledge of the Rev 4 emergency procedure
16 guidelines that are generically applied and we are talking
17 from the Nine Mile II specific procedures.

18 In the C5 for Nine Mile II, you really don't see -
19 - there is an ongoing statement here that says are rods
20 inserted to position two or the reactor will shut down under
21 all conditions without boron, exit this procedure and enter
22 RPV control RL section.

23 I really don't see the flavor of what you are
24 talking about in these procedures about the analysis on the
25 reactor being shut down or making a determination if reactor



1 is shut down. Let me add here, because you don't have these
2 procedures in front of you, there is another ongoing step
3 that is combined with a number of other conditions with
4 respect to the suppression pool and the SRV's opening.

5 It says if reactor power is above four percent or
6 cannot be determined, then continue at another point which
7 is looking at main steam lines and another leg of the C5
8 situation. Let me add another piece of information. The
9 licensee has given instructions to the operator that a shut
10 down reactor is less than range six and seven on the IRM's.

11 MR. KAUFFMAN: And, subcritical.

12 MR. CONTE: And, subcritical. What do you think?
13 I have said a mouth full here. Can you comment?


14 MR. SMITH: Sure. I have an opinion on most any
15 subject you want to bring up.

16 MR. CONTE: Go ahead.

17 MR. SMITH: First of all, the steps that you just
18 quoted, reactor power is above the four percent number.
19 There should be a subsequent -- two other subsequent
20 conditions on suppression pool temperature and SRV open.

21 MR. CONTE: There is.

22 MR. SMITH: That is the criteria for the operator
23 to lower reactor water level. Those three criteria in step
24 C5-2, at least in the generic guidelines, are indicative of
25 the reactor is at significant power; it is not shut down;



1 and, significant heat is being rejected in the containment.


2 That is where the operator makes the determination
3 of whether or not he wants a lower level. What I have
4 spoken to earlier about alternate ways to determine reactor
5 power given that the APRM's were not working that day that,
6 I am getting out of what is called Appendix B to the
7 emergency procedure guidelines which is the technical basis
8 document, which goes through each one of the steps within
9 the emergency procedure guidelines and describes the basis
10 for them.

11 This is guidance that is in the technical basis
12 report in terms of how he would determine reactor power.

13 MR. CONTE: This is for the Rev 4 of the EPG's.

14 MR. SMITH: Yes. The intent of how this technical
15 basis document is to be used was to provide this to the
16 procedure writer and the training people in order to use
17 this an ensure that all the thoughts that were made in
18 developing the emergency procedure guidelines are somehow
19 incorporated into the training program to at least allow the
20 operator to get the wisdom or the knowledge that we use to
21 try to come up with these.

22 I can't comment on whether Nine Mile has
23 incorporated that into their training program, but that
24 information is available as part of the generic procedure
25 guidelines to be incorporated into the training program. I



1 think that answers the first part.

2 MR. CONTE: Should rod position indication be
3 safety grade?

4 MR. SMITH: I wouldn't tough that thing with a ten
5 foot pole.

6 MR. CONTE: That's an honest answer. We can
7 appreciate that. Say that again, about your plant?

8 MR. SMITH: I might end up having to implement
9 that commitment at my plant, and my management would not be
10 too pleased if they saw this in print.

11 MR. CONTE: Thank you.

12 MR. JORDAN: I have one question. I think you
13 mentioned the fact that Appendix B gives a criteria. Can
14 you give us what you know as far as when it says the reactor
15 will not remain shut down without boron. Can you give me an
16 idea of what guidelines you expect the utility to give to
17 the operators on what that means and how he can or cannot
18 determine that?

19 MR. SMITH: I really think that determination of
20 condition that reactor will maintain -- will be shut down
21 under all conditions without boron is not a decision that
22 the operator really probably has the indication or perhaps
23 the knowledge to make on the fly.

24 I believe that the intent of that step was to have
25 the operator consult the reactor engineer and the reactor

1. The first part of the document discusses the importance of maintaining accurate records of all transactions.

2. It also highlights the need for regular audits to ensure the integrity of the financial data.

3. The document further emphasizes the role of technology in streamlining financial processes.

4. Additionally, it notes the importance of transparency and accountability in financial reporting.

5. The document concludes by stating that these practices are essential for the long-term success of any organization.

6. Finally, it encourages all stakeholders to work together to ensure the highest standards of financial management.


1 engineer, based on his training and his understanding of the
2 core configuration or rod configuration, would make a
3 determination that the reactor could be cooled down even
4 though all the rods were not fully inserted.

5 The example that I would offer would be if one rod
6 was notched out several notches in two quadrants -- the rods
7 were notched adjacent to each other by one rod out and the
8 northwest quadrant of one out in the southeast quadrant -- I
9 think after looking at that, that the reactor engineer would
10 have a fair confidence that the reactor is not going to go
11 critical again during a cool down.

12 The intent was to not leave the operator in the
13 Contingency 5 level power control procedure if the reactor
14 engineer could make that determination that the reactor will
15 be shut down. The condition was superimposed of not having
16 any boron in the reactor to assure that if there was any
17 boron washout that the reactor would not return to power. I
18 hope that answered your question.

19 MR. JORDAN: You did. Thank you, Phil.

20 MR. CONTE: I think I will get complicated on you
21 again here, Phil. In looking at the actual situation that
22 the operators had with the low power, they were trying to
23 implement these EOP's. On the one section on level control
24 they were in the C5 and were very much aware of a stop
25 statement or wait statement before exiting C5 in order to



1 get out and back into RL leg of the RPV control.

2 The wait statement says that all rods are inserted
3 to at least position 02 or the reactor will remain shut down
4 without boron. I think you explained that. Once again,
5 they didn't have the rod position indication and they didn't
6 have an analyst telling them that the reactor will remain
7 shut down, so they were on hold at that point.


8 They didn't have feed and condensate but at least
9 feed and condensate was kind of behind the stops because
10 pressure was high. Then, there's another wait statement on
11 the RP leg of RPV control which has four conditions. Two of
12 them are duplicative of the two that I just mentioned, in
13 order to exit C5 and then it adds another or. If boron is
14 being injected SLC tank drops to 900 gallons or, the reactor
15 was shut down and boron has been injected.

16 This stop sign appears right after the stabilize
17 reactor pressure. It is apparently a go for cool down.

18 MR. SMITH: Yes.

19 MR. CONTE: What we get out of it is that it's an
20 analysis that permits you to cool down to assure that you
21 won't go critical again. However, if it gives you the go
22 ahead there is an ongoing statement that says the reactor is
23 not shut down return to B, which takes you back up to
24 stabilize pressure.

25 MR. SMITH: Correct.



1 MR. CONTE: The operators were trying to --
2 because they were using RCIC, RCIC was bringing them down.
3 There was no ATWS, it was a very low heat load and RCIC was
4 able to handle it. They were initially confused. They
5 eventually figured out that all I need my go ahead here is
6 the reactor is shut down -- they were below the range six
7 and seven on the IRM's. They had SRM indication, so they
8 made the go ahead.

9 Those two legs appear to be in conflict with one
10 another, appear to be. Do you have an opinion on that?

11 MR. SMITH: Sure. I don't think they are. The
12 criteria in vessel pressure control, at least in the
13 guidelines set that I am looking at here is RC/P-3, which
14 specifies when either -- all the rods are inserted to
15 position 02 or you know that the reactor will maintain, will
16 be shut down under all conditions without boron, or you have
17 injected the cold shut down boron wait which is your 900
18 gallon number. That assures that the reactor will be shut
19 down under cold conditions with no voids, no xenon. There
20 are a number of functions that go into calculation of that
21 weight.

22 The last one is the reactor is shut down now but I
23 haven't injected boron and I don't have a confidence that
24 the reactor will be shut down as I cool down. Understand if
25 the operator is trying to use that last bullet as the



1 criteria for cooling down, he should also be in Contingency
2 5 which gives him all the guidance on be careful how fast
3 you inject into the reactor and be careful where that
4 injection source is, either inside the shroud or outside the
5 shroud.

6 He is conscious of that, and as he begins his cool
7 down at less than 100 degrees per hour, he still has
8 conditional statement which applies that if, while you are
9 cooling down the reactor is not shut down and begins to
10 return to power then stop the cool down and stabilize
11 pressure again and take a look again at the conditions which
12 would allow you to cool down again.

13 I really don't think they are in conflict. In
14 fact, I think they work well together in terms of allowing
15 the operator to depressurize if he needs to. An example of
16 where he would is if he had this event plus he had a leak.
17 Certainly, there is impetus if you have a leak to
18 depressurize the reactor to reduce the rate at which you are
19 losing inventory, even though the reactor may not be shut
20 down and there's a possibility that as you depressurize and
21 get low in pressure the reactor may start to return to
22 power.

23 You are counting on the operator in Contingency 5
24 being conscious of the rate at which injection should be put
25 into the reactor to assure that he doesn't have an excessive




1 reactivity spike.

2 MR. CONTE: I am not going to repeat everything
3 you have said, but I think the message you are sending us is
4 that the last condition the reactor is shut down and no
5 boron has been injected is to combat another situation where
6 you do have a leak, you want to stop the leak, and there is
7 impetus to get depressurized; is that correct?

8 MR. SMITH: That is the first. It also gives the
9 operator the flexibility that if he can determine shut down
10 now while he is waiting for his reactor engineer to
11 determine that it will be shut down forever with the rod
12 configuration he has, he is allowed to start his cool down.
13 If it takes 20, 30 minutes or an hour for the reactor
14 engineer to make that determination at least the operator
15 has been given some guidance on permitting himself to cool
16 down to get the reactor pressure vessel into a lower energy
17 state, both for the leak concerns and in general cooling the
18 reactor down.

19 I believe that the conditional statement which
20 applies to terminating the cool down if the reactor -- if it
21 is determined that the reactor cannot be assured to be shut
22 down, covers the case where the reactor may return to
23 criticality during depressurization.

24 MR. KAUFFMAN: Phil, that covers the part of the
25 event to where in Nine Mile's definitions they had not



1 determined that they were shut down until they had looked at
2 the IRM's or source range monitors. Initially in this
3 event, they couldn't say yes we were shut down, we were
4 allowed to depressurized.

5 At that point they were at a point where, if they
6 ran RCIC they would depressurize. Yet, they had a step that
7 said stabilize pressure. I guess what I am trying to
8 understand is, what does the stabilize term mean and how do
9 you expect them to implement the level and pressure before
10 they can say yes we are shut down and it's okay to cool
11 down?

12 MR. SMITH: The stabilize step is intended that
13 the operator stops a trend of increasing or decreasing
14 pressure. The stabilization of the pressure, if the reactor
15 is not shut down, it is important to stabilizing reactor
16 water level and is important to stabilizing reactor power.
17 Without having stabilized the pressure it would be difficult
18 for the operator to control the other two parameters if the
19 reactor was indeed not shut down.

20 Let's see if there is a definition for stabilize.
21 What the operator is supposed to do -- I would interpret
22 that the operator should have tried to control pressure
23 within a certain band, and as part of implementation of the
24 emergency procedure guidelines different plants have chosen
25 a band for what constitutes stabilize. Maybe it's within



1 100 pounds, 150 pounds of the high pressure scram setpoint.

2 That is the band that the operator is given to try
3 and control the pressure within until he comes to the next
4 step in trying to make the determination on whether the
5 reactor is shut down enough for him to depressurize the
6 reactor vessel. Concurrent with this, he should be in
7 Contingency 5, trying to control water level within the
8 normal band, understanding the caution about increasing flow
9 too much.

10 I am not sure that I have answered your question
11 real clean.

12 MR. KAUFFMAN: I am going to continue on here. I
13 am the operator, I am running RCIC, and I see that I am
14 depressurizing --

15 MR. CONTE: My level is high.

16 MR. KAUFFMAN: My level is high. I guess I am
17 trying to visualize if I am an operator what options I have
18 in front of me. One is, I have a very wide level band. I
19 can turn off RCIC, watch level, coast down, and repressurize
20 and attempt to stabilize pressure that way. I can run RCIC
21 and maybe, since I have some steam loads, I can secure my
22 auxillary steam loads. That may have some negative effect
23 later of maintaining condenser available -- it's nice to
24 have -- steam seals, air ejectors, that sort of thing.

25 What I might be really concerned about this de-



1 stabilization and say I am going to shut my MSIV's and turn
2 off RCIC and control pressure with my SRV's. In the back of
3 my mind I know that gets me closer to SLC injection.

4 I guess what I am trying to say is, are these
5 reasonable thoughts for him to go through? Is it reasonable
6 to make this guy have to pick between these different
7 options? How would you expect people to respond to this
8 situation?

9 MR. SMITH: Understand first, I don't have a
10 reactor operator license. So, I am speaking based on my
11 knowledge of the emergency procedure guidelines. If RCIC
12 was the system that I had available and RCIC by itself was
13 depressurizing me, that would make me a little more
14 confident that the reactor was probably shut down.
15 Understanding how much steam RCIC happens to draw off of the
16 reactor vessel and what it would inject, that it doesn't
17 match decay heat for a while after shutdown, at least on
18 some representative BWR 4's or 3's.

19 I don't believe that he would go and try and
20 isolate the main condenser to try and stabilize pressure.
21 As I said, the level control guidance gives him a fairly
22 wide band in order to control water level within. I would
23 say that he would use RCIC as necessary to stay within that
24 band, also trying to keep reactor vessel pressure as stable
25 as he could. If there were not a lot of other steam loads



1 that were sucking reactor level pressure down, he would
2 probably be in pretty good shape.

3 If these auxillary steam loads were sucking vessel
4 pressure down that, to me, would be more of an indication
5 that the reactor really was not at power. I think I have
6 done this in a roundabout way for you.

7 MR. CONTE: Let me rephrase that question here.
8 The stabilize steps says -- the EOP's say stabilize RPV
9 pressure below 1070 psig using the main turbine bypass
10 valves of the RPV pressure control with the systems listed
11 below if necessary.

12 You almost get the impression that this step is
13 written on a high pressure situation and not a low pressure
14 situation.

15 MR. SMITH: Certainly, the high pressure situation
16 does represent more of a challenge to the integrity of the
17 reactor vessel. The stabilize step was there primarily to
18 have the operator prevent SRV cycling that may be impacting
19 his control of the other parameters.

20 I am trying to find in the generic technical basis
21 where it talks about the stabilize step. Bear with me for a
22 moment here, because my fingers aren't working very well
23 turning the pages. The generic technical basis does
24 describe that there is no low end of the pressure control
25 range; that thereby permits vessel pressure to be reduced to



1 below the shut of head of low pressure systems if injection
2 from these systems is necessary to establish and maintain
3 adequate core cooling.

4 Primarily, it is concerned with the high pressure
5 end and the top end of that -- I think you quoted 1070
6 pounds -- is likely to be the high vessel pressure scram
7 setpoint. You want to stay below that setpoint to assure
8 that if the reactor was indeed not shut down that you would
9 be allowed to reset the scram and potentially drive rods
10 again.

11 MR. CONTE: Thank you. Are there any other
12 questions?

13 MR. KAUFFMAN: I had a question back to when the
14 reactor is depressurizing and you talked about it would be
15 reasonable for him to have control of his level valves and
16 slowly put water in.

17 I guess the background on this event is that his
18 feedwater reg valves were filled full up. In this event, to
19 some extent the operator, if he was going to prevent that
20 uncontrolled injection it would have to anticipate the
21 booster pump injection. Your first answer indicated that
22 that really wouldn't be where his thoughts were or how this
23 was intended to be implemented.

24 I guess I am saying I thought the operator should
25 have anticipated booster pump injection and had the pumps



1 turned off or the valves shut. I guess what I am asking is,
2 are my expectations too high? Do you think I am wrong?

3 MR. SMITH: Certainly, condensate and feedwater is
4 one of the systems he would be using to maintain reactor
5 water level and Contingency 5. In fact, that would probably
6 be probably his first choice of systems to use. Whether or
7 not he should have been conscious that the reg valves had
8 failed in their full open position or he had indication that
9 the valves were in their full open position, is something I
10 don't know.

11 I think that if you were going to error and permit
12 an injection from a system, condensate booster pumps would
13 probably be the one I would pick to error on, understanding
14 the mixing that happens before the water gets to the bottom
15 of the core.

16 Perhaps in hindsight, that he should have made
17 some efforts to try and close the parallel valve -- not the
18 parallel valve but feed reg valves -- perhaps. Certainly, I
19 think he was awful busy at that time and he had to take some
20 priorities on what actions he was going to take.
21 Understanding that the transient seemed to turn out okay, I
22 would say he probably chose the right things.

23 MR. KAUFFMAN: I guess it is going to get back to
24 the importance of that caution in that, that caution sounds
25 like there are pretty dire consequences if this injection



1 occurs. I guess the question I have is, if he is busy doing
2 other things, should he be looking real closely at his EOP's
3 or should he be running around and doing other things.

4 MR. SMITH: I think that if he is in Contingency
5 5, my opinion is that he ought to be more conscious of
6 controlling the injection into the vessel and controlling
7 the vessel parameters, understanding that lack of control of
8 these parameters has certainly a much greater impact if the
9 reactor is truly not shut down.

10 Perhaps from that standpoint he should have --
11 perhaps he should have taken more action to assure that the
12 condensate booster pumps did not inject uncontrolled.

13 MR. CONTE: That's all we have for questions. We
14 have some closing comments for you, Phil. Mike Jordan.

15 MR. JORDAN: Phil, I just want to thank you for
16 your assistance in helping us clarify some points on the
17 EOP's. We would ask also that you not relate your concerns
18 that we have addressed here to anybody outside of yourself
19 because, until we have come up with our final conclusion on
20 our report -- until our report is issued. A lot of these
21 are just concerns that we have that may or may not appear
22 anyplace else.

23 MR. SMITH: I understand that, and I will abide by
24 that.

25 MR. JORDAN: Do we have your address?



1 MR. SMITH: It's GPU Nuclear Corporation, 1 Upper
2 Pond Road, Parsippany, New Jersey 07054.

3 MR. JORDAN: We will see if we can get a copy of
4 this transcript mailed to you. We ask that you not copy it.
5 If you want a copy of the transcript we will be glad to send
6 that to you after we issue our report, when it becomes a
7 public document. If you wish to request a copy of it when
8 you send your transcript back, annotate that you want a copy
9 of the transcript.

10 MR. SMITH: That would be fine.

11 MR. CONTE: I have two more comments -- one is a
12 question. When we were talking about this study -- in
13 review of my notes here and the thought just came to me --
14 when we were talking about this study with the LPCI
15 injection and so many dollars of reactivity, this seems to
16 be a beyond design basis event.

17 Why did General Electric do this study? Was it in
18 response to a staff concern, was it their own volition or
19 what?

20 MR. SMITH: This was in response to questions from
21 the Emergency Procedures Committee as we were developing
22 Contingency 5 as to whether there was a real downside to
23 distinguishing between inside the shroud and outside the
24 shroud systems, and whether there was a need for the
25 operator to have some additional guidance or precaution in



1 terms of how fast he would inject water into the reactor.

2 Understand that that analysis or evaluation, from
3 what I remember of it -- since it was probably 1981 or 1982
4 timeframe -- I believe was looking at a complete injection
5 of LPCI into an unrodded core. The water basically
6 accumulated in the upper plenum above the core and then fell
7 into it almost as a slug. That's where the reactivity
8 excursion came from.

9 MR. CONTE: One more question before we go off the
10 record. I am going to ask you to stay on the line after we
11 go off the record because the Court Reporter may have some
12 questions for you on some terminology that you used. One
13 more question.

14 Have we asked the right questions? Do you have
15 anything to offer or would you like to clarify anything that
16 you have made statements on about the topics this morning?

17 MR. SMITH: Maybe a quick summary of points. I
18 believe the operator was correct in entering the Contingency
19 5 procedure based on not being inserted and the reactor was
20 shut down. It would appear that he made that determination
21 and correctly left that procedure that the reactor was shut
22 down. I guess those are the only summary of what I have of
23 it.

24 MR. CONTE: I guess the other main point that you
25 made based on the situations that we gave you was that these



1 legs are all consistent with one another.

2 MR. SMITH: Yes, that is true. I believe that
3 they are. I believe that the Procedures Committee has taken
4 significant efforts to assure that they are consistent with
5 each other.

6 MR. JORDAN: Phil, the document that you mentioned
7 about the calculation of the cold water injection, is that
8 GE's?

9 MR. SMITH: That is General Electric's. I believe
10 that it is probably GE proprietary. It is not a document
11 that I have ever seen physically -- physically seen. I have
12 no knowledge in what state of documentation it is, whether
13 it is a formalized calculation that General Electric did,
14 whether it is just some analysis that one of the engineer's
15 happened to run. I don't know in what condition it is.

16 As I said, I have never physically seen it.

17 MR. CONTE: Okay, we are going to go off the
18 record and ask you to stay on.

19 [Whereupon, at 11:09 a.m., the meeting concluded.]

20

21

22

23

24

25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: Philip Smith

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Official Reporter
Ann Riley & Associates, Ltd.



OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U.S. Nuclear Regulatory Commission
Incident Investigation Team

Title: Telephone Conference Call
Interview Of Philip Smith

Docket No.

LOCATION: Bethesda, Maryland


DATE: Thursday, September 19, 1991 PAGES: 1 - 36

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

Dupe of

~~9305070338~~




ERRATA SHEET

ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
2	20	Change "Team" to "Senior" transcription error
2	21	Insert "Systems" before "Engineering" transcription error
4	12	Change "read" to "reed" typographical error
5	16	Change "level" to "level" transcription error
6	14	Change "RPM's" to "APRM's" transcription error
14	21	Change "circulation" to "recirculation" transcription error
21	4	Change "tough" to "touch" transcription error
24	15	Delete "will maintain," transcription/grammatical error
26	9	Insert "the reactor is" before "shutdown" transcription error
32	6	Delete "probably" transcription/grammatical error.
36	11	Delete "-- physically seen" transcription/grammatical error.

Date 13 Oct
1991

Signature Philip S. Smith




1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 INCIDENT INVESTIGATION TEAM
4
5

6 Telephone Conference Call
7

8 Interview of Philip Smith
9

10
11 Nuclear Regulatory Commission
12 The Woodmont Building
13 Room W-102
14 8120 Woodmont Avenue
15 Bethesda, Maryland
16 Thursday, September 19, 1991
17
18

19 The meeting in the above-entitled matter convened,
20 pursuant to notice, in closed session at 10:00 a.m.
21
22
23
24
25



P R O C E E D I N G S

[10:03 a.m.]

1
2
3 MR. CONTE: Good morning. My name is Richard
4 Conte from Region I. I am a member of the Incident
5 Investigation Team investing the event of August 13 at Nine
6 Mile II. We are in a conference call with Mr. Philip Smith
7 from GPU Nuclear. I believe he is at Parsippany, New
8 Jersey. The NRC members are at the Woodmont Building in
9 Bethesda, Maryland. The time is 10:03.

10 We will start out by going around the room here in
11 Bethesda, and then we will ask you to identify yourself,
12 Phil. My name, as I said, is Richard Conte.

13 MR. VATTER: Bill Vatter from INPO.

14 MR. JORDAN: Mike Jordan, member of the NRC IIT
15 Team.

16 MR. KAUFFMAN: John Kauffman, NRC, AEOD.

17 MR. STONER: Jim Stoner, with Duke Power.

18 MR. CONTE: We have a Court Reporter here also.
19 Phil, could you introduce yourself?

20 MR. SMITH: Sure. I am Philip Smith, Team
21 Engineer, Engineering Department at GPU Nuclear. I am also
22 Chairman of the BWR Owners Group Emergency Procedures
23 Guideline Committee.

24 MR. CONTE: Thank you, Phil. We are ready to go
25 around the room and get started. I think Mr. Vatter has one



1 of the first questions.

2 MR. VATTER: Phil, one of the problems that we are
3 most interested in is when the operators did not have any
4 indication of control rod position in this event, what could
5 have been the worst reactivity situation that they would
6 have had to deal with --

7 MR. CONTE: Let me interrupt here. I think we need
8 to establish how much Mr. Smith knows about the Nine Mile II
9 event. Phil, how much do you know; could you tell us?

10 MR. SMITH: I talked to several people at Nine
11 Mile about the event. My understanding of it is that it was
12 a loss of power or load reject out in the turbine, and that
13 ended up causing a loss of off-site power and then failure
14 of some transfer switches to go over to DC power or
15 alternate. That resulted in a loss of some amount of
16 control room indication for 20 to 25 minutes.

17 MR. CONTE: Let me see if we can get you up to
18 speed a little more in terms of how the operators were
19 implementing the EOP's. They are using Rev 4 of the Boiler
20 EOP's. Primarily they were in RP -- when the event
21 happened, as you said, there was a loss of power supplies.
22 They lost all indication of rod position; five
23 uninterruptable power supplies went down simultaneously.

24 That resulted in a lot of front panel information
25 lost except for safety grade instrumentation on reactor



1 pressure and reactor vessel level. Post-accident monitors
2 went in the fast -- recorders went into fast speed.
3 Electrical distribution volt meters and amperages, that was
4 still okay because they were apparently independently
5 powered.

6 APRM readings were gotten from the back panel.
7 The recorders for APRM's and IRM's were lost in the front
8 panel. Are you following me so far?

9 MR. SMITH: Sure.

10 MR. CONTE: Once again, rod position indication,
11 there are multiple ways of finding rod position indication.
12 However, the read switches all come off of one power supply;
13 therefore, that essentially disabled one of those five power
14 supplies and others deal with the rod position indication --
15 rod minimizer, rod sequence control -- those are the things
16 that were basically unavailable for rod position indication.

17 When the event happened the preliminary assessment
18 was they had APRM's down scale less than four percent. No
19 rod position. I guess they diagnosed or assessed that they
20 were in a transient on the reactor besides the electrical
21 transient, so they decided to manually scram. The other key
22 thing here that gets you into the EOP's is that feedwater
23 was lost because of that power supply problem, and that
24 created a low level situation and an entry into the RPV
25 control.



1 Are you with me?

2 MR. SMITH: The volume dropped off, and I can
3 hardly hear you at all.

4 [Disconnected.]

5 MR. CONTE: We are going to call you back.

6 [Reconnected.]

7 MR. CONTE: Back on the record. For the record,
8 we had a phone communication problem. We had to switch
9 phones, so we are back on the record.

10 Phil, I was giving you a run down of equipment
11 that was lost. I got to where there was a loss of feedwater
12 and an entry into the RPV control on level. Did you
13 understand everything up to that point?

14 MR. SMITH: I have it.

15 MR. CONTE: One of the key things in the RPV
16 control and the lever leg was the operators were faced with
17 a question, if all control rods are not inserted into at
18 least position 02 and the reactor will not remain shutdown
19 without boron, exit this section and go into C5 which is the
20 contingency on power level control.

21 MR. SMITH: Correct.

22 MR. CONTE: The operator exited and went to C5,
23 primarily on the information of rod position. He didn't
24 have rod position, he didn't know where he was, and he
25 didn't have a reactor analyst to tell him that the reactor



1 will remain shutdown so he went into the ATWS procedure.

2 Setting that stage, I am going to ask Bill Vatter
3 to ask the question again.

4 MR. VATTER: Thank you, Rich. I am sorry. I sort
5 of jumped in the middle of it, Phil. Basically what they
6 had was a scram with loss of feed and they didn't know where
7 the rod position was.

8 We are trying to postulate different ways that a
9 loss of rod position indication could have been a serious
10 problem. One of the ways that we are postulating is that
11 they also had an ATWS combined with loss of rod position
12 indication. If they did have an ATWS it would have had to
13 have been a partial ATWS because they did know the power was
14 down scale on the RPM's. A little bit later they had the
15 IRM's driven in, and they could see that they were going
16 down in there.

17 If some of the rods did not scram what kind of a
18 reactivity situation might have existed such that if they
19 added cold water that they would have had a recriticality
20 and resultant core damage from the recriticality?

21 MR. SMITH: Let me preface answering the question
22 with, it is my understanding that they could determine that
23 the reactor was indeed shut down, and when you get into
24 Contingency 5 procedure the first statement asks whether the
25 operator can determine that reactor power is above or below




1 the down scale trip.

2 Understanding that the front panel indications of
3 reactor power were unavailable, there are alternate means of
4 determining reactor power, one of which is reactor period
5 looking at steam flow, looking at vessel pressure and level
6 trends, perhaps a number of open SRV's. Suppression pool
7 temperature and temperature trends, all indications to the
8 operator of what reactor power is doing and whether or not
9 he is above or below the down scale trip; i.e., does he have
10 the reactor shut down.

11 MR. CONTE: It seems like the exiting to the ATWS
12 procedure is solely dependent on the rod position alone.

13 MR. SMITH: That is very true. When you get into
14 Contingency 5, as I was trying to say, there is criteria for
15 which the operator makes the decision on whether the reactor
16 is making sufficient power and heating the containment.
17 Under these conditions, as I understand them, he was not
18 getting sufficient heat to the suppression pool and he did
19 not have significant power in the reactor.

20 Therefore, he would have controlled water level in
21 the same manner that you would had you had a normal scram.
22 The level power control procedure, it directs the operator
23 to make an assessment whether or not reactor power is above
24 the down scale trip or cannot be determined. In addition to
25 that, he has to have suppression pool temperature above a



1 curve in the EOP's called boron initiation injection
2 temperature which is criteria for shooting boron into the
3 core. Third he has to have an SRV open or drywall pressure
4 above the high drywall pressure scram set point as an
5 indication of the reactor is still at significant power and
6 is rejecting significant amount of heat to the containment.

7 If that is true, then the operator goes through
8 the steps of lowering reactor water level to suppress the
9 reactor power and wait for the boron to shut the reactor
10 down. In this case, I don't believe that he met those entry
11 conditions to lower reactor water level. Therefore, the
12 next step in the Contingency, Step C5-3, directs the
13 operator to maintain water level within the normal band with
14 his normal injection systems.

15 I believe that the operator would have controlled
16 water level within the normal band.

17 MR. VATTER: That is basically what happened,
18 Phil. He had a little problem with condensate booster pumps
19 started injecting when pressure went down. That is the
20 direction that he was going.

21 MR. SMITH: Okay.

22 MR. VATTER: The focus of my question is, the
23 reactor is shut down but we don't know how much it is shut
24 down. There may have been one or more rods that didn't
25 insert or inserted partway, because he hasn't any position




1 indication.

2 What we would like to know is, if there has been
3 any analysis done to determine what might happen if you had
4 a large amount of cold water injected in that circumstance.
5 We are particularly looking at a caution in Niagra Mohawk's
6 procedure that says in the C5 procedure it says: "Caution.
7 Raising injection flow rapidly may induce a large power
8 excursion and result in substantial core damage."

9 He is in the C5 procedure because the entry
10 condition that is spelled out in the RPV control procedure
11 says that if the rods are not all at 02 and the reactor will
12 not remain shut down without boron, he really didn't know
13 either of those things so he went over to C5. That's where
14 he was. He went past that caution that I just reiterated to
15 you.

16 We don't understand the significance of that
17 caution and what it is based on.

18 MR. SMITH: The significance of the caution is
19 based on having the operator aware that because he cannot be
20 certain that the reactor is shut down then care must be
21 taken in establishing injection flow rates into the reactor.
22 The criteria for systems to be used is systems which inject
23 outside of the reactor shroud, understanding that when they
24 inject in the downcomer that the water as it is transported
25 through the recirculation loops mixes with warmer water in



1 the reactor and, therefore, reduces the cold water addition
2 to the reactor core and hence your reactivity addition.

3 He is directed to go to outside the shroud systems
4 first. He would not try inside the shroud systems unless he
5 could not maintain water level with those outside shroud
6 systems. If he decided he needed to go to inside the shroud
7 systems, he is directed to terminate and prevent all
8 injection from inside the shroud systems and to depressurize
9 the reactor, realizing that as pressure drops down you don't
10 want to have the low pressure ECCS systems injecting at an
11 uncontrolled rate because the reactivity excursion could be
12 significant.

13 There is some work that has been done by General
14 Electric, I think, many years ago which suggested that the
15 reactivity addition due to uncontrolled LPCI injection into
16 the reactor core could be in excess of one dollar of
17 reactivity. There is some debate on how much in excess of
18 one dollar it is, but I think it's sufficient to say that if
19 it is in excess of one dollar that's too much.

20 That was the basis for that caution that was in
21 there, to say that be aware operator that if the reactor is
22 not shut down to be careful on the rate at which you
23 increase flow rates into the reactor because of the cold
24 water effect.

25 MR. VATTER: Phil, do you know if there was any



1 analysis for a partial ATWS that shut the plant down but
2 there was a potential for recriticality with perhaps adverse
3 rod configuration that would cause one region of the core to
4 have maybe some fuel damage. Was there any work on partial
5 ATWS and trying to figure out what the worst case might be?

6 MR. SMITH: I don't recall that there was any
7 specific work on partial ATWS. I know that they looked at
8 all rods out condition. In fact, I think you would agree
9 that the worst case for reactivity addition would be if the
10 reactor was several decades below the heating range when you
11 injected the cold water, because the power and reactivity
12 addition rate and -- power would continue to increase on
13 almost an exponential basis until either Doppler or voids
14 turned it around.

15 I think you would agree that that would be the
16 worst case in terms of depositing energy to the fuel.

17 MR. VATTER: Right. What we would like to know is
18 if anybody has tried to quantify how bad that worst case is?

19 MR. SMITH: As I said, I have seen numbers that
20 have ranged upwards from one dollar up to eight or nine
21 dollars worth of reactivity. I don't know that people have
22 gone and connected the reactivity addition with what sort of
23 fuel damage or fracture or cladding perforations you may
24 expect because of that.

25 MR. VATTER: I think eight or nine dollars worth



1 of reactivity will be a big deal.

2 MR. SMITH: It will certainly get your attention,
3 yes. Understand that the way Contingency 5 is structured
4 that first making the operator aware that uncontrolled or
5 rapidly increasing injection into the reactor core can
6 result in these conditions; that he is sensitized to that,
7 and that he would use systems which inject outside the
8 shroud first to minimize the effect of reactivity addition
9 on to the core.

10 MR. VATTER: I understand that. Of course, the
11 normal feedwater system is outside the shroud.

12 MR. SMITH: True.

13 MR. VATTER: In this event they had an unexpected
14 injection from the condensate booster pumps. The pressure
15 drifted down fairly slowly, and the condensate booster pumps
16 caught them unaware. It put in a large amount of water and
17 they went off scale high. We don't think that they put
18 water in the steam lines, but they got close.

19 MR. CONTE: I would like to emphasize that this
20 was not an ATWS also.

21 MR. SMITH: True.

22 MR. VATTER: Right. All the rods were in, but if
23 all the rods were not all in -- if they were in that sort of
24 an undesirable configuration that we were talking about
25 which, apparently there has not been any analysis done, what



1 do you think might be the worst case reactivity
2 recriticality kind of an event from just condensate booster
3 pumps shooting in water?

4 MR. KAUFFMAN: As an aside here, the feedwater reg
5 valves failed in their 100 percent open position, so they
6 were wide open.

7 MR. SMITH: Again, I can tell you where I would
8 expect reactor power to end up. If reactor water level is
9 up into the normal range or slightly above the normal range,
10 if the rods were completely withdrawn or were significantly
11 out, you might expect to have a steady state power in the
12 range of 40 to 60 percent power.

13 Certainly, the rate at which the condensate
14 booster pumps would slug the water in there and whether or
15 not there was any feedwater heating left would certainly
16 affect the peak power before it steadied out in around the
17 40 to 60 percent range.

18 MR. VATTER: Of course, we started now from below
19 the heating range. The operator knows that reactor is
20 subcritical, he has no APRM indication, but it might be only
21 slightly subcritical.

22 MR. SMITH: I would be hesitant to quote you a
23 number of what the spike could be, because there are just
24 several fairly important variables that would influence how
25 high the peak would be. Certainly, it could twice or three



1 times the average power. Anything above that, I would be
2 hesitant to kind of offer an opinion on.

3 MR. VATTER: I guess one scenario that has been
4 going through our minds is that several rods in a very bad
5 configuration failed to scram but the reactor is
6 subcritical. Then, this power drifts down below the heating
7 range a few decades, and the condensate booster pump
8 injection causes a recriticality with a power peak in that
9 area of the core where the rods didn't scram; and that,
10 maybe the core gets hurt from all of that.

11 Is that a potential concern do you think, or do
12 you think it couldn't happen?

13 MR. SMITH: I would say it wouldn't be a very
14 large concern. Understanding the mixing of the condensate
15 booster pump water with the rest of the water in the
16 reactor, understanding how it would mix as it came through
17 the diffusers from the recirc loops back into the lower
18 plenum of the reactor vessel, and it would kind of
19 homogenize out. I think you need to look at some relative
20 flow rates of the water in the reactor vessel, the
21 circulation flow, versus what you are going to inject from
22 the condensate booster pumps.

23 I would think that the cold water effect would
24 have been reduced significantly by the mixing. Certainly, a
25 way to tell that is to look at recirc loop temperature and



1 to see how far that fell off during the condensate booster
2 pump injection. That would give you a feel for what the
3 temperature of the water was that was going into the core.

4 MR. VATTER: That's a good thought, although we
5 won't get much out of that, Phil. The process computer went
6 down with the event and none of that data is available.

7 MR. CONTE: Phil, how do you expect operators to
8 implement this caution?

9 MR. SMITH: That caution?

10 MR. CONTE: Yes, practically speaking.

11 MR. SMITH: I would expect the operator to
12 understand that injection of the water can have a
13 detrimental effect on his ability to control reactor water
14 level and power. I would expect that in trying to control
15 reactor water level where this caution does appear, that he
16 would be careful in terms of how much he opened up for
17 example the feedwater regulating valves or whatever
18 injection valve on the system he was using and would not
19 just try and open the valve to full position immediately.

20 The EPG's do provide him a fairly wide level
21 control band for this action. It does not necessitate that
22 he take rapid and potentially too rapid operator action
23 which could result in the high reactivity addition rate.

24 MR. CONTE: What I think I am hearing you say is
25 an operator tweaks on whatever controller he has and looks



1 for a level response, it doesn't get a level response and
2 tweaks a little more. Once he gets a level response, he
3 kind of holds it there and makes sure the level is slowly
4 coming up. You really can't put a GPM number on this; is
5 that correct?

6 MR. SMITH: You surely can't, because the state of
7 being in this contingency procedure is that you are unsure
8 first whether the reactor is shut down or what the rod
9 configuration is. Certainly, you just wouldn't want to
10 arbitrarily establish a flow number because it would work
11 for several cases but not for all. It could be that for one
12 of the cases for which it did not work would be the one
13 where that could give you some reactivity addition.

14 As you said, I believe he would look at level
15 response. He would also look at power response if he had
16 power indication available. By tweaking the controller and
17 little bit and saw a little bit of level response and didn't
18 see too much on the power, that may give him an indication
19 that he can tweak it a little bit more until he starts
20 seeing power come up with that.

21 That is my opinion on how the operator would
22 implement that caution.

23 MR. CONTE: Okay. I had another question -- I
24 have two more questions. Let's back up when he exits the RP
25 level control, he exits the C5. What do you think about



1 that situation? Basically rod position, you may or may not
2 know this, but the rod position indication is not considered
3 safety grade. The power supplies for this event were not
4 safety grade.

5 What do you think about the situation where there
6 was no ATWS and the operator was forced into being fooled
7 that he had an ATWS; what do you think about that?

8 MR. SMITH: I would not characterize it that he
9 was fooled into thinking he had an ATWS. I would
10 characterize it as he could not confirm the reactor was shut
11 down. If he could not confirm that, I believe that it is
12 prudent to take actions and precautions that would be
13 sensitive to the fact that the reactor may not be shut down
14 rather than trying to make a determination initially that
15 the reactor is shut down and that a normal reactor level
16 control kind of initiating injection without regard to
17 whether it is inside the shroud or outside shroud, or
18 without regard to the rate of flow increase.

19 I think it is very appropriate that if the
20 operator cannot determine that the reactor is shut down,
21 that he should take precautions and assume that it is not.
22 Understand in this condition that because I believe that the
23 operator could make a determination that really the APRM's
24 were probably down scale and that he was not heating the
25 containment, his actions in terms of controlling reactor



1 water level would not be different than what he would do for
2 normal scram with the exception of this precaution on how
3 fast to increase the flow rate.

4 He is not really doing anything different than he
5 would if he had known that all the rods went in and he was
6 recovering from the scram.


7 MR. CONTE: What I am hearing is that you are
8 supporting the operator actions to enter C5?

9 MR. SMITH: Absolutely.

10 MR. CONTE: You mentioned something earlier, that
11 it is appropriate to go into C5 because it gets the operator
12 to take a look at the situation in the containment and the
13 situation with respect to reactor power. I realize and I
14 wanted to emphasize this point, you are probably talking
15 from your knowledge of the Rev 4 emergency procedure
16 guidelines that are generically applied and we are talking
17 from the Nine Mile II specific procedures.

18 In the C5 for Nine Mile II, you really don't see -
19 - there is an ongoing statement here that says are rods
20 inserted to position two or the reactor will shut down under
21 all conditions without boron, exit this procedure and enter
22 RPV control RL section.

23 I really don't see the flavor of what you are
24 talking about in these procedures about the analysis on the
25 reactor being shut down or making a determination if reactor



1 is shut down. Let me add here, because you don't have these
2 procedures in front of you, there is another ongoing step
3 that is combined with a number of other conditions with
4 respect to the suppression pool and the SRV's opening.

5 It says if reactor power is above four percent or
6 cannot be determined, then continue at another point which
7 is looking at main steam lines and another leg of the C5
8 situation. Let me add another piece of information. The
9 licensee has given instructions to the operator that a shut
10 down reactor is less than range six and seven on the IRM's.

11 MR. KAUFFMAN: And, subcritical.

12 MR. CONTE: And, subcritical. What do you think?
13 I have said a mouth full here. Can you comment?

14 MR. SMITH: Sure. I have an opinion on most any
15 subject you want to bring up.

16 MR. CONTE: Go ahead.

17 MR. SMITH: First of all, the steps that you just
18 quoted, reactor power is above the four percent number.
19 There should be a subsequent -- two other subsequent
20 conditions on suppression pool temperature and SRV open.

21 MR. CONTE: There is.

22 MR. SMITH: That is the criteria for the operator
23 to lower reactor water level. Those three criteria in step
24 C5-2, at least in the generic guidelines, are indicative of
25 the reactor is at significant power; it is not shut down;



1 and, significant heat is being rejected in the containment.


2 That is where the operator makes the determination
3 of whether or not he wants a lower level. What I have
4 spoken to earlier about alternate ways to determine reactor
5 power given that the APRM's were not working that day that,
6 I am getting out of what is called Appendix B to the
7 emergency procedure guidelines which is the technical basis
8 document, which goes through each one of the steps within
9 the emergency procedure guidelines and describes the basis
10 for them.

11 This is guidance that is in the technical basis
12 report in terms of how he would determine reactor power.

13 MR. CONTE: This is for the Rev 4 of the EPG's.

14 MR. SMITH: Yes. The intent of how this technical
15 basis document is to be used was to provide this to the
16 procedure writer and the training people in order to use
17 this an ensure that all the thoughts that were made in
18 developing the emergency procedure guidelines are somehow
19 incorporated into the training program to at least allow the
20 operator to get the wisdom or the knowledge that we use to
21 try to come up with these.

22 I can't comment on whether Nine Mile has
23 incorporated that into their training program, but that
24 information is available as part of the generic procedure
25 guidelines to be incorporated into the training program. I



1 think that answers the first part.

2 MR. CONTE: Should rod position indication be
3 safety grade?

4 MR. SMITH: I wouldn't touch that thing with a ten
5 foot pole.

6 MR. CONTE: That's an honest answer. We can
7 appreciate that. Say that again, about your plant?

8 MR. SMITH: I might end up having to implement
9 that commitment at my plant, and my management would not be
10 too pleased if they saw this in print.

11 MR. CONTE: Thank you.

12 MR. JORDAN: I have one question. I think you
13 mentioned the fact that Appendix B gives a criteria. Can
14 you give us what you know as far as when it says the reactor
15 will not remain shut down without boron. Can you give me an
16 idea of what guidelines you expect the utility to give to
17 the operators on what that means and how he can or cannot
18 determine that?

19 MR. SMITH: I really think that determination of
20 condition that reactor will maintain -- will be shut down
21 under all conditions without boron is not a decision that
22 the operator really probably has the indication or perhaps
23 the knowledge to make on the fly.

24 I believe that the intent of that step was to have
25 the operator consult the reactor engineer and the reactor



1 engineer, based on his training and his understanding of the
2 core configuration or rod configuration, would make a
3 determination that the reactor could be cooled down even
4 though all the rods were not fully inserted.

5 The example that I would offer would be if one rod
6 was notched out several notches in two quadrants -- the rods
7 were notched adjacent to each other by one rod out and the
8 northwest quadrant of one out in the southeast quadrant -- I
9 think after looking at that, that the reactor engineer would
10 have a fair confidence that the reactor is not going to go
11 critical again during a cool down.

12 The intent was to not leave the operator in the
13 Contingency 5 level power control procedure if the reactor
14 engineer could make that determination that the reactor will
15 be shut down. The condition was superimposed of not having
16 any boron in the reactor to assure that if there was any
17 boron washout that the reactor would not return to power. I
18 hope that answered your question.

19 MR. JORDAN: You did. Thank you, Phil.

20 MR. CONTE: I think I will get complicated on you
21 again here, Phil. In looking at the actual situation that
22 the operators had with the low power, they were trying to
23 implement these EOP's. On the one section on level control
24 they were in the C5 and were very much aware of a stop
25 statement or wait statement before exiting C5 in order to



1 get out and back into RL leg of the RPV control.

2 The wait statement says that all rods are inserted
3 to at least position 02 or the reactor will remain shut down
4 without boron. I think you explained that. Once again,
5 they didn't have the rod position indication and they didn't
6 have an analyst telling them that the reactor will remain
7 shut down, so they were on hold at that point.

8 They didn't have feed and condensate but at least
9 feed and condensate was kind of behind the stops because
10 pressure was high. Then, there's another wait statement on
11 the RP leg of RPV control which has four conditions. Two of
12 them are duplicative of the two that I just mentioned, in
13 order to exit C5 and then it adds another or. If boron is
14 being injected SLC tank drops to 900 gallons or, the reactor
15 was shut down and boron has been injected.

16 This stop sign appears right after the stabilize
17 reactor pressure. It is apparently a go for cool down.

18 MR. SMITH: Yes.

19 MR. CONTE: What we get out of it is that it's an
20 analysis that permits you to cool down to assure that you
21 won't go critical again. However, if it gives you the go
22 ahead there is an ongoing statement that says the reactor is
23 not shut down return to B, which takes you back up to
24 stabilize pressure.

25 MR. SMITH: Correct.



1 MR. CONTE: The operators were trying to --
2 because they were using RCIC, RCIC was bringing them down.
3 There was no ATWS, it was a very low heat load and RCIC was
4 able to handle it. They were initially confused. They
5 eventually figured out that all I need my go ahead here is
6 the reactor is shut down -- they were below the range six
7 and seven on the IRM's. They had SRM indication, so they
8 made the go ahead.

9 Those two legs appear to be in conflict with one
10 another, appear to be. Do you have an opinion on that?

11 MR. SMITH: Sure. I don't think they are. The
12 criteria in vessel pressure control, at least in the
13 guidelines set that I am looking at here is RC/P-3, which
14 specifies when either -- all the rods are inserted to
15 position 02 or you know that the reactor will maintain, will
16 be shut down under all conditions without boron, or you have
17 injected the cold shut down boron wait which is your 900
18 gallon number. That assures that the reactor will be shut
19 down under cold conditions with no voids, no xenon. There
20 are a number of functions that go into calculation of that
21 weight.

22 The last one is the reactor is shut down now but I
23 haven't injected boron and I don't have a confidence that
24 the reactor will be shut down as I cool down. Understand if
25 the operator is trying to use that last bullet as the



1 criteria for cooling down, he should also be in Contingency
2 5 which gives him all the guidance on be careful how fast
3 you inject into the reactor and be careful where that
4 injection source is, either inside the shroud or outside the
5 shroud.

6 He is conscious of that, and as he begins his cool
7 down at less than 100 degrees per hour, he still has
8 conditional statement which applies that if, while you are
9 cooling down the reactor is not shut down and begins to
10 return to power then stop the cool down and stabilize
11 pressure again and take a look again at the conditions which
12 would allow you to cool down again.

13 I really don't think they are in conflict. In
14 fact, I think they work well together in terms of allowing
15 the operator to depressurize if he needs to. An example of
16 where he would is if he had this event plus he had a leak.
17 Certainly, there is impetus if you have a leak to
18 depressurize the reactor to reduce the rate at which you are
19 losing inventory, even though the reactor may not be shut
20 down and there's a possibility that as you depressurize and
21 get low in pressure the reactor may start to return to
22 power.

23 You are counting on the operator in Contingency 5
24 being conscious of the rate at which injection should be put
25 into the reactor to assure that he doesn't have an excessive



1 reactivity spike.

2 MR. CONTE: I am not going to repeat everything
3 you have said, but I think the message you are sending us is
4 that the last condition the reactor is shut down and no
5 boron has been injected is to combat another situation where
6 you do have a leak, you want to stop the leak, and there is
7 impetus to get depressurized; is that correct?

8 MR. SMITH: That is the first. It also gives the
9 operator the flexibility that if he can determine shut down
10 now while he is waiting for his reactor engineer to
11 determine that it will be shut down forever with the rod
12 configuration he has, he is allowed to start his cool down.
13 If it takes 20, 30 minutes or an hour for the reactor
14 engineer to make that determination at least the operator
15 has been given some guidance on permitting himself to cool
16 down to get the reactor pressure vessel into a lower energy
17 state, both for the leak concerns and in general cooling the
18 reactor down.

19 I believe that the conditional statement which
20 applies to terminating the cool down if the reactor -- if it
21 is determined that the reactor cannot be assured to be shut
22 down, covers the case where the reactor may return to
23 criticality during depressurization.

24 MR. KAUFFMAN: Phil, that covers the part of the
25 event to where in Nine Mile's definitions they had not



1 determined that they were shut down until they had looked at
2 the IRM's or source range monitors. Initially in this
3 event, they couldn't say yes we were shut down, we were
4 allowed to depressurized.

5 At that point they were at a point where, if they
6 ran RCIC they would depressurize. Yet, they had a step that
7 said stabilize pressure. I guess what I am trying to
8 understand is, what does the stabilize term mean and how do
9 you expect them to implement the level and pressure before
10 they can say yes we are shut down and it's okay to cool
11 down?

12 MR. SMITH: The stabilize step is intended that
13 the operator stops a trend of increasing or decreasing
14 pressure. The stabilization of the pressure, if the reactor
15 is not shut down, it is important to stabilizing reactor
16 water level and is important to stabilizing reactor power.
17 Without having stabilized the pressure it would be difficult
18 for the operator to control the other two parameters if the
19 reactor was indeed not shut down.

20 Let's see if there is a definition for stabilize.
21 What the operator is supposed to do -- I would interpret
22 that the operator should have tried to control pressure
23 within a certain band, and as part of implementation of the
24 emergency procedure guidelines different plants have chosen
25 a band for what constitutes stabilize. Maybe it's within



1 100 pounds, 150 pounds of the high pressure scram setpoint.

2 That is the band that the operator is given to try
3 and control the pressure within until he comes to the next
4 step in trying to make the determination on whether the
5 reactor is shut down enough for him to depressurize the
6 reactor vessel. Concurrent with this, he should be in
7 Contingency 5, trying to control water level within the
8 normal band, understanding the caution about increasing flow
9 too much.

10 I am not sure that I have answered your question
11 real clean.

12 MR. KAUFFMAN: I am going to continue on here. I
13 am the operator, I am running RCIC, and I see that I am
14 depressurizing --

15 MR. CONTE: My level is high.

16 MR. KAUFFMAN: My level is high. I guess I am
17 trying to visualize if I am an operator what options I have
18 in front of me. One is, I have a very wide level band. I
19 can turn off RCIC, watch level, coast down, and repressurize
20 and attempt to stabilize pressure that way. I can run RCIC
21 and maybe, since I have some steam loads, I can secure my
22 auxillary steam loads. That may have some negative effect
23 later of maintaining condenser available -- it's nice to
24 have -- steam seals, air ejectors, that sort of thing.

25 What I might be really concerned about this de-



1 stabilization and say I am going to shut my MSIV's and turn
2 off RCIC and control pressure with my SRV's. In the back of
3 my mind I know that gets me closer to SLC injection.

4 I guess what I am trying to say is, are these
5 reasonable thoughts for him to go through? Is it reasonable
6 to make this guy have to pick between these different
7 options? How would you expect people to respond to this
8 situation?

9 MR. SMITH: Understand first, I don't have a
10 reactor operator license. So, I am speaking based on my
11 knowledge of the emergency procedure guidelines. If RCIC
12 was the system that I had available and RCIC by itself was
13 depressurizing me, that would make me a little more
14 confident that the reactor was probably shut down.
15 Understanding how much steam RCIC happens to draw off of the
16 reactor vessel and what it would inject, that it doesn't
17 match decay heat for a while after shutdown, at least on
18 some representative BWR 4's or 3's.

19 I don't believe that he would go and try and
20 isolate the main condenser to try and stabilize pressure.
21 As I said, the level control guidance gives him a fairly
22 wide band in order to control water level within. I would
23 say that he would use RCIC as necessary to stay within that
24 band, also trying to keep reactor vessel pressure as stable
25 as he could. If there were not a lot of other steam loads



1 that were sucking reactor level pressure down, he would
2 probably be in pretty good shape.

3 If these auxillary steam loads were sucking vessel
4 pressure down that, to me, would be more of an indication
5 that the reactor really was not at power. I think I have
6 done this in a roundabout way for you.

7 MR. CONTE: Let me rephrase that question here.
8 The stabilize steps says -- the EOP's say stabilize RPV
9 pressure below 1070 psig using the main turbine bypass
10 valves of the RPV pressure control with the systems listed
11 below if necessary.

12 You almost get the impression that this step is
13 written on a high pressure situation and not a low pressure
14 situation.

15 MR. SMITH: Certainly, the high pressure situation
16 does represent more of a challenge to the integrity of the
17 reactor vessel. The stabilize step was there primarily to
18 have the operator prevent SRV cycling that may be impacting
19 his control of the other parameters.

20 I am trying to find in the generic technical basis
21 where it talks about the stabilize step. Bear with me for a
22 moment here, because my fingers aren't working very well
23 turning the pages. The generic technical basis does
24 describe that there is no low end of the pressure control
25 range; that thereby permits vessel pressure to be reduced to



1 below the shut of head of low pressure systems if injection
2 from these systems is necessary to establish and maintain
3 adequate core cooling.

4 Primarily, it is concerned with the high pressure
5 end and the top end of that -- I think you quoted 1070
6 pounds -- is likely to be the high vessel pressure scram
7 setpoint. You want to stay below that setpoint to assure
8 that if the reactor was indeed not shut down that you would
9 be allowed to reset the scram and potentially drive rods
10 again.

11 MR. CONTE: Thank you. Are there any other
12 questions?

13 MR. KAUFFMAN: I had a question back to when the
14 reactor is depressurizing and you talked about it would be
15 reasonable for him to have control of his level valves and
16 slowly put water in.

17 I guess the background on this event is that his
18 feedwater reg valves were filled full up. In this event, to
19 some extent the operator, if he was going to prevent that
20 uncontrolled injection it would have to anticipate the
21 booster pump injection. Your first answer indicated that
22 that really wouldn't be where his thoughts were or how this
23 was intended to be implemented.

24 I guess I am saying I thought the operator should
25 have anticipated booster pump injection and had the pumps



1 turned off or the valves shut. I guess what I am asking is,
2 are my expectations too high? Do you think I am wrong?

3 MR. SMITH: Certainly, condensate and feedwater is
4 one of the systems he would be using to maintain reactor
5 water level and Contingency 5. In fact, that would probably
6 be probably his first choice of systems to use. Whether or
7 not he should have been conscious that the reg valves had
8 failed in their full open position or he had indication that
9 the valves were in their full open position, is something I
10 don't know.

11 I think that if you were going to error and permit
12 an injection from a system, condensate booster pumps would
13 probably be the one I would pick to error on, understanding
14 the mixing that happens before the water gets to the bottom
15 of the core.

16 Perhaps in hindsight, that he should have made
17 some efforts to try and close the parallel valve -- not the
18 parallel valve but feed reg valves -- perhaps. Certainly, I
19 think he was awful busy at that time and he had to take some
20 priorities on what actions he was going to take.
21 Understanding that the transient seemed to turn out okay, I
22 would say he probably chose the right things.

23 MR. KAUFFMAN: I guess it is going to get back to
24 the importance of that caution in that, that caution sounds
25 like there are pretty dire consequences if this injection



1 occurs. I guess the question I have is, if he is busy doing
2 other things, should he be looking real closely at his EOP's
3 or should he be running around and doing other things.

4 MR. SMITH: I think that if he is in Contingency
5 5, my opinion is that he ought to be more conscious of
6 controlling the injection into the vessel and controlling
7 the vessel parameters, understanding that lack of control of
8 these parameters has certainly a much greater impact if the
9 reactor is truly not shut down.

10 Perhaps from that standpoint he should have --
11 perhaps he should have taken more action to assure that the
12 condensate booster pumps did not inject uncontrolled.

13 MR. CONTE: That's all we have for questions. We
14 have some closing comments for you, Phil. Mike Jordan.

15 MR. JORDAN: Phil, I just want to thank you for
16 your assistance in helping us clarify some points on the
17 EOP's. We would ask also that you not relate your concerns
18 that we have addressed here to anybody outside of yourself
19 because, until we have come up with our final conclusion on
20 our report -- until our report is issued. A lot of these
21 are just concerns that we have that may or may not appear
22 anyplace else.

23 MR. SMITH: I understand that, and I will abide by
24 that.

25 MR. JORDAN: Do we have your address?



1 MR. SMITH: It's GPU Nuclear Corporation, 1 Upper
2 Pond Road, Parsippany, New Jersey 07054.

3 MR. JORDAN: We will see if we can get a copy of
4 this transcript mailed to you. We ask that you not copy it.
5 If you want a copy of the transcript we will be glad to send
6 that to you after we issue our report, when it becomes a
7 public document. If you wish to request a copy of it when
8 you send your transcript back, annotate that you want a copy
9 of the transcript.

10 MR. SMITH: That would be fine.

11 MR. CONTE: I have two more comments -- one is a
12 question. When we were talking about this study -- in
13 review of my notes here and the thought just came to me --
14 when we were talking about this study with the LPCI
15 injection and so many dollars of reactivity, this seems to
16 be a beyond design basis event.

17 Why did General Electric do this study? Was it in
18 response to a staff concern, was it their own volition or
19 what?

20 MR. SMITH: This was in response to questions from
21 the Emergency Procedures Committee as we were developing
22 Contingency 5 as to whether there was a real downside to
23 distinguishing between inside the shroud and outside the
24 shroud systems, and whether there was a need for the
25 operator to have some additional guidance or precaution in



1 terms of how fast he would inject water into the reactor.

2 Understand that that analysis or evaluation, from
3 what I remember of it -- since it was probably 1981 or 1982
4 timeframe -- I believe was looking at a complete injection
5 of LPCI into an unrodded core. The water basically
6 accumulated in the upper plenum above the core and then fell
7 into it almost as a slug. That's where the reactivity
8 excursion came from.

9 MR. CONTE: One more question before we go off the
10 record. I am going to ask you to stay on the line after we
11 go off the record because the Court Reporter may have some
12 questions for you on some terminology that you used. One
13 more question.

14 Have we asked the right questions? Do you have
15 anything to offer or would you like to clarify anything that
16 you have made statements on about the topics this morning?

17 MR. SMITH: Maybe a quick summary of points. I
18 believe the operator was correct in entering the Contingency
19 5 procedure based on not being inserted and the reactor was
20 shut down. It would appear that he made that determination
21 and correctly left that procedure that the reactor was shut
22 down. I guess those are the only summary of what I have of
23 it.

24 MR. CONTE: I guess the other main point that you
25 made based on the situations that we gave you was that these

...



1 legs are all consistent with one another.

2 MR. SMITH: Yes, that is true. I believe that
3 they are. I believe that the Procedures Committee has taken
4 significant efforts to assure that they are consistent with
5 each other.

6 MR. JORDAN: Phil, the document that you mentioned
7 about the calculation of the cold water injection, is that
8 GE's?

9 MR. SMITH: That is General Electric's. I believe
10 that it is probably GE proprietary. It is not a document
11 that I have ever seen physically -- physically seen. I have
12 no knowledge in what state of documentation it is, whether
13 it is a formalized calculation that General Electric did,
14 whether it is just some analysis that one of the engineer's
15 happened to run. I don't know in what condition it is.

16 As I said, I have never physically seen it.

17 MR. CONTE: Okay, we are going to go off the
18 record and ask you to stay on.

19 [Whereupon, at 11:09 a.m., the meeting concluded.]
20
21
22
23
24
25



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: Philip Smith

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Official Reporter
Ann Riley & Associates, Ltd.

