

ORIGINAL

07-114A-91

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Incident Investigation Team

Title: Nine Mile Point Nuclear Power Plant  
Interview of: MIKE CONWAY

Docket No.

LOCATION: Scriba, New York

DATE: August 17, 1991

PAGES: 1 - 77

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950.

93 05/10/83

9305100183 911031  
PDR ADOCK 05000410  
S PDR

1000


25



ADDENDUM TO INTERVIEW OF MICHAEL S. CONWAY STAT. SHIRT SEWER  
(Name/Position)

Page	Line	Correction and Reason for Correction
6	11	EPR TO APRM : TERMINOLOGY CORRECTED
7	6	EPRM TO APRM : " "
10	21	STRIKE / REMOVE THE "I" : NOT RELEVANT & MAKES NO SENSE
12	1	CHANGE FLAT TO BLACK IE: NO POWER AVAILABLE/INDICATED
15	8	ADD 'IN' FOLLOWING FILTER : TO MAKE MORE SENSE
16	3	RCE TO RCIC : CORRECT TERMINOLOGY
16	13	RCE TO RCIC AND THAT IS "WAS" RUNNING, NOT WASN'T
17	2	CHANGE LB-10'S TO LV-10'S : TO CORRECT TERMINOLOGY
18	9	202.3 FROM 2023 : WHICH IS ASHLEB
20	7	SHIBS TO SEAL : CORRECT TERMINOLOGY
20	21	MIBANS TO MAINTENANCE : CONTEXT REFERENCE
21	19	RAD TO ROD : CORRECT TERMINOLOGY
22	11	PURRING TO PURSUING : TYP
23	6	QUOTE : UNCERTAIN WHY THIS IS IN THIS LINE
24	13	ARCH OR T RIR : CORRECT TERMINOLOGY
26	8	INC TO IAC : CORRECT TERMINOLOGY
26	12	INC TO IAC : " " " "
26	17	RAD WATH TO ROD WORTH : CORRECT TERMINOLOGY
27	15	RAD TO ROD : CORRECT TERMINOLOGY
28	14	RPS TO RPV & OP TO EOP : TERMINOLOGY CORRECTED
28	15	WOIGHT TO WAIT : PROP. TERMINOLOGY
31	8	RNC TO IAC : PROP. TERMINOLOGY
31	17	RFS TO RPS : " "
32	6	RFS TO RPS : " "
33	1	PLANNA TO POINTS : CONTEXT REFERENCE
36	14	S ET AL. TO S @ ALL : PROP. TERMINOLOGY
36	19	AT COI TO COOL : " " " "
44	25	PRNTALS TO PRNIT : CONTEXT REFERENCE
45	17	FINIX TO FANS : CONTEXT REFERENCE
46	7	EPRMS TO APRMS : PROP. TERMINOLOGY
46	23	" " " " " "
52	2	AND I HAD TO AND ARI HAD COMB IN : CONTEXT REFERENCE

Page 1 of 2 Signature *Michael S. Conway* Date 10/2/91





ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
55	15	MAD TO MANNED : CONTEXT RESTORED
59	15	MODERATOR TO MONITORER : CONTEXT RESTORED
59	16	NON-LOP TO NON-LOT : CORRECT TERMINOLOGY
61	2	HILLIKER TO HILLER : CORRECT NAME
63	19	ADD "POWERED FROM" : <del>ADD</del> <sup>ADD</sup> CONTEXT REFERENCE
73	8	MIGHT TO RISK : CONTEXT RESTORED
74	21	ALL ROBS IN TO ALL ROBS NOT IN : CORRECT PROCEDURE REFER
75	1	DOWN TO DOWN : CONTEXT
75	8	RPB TO RPV : PROPER TERMINOLOGY

Date 10-7-91

Signature





UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

-----  
Interview of :  
MIKE CONWAY :  
(Closed) :  
-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Saturday, August 17, 1991

The interview commenced, pursuant to notice,  
at 12:12 p.m.

PRESENT FOR THE IIT:  
John Kauffman, NRC  
Mike Jordan, NRC

1975

1.00

1.00





## P R O C E E D I N G S

[12:12 p.m.]

1  
2  
3 MR. KAUFFMAN: Today's date is August 17, 1991.  
4 We're in the P building at Niagara Mohawk power unit number  
5 2. My name is John Kauffman. I'll be leading the  
6 interview. I'm with NRC/AEOD.

7 MR. JORDAN: I'm Mike Jordan. I'm with the NRC,  
8 out of Region III. I'm a section chief.

9 MR. CONWAY: And I'm Mike Conway. I work for  
10 Niagara Mohawk. I'm a station shift supervisor.

11 MR. KAUFFMAN: Great. Now that we have the  
12 preliminaries out of the way, I'd just like to have Mike  
13 start off and tell us a little bit about his previous work  
14 history, background, education, number of years on the job,  
15 et cetera.

16 MR. CONWAY: Okay. Prior to working for Niagara  
17 Mohawk, I graduated from high school; I never went to  
18 college; I joined the Navy and became a Navy nuke. I spent  
19 six years in there, aboard submarines out of Charleston,  
20 South Carolina. Then I got hired by Niagara Mohawk.

21 When I first came to work here, I got hired as an  
22 auxiliary operator at Unit One. I was sent to license class  
23 and received a hot license, reactor operator, at Unit One,  
24 at which time there were several of us that did that, and  
25 then we were sent to Unit Two, which was in the construction

4

5



1 phase.

2 MR. KAUFFMAN: What year was it you were hired on  
3 as an aux operator?

4 MR. CONWAY: November, 1982.

5 MR. KAUFFMAN: When did you get your license?

6 MR. CONWAY: The first license -- I want to say  
7 that was February -- around that time -- early '84.


8 MR. KAUFFMAN: And then you stood shift --

9 MR. CONWAY: I didn't have any operating time.  
10 Basically, I believe, the company's philosophy at that time  
11 was to obtain a hot license on Unit One and then start  
12 learning Unit Two, which was in construction, because we had  
13 to obtain cold licenses, and they felt that that would give  
14 us a good basis and background for a cold license on Unit  
15 Two. It worked pretty well. I successfully passed a Unit  
16 Two cold license reactor operator exam.

17 MR. KAUFFMAN: When was that? Do you know? A  
18 long time ago?

19 MR. CONWAY: I don't remember the specific dates  
20 here, or time. That's on record someplace. I'm sure you  
21 can obtain that information.

22 I spent at least five years as a reactor operator  
23 at Unit Two, control room operator, plant operator. The way  
24 we work our shift program is, we rotate in plant and in  
25 control room for responsibilities.



1           Then, a year and a half ago, I was sent to senior  
2 reactor operator class, and last August I passed the exam.  
3 Prior to that, I was in the union. Once they send you to  
4 class and you get your SRO, they offer you a management  
5 position, and I was offered a station shift supervisor job  
6 and accepted and started December 1 of last year.

7           MR. KAUFFMAN: In the Navy, you were --

8           MR. CONWAY: Machinist's mate.

9           MR. KAUFFMAN: I'm just trying to establish  
10 background.

11           I guess the next thing we'd like to talk about is  
12 the August 13 event that you were station shift supervisor  
13 for, the plant conditions prior to the event and then what  
14 you saw and what you did.


15           MR. CONWAY: Okay. We were just finishing up a  
16 midnight shift. It was approximately 10 of 6 in the  
17 morning, and we had 100 percent power, preparing our shift  
18 turnovers. The work was done for that shift.

19           MR. KAUFFMAN: Can I interrupt?

20           MR. CONWAY: Sure.

21           MR. KAUFFMAN: One thing I haven't heard from  
22 anybody is the power history, how long the plant had been up  
23 and operating before this.

24           MR. CONWAY: It's funny you should say that, and  
25 it's one of those things we knock on wood when we say; we




1 kind of keep track of how long we've been on the grid and  
2 stuff like that. It had been about 121 days we had been  
3 operating, and of course, I knocked on wood after I said,  
4 Yes, 121st day, on the shift brief and stuff like that.

5           We were doing our turnovers, and I think Mike  
6 Eron, my assistant, was reviewing the shift checks. Most of  
7 the plant operators were getting ready for their turnovers.  
8 I was at my desk in the control room, and we heard a pop,  
9 kind of a popping sound. When I looked up from preparing my  
10 turnover, I noticed all the annunciators in the control room  
11 were out. They were not lit, any of the ones that were  
12 previously lit.

13           An eerie silence type thing. Normally you hear  
14 typers printing or the hum of fans blowing, power supplies,  
15 that type of thing. Everything went quiet. Of course, I  
16 ran out of the office and asked what happened, what's going  
17 on. It looked to me like some sort of a power failure. It  
18 was very hard to tell immediately. Obviously, when you  
19 lose all the annunciators, that's related to a power supply  
20 problem.

21           We immediately checked what power level and  
22 pressure were on the 603 panel, and the records had all  
23 stopped, and indicators had failed either up-scale or down-  
24 scale, some of them as-is.

25           One of the odd things about it was that the






1 instrumentation seemed to be not functioning, and the alarms  
2 didn't function at all, and all the computer CRTs went  
3 black, but we still had indications for all motors, the red-  
4 green lights, for valve positions, red-green lights -- we  
5 still had all those type of indications still available.  
6 Over on the electric plant boards, we still had a meter  
7 indication available for all power, for all our electric  
8 supplies to the different switch gears and stuff.

9           When I got the report that, we can't tell what  
10 power is because chart recorders had stopped, I yelled out,  
11 Somebody check the EPR meters in the back. I believe it was  
12 Mike Eron that went to the back, he and another operator --  
13 I'm not sure which one; I want to say Dave Hanczyk, but I'm  
14 not sure.

15           While they went to the back, I immediately walked  
16 over to the 601 panel and looked at the PAM recorders, post-  
17 accident monitoring, and noted that they had tripped to fast  
18 speed. They normally run on slow but trip to fast speed  
19 when certain initiating conditions occur -- high reactor  
20 pressure or low water level in the vessel. They were  
21 running. Pressure was about 940, and vessel level was  
22 getting about 175, 180, in that range, and they were running  
23 at fast speed. It looked like a flat-line trace.

24           While I was there, I turned and looked at the 603  
25 panel. I noticed that the recirc pumps had down-shifted to




1 low speed and that, on what we call the Rubik's Cubes, or  
2 the redundant reactivity control system, on 603, we had an  
3 indication of an ARI, alternate rod insertion, and a down-  
4 shift of the pumps.

5 At that time, I think, Mike Eron came up from the  
6 back panels and said the EPRMs are reading down-scale. He  
7 said, I recommend we place the mode switch to a shutdown. I  
8 said, I agree; some event's going on. I directed the CSO to  
9 place the mode switch in shutdown.

10 At that time, people started performing their  
11 immediate actions for the prior procedures for a scram.  
12 During that time, I was also receiving reports. Somebody  
13 said, It looks like the feed pump has just tripped. At that  
14 time, I believe, I assigned one of the non-licensed  
15 operators, Eric Hoffman, to watch level and pressure on the  
16 601 panel and keep me informed of the status, if you see any  
17 changes in the trends.

18 Then I turned around to our EOPs laying on top of  
19 the computer CRT in front of the 601 panel. I turned around  
20 to that, and I asked power, level and pressure. They gave  
21 me the readings, and I'd jot them down on the boards there,  
22 just as a formality, to try to focus on what I need to do  
23 next.

24 I got the report that the level was starting to  
25 slowly lower, so I ordered RCIC initiated, and I believe



1 Mark Davis started. He reported a problem -- it appeared  
2 after he initiated that the speed was oscillating, and he  
3 ended up having to take manual control. I was inquiring, Do  
4 we have injection flow yet, and he said, Not yet; it looks  
5 like one of the inboard check valves did not open. Then he  
6 said, Okay, now I have indication of flow.

7 Let's see. What happened next?

8 MR. KAUFFMAN: Did he put it in manual?


9 MR. CONWAY: He placed the speed controller in  
10 manual. It's a flow speed controller type arrangement, and  
11 he placed it in manual. That steadied the flow out. The  
12 speed, pressure, and flow were all oscillating around, and  
13 that stabilized RCIC at that time.

14 MR. KAUFFMAN: Then he got the injection valve.

15 MR. CONWAY: Well, the injection valve had opened,  
16 but we were waiting for the inboard check to swing open. I  
17 don't ever recall him saying that it did swing open, but it  
18 did show that we were getting injection flow and we had a  
19 slowly rising trend in level at that point.

20 Also, simultaneously with that, pressure slowly  
21 started coming down, because RCIC was spraying in on top of  
22 the steam bubble inside the core.

23 I guess, prior to RCIC restoring the level, the  
24 level dropped down to a low enough value, 159.3. I think I  
25 received a report from the operator that the level was now



1 down to 159, and at that time I entered the emergency  
2 operating procedures; that's one of our entry conditions.

3 I made that declaration to everybody in the  
4 control room, that we had entered those; again, received  
5 reports on where we were. Once I entered the EOPs, I  
6 followed down through the RQ leg, which is dealing with  
7 power. Pressure was fairly stable -- we didn't have a  
8 problem with that -- and level was still lowering, but we  
9 had RCIC injecting, and I was expecting it to turn, at which  
10 time it did slowly start turning it.

11 I was in the RQ leg. I realized at that time that  
12 one of the conditions to exit RQ if there was a non-scam  
13 condition is all rods into at least 0-2. I realized at that  
14 time that we could not tell what the position of the control  
15 rods were, because the full-core display had gone black. We  
16 couldn't tell from the rod worth minimizer or the rod  
17 sequence control where the rods were. When we tried to  
18 select rods, of course, we couldn't tell where they were,  
19 either, on the full rod display.

20 At that time, I made the declaration to everybody,  
21 Be aware that, since we can't tell where the control rods  
22 are at this time, we believe we've had a scam, but -- since  
23 we can't tell the position of the control rods -- we are  
24 still in the RQ leg is EOPs, and that I'm exiting RL leg,  
25 which is our normal water level control in EOPs, and going

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both primary and secondary research techniques. The primary data was collected through direct observation and interviews with key stakeholders. The secondary data was obtained from publicly available sources and internal company records.

The third section details the findings of the study. It shows that there is a significant correlation between the variables being studied. The data indicates that as one variable increases, the other tends to decrease, suggesting an inverse relationship. These findings are supported by statistical analysis and are consistent with previous research in the field.

Finally, the document concludes with a series of recommendations based on the research findings. It suggests that organizations should focus on improving their data collection processes and ensuring that all information is properly documented. Additionally, it recommends regular audits to maintain the integrity of the data and to identify any potential areas of concern.





1 to C5, which is power level control, our contingency EOP.

2 I believe then, once I was in C5, I directed the  
3 ADS inhibit switches to be placed in on; that's one of the  
4 steps that has to be performed. Then I assigned, I think,  
5 another operator to come in, Brian Hilliker, who had come in  
6 early -- he was just starting a day shift -- to take control  
7 of RCIC and gave him a water level band, I believe, of -- I  
8 want to say 170 to 190 on wide-range indication.

9 MR. JORDAN: Who was that?

10 MR. CONWAY: Brian Hilliker -- I believe he was  
11 the operator assigned RCIC control.

12 MR. JORDAN: And he was on the next shift?

13 MR. CONWAY: He is actually a relief shift person  
14 who was coming in to work days. He had come in a little bit  
15 early.

16 MR. JORDAN: Okay.

17 MR. CONWAY: I also directed actions per -- you  
18 know, following down the RQ leg, is ARI initiated? I asked  
19 that question, and that report was, Yes, it had. I dropped  
20 through, got down, turbine was off the line, dropped  
21 through, I MSIV still open, got down to another decision  
22 block, where we have to start implementing actions per our  
23 EOP 6, our support procedure for taking action to insert  
24 control rods. I think the oncoming day-shift CSO was in at  
25 that time, also, and I assigned him that responsibility --



1 that was Dave Rathbun -- to do EOP 6, attachment 14, to  
2 start working that and seeing what we can do to insert  
3 control rods. I told him, I know at this time we don't have  
4 any indication, but we need to start working on something.

5 Sometimes during this time period, our aux  
6 operators all started coming back from downstairs -- all the  
7 lights had gone out in the control building, where they do  
8 their turnover -- and they came all running back up the  
9 control room to find out what was going on.

10 MR. KAUFFMAN: When you say lights off in the  
11 control room, you mean all lights, part of the lights?

12 MR. CONWAY: In the control room we still had  
13 lighting. As far as which lighting went out, you'll have to  
14 ask those guys; they were out there. I can't specifically  
15 say.

16 MR. KAUFFMAN: So the report to you, you don't  
17 remember.

18 MR. CONWAY: They never said anything about the  
19 lighting; they just all came running in. They saw that we  
20 were in some sort of event, that I was implementing the  
21 EOPs. I directed, I think, Aaron Armstrong and a couple  
22 other guys to go down to the normal switchgear building and  
23 down to the UPS's and check out what was going on; there  
24 must be a problem down there. Those guys went running out.

25 Of course, during this time we didn't have our



1 Gaitronics available, either. We noticed that was flat. We  
2 wanted to make a station announcement, the reactor scram,  
3 call the troops. That wasn't possible.


4 Also, Al Denny, who was our shift emergency plan  
5 coordinator, approached me somewhere in this time frame and  
6 showed me his recommendation for classifying the event based  
7 on EAP-2. He recommended site area emergency, based on loss  
8 of control of annunciators and a transient in progress. As  
9 soon as I read that, I said, I concur. I made the  
10 announcement to the control room. That was like 6 o'clock.

11 MR. KAUFFMAN: This whole discussion here is all  
12 in about 10 minutes.

13 MR. CONWAY: All in about 10 minutes -- a lot of  
14 things going on at once.

15 I believe at that time Mike Eron says, I'll call  
16 Unit One and have them make the announcement, because we  
17 didn't have our Gaitronics available. He went into the  
18 clerk's office, I believe -- or he did it at the phone desk;  
19 I'm not sure where he did it, but he made the phone call to  
20 Unit One. We didn't hear the announcement, because, of  
21 course, our Gaitronics were out. I assumed that they had  
22 done that, because then people started taking actions  
23 accordingly.

24 Eventually -- I want to say from the time I  
25 entered the EOPs, which was, I want to say, three to five



1 minutes after the initial event occurred, through the next  
2 five minutes, we eventually turned level. I don't remember  
3 the lowest it goes; I want to say 140 was the lowest at that  
4 time, before level started turning and coming back up.


5           Meanwhile, pressure was starting to slowly decay  
6 off. It was down in the 800s at that time, as RCIC started  
7 turning levels. The level was coming up, and the pressure  
8 was slowly starting to come down.

9           MR. KAUFFMAN: Is that normal for the decay heat  
10 you had or after other scrams?

11           MR. CONWAY: Is that normal? I would say I would  
12 expect it to do that because RCIC was running; it uses steam  
13 from the vessel as motive steam, and it also sprays inside  
14 the core.

15           MR. KAUFFMAN: I'm really asking your plant-  
16 specific -- You know, at some plants you might expect that  
17 it won't bring pressure down, based on what people see after  
18 transients; and at some plants you might say, yes, it takes  
19 enough steam, and that brings it down.

20           MR. CONWAY: I expected this type of thing to  
21 happen, and of course I had continuous updates on what level  
22 and pressure were from Eric Hoffman. He was keeping me  
23 pretty well informed. Every minute, I've got to say, he was  
24 giving me an update on what was going on. I was becoming  
25 aware of the fact that level was going up, was rising, and





1 pressure was lowering. Since we were in RQ and C5, we could  
2 not commence a cool-down until we knew where our control  
3 rods were. I was being very conscious of that and starting  
4 to get worried. This seemed to be our only injection  
5 source.

6 At the time, it looked like pressure, level were  
7 under control. Power was less than 4 percent, so it looked  
8 like we weren't in an ATWS condition because of the way the  
9 plant was responding.

10 MR. KAUFFMAN: Can I interrupt with a question  
11 here real quick?

12 MR. CONWAY: Go ahead.

13 MR. KAUFFMAN: You said it was your only injection  
14 source. Did you not have CRD? Did something happen?

15 MR. CONWAY: CRD was also running.

16 MR. KAUFFMAN: Okay.

17 MR. CONWAY: I tend to overlook that as an  
18 injection source. It's a very small quantity.

19 MR. KAUFFMAN: Sure.

20 MR. CONWAY: Yes, it was running and injecting, I  
21 guess you could say, at that point.

22 MR. KAUFFMAN: Okay.

23 You recognized that the EOPs wouldn't let you cool  
24 down at the point I interrupted. It was your only source --  
25 RCIC was --



1           MR. CONWAY: I was starting to inquire about those  
2 other sources. We knew that all the instrumentation -- I  
3 also inquired on the drywell parameters. I think I assigned  
4 one of the guys coming in to find out what drywell pressure  
5 is; I need to know what drywell pressure and a full set of  
6 drywell parameters. I think it was Jay Lawrence I asked; he  
7 was one of the oncoming shift personnel, also.

8           At this time, people were starting to filter, a  
9 few at a time, into the control room. As soon as people  
10 were coming in, I was directing them out. I sent one of the  
11 other non-LOPs out, for instance, to check down on the local  
12 instrument panels on the reactor building, 261. I asked him  
13 to check level and pressure at the instrument racks down  
14 there to confirm what our level and pressure -- that the  
15 instruments that we were reading were in fact accurate. I  
16 was fairly comfortable, because both PAM recorders were  
17 indicating the same, both Div 1 and Div 2. These instrument  
18 racks, of course, they are strictly analog indicators,  
19 direct hook to the vessel, and there is no way that these  
20 can be misleading me. Since there was no Gaitronics, he had  
21 to run all the way down and come all the way back with a  
22 report. And, yes, his report confirmed that level and  
23 pressure were where we thought.

24           Let's see.

25           Right now the level is rising, the pressure is



1 lowering. It's going to get concerned with cool-down.

2 I made that apparent to Brian Hilliker, who was  
3 controlling RCI -- Brian, watch our pressure, I don't want a  
4 cool-down, don't drop below 600 pounds I believe I told him.  
5 I think I wrote down EOPs maintain 500 to 600 or something  
6 like that. I may have given him that band. I don't  
7 remember. At that time I think was just making him aware  
8 that we're cooling down -- that we don't want to cool down,  
9 maintain it above 600 pounds.

10 Level was back up in the normal band, I want to  
11 say in the 180s, in that range, when it looked like we were  
12 going to have a problem with pressure, that it was going to  
13 start lowering, continue to lower because RCI wasn't running  
14 and injecting and I had him stop injection with RCI at that  
15 time.

16 Level continued to rise and pressure continued to  
17 lower, get down to about 590 pounds and I was getting pretty  
18 concerned. It looked like one time it had stabilized and  
19 that was only for it looked like a period of a minute and  
20 then the next report I got was that, yes, it's still  
21 lowering.

22 Then I became conscious of another problem. The  
23 booster pumps, booster pumps were still running and I was  
24 concerned that once we dropped below their shutoff head that  
25 I asked close -- you know, I'm worried about injection from

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50  
 51  
 52  
 53  
 54  
 55  
 56  
 57  
 58  
 59  
 60  
 61  
 62  
 63  
 64  
 65  
 66  
 67  
 68  
 69  
 70  
 71  
 72  
 73  
 74  
 75  
 76  
 77  
 78  
 79  
 80  
 81  
 82  
 83  
 84  
 85  
 86  
 87  
 88  
 89  
 90  
 91  
 92  
 93  
 94  
 95  
 96  
 97  
 98  
 99  
 100



1 the booster pumps at this time. We don't want that to  
2 happen, let's close the LB-10s for the feed pumps and then  
3 the report back was I got that we can't, they are locked up,  
4 we don't have any power to them, at which time I said does  
5 it look like we may be injecting with the booster pumps and  
6 they said we don't know, we can't tell. The instruments  
7 aren't registering that, at which time I said, very well,  
8 secure the booster pumps. We don't want injection from that  
9 source and during that time it was reported that the level  
10 had gone above 202 on their wide range recorders, the PAM  
11 recorders. The pressure was down around I want to say 530  
12 pounds. I'm not real specific on the pressure. If I had a  
13 flow chart in front of me I could tell you about where we  
14 were but it was in the 500 range and level had gone off our  
15 indicator at that time.

16 MR. KAUFFMAN: Quick question. Did you just think  
17 that the booster pumps injecting or was there some  
18 procedural guidance that led you to that?

19 MR. CONWAY: I was aware of the fact that the  
20 booster pumps could inject, especially if the LV-10s were  
21 open. That would have been the only flow restriction in  
22 their flow path and since they had several options closed  
23 the feed pump discharge valves, which take about -- well, it  
24 seems to me about five minutes a stroke -- I don't think  
25 they take quite that long, close the 21s which are the feed

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The goal is to ensure that the information gathered is both reliable and comprehensive.

The third section provides a detailed breakdown of the results. It shows that there has been a significant increase in sales over the period covered. This is attributed to several factors, including improved marketing strategies and better customer service.

Finally, the document concludes with a series of recommendations for future actions. It suggests that the company should continue to invest in research and development to stay ahead of the competition. Additionally, it recommends regular audits to ensure ongoing compliance with all relevant regulations.





1 header stops and the same type thing. They're long-winded  
2 valves so I felt that securing the booster pumps was the  
3 surest way to stop injection if there was any from the  
4 booster pumps and the way the level was rising I had to  
5 believe with RCI secured, you know, we are going to get a  
6 combination of the level swell from cool water injection and  
7 I was concerned that, yes, they were injecting.

8           So we have a procedure that says if we reach Level  
9 8, which is 2023, and if we believe we have booster pump  
10 injection we're supposed to take action to prevent that from  
11 happening because they are worried about over-filling the  
12 vessel, flooding up to the steam lines and then taking away  
13 pressure control.

14           During this time bypass valves appeared to be  
15 controlling pressure stable. That's when it was maintaining  
16 it around 940 initially, then the report I got was we had  
17 half a bypass valve open and then it ended up dropping up to  
18 a quarter open and that was I think the last report I got on  
19 bypass valve position.

20           MR. KAUFFMAN: That was real early on.

21           MR. CONWAY: That was much earlier, yes.

22           That was back when I first entered EOPs. I  
23 dropped down through and found out what I am going to use  
24 for pressure control. It didn't look like -- you couldn't  
25 tell if any SRVs were cycled unless you were there when they




1 initially did. I guess we found out afterwards that two SRVs  
2 did actuate but initially at that time we did not know that.

3 I don't believe anybody saw that. I personally  
4 did not see any SRV actuation occur. Of course one of the  
5 key indicators of that is annunciation of the valve  
6 actuation and we didn't have that.

7 We were about I would say pretty close to 30  
8 minutes into the event now and the pressure was starting to  
9 stabilize right around mid-500s or mid to low 500s. Level  
10 was offscale high. We couldn't tell where it was when  
11 suddenly annunciators started coming back on and meters  
12 started coming back on scale and chart recorders started  
13 running and I breathed a sigh of relief and said, all right,  
14 we'd got annunciators and instrumentation back.

15 I immediately asked for a report of level. I  
16 still had an indication that it was still upscale, greater  
17 than 202.3 and shortly within I've got to say two or three  
18 minutes after that, it started coming back on and I got the  
19 report of 198 inches and lowering.

20 I then told one of the other operators that was in  
21 the control room -- I want to say Jim Graff, who had come in  
22 -- he's also a relief operator, he'd come in early for days  
23 -- to start making preparations to restart the booster  
24 pump. I wanted to be able to have those as an injection  
25 source.



1 I had -- somebody reported condenser vacuum was 23  
2 inches and it looked like it was slowly lowering and so we  
3 started making some plans at that time. More people had  
4 come in and we had -- I was working with Mark Davis to try  
5 to get a plan for him and Mike Eron what's going on here,  
6 and we talked about stuff like -- started getting aux  
7 boilers running so we can establish shield steam for the  
8 main condenser and utilize that as a primary heat sink.

9 Booster pumps of course, available so that we  
10 could have a reliable source of injection in addition to  
11 RCI.

12 What else? Work on getting the condenser removal  
13 pump started, the hoggers to work on our vacuum problem.

14 We talked about -- let's see, early on after I had  
15 ordered RCI started I also ordered suppression pool cooling  
16 on RHR alpha pump and so that was -- that was circulating.

17 We wanted to make plans to get RHR Bravo and  
18 Charlie, which were in an out of service condition. We had  
19 just marked them up to our maintenance earlier that shift  
20 so we had started taking action to get that back.

21 MR. JORDAN: Which one was on means?

22 MR. CONWAY: RHR Alpha -- or excuse me, RHR Bravo  
23 and Charlie. They were out of service ECCS pumps.

24 MR. KAUFFMAN: The work hadn't started. They were  
25 just more or less tagged out but --

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The goal is to ensure that the information gathered is both reliable and comprehensive.

The third section provides a detailed breakdown of the results. It shows that there has been a significant increase in sales over the period analyzed. This is attributed to several factors, including improved marketing strategies and better customer service.

Finally, the document concludes with a series of recommendations for future actions. It suggests that the company should continue to invest in its marketing efforts and focus on building long-term relationships with its customers.



1 MR. CONWAY: We had valves de-energized that we  
2 were going to do electrical PMS on and pump control switches  
3 were in pulled lock.

4 MR. KAUFFMAN: That's not on the floor. He could  
5 have gotten them back relatively easily by --

6 MR. CONWAY: All we knew is we sent people out and  
7 they cleared the tags on the valves, turned the breakers  
8 back on so they were on in fairly quick time.

9 What else were we doing? There was a lot going on  
10 at once. I remember I was giving updates, you know, during  
11 this time period to keep everybody informed of what was  
12 going on and where we were going, where we are now, here's  
13 what we're doing, control level and pressure.

14 One of our plans was to assign someone eventually  
15 to use the -- to the bypass valves but at this time we still  
16 didn't know -- well, wait a minute.

17 We got power back and we had -- I got the report.  
18 Finally, it took about ten minutes because we had to go  
19 around and check, using the Rad Select and between that and  
20 RSCS and we had to restart the rod drive control cabinet,  
21 and finally we got core scanned and we got the report that  
22 six -- we could not tell the position of six rods and I made  
23 that clear in my update.

24 MR. KAUFFMAN: You were the Emergency Director  
25 during all this time?





1 MR. CONWAY: Yes. One of the responsibilities of  
2 the shift Emergency Plan Coordinator, of course, is to  
3 assist me in implementing that duty. He makes -- he can  
4 make an initial recommendation on classification. He  
5 ensures all the notifications are made to outside agencies,  
6 for instance. That's part of his duty.

7 Also during the first few, I guess I'll say the  
8 first ten minutes Tom Tuttle, one of our STAs, had come in  
9 to relief Al Denny and I asked him if he would verify that  
10 we are doing everything we can do for loss of annunciators.  
11 This is prior to getting the power back so he was pursuing  
12 looking at that. We have had a procedure for loss of all  
13 annunciators but nobody thought we'd ever use that.

14 He was looking at that.

15 MR. KAUFFMAN: Did you have any problems sounding  
16 the sirens or making announcements?

17 MR. CONWAY: Once we got power back to the UPS we  
18 immediately made a follow-up announcement to let everybody  
19 know what was going on.

20 We also started getting reports that -- from the  
21 guys we sent out into the turbine building to start working  
22 on getting the aux boilers back and starting up the  
23 condenser air removal pumps, that were CAM, Continuous Air  
24 Matters in alarm in the building and of course we reported  
25 that to Rad Protection immediately and we made an



1 announcement to stay clear of the turbine building and then  
2 worked with Rad Protection to get people in and out and they  
3 were doing surveys of both the reactor building and the  
4 turbine building to find out what levels were in there.

5           It turns out there was no problem at all. They  
6 were I guess, quote, since we were running all our people  
7 through them, when they had to go out of the building they  
8 were keeping track of who was going where and that kind of  
9 thing along with our CSO. Of course he was keeping --

10           MR. KAUFFMAN: Maybe I'm jumping ahead. What time  
11 did you get relieved as the Emergency Director? We're not,  
12 it's not our charter to look extensively at the emergency  
13 planning aspects but certainly we're interested in how you  
14 got around your communications and how all the people coming  
15 in and being sent out in the plant and this and that and the  
16 other got handled.

17           MR. CONWAY: I got relieved as Site Emergency  
18 Director at 7:38 by Marty McCormick.

19           MR. KAUFFMAN: Did you ever start getting help I  
20 guess from the TSC and OSC?

21           MR. CONWAY: I found out afterward, it seemed to  
22 take an awful long time to me to even get communications  
23 from them. It turned out that there was a little bit of a  
24 problem at Security in that I found our, afterwards of  
25 course, that there was a couple TSC staff members that they

22  
23



1 weren't letting them through even though they had emergency-  
2 related functions. That was just a matter that they had new  
3 ID cards issued, emergency ID cards and I think the guards  
4 just were not familiar with the new format and once they got  
5 that cleared up, they were in.

6           They got staffed up and then of course it was  
7 matter with me becoming comfortable with having time to turn  
8 over and so it wasn't like as soon as they got in there I  
9 was going to give it to them. I wanted to make sure the  
10 plant was in a stable condition, we had a plan of action and  
11 that we had backup contingencies like steam condensing  
12 available with all those normally de-energized valves for  
13 Appendix R purposes turned back on and available on Arch or  
14 Alpha in the event that we lost -- we couldn't maintain  
15 vacuum in the condenser -- that was going to be our heat  
16 sink.

17           When it looked like pressure had stabilized, we  
18 had gotten power back to our UPS's and we had a booster pump  
19 running finally and they were having problems getting  
20 injection into the vessel. Its level was starting to  
21 slowly lower.

22           It turned out the problem, they were -- comes with  
23 our, I guess our procedure has a start to booster pumps.  
24 They were worried always about our feed pump seals and would  
25 like to protect them, had a lot of problems with them in the

1 2

3 4

5 6

7 8

9 10

11 12

13 14

15 16



1 past, and what we did to start the booster pump back up was  
2 to close the suction valves for the feed pumps. My  
3 intention of course was to use the LB-55s, which are the  
4 high pressure, low flow feedwater control valves as a method  
5 of injection control in the vessel.

6           They couldn't get the feed pump suctions, the MOV-  
7 84 valves open because of the DP across them. The feed  
8 pumps were locked in. Downstream the MOV was like 200 pounds  
9 and upstream was like 700 and that was too excessive a DP  
10 and at that time we were restricting access to the turbine  
11 building and hadn't worked our plan out with Rad Protection  
12 yet and we hadn't gotten the survey results back and we  
13 couldn't send anybody in to it, which is where the location  
14 of the bypass valve is, to equalize around them.

15           They were feeding on the low flow, low pressure  
16 valve, the LV-137 at full capacity and the level was still  
17 lowering.

18           Got down to -- I started asking, well, you know,  
19 we need to find out what we can do and I think I assigned  
20 another operator to assist him and Jim Graff into working  
21 out what we can do to get injection we need to get that  
22 available.

23           I think the lowest level it got was I ended up re-  
24 entering EOPs on low water level when we crossed 159 again  
25 and we -- at about 140 inches I am thinking, the core is





1 still covered but we need to start thinking about getting  
2 RCI running again and available for injection.

3 I was just getting ready to get that work when my  
4 reports were the level looks like it's stabilized and it was  
5 at 133 inches and the next report I got after that was level  
6 is now 134 and slowly rising and it rose real slow.

7 During this time period still hadn't -- we were  
8 trying to get INC people in through the TSC. They were  
9 still being kept out off-site, into the building and  
10 computer people into the building to get the process  
11 computer restarted, the rad waste SPDS computer back up, get  
12 the INC guys in to -- INC people in to work on getting our  
13 control rod indication back.

14 We weren't sure where the rods -- we were showing  
15 a blank display on our four rod display and you couldn't  
16 tell -- we weren't getting the red full in lights on the  
17 RSCS and the rad waste minimizer was giving us conflicting  
18 information. It said all but one were in and then it said  
19 they're all in and then it would go back to all but one and  
20 we were getting conflicting data so we were still under the  
21 assumption that all rods were not in and we were operating  
22 under that restriction.

23 I had given direction to Jim Graff to feed slowly  
24 based on the fact that all rods were not in. We didn't want  
25 to get power excursions.




1 I told Mark Bodoh, who was watching level on 603  
2 to be conscious of reactor power and notify me if we have  
3 any increase in counts on our SRMs.

4 MR. JORDAN: What were you injecting with to turn  
5 the level? You got it down to 133 and then it started to  
6 come to 134.

7 MR. CONWAY: It was with the condensate booster  
8 pump through the low flow, low pressure valve which has a  
9 limited capacity. It's like a four inch line and I think  
10 we were getting between 400 and 600 gallons a minute and  
11 then we said he started a second condensate pump and that  
12 got a little bit more flow because it increased the  
13 discharge head of the booster pump.

14 So while were trying to work on getting people to  
15 get rad indication back, it looked levels started to turn.  
16 It was being taken in control but rising in a very slow  
17 rate. Pressure was still fairly stable and now starting to  
18 recover and come back up and slowly rise.

19 So we had pressure coming back up, level coming  
20 back up, pressure rose about 600 or 700 pounds I would lose  
21 my booster pump injection so I started thinking we need to  
22 stabilize pressure at this pressure range and I assigned  
23 that task to R. J. Reynolds on the turbine bypass valves. I  
24 said R. J., maintain 500 to 600 pounds; we are in an ATWS.  
25 We don't want to cool down. Be conscious that we don't have



1 vacuum stabilized yet. We don't have the hogger on. We  
2 don't have steam seals. We are working on getting the  
3 boiler and hoppers running but in the interim you need to be  
4 conscious of condenser vacuum so if you get -- if vacuum  
5 drops to 15 inches I want you to close turbine bypass  
6 valves to protect the condenser.

7           Let's see. We began cracking the bypass valve to  
8 stabilize pressure using the bypass opening jack and  
9 pressure at that time stabilized right in that range, around  
10 550. That level was still slowly, real slowly rising. Of  
11 course he was bleeding a little steam off and we were  
12 limiting the injection so it was coming up real slow.

13           During that time period Mike Eron pointed out to  
14 me in the RPD control of the OP there is an override in one  
15 of the weight blocks, or stop sign shaped block that gives  
16 you the chance that it says if the reactor is shut down and  
17 no boron has been injected you can continue past that stop  
18 and commence a cooldown.

19           At that time I asked what power was, so when he  
20 said ten to the third on the SRMs I said okay, we are  
21 definitely below the heating range and we haven't injected  
22 boron -- we can begin a cooldown.

23           One of our ODIs gives us a little description that  
24 part of our departmental policy is we feel that we are shut  
25 down if we are less than the heating range on IRMs, which is



4

5

6

7

8

9

10

11

12

13

14



1 less than range 6 or 7.

2 MR. KAUFFMAN: Sounds like a conduct of ops  
3 procedure, something like that.

4 MR. CONWAY: It is Operation Department  
5 Instruction on EOP implementation, lessons learned from  
6 simulator runs.

7 MR. JORDAN: What point is that? What's the  
8 condition you consider shutdown?

9 MR. CONWAY: On IRMs, below the heating range,  
10 which is range 6 or 7.

11 MR. JORDAN: So below 6 or 7 on the IRMs --

12 MR. CONWAY: We're fairly confident that we are  
13 shut down.

14 MR. JORDAN: As long as you are below the heating  
15 range.

16 MR. CONWAY: Correct and it was reported to me  
17 that we were on SRMs, about ten to the third.

18 MR. KAUFFMAN: We are probably interested in  
19 seeing that procedure. Do you happen to know the number of  
20 it? No?

21 MR. CONWAY: I don't remember the number of it,  
22 not specifically.

23 It gives that kind of guidance in there though.

24 MR. KAUFFMAN: Okay.

25 MR. CONWAY: It's not specific but we have been





1 trained on saying, yes, we can say that. Same thing with  
2 one rod is out. We know that our shutdown margin test covers  
3 the fact that our most reactive rod is fully withdrawn so if  
4 we had all but one rod full then we know we could still say  
5 we're shut down, fairly confident.

6           So he pointed that out to me and at that time we  
7 still had to stay in the power level control because it  
8 doesn't give me an out until all rods indicate in, so we  
9 were still in there for level control and it gives me a  
10 pretty wide band, minus 14 to 202 I think is my band at that  
11 point and I gave them the band. I changed the level band  
12 with the booster starting, 165 to 180, so that we didn't  
13 refill too rapidly and I told him to feed slowing and he  
14 said he was feeding as fast as he could anyway. The level  
15 was still coming up slow.

16           At that point things were starting to shape up a  
17 lot better. We had a lot more people in. Jerry Helker was  
18 in. He's -- I was asking him for advice and between he,  
19 myself and Mike Eron and Al DeGracia, who is head of the Op  
20 Support Department for us -- he was in also.

21           We were formulating a plan to where we were going  
22 to go and what we were going to do next and since we were  
23 now able to cool down, we could start lowering our pressure  
24 band and enable conditions to even get better.

25           MR. KAUFFMAN: About what time was this?



1 MR. CONWAY: This was right around the time I got  
2 relieved by Martin McCormick of the TSC, so it was about  
3 7:38.

4 It's written down here. Let's see -- 0630 I had  
5 all rods in except for six, the six control rods and 0700 we  
6 had finally got the indication that all rods were in and we  
7 had done stuff interim to that, trying to -- we hadn't  
8 gotten RNC techs in yet. We were working at EOP 6,  
9 Attachment 14, and one of the things we can do is reset the  
10 scram.

11 I think it was Dave Rathbun we felt that one of  
12 the reasons we may not have had indication of these rods is  
13 they may be over-driven in, and that by resetting the scram  
14 it may allow them to settle out to 00 and get an indication  
15 back so I said very well, let's take those actions.

16 Well, one of the things that we needed to do is  
17 then install the RFS jumpers. I said make it so, and he  
18 installed it. We reset the scram and we got our rod  
19 indication back at that point.

20 MR. JORDAN: And that is what you were looking for  
21 before you started cooling down, was the rod indication for  
22 the six rods?

23 MR. CONWAY: No. We didn't need that specifically  
24 because the RP leg says if you are shut down and no boron  
25 has been injected and the determination was mine that since



1 we were below the heating range on IRMs we were in fact shut  
2 down and that, you know, when I made that call and made the  
3 announcement that we were transitioning here to be conscious  
4 of power rising on SRMs, notify me immediately, I told Mark  
5 Bodoh, who was over on 603 panel.

6           Once we installed the RFS jumpers and reset the  
7 scram we did finally get an indication of all rods in and  
8 then it took a while for them to confirm that also, but they  
9 checked it on several sources and the rad waste minimizer  
10 was showing still one rod and we had full-in on full core  
11 display and full-in on RSCS but our rad waste minimizer was  
12 still in and out whether or not whether that rod was in or  
13 not.


14           We had it at least confirmed on two different  
15 indications.

16           In any case, one rod is definitely within our  
17 shutdown margin requirement.

18           Shortly after that, the process computer got  
19 restored; the computer techs came in and restored the  
20 process computer.

21           MR. JORDAN: So you're saying you started cooling  
22 down around 7; is that what you said? I was just curious.

23           MR. CONWAY: Specifics as far as time? I don't  
24 remember a specific time that I gave that. Let me think  
25 here a minute.



1 I remember Mike had planned that out to me, Mike  
2 Eron. I don't remember specifically when that was, time-  
3 wise. I know it was before we had all the rods indicating  
4 full in, though.

5 MR. JORDAN: Okay.

6 MR. CONWAY: And that was at 0700. It had to have  
7 been 6:30, after we got our power back to the UPS's, and  
8 7:00, which is when all rods were indicated full in, except  
9 for -- yes, all rods were indicated full in at 0700.

10 MR. JORDAN: Okay.

11 MR. CONWAY: It had to have been fairly close to  
12 that time period, because we logged here we started the  
13 booster pump at 0640, and that was right after we had  
14 restored power. We had worked on getting that back; we had  
15 people out in the plant to do that.

16 We restored power to the UPS's at 0622.

17 Then, at 0738, I got relieved by Marty McCormick.  
18 I turned over to him where we were, what my intention were  
19 on what we do with the plant, and my feelings that things  
20 had stabilized fairly well and that I was interested in  
21 turning the site emergency directorate over to him. He  
22 said, Yes, he was ready, and we conducted a turnover over  
23 the phone. He relieved me of that function, and I made the  
24 announcement to everybody in the control room. We continued  
25 to cool down the plant.





1           You know, we placed RCIC in standby after making  
2           sure the booster pumps were running. We lowered our  
3           pressure band; we waited a full hour maintaining 500 to 600  
4           pounds so we'd ensure we didn't exceed our cool-down rate.  
5           I think at quarter after 7 I lowered the pressure band 300  
6           to 400 pounds.

7           Over the next couple hours, we just worked with  
8           getting things going. One of those things was trying to  
9           work with the OSC, ops support center, to get people in and  
10          out of the plant and get damage control teams out looking at  
11          UPS's. I discussed early with Marty McCormick about his  
12          interest in trying to get the UPS's back on their normal  
13          power supply and have the maintenance and DC available again  
14          as a backup. We formulated a plan, and we discussed this  
15          with Jerry Helker and Al de Gracia, Mike Eron -- the group  
16          of us in the control room, the senior management guys. We  
17          got together and came up with a plan of doing this, going  
18          from the Charlie and Delta, Bravo, Alpha, and Gulf, in that  
19          order, to minimize the possibility of losing one of them in  
20          the interim. We didn't know the status of the UPS's, other  
21          than that they were on a maintenance power. Doing the  
22          lighting ones first, Charlie and Delta were the minimum  
23          impact, other than that we would have lost half our  
24          Gaitronics system, our alarm announcement system, if one of  
25          them failed to transfer successfully. But we successfully

1

2

3

4



1 transferred all of them, except for the Alpha and Bravo,  
2 which were the major instrument bus suppliers.

3 My concern, of course, with those two was that at  
4 that time feedwater level control was in automatic on the  
5 LV-137, feeding with a booster pump, and the impact was that  
6 we could have lost that feedwater level control function.  
7 Everybody was aware of when we were doing that, and we were  
8 keeping TSC updated and posted.

9 Then we started shutting down our auxiliary  
10 systems, off-gas, steam generator-injectors. I got a report  
11 that the vent GEMS -- or, no, the stack GEMS -- had given us  
12 an alarm, saying it was inop, and we notified the dose  
13 assessment advisor, and he was going to get grab samples  
14 arranged for. We got results back.

15 MR. KAUFFMAN: Who is responsible for the samples?

16 MR. CONWAY: The chemistry department does it  
17 through the dose assessment advisor. They send out teams  
18 from the OSC to do that.

19 MR. JORDAN: Information like that gets fed  
20 through the control room, and then you feed it from the  
21 control room to the TSC; is that how that works?

22 MR. CONWAY: Correct.

23 MR. JORDAN: Okay.

24 MR. CONWAY: Of course, during this time, I was  
25 doing updates with Al Denny, the shift emergency plant

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The goal is to ensure that the information gathered is both reliable and comprehensive.

The third section focuses on the results of the analysis. It shows that there is a clear trend in the data, which suggests that the current strategy is effective. However, there are some areas where improvement is needed, particularly in terms of efficiency and cost reduction.

Finally, the document concludes with a series of recommendations for future work. These include implementing new software tools, training staff on best practices, and conducting regular audits to ensure ongoing accuracy and compliance.



1 coordinator, 30-minute updates on where we were and where we  
2 were going, as far as further notification purposes.

3 Let's see. Did I forget anything?

4 We continued to shut down the auxiliary systems  
5 that we no longer needed that were part of the steam plant.  
6 During that time period where I was concerned about cooling  
7 down. I had ordered Jim Emery to work on using OP-101-  
8 Charlie, which is our shutdown procedure, to start closing  
9 off aux steam loads and steam drains to lower our pressure  
10 reduction. That helped stabilize things, too, finally, as  
11 far as pressure. That was back early on, though, before we  
12 got power restored.

13 Other things we did: We started our shift checks  
14 for -- we call them S et al., which covers all our  
15 different modes and assures we have the required  
16 instrumentation available to monitor the plant in all five  
17 modes of operation. It covers all those things. We started  
18 those to start checking our instruments.

19 Also, early on, it started the OSP-RCS at 001,  
20 which monitors your cool-down rate. Earlier on, we were  
21 concerned -- it was like shortly after we had declared the  
22 site area emergency, and I wanted somebody watching that  
23 specifically. I think it was Rich DeLong. He was watching  
24 that specifically and keeping me informed of what our rate  
25 was.

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50  
 51  
 52  
 53  
 54  
 55  
 56  
 57  
 58  
 59  
 60  
 61  
 62  
 63  
 64  
 65  
 66  
 67  
 68  
 69  
 70  
 71  
 72  
 73  
 74  
 75  
 76  
 77  
 78  
 79  
 80  
 81  
 82  
 83  
 84  
 85  
 86  
 87  
 88  
 89  
 90  
 91  
 92  
 93  
 94  
 95  
 96  
 97  
 98  
 99  
 100



1 MR. JORDAN: He was monitoring the cool-down rate  
2 based on --

3 MR. CONWAY: He was using steam pressure and  
4 saturation tables to monitor the cool-down rate.

5 MR. JORDAN: Okay. That's what his function was,  
6 though.

7 MR. CONWAY: Yes.

8 MR. JORDAN: Okay.

9 MR. CONWAY: He ended up turning that over to  
10 somebody else, I believe, later on, but initially he was the  
11 one keeping track of that.

12 We also began restoring the things we had  
13 overridden -- ADS -- placed those back in normal -- ADS  
14 inhibits, which is back into normal -- and removed the RPS  
15 jumpers we had installed to reset the scram once we had  
16 risen above 159, the low scram setpoint, or reactor water  
17 scram setpoint.

18 During this time, Mike Eron was trying to get me  
19 to start a cool-down, and I was hesitant to do that, because  
20 my level was still low. I felt that, if I had started a  
21 cool-down and begun lowering, I was going to cook my level  
22 off, and then I would have less inventory. With lower  
23 pressure, granted, I might be able to get a little more  
24 injection flow, but I wanted to make sure level was back in  
25 a stable band. Once level got back up to 180 inches, I

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100





1 directed the pressure band to be changed at that time --  
2 that in conjunction with the time period that all this  
3 occurred. So like at quarter after 7, I said, Okay, we have  
4 water level now, and now we can lower our pressure band 300  
5 to 400 at that time.

6 Eventually -- and it seemed like forever -- I got  
7 relieved.

8 MR. KAUFFMAN: What time was that?

9 MR. CONWAY: I want to say 11 o'clock, pretty  
10 close to 11 o'clock. I don't have the exact time written  
11 down in my log here, but right around 11 o'clock -- 10 of,  
12 something like that. We started a turnover. George Moyer  
13 was my relief.

14 MR. KAUFFMAN: You had an exciting morning.

15 MR. CONWAY: Yes. Then I went home and had a  
16 cocktail.

17 [Laughter.]

18 MR. KAUFFMAN: And had to get back in at midnight.


19 MR. CONWAY: That's right.

20 MR. KAUFFMAN: We won't get into how much shift  
21 work he's allowed to work.

22 [Laughter.]

23 MR. CONWAY: I met the requirement. You mean the  
24 eight hours off and all that?

25 MR. KAUFFMAN: Yes.



1 MR. CONWAY: I had the eight hours off. Is that  
2 what you mean by the shift work requirement? No more than  
3 16 hours, eight hours on the panel.

4 MR. JORDAN: So, during your time up until 11  
5 o'clock, was it the suction valves for the feedwater that  
6 were closed, so that you could not equal-pressurize around,  
7 so that you could get -- You were just using your -- You  
8 were feeding with your condensate booster through the --

9 MR. CONWAY: LV-137 valve.

10 MR. JORDAN: LV-137?

11 MR. CONWAY: That's correct.

12 MR. JORDAN: Okay.

13 So when you left, they were still feeding through  
14 LV-137? Was that the level?

15 MR. CONWAY: Startup valve, low-flow, low-  
16 pressure, feedwater control valve.

17 MR. JORDAN: Okay.

18 MR. CONWAY: I may have missed a few things here  
19 and there in my recollection of what happened, but a lot of  
20 things were happening at once.

21 MR. JORDAN: We're here for 10 days, trying to  
22 figure out what happened and reconstruct the event.

23 MR. CONWAY: I think the best reconstruction  
24 occurred at the initial debriefing, to tell you the truth,  
25 where we had everybody that was there inputting all the



1 information. That was all we did, and we ran it like our  
2 simulator critiques that we have at training. We don't tell  
3 people what we saw; we just ask -- what did you see, you  
4 know, and just poll everybody that was there. People supply  
5 everything. It pulls a picture together a lot better.

6 MR. KAUFFMAN: This question probably has been  
7 asked before, because Gene was here and it's Gene's favorite  
8 question: Were there any things that you would like to have  
9 had? Obviously, you'd like to have the UPS's.

10 MR. CONWAY: The UPS's would have been a nice  
11 thing to have back.

12 MR. KAUFFMAN: But do you have any ideas of things  
13 that could have made the response better or that you would  
14 like to have had that would have helped, or, for the things  
15 that you felt happened good, is there a reason that you  
16 think is important enough that everybody should have?

17 MR. CONWAY: The fact that we had a separation  
18 between normal instrumentation and, of course, divisional  
19 safety-related instrumentation was a major factor in helping  
20 figure out what we had now. When the event first occurred,  
21 we were scrambling to find out what we did have.

22 All our balance-of-plant equipment continued to  
23 run. The fact that we couldn't monitor it -- it still ran  
24 fine. That was, of course, a plus. We didn't have to deal  
25 with any major losses like loss of our condenser. That kind



1 of thing would have really complicated things. I mean, it  
2 would have made it more difficult to stabilize the plant,  
3 but it could have been done, in my opinion.

4 That, alone, helped us grasp control, to assess  
5 what we had, take the necessary actions initially, and grab  
6 control of what we had and stabilize the plant with the  
7 minimum number of people we had there, until we could get  
8 more people coming in. It worked.

9 RCIC worked. There were little problems with  
10 control. The oil has to heat up, and we don't run it  
11 routinely; quarterly is about all we ever run it.

12 Those kinds of things all help pull it all  
13 together to tie it up.

14 We had, still, all our drywell parameter  
15 indications available from the divisional meters. We knew  
16 there was no concern with the drywell. Although drywell  
17 temperature was starting to rise, one of the reports I got  
18 was that drywell unit coolers had tripped off. Mike Eron  
19 specifically brought that to my attention, that temperatures  
20 were rising, pressure was slowly rising. I think the  
21 pressure got to 0.7 psig, and the highest temperature was  
22 reported at 165 by Jay Lawrence. He said he had one at 165,  
23 one at 150, and the other four were at about the 130- to  
24 140-degree range. I assessed that and felt that I didn't  
25 need to enter the primary containment EOPs. I knew that the

1.

2.

3.

4.

5.

6.

7.

8.

9.





1 reason they were rising was that drywell cooling was off.

2           The fans had tripped. The cooling water valves  
3 were still lined up, which are primary containment isolation  
4 valves; they were still lined up. We didn't get an  
5 isolation. That would have been another thing. They come  
6 off another, separate UPS, the 3-series UPS, for all that  
7 primary containment logic and scram logic and all that. I'm  
8 thankful we didn't have a problem -- if primary containment  
9 had bottled up, with MSIVs shut, that would have pretty  
10 much sent us into using SRVs as pressure control and the  
11 suppression pool as our heat sink. That would have made  
12 things a little bit more difficult still, but I think we  
13 would have had it all under control eventually.

14           Other things that helped: having people  
15 knowledgeable enough to know how to re-energize the UPS's  
16 available at the time. That was a plus. There was a  
17 certain --

18           MR. KAUFFMAN: Is that normal, that people know  
19 how to do that, or was that some expertise that just  
20 happened to be there that day?

21           MR. CONWAY: I think there are enough people that  
22 know that, because of the way they have the shifts  
23 complemented out -- I want to say that the people of my  
24 vintage, for instance, we had some training on doing that  
25 because we were involved extensively in the start-up program



1 here. There were enough of us that were involved or working  
2 with marking these things up for maintenance that, I think,  
3 the diversification of enough people were on each shift that  
4 knew how to do it -- I guess I'm just pointing out that I  
5 was lucky enough to have one on my shift at the time.

6 MR. JORDAN: Do you know if it's the normal  
7 training program to have people know how to do that?

8 MR. CONWAY: I don't believe it is.

9 MR. JORDAN: In your normal routine, refresher  
10 training or anything like that, there's not a normal --

11 MR. CONWAY: We don't cover how to restore from a  
12 loss of all UPS, no. I mean, that's something you don't  
13 even conceive of happening.

14 MR. JORDAN: Okay.

15 MR. CONWAY: We talk about transfers back and  
16 forth, what causes them, that kind of thing, and how they  
17 work. Of course, that how-they-work type thing, coupled  
18 with the way the failure looked, we didn't observe it as a  
19 load problem, because all of them went. All but that one  
20 series -- every one of them -- had tripped. For that  
21 reason, we didn't feel it was a load problem; it was just a  
22 matter of getting the power back. Whether or not it was  
23 available was -- [Pause]

24 MR. JORDAN: I'm just curious about what  
25 parameters you were monitoring. You stated you had an



1 individual at the -- was it 603?

2 MR. CONWAY: The 601.

3 MR. JORDAN: The 601?

4 MR. CONWAY: Yes.

5 MR. JORDAN: -- that was looking at the level and  
6 pressure and maintaining the level with the RCIC.

7 MR. CONWAY: Correct.

8 MR. JORDAN: You mentioned you had somebody that  
9 at least -- You got reports back on a continuous basis; you  
10 said once every minute or some period of time.


11 MR. CONWAY: Three minutes, sure.

12 MR. JORDAN: Well, you felt comfortable knowing  
13 your knowledge of at least level and pressure. What other  
14 parameters did you have a feedback or a person that, while  
15 you were in the condition, for the 30 minutes or  
16 whatever --

17 MR. CONWAY: I was getting parameters on drywell,  
18 primary containment conditions --

19 MR. JORDAN: On a continuous basis?

20 MR. CONWAY: Not on a continuous basis. When I  
21 got the initial set of parameters for the containment, I  
22 felt that there was no cause for concern in the containment,  
23 other than the slowly rising temperature; we started taking  
24 action to correct that. Once we got power back, of course,  
25 I know Mike Eron was looking into the printers to try to



1 figure out how to get some jumpers in, to get the unit  
2 coolers back running, because ultimately we would have ended  
3 up in those.

4 We tried our LOCA bypass, which is our normal way  
5 of --

6 MR. JORDAN: Oh, they didn't come back on as soon  
7 as you got power back to them?

8 MR. CONWAY: When we got power back on, we then  
9 had power to allow the LOCA bypass switch relays -- the  
10 switch is actually relays to bypass the contacts. Those  
11 relays were de-energized when the UPS's went down, so, even  
12 with our LOCA bypass switches on, we could not restart the  
13 fans; the valves were fine, but we couldn't tell the fans,  
14 Hey, the valves are really open, because the relays wouldn't  
15 pick to allow that function to occur. Once we got the UPS's  
16 re-energized, it was just a matter of going back and  
17 restarting the fans to get drywell cooling restored, and  
18 that's exactly what we did.

19 MR. JORDAN: Did you have somebody go out locally  
20 to reset the relays?

21 MR. CONWAY: The control switches are on one of  
22 the panels in the back of the control room.

23 MR. JORDAN: Okay.

24 What other parameters did you have somebody  
25 stationed at to give you some type of a feedback? Level,






1 pressure, containment --

2 MR. CONWAY: After we got our power back to the  
3 UPS's, somebody was monitoring power at 603.

4 MR. JORDAN: Did you have somebody monitoring  
5 power before that?

6 MR. CONWAY: Prior to that, no. After the initial  
7 report Mike Eron gave us that EPRMs were down-scale -- I  
8 think Dave Hanczyk was back there with him, too -- Mark  
9 Davis, I think, was driving in detectors at that time. I  
10 think, as a matter of fact, Dave Hanczyk asked, Well, how  
11 are we going to know what power is if we're coming down? I  
12 said, Well, we can always look at the meters, the IRM meters  
13 on the back panels, on the drawers. He says, All right;  
14 I'll go check those. I know he went and looked at them -- I  
15 believe he did. I don't know specifically that he did. He  
16 never gave me a report back that he did, but Mark Davis was  
17 telling me that we had down-scale indications on IRMs when  
18 they would come in, so he was giving me feedback from that  
19 aspect -- that, yes, power was tracking down -- and then,  
20 when we got our front-panel meters restored, we got reports  
21 that we're on SRMs now and that they're trending down, also.

22 MR. JORDAN: I'm somewhat confused. You  
23 originally went back and looked at the EPRMs that were  
24 indicated down-scale, the LPRMs that were indicated down-  
25 scale, which indicated that the reactor power was down.



1 MR. CONWAY: Less than 4 percent, yes.

2 MR. JORDAN: Less than 4.

3 And that was early in the program.

4 MR. CONWAY: That was one of the first things we  
5 did.

6 MR. JORDAN: Okay.

7 MR. CONWAY: We knew where pressure was; we knew  
8 where level was; we needed to plan where power was.

9 MR. JORDAN: Okay. Then, from that time until you  
10 got power back, with your 601 panel -- is that what it is,  
11 the main panel? Is that 601 or 603?

12 MR. CONWAY: It's 603, where the full-core  
13 displays are.

14 MR. JORDAN: Okay, the 603 panel.

15 -- until you got power back to your NIs from the  
16 603, who was doing what as far as power goes?

17 MR. CONWAY: I didn't assign somebody specifically  
18 to monitor power.

19 MR. JORDAN: Okay.

20 MR. CONWAY: I believe Mark Davis was doing that,  
21 when he could. I know he was driving in detectors, and I  
22 don't know if he was going back and checking it or not. I  
23 didn't get any further reports until after we got power  
24 restored, and that we were on SRMs.

25 MR. JORDAN: Okay.



1           MR. CONWAY: I believe he had driven the detectors  
2 in and he was ranging down on the range switches, because he  
3 had down-scale alarms in on that 603 panel. So I believe  
4 he was monitoring it, and I believe one time he also  
5 reported to me that IRMs down-scales are in, but, until the  
6 chart recorders got power back, we couldn't track them on  
7 the front panel, and I don't think he felt comfortable  
8 enough to leave the front to go to the back to check, but  
9 you can ask him.

10           MR. JORDAN: Okay.

11           MR. KAUFFMAN: I guess I have a couple more  
12 follow-up questions.

13           This one I brought with me from Washington,  
14 because of the 50.72 report that initially came in. It said  
15 that pressure control was lost at the start of the event,  
16 and I was wondering where that came from, if you guys said  
17 that or we got it wrong on our end or I have a  
18 misunderstanding.

19           MR. CONWAY: I have never said that, and up to  
20 this point I have never heard we had lost pressure control.  
21 I've got to believe that, based on the load reject that we  
22 took because of the main transformer fault, yes, in fact,  
23 pressure did go high enough to pick up two SRVs on pressure-  
24 relief function. If that constitutes loss of pressure  
25 control then that's why they said that, but I don't believe



1 at any time I had lost control of pressure, and I was taking  
2 actions, if I felt I was getting that way, to control it,  
3 and I did.

4 MR. KAUFFMAN: Who made the red phone calls here?

5 MR. CONWAY: Our communicator. Initially it's  
6 done from the control room by our rad waste operators, who  
7 are trained as communicators. Basically, they read the fact  
8 sheet that's prepared by our shift emergency plant  
9 coordinator and authorized by myself as the SED. They read  
10 that to the red phone line.

11 MR. KAUFFMAN: You don't recall signing anything  
12 like that.

13 MR. CONWAY: That might have come from the TSC,  
14 but no.


15 MR. KAUFFMAN: Okay.

16 MR. CONWAY: All we made mention of was loss of  
17 annunciators and that all rods weren't in and that kind of  
18 stuff. The rod position was unknown, and level and pressure  
19 were stabilized.

20 I'm not sure where that came from. That's  
21 interesting, though. I wouldn't even perceive it that way.

22 MR. KAUFFMAN: Ultimately I can go back to  
23 Washington, I guess, and if need comes up we can have them  
24 play the tape, because those are all taped.

25 This week has all been kind of hectic for me, too.






1 In fact, I had a good Tuesday. I was not working Tuesday.  
2 When I came in, I grabbed the reports that were there and  
3 talked to people about what happens. I may have, in haste,  
4 misread it, or it might not have been a report from when you  
5 were there. I don't recall the specifics of the 50.72 phone  
6 call.

7 MR. CONWAY: It was approximately three hours in,  
8 I believe, that TSC called over and had one of the -- I  
9 think it was, as a matter of fact, Tom Tuttle at the time --  
10 asked him to check on a few indications. One of the things  
11 he was looking at was SRV temperatures. As soon as he read  
12 the recorder, he said he showed two that had spiked  
13 significantly higher than the rest, or showed two spikes, I  
14 should say. He said that may have indicated an SRV. He  
15 reported that to me, and I said, Well, keep the TSC informed  
16 and let them know what happened.

17 At that time, we suspected that those two had  
18 lifted, so we initiated our procedure for cycling our  
19 drywell vacuum breakers, which is supposed to be done within  
20 two hours. Of course, we didn't even think that we actually  
21 had an SRV. We had no way of telling that; no one had seen  
22 the valve actuate, as far as indication of the change. And  
23 our annunciation was lost. That first ten minutes was a lot  
24 of unknowns in there.

25 One of the things we didn't think to look at was



1 that recorder. There was no power to that recorder, anyway;  
2 it wouldn't have shown anything. At least I don't believe  
3 there was power to it. Obviously there was something, or  
4 the residuals were still there from when they opened, to  
5 show the spikes. I'm not sure.

6 MR. KAUFFMAN: I guess another question I had was  
7 what you've said and what we've heard from other places:  
8 that the RO recommended a scram, and I guess my basic  
9 question is just the background and what's the policy on  
10 when ROs initiate scram, when they recommend scram.

11 MR. CONWAY: Well, I had already come to that  
12 conclusion and was basically waiting to hear what power was.

13 MR. JORDAN: At your ASSS?

14 MR. CONWAY: That's correct.

15 MR. JORDAN: That's the assistant?

16 MR. CONWAY: The assistant station shift  
17 supervisor.

18 MR. JORDAN: Your assistant. Okay.

19 MR. CONWAY: He becomes the legal STA once we  
20 enter the emergency plan.

21 MR. JORDAN: All right.

22 MR. CONWAY: He had just come from the back panel.  
23 I was at the 601 panel, looking at the level and pressure.  
24 I recognized that some event had occurred, other than just  
25 the loss of the annunciators, and, when I had turned my head

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The goal is to ensure that the information gathered is both reliable and comprehensive.

The third section provides a detailed breakdown of the results. It shows that there has been a significant increase in certain areas, while other areas remain relatively stable. These findings are crucial for understanding the overall performance and identifying areas for improvement.

Finally, the document concludes with a series of recommendations based on the data. It suggests that certain strategies should be adopted to optimize performance and reduce costs. The author also notes that ongoing monitoring and reporting will be necessary to track progress and make adjustments as needed.



1 to look at the 603 panel, on 602 recirc pumps had down-  
2 shifted and I had come in at that point. At that minute, he  
3 said, I recommend we scram. I said, I agree.

4 It's ultimately my call to direct that, unless one  
5 of the reactor operators -- or senior reactor operators, for  
6 that matter -- feels that conditions warrant that, and they  
7 don't need to wait to be told to do that.

8 MR. KAUFFMAN: My question was really, is it a  
9 requirement they do it? Is it a courtesy? Is it something  
10 that, if they're not really sure, they tell you what they  
11 think and let you make the decision?

12 MR. CONWAY: That's correct, and they're always  
13 told that: if they're not sure, they're supposed to raise  
14 that question, of course, to the SSS, and he makes that  
15 decision. That's why I get the big bucks, right?

16 MR. JORDAN: Right.

17 [Laughter.]

18 MR. KAUFFMAN: You got the big bucks for what  
19 happened on Tuesday.

20 MR. CONWAY: Right.

21 MR. KAUFFMAN: Another question I had is, I guess  
22 a lot of people eventually came up to the control room, and  
23 I guess the question of crowd control and how you maintain  
24 control of the people and how you got them to do what you  
25 wanted without losing control of them and having all those




1 people running around doing things you didn't want to do --  
2 just how you handled that whole thing.

3 MR. CONWAY: Congestion in the control room -- it  
4 started building a couple times. What I did is, I just  
5 grabbed the first person I saw, and I would say, Clear  
6 everybody out of here that isn't actively doing something  
7 right now. The control room is getting very congested and  
8 noisy. I could have yelled out, Hey, everybody shut;  
9 anybody that doesn't belong here, get out of here. But I  
10 know Mark Davis had assigned people to do certain functions,  
11 as to the CSO, because I had given him tasks to perform.  
12 Rather than just clear everybody out and then find that  
13 those people were actually doing something over here, I  
14 wanted to let this person -- I had to do that twice, and  
15 the person that I did assign that to, they would walk; they  
16 would ask somebody, Do you have business here, or are you  
17 just hanging -- because that's our assembly area, also, and  
18 that promotes that congestion. If they said no, then they  
19 were asked to move someplace else in the control room; the  
20 noise was becoming a bit much, and the congestion.

21 That's how I ended up clearing the control room  
22 twice.

23 MR. KAUFFMAN: It was really two parts. It's how  
24 just basically you can manage it, how you control the crowd  
25 and then to some degree how you kept track of what






1 everybody was doing and --

2 MR. CONWAY: Through Mark Davis -- I would  
3 continually check with him on what's the progress on the  
4 board, the hoppers, who's working on it, you know, and he  
5 would say so-and-so is working on that, so-and-so on this,  
6 this and that. He knew who was doing what where and of  
7 course the people in the control room that I had assigned  
8 positions I kept aware of them.

9 You know, like I assigned one of the other CSOs  
10 they had coming in the duty of following along with what we  
11 are doing here and OP-101-C, our shutdown procedure, and  
12 verify, try to parallel it and confirm and one of the things  
13 he pointed out was our cooldown rate is limited from normal  
14 temperature down to 450 degrees because they're worried  
15 about crudburst and complicated chemistry controlling the  
16 core and he pointed that out to me after I had R.J.  
17 Reynolds, who was controlling pressure and at that point we  
18 had started a cooldown rate that I told him 100 degrees an  
19 hour was his rate and don't exceed that. He had just -- I  
20 don't think he had even started yet. He was still in the  
21 pressure stabilization type process when Bob Spooner had  
22 pointed that out to me, that 25 is the limit and then of  
23 course at that time I corrected, made the correction to my  
24 order to limit down to 25 down to 450.

25 MR. KAUFFMAN: If the people in the plant ran into



1 problems or had questions they were dealing with the CSO?

2 MR. CONWAY: Yes, unless there was something that  
3 they felt needed to be brought specifically to my attention  
4 or Mark would bring them over to me and say this and this  
5 and this and we would make the necessary decisions.


6 A lot of them were done as a group like that. We  
7 would get together and talk as a group -- here's what our  
8 plan, here's how we're going. We've got a lot of  
9 contingency backup in case this fails or this fails. We  
10 look like we are in good shape here.

11 MR. KAUFFMAN: Can you recall any problems that  
12 the people out in the plant had that needed to be brought up  
13 and resolved?

14 MR. CONWAY: One of the those problems was after  
15 the TSC got mad and the OSC everything had to go through the  
16 OSC as far as for accountability process, right?

17 That as far as I am concerned bottlenecked our  
18 recovery. I mean it slowed it right down because we had to  
19 physically at first send people over to the OSC, which is at  
20 Unit One and then they would be dispatched as part of a  
21 damage control team out to the plant, which later on we got  
22 them to change that into just notifying them who was going  
23 out and where but initially that's how they were running it.  
24 Boy, that slowed it down a lot!

25 MR. JORDAN: How did you communicate with the OSC



1 in Unit One?

2 MR. CONWAY: Through our communicator. Gus had a  
3 phone number we could dial. We found out what the phone  
4 number was.

5 MR. JORDAN: Was communications available? I mean  
6 was --

7 MR. CONWAY: We don't have a direct line to the  
8 OSC. To the TSC we do and basically we would tell people,  
9 you know, the TSC, that we are sending people out to go do  
10 this and then they would notify the OSC and then the OSC  
11 would call and say, hey, you need to send them over here.  
12 We'd say "Aw-w-w."

13 MR. JORDAN: How about just normal communications.  
14 I mean you'd use the telephone, okay. Is that because the  
15 communications was lost or that is the normal method you  
16 would have done it like to the TSC or the OSC?

17 MR. CONWAY: TSC is done by phone.

18 MR. JORDAN: Okay, how about the OSC?

19 MR. CONWAY: OSC we do not have a dedicated line  
20 for that but of course any phone in the control room could  
21 have called them.

22 MR. JORDAN: So that is how your normal  
23 communications --

24 MR. CONWAY: With the OSC.

25 MR. JORDAN: If you hadn't lost your power



1 supplies, okay, you would still have had the problem with  
2 the communications that you had with the TSC -- not the TSC  
3 but the OSC.

4 MR. CONWAY: I don't know if I would call it a  
5 problem, other than the fact that it was more of a  
6 procedural type thing.

7 MR. JORDAN: Okay.

8 MR. CONWAY: Right? They were saying, oh, you've  
9 got to come over here to do it. It wasn't really a  
10 communication type thing.

11 MR. JORDAN: Okay.


12 MR. CONWAY: Initially the only communication  
13 problems were okay, we couldn't make an announcement to  
14 everybody on the site, in the Two site, right?

15 Unit One had to make that call and the Gaitronics  
16 merge when either stations makes, sounds one of the station  
17 alarms -- the fire alarm, the station alarm or the  
18 evacuation alarm, both systems merge and the announcements  
19 are heard at both stations simultaneously, but we lost our  
20 Gaitronics and so their station announcement -- they heard  
21 it at their station but nobody at our station did.

22 MR. KAUFFMAN: Was there some kind of a  
23 contingency or backup to deal with that?

24 MR. CONWAY: Not that I am aware of.

25 I was asked to speculate on that the other day and





1 my answer to that was I would have probably contacted  
2 security and had them dispatched to various locations of the  
3 plant and make sure people were kept informed that they were  
4 supposed to be at their assembly areas.

5 Of course there were very few people on site at  
6 that time anywhere so when Security was notified that that  
7 was occurring they stopped everybody from coming in and that  
8 helped for accountability purposes and notification of  
9 people.

10 The Gaitronics of course -- one half is powered  
11 off of one UPS and the other half is powered off the other  
12 UPS and then our radio system, Leaky Wire, is powered off a  
13 third UPS, so chances of losing all three simultaneously  
14 were pretty --

15 MR. JORDAN: -- remote but it happened.

16 MR. CONWAY: -- remote but it happened, yes.

17 MR. JORDAN: So you don't know when you notified  
18 Unit One to notify the plant whether or not that  
19 notification actually went into Unit Two or not? Or you do  
20 know?

21 MR. CONWAY: We did not hear any announcement over  
22 the Gaitronics in the control room, let me put it that way,  
23 and we would have heard it -- we routinely hear it every  
24 Friday they test their station alarms and we test ours.

25 MR. JORDAN: Okay.



1 MR. CONWAY: And we usually hear theirs in the  
2 control room and I didn't hear it, so I've got to believe it  
3 did not go out.

4 MR. KAUFFMAN: I've got some more good questions  
5 here.


6 One of the questions I have was as the UPS's got  
7 re-powered and started getting their annunciators back, how  
8 did you go about I guess looking at them and figuring out if  
9 there are more problems. How did you just handle the  
10 situation of the alarms coming back.

11 MR. CONWAY: The people on those boards handled  
12 it.

13 For instance, Brian Hilliker was assigned a 601  
14 panel. He was over there running RCI and then I had him  
15 relieve Eric Hoffman for moderating level and pressure  
16 because he is a reactor operator and Eric was just non-LOP  
17 initially. He was all I had so I stationed him there. I  
18 wanted my ROs doing other things.

19 He responded accordingly by the procedure to the  
20 alarms that were in. If he felt that something needed to be  
21 brought to my attention he was going to do that.

22 I did not give any specific directions on, you  
23 know, if there are any abnormal alarms, let me know.  
24 Everybody knows. If it's abnormal, they're going to let me  
25 know. They have to. The procedure will even say notify the



1 SSS right in it and so as the alarms came back in, of course  
2 some of them were fast flash, some slow flash, which means  
3 the condition had been an alarm and cleared, they would have  
4 kept me notified.

5 I didn't get any notification of anything abnormal  
6 from annunciators that were received or cleared, that I  
7 recall.

8 MR. KAUFFMAN: I guess these two are kind of tied  
9 together here. It just occurred to me now and it might have  
10 been a good thing to write them all down since -- I guess  
11 the printer and stuff wasn't working then but --

12 MR. CONWAY: Oh, I see, yes. Hindsight.

13 MR. KAUFFMAN: It just occurred to me too, but  
14 that's like one of our assistant SSS's was -- he had gotten  
15 there early also and he was walking around with a pad of  
16 paper, keeping a rough log of what was going on.

17 MR. KAUFFMAN: That was my next question --

18 MR. CONWAY: When I saw this log --

19 MR. KAUFFMAN: That's where a lot of this  
20 information came from. No offense to -- I guess it is your  
21 writing in here early on --

22 MR. CONWAY: This is me, yes!

23 MR. KAUFFMAN: It's kind of sloppy and then when  
24 the event happened it gets neat and --

25 MR. CONWAY: What we did was, this log was

2  
3  
4  
5



1 generated from I've got to say three sets of notes, one that  
2 was kept by Jerry Hilliker, who had come in after the event  
3 had occurred. I am not sure specifically what time he came  
4 in.

5 He and I together worked out the site emergency  
6 director checklist to make sure we were doing everything we  
7 had to do prior to being relieved by the TSC.

8 Don Bosnick, who was the Assistant SSS that was  
9 oncoming, who had come in early to start a turnover, he had  
10 kept some notes, and then Mike Garbus, who is one of our  
11 CSOs on relief shift who had also started keeping a rough  
12 log from approximately seven o'clock on when he came in.


13 In between all those three notes, basically  
14 between Mike Eron, Mark Davis and myself, we read through  
15 what they had written down and filled in blanks where they  
16 weren't sure of what was going on when and then I told Don,  
17 put in a log, Don, and that is where this log came from.

18 So it is not like we were writing during the whole  
19 thing. I personally -- the only place I was writing was on  
20 the EOP boards. That's where I was doing my writing.

21 MR. KAUFFMAN: We would be asking other questions  
22 I think if the reactor melted but you kept a really good  
23 log!

24 [Laughter.]

25 MR. KAUFFMAN: So -- this is kind of an EP





1 question again that just occurred to me. Do you know what  
2 you would do if say you hadn't restored the UPS's and the  
3 TSC is now up and activated, right, and they want  
4 information on point parameters and this, that and the other  
5 and your SPDS is down, your computer is down -- well, I'm  
6 guessing. I would guess in the E-Plan there is some way to  
7 get information to the other emergency response facilities  
8 that need if the primary means are down.

9 MR. CONWAY: The communicator, the communications  
10 aide who is in the control room, of course is in direct  
11 communication with the TSC the whole time and with the  
12 communicator on the other end and they have I believe a data  
13 sheet they ask for parameters for and basically he would say  
14 ask me or someone else -- I think Don Bosnick who as a  
15 matter of fact was taking care of a lot of that because I  
16 wasn't aware of them asking for anything --

17 MR. KAUFFMAN: What about the old paper method?

18 MR. CONWAY: Basically the paper method, yes.  
19 They had a checksheet and for different parameters and they  
20 would have asked for those and if we had the  
21 instrumentation available we would have given them what  
22 they wanted. If not, then it would have been sorry, not  
23 available or we would have tried to figure out how to get  
24 that information for them, if it was important.

25 You would be reading it to them and they would



1 have a similar sheet on the other end of the phone and  
2 writing it all down and that's how they would get it.

3 MR. KAUFFMAN: I used to run drills. We'd break  
4 these sort of things to force the communications channels  
5 because that is a real good way to check the effectiveness  
6 of the communications in the organization if you are a drill  
7 controller is to interject something and see how long it  
8 takes to come out the other end.

9 MR. CONWAY: There is also another method. Of  
10 course they have the remote video camera that is controlled  
11 from the TSC.

12 MR. KAUFFMAN: Oh, I didn't see those up there.

13 MR. CONWAY: It's in the control room and I don't  
14 know when they pull the lens cap off but of course from  
15 that they can -- zoom in, zoom out and they can get a lot of  
16 the front panel information themselves. They can watch me  
17 pull my hair out, do anything they want, so that was  
18 available as another information-gathering device.


19 MR. KAUFFMAN: Where is that --

20 MR. CONWAY: I have no idea.

21 MR. KAUFFMAN: That's a rhetorical question.

22 MR. CONWAY: I understand. That didn't need an  
23 answer, eh?

24 MR. KAUFFMAN: Well, let's see. Anything on my  
25 list that we didn't cover? We might let Mike talk about



1 this one.

2 MR. JORDAN: Maybe we've already explored this and  
3 I have missed the concern, and that's if you didn't get the  
4 UPS back in a half an hour and it would have continued to be  
5 out, what was the major problems that you had? I mean  
6 you're into this thing half an hour and the adrenalin now is  
7 down to the point where you are doing something that is  
8 pretty stable, hopefully stable. What were your major  
9 problems that you had as far as if this thing went on for a  
10 long period of time that you had to overcome?

11 MR. CONWAY: The level was fairly well under  
12 control. The pressure was under control. Establishing a  
13 permanent form of heat sink would have been difficult. For  
14 instance, no vacuum indication would have been -- they had  
15 no idea what was going on in condenser vacuum and that was  
16 another thing I did. Somebody said, well, we don't know  
17 what the condenser vacuum is doing right now and we had  
18 half, that was when we had half a bypass valve open, right,  
19 so I'm like -- yeah, we better send somebody out to look at  
20 that, so I dispatched a non-LOP -- well, actually I think I  
21 told Jim Graff send somebody out to check condenser vacuum  
22 locally and get back to us on what we have.

23 MR. JORDAN: And did they do that?

24 MR. CONWAY: Because Gaitronics was down, the  
25 Leaky Wire system is down, they had to go out to the plant



1 and then get their reading and then come back to the control  
2 room.

3 MR. JORDAN: Did they have problems in doing that?  
4 Do you know?

5 MR. CONWAY: Did they?

6 MR. JORDAN: Yes.

7 MR. CONWAY: I didn't receive a report that there  
8 was difficulty doing it other than they were breathing hard  
9 when they got back.

10 I think that may have been the guy that reported  
11 the CAMs were alarming out in the turbine building, you  
12 know, and of course one of his responsibilities is to see if  
13 it is reading anything and get out of the area.

14 MR. JORDAN: Okay. We had some indication there  
15 were some lighting problems and I think you alluded to it  
16 earlier, that there was some lighting problems.

17 MR. CONWAY: I wasn't aware of any in the control  
18 room.

19 MR. JORDAN: As far as the control room lighting  
20 you noticed no degradation of the lighting system?

21 MR. CONWAY: I don't recall ever noticing it.

22 MR. JORDAN: Do you know what kind of lighting  
23 problems they had out in the plant?

24 MR. CONWAY: I understand that --

25 MR. JORDAN: What reports did you get?





1 MR. CONWAY: -- that control building lighting was  
2 out. I didn't receive any reports during it. Afterwards, in  
3 the debriefing it came out that lighting was out.

4 MR. JORDAN: As far as these guys who went out and  
5 coming back to you --

6 MR. CONWAY: No one said anything about the lights  
7 were out or anything like that.

8 MR. JORDAN: -- their access to and from to get  
9 this information, they didn't report anything to you about  
10 problems with lighting being out?

11 MR. CONWAY: No, they didn't.

12 MR. JORDAN: And the difficulty of transversing  
13 from one point to another?

14 MR. CONWAY: No, they didn't, not until the  
15 debriefing. It came out in the debriefing. Luckily  
16 everybody had their trusty flashlight though that we are not  
17 really required to carry but everybody does, at least the  
18 plant operators.

19 Most plant operators don't leave the control room  
20 without a flashlight or to go out in the plant so everybody  
21 had their flashlights.

22 MR. JORDAN: Okay.

23 MR. CONWAY: I don't know if I fully answered your  
24 question.

25 MR. JORDAN: You did. I was just curious.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



1           MR. CONWAY: If it took longer we would to have  
2 come up with other contingencies and we were working on  
3 that. We were working on getting steam condensing available  
4 on RHR Alpha. That was going to be our secondary backup  
5 method, right, for if we couldn't tell what was going on in  
6 the main condenser and bypass valves.

7           MR. KAUFFMAN: Some plants aren't analyzed because  
8 of piping or whatever to use it, steam condensing mode.

9           MR. JORDAN: Have you ever used it?

10          MR. CONWAY: Yes. We used it during the startup  
11 and test program, I know that.

12          MR. JORDAN: Do you train on it?

13          MR. CONWAY: Yes. In the simulator we train on  
14 how to use that.

15          MR. JORDAN: Okay.


16          MR. CONWAY: So I think it would have taken a  
17 little bit longer to finally get to a stable, a more stable  
18 condition -- I don't want to say -- because it was stable  
19 during that time period anyway.

20          MR. JORDAN: But your main concern, you lost --

21          MR. CONWAY: As far having problems?

22          MR. JORDAN: You had eventually lost your heat  
23 sink and you recognized that so you are addressing the loss  
24 of heat?

25          MR. CONWAY: Alternate methods of heat sink.



1 MR. JORDAN: Of heat sink and as one of the  
2 concerns if this thing would have gone for a long period --

3 MR. CONWAY: We had to look at long term, right.  
4 We also had talked about making the high pressure core  
5 spray pump injection valves available and that was always  
6 available the whole time as a make-up source, high pressure  
7 make-up source.

8 We always had that available also. This was  
9 before, you know, we got control with the booster pumps and  
10 stuff, always had that available as an option for a make-up  
11 source so we had an option for heat sink and pressure  
12 control and an option for inventory make-up source.

13 MR. JORDAN: So what were we going to use for an  
14 option for pressure control?

15 MR. CONWAY: Steam condensing. Steam condensing  
16 does both.

17 MR. JORDAN: Does both.

18 MR. CONWAY: It will take steam off the reactor  
19 and condenses it and you can control your cool down rate on  
20 and off, just raise or lower level and that would have  
21 helped as our pressure control and ultimately the service  
22 water system is the heat sink.

23 MR. JORDAN: Okay. Any other things you have got  
24 as far as long term concerns? What you are saying is the  
25 communications, you circumvented that by sending people



1 running in and out, okay? And so that got to be less of a  
2 problem. It was a difficult problem but that was taken care  
3 of and I understand you were going to be using the RHR for  
4 the ultimate heat sink as well as pressure control and you  
5 are going to use HPCS or HPCI, HPCS I guess is what you have  
6 here --

7 MR. CONWAY: As a backup to RCIC.

8 MR. JORDAN: As a backup to RCIC once RCIC's  
9 pressure gets down too low or RCIC is no longer functioning.  
10 Can you throttle the injection valve?

11 MR. CONWAY: We did not make it throttle-able. At  
12 the time we had discussed it, Mike Eron and I, had talked  
13 about that and Mark Davis that it was always available the  
14 whole time and we talked about it was always available. We  
15 could have started it and injected at any time --

16 MR. JORDAN: And you could throttle that valve?

17 MR. CONWAY: And we have a procedure in our EOP  
18 support procedure, the EOP-6, that allows us to make that,  
19 tells us how to make it throttle-able. We have to lift a  
20 lead out and a panel.

21 MR. JORDAN: Maybe you covered this also and I  
22 missed it.

23 Did the scenario of loss of annunciators and  
24 without the loss of your full core display -- have your  
25 people been trained on that?





1 MR. CONWAY: No. We have not. We have not trained  
2 on loss of annunciators.


3 MR. JORDAN: You lost a bunch of annunciators.  
4 Did you get any in?

5 MR. CONWAY: Yes. There were six alarms that were  
6 in and would not acknowledge. They were on the 601 panel,  
7 the 100 block, the first block there. There were four in a  
8 row and then the two below it were I think the 630, P-630,  
9 annunciator power supply failure -- I think that's what  
10 those read, those two, and the four directly above it which  
11 deal with service water were flashing and why those four  
12 above it came in I have no idea. I don't know how they  
13 related.

14 MR. JORDAN: And the two below? What do they  
15 mean?

16 MR. CONWAY: They mean that panel 630, one of our  
17 major annunciator panels down in the relay room, had lost  
18 power or they wouldn't acknowledge. We tried acknowledging  
19 them but they still wouldn't acknowledge and of course no  
20 audible alarm for them at all.

21 MR. JORDAN: Okay. As far as taking action  
22 outside of the EOPs, was there any actions that you took  
23 that says this -- or your procedures that you felt that in  
24 order to not do this you would just as soon not do it and  
25 chose not to do it?



1           Was there any actions that were required to be  
2 done by your EOPs or by your procedures that you had  
3 difficulty in doing? You said this procedure requires this  
4 but we are not quite in this condition and therefore we want  
5 to do this instead?


6           MR. CONWAY: No. I can't recall a single one.

7           MR. JORDAN: So you didn't have to use the 5054.X  
8 or anything else as far as your directing your people, that  
9 says, hey, I'm outside my tech specs --

10          MR. CONWAY: No. I guess the only thing that  
11 would have been along that line would have been get me the  
12 UPS's back. That was the direction I gave the operators I  
13 sent out. You know, once I got the report back that all the  
14 UPS's had tripped I sent Dave Hanczyk and a couple other  
15 guys out in the plant, you know, I need to get those UPS's  
16 back, do what you have to do.

17          That was the only other direction I gave that was  
18 not proceduralized per se. Everything else through the  
19 EOPs and our normal procedures that we were trying to  
20 parallel through the whole time. Everything worked well.  
21 You know, like the condensate booster pumps startup  
22 procedure complicated feedwater because we could not get  
23 that suction valves open and get flows through --

24          MR. JORDAN: You couldn't get the section valve  
25 open because of the --



1 MR. CONWAY: -- the DP on the valves.

2 MR. JORDAN: And you couldn't get the DP opened  
3 because of the fact that --

4 MR. CONWAY: One of the problems we had there --

5 MR. JORDAN: Why didn't go ahead and open them  
6 anyway?


7 MR. CONWAY: They tried that. They physically  
8 would not open but there is a large DP on it and those  
9 valves just don't operate against a large DP.

10 MR. JORDAN: They just wouldn't open.

11 MR. CONWAY: Correct. The other thing that  
12 probably complicated this was the fact that we lost the DRMS  
13 computer, which is like our rad monitoring computer and when  
14 we had these CAMs alarming we couldn't go to that and say,  
15 hey, here's what we really got -- we don't have anything  
16 else going on there, and they were the little portable ones  
17 out there, right, that they have out monitoring the building  
18 that were in alarm.

19 They probably went on rate of change because the  
20 rad levels changed or something. I never did get a report  
21 back why they were alarming but it was probably something  
22 simple -- all the rad levels dropped off.

23 MR. KAUFFMAN: Were there any places in the EOPs  
24 where the EOP put you in a loop and it was on something that  
25 maybe didn't seem important or good and you said, boy, the



1 EOP here has got me stuck and wasting my people and time on  
2 things that I could be better using elsewhere?

3 MR. CONWAY: The only time I felt even close to  
4 that was when I was in C-5 and I got the little override in  
5 RP that says the reactor's shutdown and no boron has been  
6 injected; start a cooldown.


7 Then there is also a precaution there that says if  
8 power starts to right or something, return it, B or  
9 something like that, and that brings you back in as a  
10 different form -- tells you to stop the cooldown, basically.

11 I read that and I wanted to apply it over here  
12 over on C-5 also but I couldn't because that particular  
13 permission was not given there. Because of that, you know,  
14 it didn't complicate things but that was the only time I  
15 felt that it would have been nice to have that over here  
16 too. I would have got out of C-5 and gone right into RL and  
17 normal water level control, but it didn't gain me anything  
18 and I didn't lose anything by doing that.

19 MR. JORDAN: The loop was the -- what was the  
20 loop? What was that? What was the restriction on C-5 that  
21 you were --

22 MR. CONWAY: It didn't give me the out I guess you  
23 could say, the permission to leave that, similar to the RP.

24 MR. JORDAN: I guess I don't understand what  
25 portion of it you were in that was difficulty. I mean





1 you're talking about rod control and we're talking about  
2 pressure. We're talking about level.

3 MR. CONWAY: Our C-5 is the power level control  
4 procedure.

5 MR. JORDAN: Okay.

6 MR. CONWAY: It gives me instructions on what I  
7 can use for injection, how I can inject, and what my band  
8 is.

9 MR. JORDAN: Okay.

10 MR. CONWAY: And once you get through the  
11 instructional type stuff you go down to the stop sign type  
12 device at the bottom and that basically says either all rods  
13 in or --

14 MR. JORDAN: All rods in? Is that what the loop  
15 was?


16 MR. CONWAY: That was down in there and that was  
17 what was keeping me in C-5. I knew I was already shut down  
18 and no boron had gone in and that was allowing me to cool  
19 down by RP but I still had to maintain a C-5 for level  
20 control purposes.

21 MR. JORDAN: And all rods in is what kept you in  
22 C-5?

23 MR. CONWAY: Correct.

24 MR. JORDAN: For level control.

25 MR. CONWAY: Correct.



1 MR. JORDAN: Even though you had your sufficient  
2 indication that the power was done --


3 MR. CONWAY: Correct.

4 MR. JORDAN: What you are saying is that you  
5 couldn't get out of C-5 because of --

6 MR. CONWAY: I'm saying that was the only thing  
7 that really boggled -- I don't want to say boggled me or it  
8 seemed -- I mean obviously if you are over in the RPB  
9 control ones those are formatted and you are very  
10 comfortable with that.

11 Here I am in a C-5 which we have routinely, you  
12 know always -- it seems like I always get the ATWS in  
13 training. I don't know why but it just seemed funny that  
14 that was not there and of course we have covered it in  
15 training before and there are purposes that you can cool  
16 down but in the event that you do start having a recovery of  
17 power because you are not fully shut down as you are cooling  
18 down you are already in C-5 and that can give you direction  
19 to lower level.

20 Now the leg of C-5 that I was in, of course,  
21 almost parallels with the exception of a few notes and  
22 restrictions and the systems you are allowed to inject with,  
23 the RL leg for the level condition I was at so there was no  
24 impact other than the fact that I felt more restricted  
25 because I couldn't use that in this case to get out of C-5.



1 MR. JORDAN: So there were systems but besides the  
2 fact of the no rods you felt there were systems you could  
3 use for injection that weren't allowed on -- I am trying to  
4 figure out what the restrictions were, the difference  
5 between two.

6 MR. CONWAY: The ones in C-5 are all the systems  
7 inject outside the shroud, so you always get pre-heating,  
8 RCIC, condensate feed water, CRD and boron, right?

9 MR. JORDAN: Okay.

10 MR. CONWAY: Whereas over in RL you can use those  
11 things plus it gives you HPCS and LPCS and all these other  
12 ones that of course are major distributors.

13 MR. JORDAN: Because you were in C-5 you were  
14 restricted? You couldn't use HPCS?

15 MR. CONWAY: Correct.

16 MR. JORDAN: Because you were in C-5.

17 MR. CONWAY: That's correct.


18 MR. JORDAN: You couldn't use LPCS, you were in C-  
19 5.

20 MR. CONWAY: Correct.

21 MR. JORDAN: Because they inject inside of the  
22 shroud, is that what it is?

23 MR. CONWAY: That's correct.

24 MR. JORDAN: Okay, and that's the restriction that  
25 you said because I've got these systems and I would like to



1 use them if I could and you were in a condition that you  
2 felt -- of course they were available the whole time anyway  
3 and ultimately if it became a problem you would end up using  
4 them anyway. It was by the way you routed around in C-5 --

5 MR. KAUFFMAN: I don't have any more.

6 MR. JORDAN: I don't have any more.

7 MR. KAUFFMAN: We would like to thank you for your  
8 time.

9 MR. CONWAY: Okay.

10 [Whereupon, at 2:05 p.m., the taking of the  
11 investigative interview was concluded.]

12

13

14

15

16

17

18

19

20


21

22

23

24

25





REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: Int. of MIKE CONWAY.

DOCKET NUMBER:


PLACE OF PROCEEDING: Scriba, N.Y.

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



JON HUNDLEY

Official Reporter  
Ann Riley & Associates, Ltd.



# OFFICIAL TRANSCRIPT OF PROCEEDINGS

**Agency:** Nuclear Regulatory Commission  
Incident Investigation Team

**Title:** Nine Mile Point Nuclear Power Plant  
Interview of: MIKE CONWAY

**Docket No.**

**LOCATION:** Scriba, New York

**DATE:** August 17, 1991

**PAGES:** 1 - 77

**ANN RILEY & ASSOCIATES, LTD.**

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950.


~~9305100183~~


1  
2  
3



ADDENDUM TO INTERVIEW OF MICHAEL S. CONWAY STAF. SHIFTS SUPER.  
(Name/Position)

Page	Line	Correction and Reason for Correction
6	11	EPR TO APRM : TERMINOLOGY CORRECTION
7	6	EPRM TO APRM : " "
10	21	STRIKE / REMOVE THE "I" : NOT RELEVANT & MAKES NO SENSE
12	1	CHANGE FWT TO BLACK IE: NO POWER AVAILABLE/INDICATED
15	8	ADD 'IN' FOLLOWING PHRASE TO MAKE MORE SENSE
16	3	RCE TO RCIC : CORRECT TERMINOLOGY
16	13	RCE TO RCIC AND THAT IT "WAS" RUNNING, NOT "WASN'T"
17	2	CHANGE LB-10'S TO LV-10'S : TO CORRECT TERMINOLOGY
18	9	202.3 FROM 2023 : WHICH IS WRONG
20	7	SHIELD TO SEAL : CORRECT TERMINOLOGY
20	21	MBANS TO MAINTENANCE : CONTEXT REFERENCE
21	19	RAD TO ROD : CORRECT TERMINOLOGY
22	11	PURSING TO PURSUING : TYP
23	6	" QUOTE : UNCERTAIN WHY THIS IS IN THIS LINE
24	13	ARCH OR T RTR : CORRECT TERMINOLOGY
26	8	INC TO IDC : CORRECT TERMINOLOGY
26	12	INC TO IDC : " " "
26	17	RAD WIDTH TO ROD WIDTH : CORRECT TERMINOLOGY
27	15	RAD TO ROD : CORRECT TERMINOLOGY
28	14	RPS TO RPY & OP TO EOP : TERMINOLOGY CHANGE
28	15	WEIGHT TO WAIT : PROP. TERMINOLOGY
31	8	RNC TO IDC : PROP. TERMINOLOGY
31	17	RFS TO RPS : " "
32	6	RFS TO RPS : " "
33	1	PLANNA TO POINTS : CONTEXT REFERENCE
36	14	S ET AL TO S @ ALL : PROP. TERMINOLOGY
36	19	AS COI TO COOL : " " "
44	25	FRONTAL TO FRANT : CONTEXT REFERENCE
45	17	FINKS TO FANS : CONTEXT REFERENCE
46	7	EPRMS TO APRMS : PROP. TERMINOLOGY
46	22	" " " " " "
52	2	AND I HAD TO <sup>AND</sup> ARI HAD COME IN : CONTEXT REFERENCE

Page 1 of 2 Signature  Date 10/2/91





ADDENDUM

<u>Page</u>	<u>Line</u>	<u>Correction and Reason for Correction</u>
55	15	MAD TO MANNA : CONTEXT REFERENCE
57	15	MODERATION TO MONITORING : CONTEXT REFERENCE
59	16	NON-LOP TO NON-LOT : CORRECT TERMINOLOGY
61	2	HILLKIRK TO HILLKIR : CORRECT NAME
63	17	ADD "PARENTS FROM" : ADD CORRECT CONTEXT REFERENCE
73	8	MIGHT TO RISK : CONTEXT REFERENCE
74	21	ALL ROSS IN TO ALL ROSS NOT IN : CORRECT PROCEDURE REFERENCE
75	1	DOWN TO DOWN : CONTEXT
75	8	RPB TO RPV : PROPER TERMINOLOGY

Date 10-7-91

Signature







UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
INCIDENT INVESTIGATION TEAM

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

-----  
Interview of :  
MIKE CONWAY :  
(Closed) :  
-----

Conference Room B  
Administration Building  
Nine Mile Point Nuclear  
Power Plant, Unit Two  
Lake Road  
Scriba, New York 13093  
Saturday, August 17, 1991

The interview commenced, pursuant to notice,  
at 12:12 p.m.

PRESENT FOR THE IIT:  
John Kauffman, NRC  
Mike Jordan, NRC

1. 1. 1.

2. 2. 2.

3. 3. 3.



## P R O C E E D I N G S

[12:12 p.m.]

1  
2  
3 MR. KAUFFMAN: Today's date is August 17, 1991.  
4 We're in the P building at Niagara Mohawk power unit number  
5 2. My name is John Kauffman. I'll be leading the  
6 interview. I'm with NRC/AEOD.


7 MR. JORDAN: I'm Mike Jordan. I'm with the NRC,  
8 out of Region III. I'm a section chief.

9 MR. CONWAY: And I'm Mike Conway. I work for  
10 Niagara Mohawk. I'm a station shift supervisor.

11 MR. KAUFFMAN: Great. Now that we have the  
12 preliminaries out of the way, I'd just like to have Mike  
13 start off and tell us a little bit about his previous work  
14 history, background, education, number of years on the job,  
15 et cetera.

16 MR. CONWAY: Okay. Prior to working for Niagara  
17 Mohawk, I graduated from high school; I never went to  
18 college; I joined the Navy and became a Navy nuke. I spent  
19 six years in there, aboard submarines out of Charleston,  
20 South Carolina. Then I got hired by Niagara Mohawk.

21 When I first came to work here, I got hired as an  
22 auxiliary operator at Unit One. I was sent to license class  
23 and received a hot license, reactor operator, at Unit One,  
24 at which time there were several of us that did that, and  
25 then we were sent to Unit Two, which was in the construction



1 phase.

2 MR. KAUFFMAN: What year was it you were hired on  
3 as an aux operator?

4 MR. CONWAY: November, 1982.

5 MR. KAUFFMAN: When did you get your license?

6 MR. CONWAY: The first license -- I want to say  
7 that was February -- around that time -- early '84.


8 MR. KAUFFMAN: And then you stood shift --

9 MR. CONWAY: I didn't have any operating time.  
10 Basically, I believe, the company's philosophy at that time  
11 was to obtain a hot license on Unit One and then start  
12 learning Unit Two, which was in construction, because we had  
13 to obtain cold licenses, and they felt that that would give  
14 us a good basis and background for a cold license on Unit  
15 Two. It worked pretty well. I successfully passed a Unit  
16 Two cold license reactor operator exam.

17 MR. KAUFFMAN: When was that? Do you know? A  
18 long time ago?

19 MR. CONWAY: I don't remember the specific dates  
20 here, or time. That's on record someplace. I'm sure you  
21 can obtain that information.

22 I spent at least five years as a reactor operator  
23 at Unit Two, control room operator, plant operator. The way  
24 we work our shift program is, we rotate in plant and in  
25 control room for responsibilities.



1           Then, a year and a half ago, I was sent to senior  
2 reactor operator class, and last August I passed the exam.  
3 Prior to that, I was in the union. Once they send you to  
4 class and you get your SRO, they offer you a management  
5 position, and I was offered a station shift supervisor job  
6 and accepted and started December 1 of last year.

7           MR. KAUFFMAN: In the Navy, you were --

8           MR. CONWAY: Machinist's mate.

9           MR. KAUFFMAN: I'm just trying to establish  
10 background.

11           I guess the next thing we'd like to talk about is  
12 the August 13 event that you were station shift supervisor  
13 for, the plant conditions prior to the event and then what  
14 you saw and what you did.


15           MR. CONWAY: Okay. We were just finishing up a  
16 midnight shift. It was approximately 10 of 6 in the  
17 morning, and we had 100 percent power, preparing our shift  
18 turnovers. The work was done for that shift.

19           MR. KAUFFMAN: Can I interrupt?

20           MR. CONWAY: Sure.

21           MR. KAUFFMAN: One thing I haven't heard from  
22 anybody is the power history, how long the plant had been up  
23 and operating before this.

24           MR. CONWAY: It's funny you should say that, and  
25 it's one of those things we knock on wood when we say; we





1 kind of keep track of how long we've been on the grid and  
2 stuff like that. It had been about 121 days we had been  
3 operating, and of course, I knocked on wood after I said,  
4 Yes, 121st day, on the shift brief and stuff like that.

5           We were doing our turnovers, and I think Mike  
6 Eron, my assistant, was reviewing the shift checks. Most of  
7 the plant operators were getting ready for their turnovers.  
8 I was at my desk in the control room, and we heard a pop,  
9 kind of a popping sound. When I looked up from preparing my  
10 turnover, I noticed all the annunciators in the control room  
11 were out. They were not lit, any of the ones that were  
12 previously lit.

13           An eerie silence type thing. Normally you hear  
14 typers printing or the hum of fans blowing, power supplies,  
15 that type of thing. Everything went quiet. Of course, I  
16 ran out of the office and asked what happened, what's going  
17 on. It looked to me like some sort of a power failure. It  
18 was very hard to tell immediately. Obviously, when you  
19 lose all the annunciators, that's related to a power supply  
20 problem.

21           We immediately checked what power level and  
22 pressure were on the 603 panel, and the records had all  
23 stopped, and indicators had failed either up-scale or down-  
24 scale, some of them as-is.

25           One of the odd things about it was that the




1 instrumentation seemed to be not functioning, and the alarms  
2 didn't function at all, and all the computer CRTs went  
3 black, but we still had indications for all motors, the red-  
4 green lights, for valve positions, red-green lights -- we  
5 still had all those type of indications still available.  
6 Over on the electric plant boards, we still had a meter  
7 indication available for all power, for all our electric  
8 supplies to the different switch gears and stuff.

9           When I got the report that, we can't tell what  
10 power is because chart recorders had stopped, I yelled out,  
11 Somebody check the EPR meters in the back. I believe it was  
12 Mike Eron that went to the back, he and another operator --  
13 I'm not sure which one; I want to say Dave Hanczyk, but I'm  
14 not sure.

15           While they went to the back, I immediately walked  
16 over to the 601 panel and looked at the PAM recorders, post-  
17 accident monitoring, and noted that they had tripped to fast  
18 speed. They normally run on slow but trip to fast speed  
19 when certain initiating conditions occur -- high reactor  
20 pressure or low water level in the vessel. They were  
21 running. Pressure was about 940, and vessel level was  
22 getting about 175, 180, in that range, and they were running  
23 at fast speed. It looked like a flat-line trace.

24           While I was there, I turned and looked at the 603  
25 panel. I noticed that the recirc pumps had down-shifted to




1 low speed and that, on what we call the Rubik's Cubes, or  
2 the redundant reactivity control system, on 603, we had an  
3 indication of an ARI, alternate rod insertion, and a down-  
4 shift of the pumps.

5 At that time, I think, Mike Eron came up from the  
6 back panels and said the EPRMs are reading down-scale. He  
7 said, I recommend we place the mode switch to a shutdown. I  
8 said, I agree; some event's going on. I directed the CSO to  
9 place the mode switch in shutdown.

10 At that time, people started performing their  
11 immediate actions for the prior procedures for a scram.  
12 During that time, I was also receiving reports. Somebody  
13 said, It looks like the feed pump has just tripped. At that  
14 time, I believe, I assigned one of the non-licensed  
15 operators, Eric Hoffman, to watch level and pressure on the  
16 601 panel and keep me informed of the status, if you see any  
17 changes in the trends.

18 Then I turned around to our EOPs laying on top of  
19 the computer CRT in front of the 601 panel. I turned around  
20 to that, and I asked power, level and pressure. They gave  
21 me the readings, and I'd jot them down on the boards there,  
22 just as a formality, to try to focus on what I need to do  
23 next.

24 I got the report that the level was starting to  
25 slowly lower, so I ordered RCIC initiated, and I believe



1 Mark Davis started. He reported a problem -- it appeared  
2 after he initiated that the speed was oscillating, and he  
3 ended up having to take manual control. I was inquiring, Do  
4 we have injection flow yet, and he said, Not yet; it looks  
5 like one of the inboard check valves did not open. Then he  
6 said, Okay, now I have indication of flow.

7 Let's see. What happened next?

8 MR. KAUFFMAN: Did he put it in manual?

9 MR. CONWAY: He placed the speed controller in  
10 manual. It's a flow speed controller type arrangement, and  
11 he placed it in manual. That steadied the flow out. The  
12 speed, pressure, and flow were all oscillating around, and  
13 that stabilized RCIC at that time.

14 MR. KAUFFMAN: Then he got the injection valve.

15 MR. CONWAY: Well, the injection valve had opened,  
16 but we were waiting for the inboard check to swing open. I  
17 don't ever recall him saying that it did swing open, but it  
18 did show that we were getting injection flow and we had a  
19 slowly rising trend in level at that point.

20 Also, simultaneously with that, pressure slowly  
21 started coming down, because RCIC was spraying in on top of  
22 the steam bubble inside the core.

23 I guess, prior to RCIC restoring the level, the  
24 level dropped down to a low enough value, 159.3. I think I  
25 received a report from the operator that the level was now






1 down to 159, and at that time I entered the emergency  
2 operating procedures; that's one of our entry conditions.

3 I made that declaration to everybody in the  
4 control room, that we had entered those; again, received  
5 reports on where we were. Once I entered the EOPs, I  
6 followed down through the RQ leg, which is dealing with  
7 power. Pressure was fairly stable -- we didn't have a  
8 problem with that -- and level was still lowering, but we  
9 had RCIC injecting, and I was expecting it to turn, at which  
10 time it did slowly start turning it.

11 I was in the RQ leg. I realized at that time that  
12 one of the conditions to exit RQ if there was a non-scam  
13 condition is all rods into at least 0-2. I realized at that  
14 time that we could not tell what the position of the control  
15 rods were, because the full-core display had gone black. We  
16 couldn't tell from the rod worth minimizer or the rod  
17 sequence control where the rods were. When we tried to  
18 select rods, of course, we couldn't tell where they were,  
19 either, on the full rod display.

20 At that time, I made the declaration to everybody,  
21 Be aware that, since we can't tell where the control rods  
22 are at this time, we believe we've had a scam, but -- since  
23 we can't tell the position of the control rods -- we are  
24 still in the RQ leg is EOPs, and that I'm exiting RL leg,  
25 which is our normal water level control in EOPs, and going



1 to C5, which is power level control, our contingency EOP.

2 I believe then, once I was in C5, I directed the  
3 ADS inhibit switches to be placed in on; that's one of the  
4 steps that has to be performed. Then I assigned, I think,  
5 another operator to come in, Brian Hilliker, who had come in  
6 early -- he was just starting a day shift -- to take control  
7 of RCIC and gave him a water level band, I believe, of -- I  
8 want to say 170 to 190 on wide-range indication.

9 MR. JORDAN: Who was that?


10 MR. CONWAY: Brian Hilliker -- I believe he was  
11 the operator assigned RCIC control.

12 MR. JORDAN: And he was on the next shift?

13 MR. CONWAY: He is actually a relief shift person  
14 who was coming in to work days. He had come in a little bit  
15 early.

16 MR. JORDAN: Okay.

17 MR. CONWAY: I also directed actions per -- you  
18 know, following down the RQ leg, is ARI initiated? I asked  
19 that question, and that report was, Yes, it had. I dropped  
20 through, got down, turbine was off the line, dropped  
21 through, I MSIV still open, got down to another decision  
22 block, where we have to start implementing actions per our  
23 EOP 6, our support procedure for taking action to insert  
24 control rods. I think the oncoming day-shift CSO was in at  
25 that time, also, and I assigned him that responsibility --



1 that was Dave Rathbun -- to do EOP 6, attachment 14, to  
2 start working that and seeing what we can do to insert  
3 control rods. I told him, I know at this time we don't have  
4 any indication, but we need to start working on something.

5           Sometimes during this time period, our aux  
6 operators all started coming back from downstairs -- all the  
7 lights had gone out in the control building, where they do  
8 their turnover -- and they came all running back up the  
9 control room to find out what was going on.


10           MR. KAUFFMAN: When you say lights off in the  
11 control room, you mean all lights, part of the lights?

12           MR. CONWAY: In the control room we still had  
13 lighting. As far as which lighting went out, you'll have to  
14 ask those guys; they were out there. I can't specifically  
15 say.

16           MR. KAUFFMAN: So the report to you, you don't  
17 remember.

18           MR. CONWAY: They never said anything about the  
19 lighting; they just all came running in. They saw that we  
20 were in some sort of event, that I was implementing the  
21 EOPs. I directed, I think, Aaron Armstrong and a couple  
22 other guys to go down to the normal switchgear building and  
23 down to the UPS's and check out what was going on; there  
24 must be a problem down there. Those guys went running out.

25           Of course, during this time we didn't have our



1 Gaitronics available, either. We noticed that was flat. We  
2 wanted to make a station announcement, the reactor scram,  
3 call the troops. That wasn't possible.

4 Also, Al Denny, who was our shift emergency plan  
5 coordinator, approached me somewhere in this time frame and  
6 showed me his recommendation for classifying the event based  
7 on EAP-2. He recommended site area emergency, based on loss  
8 of control of annunciators and a transient in progress. As  
9 soon as I read that, I said, I concur. I made the  
10 announcement to the control room. That was like 6 o'clock.

11 MR. KAUFFMAN: This whole discussion here is all  
12 in about 10 minutes.

13 MR. CONWAY: All in about 10 minutes -- a lot of  
14 things going on at once.

15 I believe at that time Mike Eron says, I'll call  
16 Unit One and have them make the announcement, because we  
17 didn't have our Gaitronics available. He went into the  
18 clerk's office, I believe -- or he did it at the phone desk;  
19 I'm not sure where he did it, but he made the phone call to  
20 Unit One. We didn't hear the announcement, because, of  
21 course, our Gaitronics were out. I assumed that they had  
22 done that, because then people started taking actions  
23 accordingly.

24 Eventually -- I want to say from the time I  
25 entered the EOPs, which was, I want to say, three to five





1 minutes after the initial event occurred, through the next  
2 five minutes, we eventually turned level. I don't remember  
3 the lowest it goes; I want to say 140 was the lowest at that  
4 time, before level started turning and coming back up.


5           Meanwhile, pressure was starting to slowly decay  
6 off. It was down in the 800s at that time, as RCIC started  
7 turning levels. The level was coming up, and the pressure  
8 was slowly starting to come down.

9           MR. KAUFFMAN: Is that normal for the decay heat  
10 you had or after other scrams?

11           MR. CONWAY: Is that normal? I would say I would  
12 expect it to do that because RCIC was running; it uses steam  
13 from the vessel as motive steam, and it also sprays inside  
14 the core.

15           MR. KAUFFMAN: I'm really asking your plant-  
16 specific -- You know, at some plants you might expect that  
17 it won't bring pressure down, based on what people see after  
18 transients; and at some plants you might say, yes, it takes  
19 enough steam, and that brings it down.

20           MR. CONWAY: I expected this type of thing to  
21 happen, and of course I had continuous updates on what level  
22 and pressure were from Eric Hoffman. He was keeping me  
23 pretty well informed. Every minute, I've got to say, he was  
24 giving me an update on what was going on. I was becoming  
25 aware of the fact that level was going up, was rising, and



1 pressure was lowering. Since we were in RQ and C5, we could  
2 not commence a cool-down until we knew where our control  
3 rods were. I was being very conscious of that and starting  
4 to get worried. This seemed to be our only injection  
5 source.

6 At the time, it looked like pressure, level were  
7 under control. Power was less than 4 percent, so it looked  
8 like we weren't in an ATWS condition because of the way the  
9 plant was responding.

10 MR. KAUFFMAN: Can I interrupt with a question  
11 here real quick?

12 MR. CONWAY: Go ahead.

13 MR. KAUFFMAN: You said it was your only injection  
14 source. Did you not have CRD? Did something happen?

15 MR. CONWAY: CRD was also running.

16 MR. KAUFFMAN: Okay.


17 MR. CONWAY: I tend to overlook that as an  
18 injection source. It's a very small quantity.

19 MR. KAUFFMAN: Sure.

20 MR. CONWAY: Yes, it was running and injecting, I  
21 guess you could say, at that point.

22 MR. KAUFFMAN: Okay.

23 You recognized that the EOPs wouldn't let you cool  
24 down at the point I interrupted. It was your only source --  
25 RCIC was --



1           MR. CONWAY: I was starting to inquire about those  
2 other sources. We knew that all the instrumentation -- I  
3 also inquired on the drywell parameters. I think I assigned  
4 one of the guys coming in to find out what drywell pressure  
5 is; I need to know what drywell pressure and a full set of  
6 drywell parameters. I think it was Jay Lawrence I asked; he  
7 was one of the oncoming shift personnel, also.

8           At this time, people were starting to filter, a  
9 few at a time, into the control room. As soon as people  
10 were coming in, I was directing them out. I sent one of the  
11 other non-LOPs out, for instance, to check down on the local  
12 instrument panels on the reactor building, 261. I asked him  
13 to check level and pressure at the instrument racks down  
14 there to confirm what our level and pressure -- that the  
15 instruments that we were reading were in fact accurate. I  
16 was fairly comfortable, because both PAM recorders were  
17 indicating the same, both Div 1 and Div 2. These instrument  
18 racks, of course, they are strictly analog indicators,  
19 direct hook to the vessel, and there is no way that these  
20 can be misleading me. Since there was no Gaitronics, he had  
21 to run all the way down and come all the way back with a  
22 report. And, yes, his report confirmed that level and  
23 pressure were where we thought.

24           Let's see.

25           Right now the level is rising, the pressure is




1 lowering. It's going to get concerned with cool-down.

2 I made that apparent to Brian Hilliker, who was  
3 controlling RCI -- Brian, watch our pressure, I don't want a  
4 cool-down, don't drop below 600 pounds I believe I told him.  
5 I think I wrote down EOPs maintain 500 to 600 or something  
6 like that. I may have given him that band. I don't  
7 remember. At that time I think was just making him aware  
8 that we're cooling down -- that we don't want to cool down,  
9 maintain it above 600 pounds.

10 Level was back up in the normal band, I want to  
11 say in the 180s, in that range, when it looked like we were  
12 going to have a problem with pressure, that it was going to  
13 start lowering, continue to lower because RCI wasn't running  
14 and injecting and I had him stop injection with RCI at that  
15 time.

16 Level continued to rise and pressure continued to  
17 lower, get down to about 590 pounds and I was getting pretty  
18 concerned. It looked like one time it had stabilized and  
19 that was only for it looked like a period of a minute and  
20 then the next report I got was that, yes, it's still  
21 lowering.

22 Then I became conscious of another problem. The  
23 booster pumps, booster pumps were still running and I was  
24 concerned that once we dropped below their shutoff head that  
25 I asked close -- you know, I'm worried about injection from






1 the booster pumps at this time. We don't want that to  
2 happen, let's close the LB-10s for the feed pumps and then  
3 the report back was I got that we can't, they are locked up,  
4 we don't have any power to them, at which time I said does  
5 it look like we may be injecting with the booster pumps and  
6 they said we don't know, we can't tell. The instruments  
7 aren't registering that, at which time I said, very well,  
8 secure the booster pumps. We don't want injection from that  
9 source and during that time it was reported that the level  
10 had gone above 202 on their wide range recorders, the PAM  
11 recorders. The pressure was down around I want to say 530  
12 pounds. I'm not real specific on the pressure. If I had a  
13 flow chart in front of me I could tell you about where we  
14 were but it was in the 500 range and level had gone off our  
15 indicator at that time.

16 MR. KAUFFMAN: Quick question. Did you just think  
17 that the booster pumps injecting or was there some  
18 procedural guidance that led you to that?

19 MR. CONWAY: I was aware of the fact that the  
20 booster pumps could inject, especially if the LV-10s were  
21 open. That would have been the only flow restriction in  
22 their flow path and since they had several options closed  
23 the feed pump discharge valves, which take about -- well, it  
24 seems to me about five minutes a stroke -- I don't think  
25 they take quite that long, close the 21s which are the feed



1 header stops and the same type thing. They're long-winded  
2 valves so I felt that securing the booster pumps was the  
3 surest way to stop injection if there was any from the  
4 booster pumps and the way the level was rising I had to  
5 believe with RCI secured, you know, we are going to get a  
6 combination of the level swell from cool water injection and  
7 I was concerned that, yes, they were injecting.


8           So we have a procedure that says if we reach Level  
9 8, which is 2023, and if we believe we have booster pump  
10 injection we're supposed to take action to prevent that from  
11 happening because they are worried about over-filling the  
12 vessel, flooding up to the steam lines and then taking away  
13 pressure control.

14           During this time bypass valves appeared to be  
15 controlling pressure stable. That's when it was maintaining  
16 it around 940 initially, then the report I got was we had  
17 half a bypass valve open and then it ended up dropping up to  
18 a quarter open and that was I think the last report I got on  
19 bypass valve position.

20           MR. KAUFFMAN: That was real early on.

21           MR. CONWAY: That was much earlier, yes.

22           That was back when I first entered EOPs. I  
23 dropped down through and found out what I am going to use  
24 for pressure control. It didn't look like -- you couldn't  
25 tell if any SRVs were cycled unless you were there when they



1 initially did. I guess we found out afterwards that two SRVs  
2 did actuate but initially at that time we did not know that.

3 I don't believe anybody saw that. I personally  
4 did not see any SRV actuation occur. Of course one of the  
5 key indicators of that is annunciation of the valve  
6 actuation and we didn't have that.

7 We were about I would say pretty close to 30  
8 minutes into the event now and the pressure was starting to  
9 stabilize right around mid-500s or mid to low 500s. Level  
10 was offscale high. We couldn't tell where it was when  
11 suddenly annunciators started coming back on and meters  
12 started coming back on scale and chart recorders started  
13 running and I breathed a sigh of relief and said, all right,  
14 we'd got annunciators and instrumentation back.

15 I immediately asked for a report of level. I  
16 still had an indication that it was still upscale, greater  
17 than 202.3 and shortly within I've got to say two or three  
18 minutes after that, it started coming back on and I got the  
19 report of 198 inches and lowering.

20 I then told one of the other operators that was in  
21 the control room -- I want to say Jim Graff, who had come in  
22 -- he's also a relief operator, he'd come in early for days  
23 -- to start making preparations to restart the booster  
24 pump. I wanted to be able to have those as an injection  
25 source.



1 I had -- somebody reported condenser vacuum was 23  
2 inches and it looked like it was slowly lowering and so we  
3 started making some plans at that time. More people had  
4 come in and we had -- I was working with Mark Davis to try  
5 to get a plan for him and Mike Eron what's going on here,  
6 and we talked about stuff like -- started getting aux  
7 boilers running so we can establish shield steam for the  
8 main condenser and utilize that as a primary heat sink.

9 Booster pumps of course, available so that we  
10 could have a reliable source of injection in addition to  
11 RCI.

12 What else? Work on getting the condenser removal  
13 pump started, the hoggers to work on our vacuum problem.

14 We talked about -- let's see, early on after I had  
15 ordered RCI started I also ordered suppression pool cooling  
16 on RHR alpha pump and so that was -- that was circulating.

17 We wanted to make plans to get RHR Bravo and  
18 Charlie, which were in an out of service condition. We had  
19 just marked them up to our maintenance earlier that shift  
20 si we had started taking action to get that back.

21 MR. JORDAN: Which one was on means?

22 MR. CONWAY: RHR Alpha -- or excuse me, RHR Bravo  
23 and Charlie. They were out of service ECCS pumps.

24 MR. KAUFFMAN: The work hadn't started. They were  
25 just more or less tagged out but --



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



1           MR. CONWAY: We had valves de-energized that we  
2 were going to do electrical PMs on and pump control switches  
3 were in pulled lock.

4           MR. KAUFFMAN: That's not on the floor. He could  
5 have gotten them back relatively easily by --


6           MR. CONWAY: All we knew is we sent people out and  
7 they cleared the tags on the valves, turned the breakers  
8 back on so they were on in fairly quick time.

9           What else were we doing? There was a lot going on  
10 at once. I remember I was giving updates, you know, during  
11 this time period to keep everybody informed of what was  
12 going on and where we were going, where we are now, here's  
13 what we're doing, control level and pressure.

14           One of our plans was to assign someone eventually  
15 to use the -- to the bypass valves but at this time we still  
16 didn't know -- well, wait a minute.

17           We got power back and we had -- I got the report.  
18 Finally, it took about ten minutes because we had to go  
19 around and check, using the Rad Select and between that and  
20 RSCS and we had to restart the rod drive control cabinet,  
21 and finally we got core scanned and we got the report that  
22 six -- we could not tell the position of six rods and I made  
23 that clear in my update.

24           MR. KAUFFMAN: You were the Emergency Director  
25 during all this time?



1 MR. CONWAY: Yes. One of the responsibilities of  
2 the shift Emergency Plan Coordinator, of course, is to  
3 assist me in implementing that duty. He makes -- he can  
4 make an initial recommendation on classification. He  
5 ensures all the notifications are made to outside agencies,  
6 for instance. That's part of his duty.


7 Also during the first few, I guess I'll say the  
8 first ten minutes Tom Tuttle, one of our STAs, had come in  
9 to relief Al Denny and I asked him if he would verify that  
10 we are doing everything we can do for loss of annunciators.  
11 This is prior to getting the power back so he was pursuing  
12 looking at that. We have had a procedure for loss of all  
13 annunciators but nobody thought we'd ever use that.

14 He was looking at that.

15 MR. KAUFFMAN: Did you have any problems sounding  
16 the sirens or making announcements?

17 MR. CONWAY: Once we got power back to the UPS we  
18 immediately made a follow-up announcement to let everybody  
19 know what was going on.

20 We also started getting reports that -- from the  
21 guys we sent out into the turbine building to start working  
22 on getting the aux boilers back and starting up the  
23 condenser air removal pumps, that were CAM, Continuous Air  
24 Matters in alarm in the building and of course we reported  
25 that to Rad Protection immediately and we made an



1 announcement to stay clear of the turbine building and then  
2 worked with Rad Protection to get people in and out and they  
3 were doing surveys of both the reactor building and the  
4 turbine building to find out what levels were in there.

5           It turns out there was no problem at all. They  
6 were I guess, quote, since we were running all our people  
7 through them, when they had to go out of the building they  
8 were keeping track of who was going where and that kind of  
9 thing along with our CSO. Of course he was keeping --

10           MR. KAUFFMAN: Maybe I'm jumping ahead. What time  
11 did you get relieved as the Emergency Director? We're not,  
12 it's not our charter to look extensively at the emergency  
13 planning aspects but certainly we're interested in how you  
14 got around your communications and how all the people coming  
15 in and being sent out in the plant and this and that and the  
16 other got handled.

17           MR. CONWAY: I got relieved as Site Emergency  
18 Director at 7:38 by Marty McCormick.

19           MR. KAUFFMAN: Did you ever start getting help I  
20 guess from the TSC and OSC?

21           MR. CONWAY: I found out afterward, it seemed to  
22 take an awful long time to me to even get communications  
23 from them. It turned out that there was a little bit of a  
24 problem at Security in that I found out, afterwards of  
25 course, that there was a couple TSC staff members that they

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

2. In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The goal is to ensure that the information is both reliable and up-to-date.

3. The third part of the document focuses on the results of the analysis. It shows that there is a clear trend in the data, which suggests that the current strategy is effective. However, there are some areas where improvement is needed, particularly in the way resources are allocated.

4. Finally, the document concludes with a series of recommendations. These are based on the findings of the analysis and are designed to help the organization achieve its long-term goals. It is important that these recommendations are implemented as soon as possible to maximize the benefits of the current strategy.




1 weren't letting them through even though they had emergency-  
2 related functions. That was just a matter that they had new  
3 ID cards issued, emergency ID cards and I think the guards  
4 just were not familiar with the new format and once they got  
5 that cleared up, they were in.

6           They got staffed up and then of course it was  
7 matter with me becoming comfortable with having time to turn  
8 over and so it wasn't like as soon as they got in there I  
9 was going to give it to them. I wanted to make sure the  
10 plant was in a stable condition, we had a plan of action and  
11 that we had backup contingencies like steam condensing  
12 available with all those normally de-energized valves for  
13 Appendix R purposes turned back on and available on Arch or  
14 Alpha in the event that we lost -- we couldn't maintain  
15 vacuum in the condenser -- that was going to be our heat  
16 sink.

17           When it looked like pressure had stabilized, we  
18 had gotten power back to our UPS's and we had a booster pump  
19 running finally and they were having problems getting  
20 injection into the vessel. Its level was starting to  
21 slowly lower.

22           It turned out the problem, they were -- comes with  
23 our, I guess our procedure has a start to booster pumps.  
24 They were worried always about our feed pump seals and would  
25 like to protect them, had a lot of problems with them in the






1 past, and what we did to start the booster pump back up was  
2 to close the suction valves for the feed pumps. My  
3 intention of course was to use the LB-55s, which are the  
4 high pressure, low flow feedwater control valves as a method  
5 of injection control in the vessel.

6           They couldn't get the feed pump suctions, the MOV-  
7 84 valves open because of the DP across them. The feed  
8 pumps were locked in. Downstream the MOV was like 200 pounds  
9 and upstream was like 700 and that was too excessive a DP  
10 and at that time we were restricting access to the turbine  
11 building and hadn't worked our plan out with Rad Protection  
12 yet and we hadn't gotten the survey results back and we  
13 couldn't send anybody in to it, which is where the location  
14 of the bypass valve is, to equalize around them.

15           They were feeding on the low flow, low pressure  
16 valve, the LV-137 at full capacity and the level was still  
17 lowering.

18           Got down to -- I started asking, well, you know,  
19 we need to find out what we can do and I think I assigned  
20 another operator to assist him and Jim Graff into working  
21 out what we can do to get injection we need to get that  
22 available.

23           I think the lowest level it got was I ended up re-  
24 entering EOPs on low water level when we crossed 159 again  
25 and we -- at about 140 inches I am thinking, the core is




1 still covered but we need to start thinking about getting  
2 RCI running again and available for injection.

3 I was just getting ready to get that work when my  
4 reports were the level looks like it's stabilized and it was  
5 at 133 inches and the next report I got after that was level  
6 is now 134 and slowly rising and it rose real slow.

7 During this time period still hadn't -- we were  
8 trying to get INC people in through the TSC. They were  
9 still being kept out off-site, into the building and  
10 computer people into the building to get the process  
11 computer restarted, the rad waste SPDS computer back up, get  
12 the INC guys in to -- INC people in to work on getting our  
13 control rod indication back.

14 We weren't sure where the rods -- we were showing  
15 a blank display on our four rod display and you couldn't  
16 tell -- we weren't getting the red full in lights on the  
17 RSCS and the rad waste minimizer was giving us conflicting  
18 information. It said all but one were in and then it said  
19 they're all in and then it would go back to all but one and  
20 we were getting conflicting data so we were still under the  
21 assumption that all rods were not in and we were operating  
22 under that restriction.

23 I had given direction to Jim Graff to feed slowly  
24 based on the fact that all rods were not in. We didn't want  
25 to get power excursions.




1 I told Mark Bodoh, who was watching level on 603  
2 to be conscious of reactor power and notify me if we have  
3 any increase in counts on our SRMs.

4 MR. JORDAN: What were you injecting with to turn  
5 the level? You got it down to 133 and then it started to  
6 come to 134.

7 MR. CONWAY: It was with the condensate booster  
8 pump through the low flow, low pressure valve which has a  
9 limited capacity. It's like a four inch line and I think  
10 we were getting between 400 and 600 gallons a minute and  
11 then we said he started a second condensate pump and that  
12 got a little bit more flow because it increased the  
13 discharge head of the booster pump.

14 So while were trying to work on getting people to  
15 get rad indication back, it looked levels started to turn.  
16 It was being taken in control but rising in a very slow  
17 rate. Pressure was still fairly stable and now starting to  
18 recover and come back up and slowly rise.

19 So we had pressure coming back up, level coming  
20 back up, pressure rose about 600 or 700 pounds I would lose  
21 my booster pump injection so I started thinking we need to  
22 stabilize pressure at this pressure range and I assigned  
23 that task to R. J. Reynolds on the turbine bypass valves. I  
24 said R. J., maintain 500 to 600 pounds; we are in an ATWS.  
25 We don't want to cool down. Be conscious that we don't have




1 vacuum stabilized yet. We don't have the hogger on. We  
2 don't have steam seals. We are working on getting the  
3 boiler and hoppers running but in the interim you need to be  
4 conscious of condenser vacuum so if you get -- if vacuum  
5 drops to 15 inches I want you to close turbine bypass  
6 valves to protect the condenser.

7           Let's see. We began cracking the bypass valve to  
8 stabilize pressure using the bypass opening jack and  
9 pressure at that time stabilized right in that range, around  
10 550. That level was still slowly, real slowly rising. Of  
11 course he was bleeding a little steam off and we were  
12 limiting the injection so it was coming up real slow.

13           During that time period Mike Eron pointed out to  
14 me in the RPD control of the OP there is an override in one  
15 of the weight blocks, or stop sign shaped block that gives  
16 you the chance that it says if the reactor is shut down and  
17 no boron has been injected you can continue past that stop  
18 and commence a cooldown.

19           At that time I asked what power was, so when he  
20 said ten to the third on the SRMs I said okay, we are  
21 definitely below the heating range and we haven't injected  
22 boron -- we can begin a cooldown.

23           One of our ODIs gives us a little description that  
24 part of our departmental policy is we feel that we are shut  
25 down if we are less than the heating range on IRMs, which is





1 less than range 6 or 7.

2 MR. KAUFFMAN: Sounds like a conduct of ops  
3 procedure, something like that.

4 MR. CONWAY: It is Operation Department  
5 Instruction on EOP implementation, lessons learned from  
6 simulator runs.

7 MR. JORDAN: What point is that? What's the  
8 condition you consider shutdown?

9 MR. CONWAY: On IRMs, below the heating range,  
10 which is range 6 or 7.

11 MR. JORDAN: So below 6 or 7 on the IRMs --

12 MR. CONWAY: We're fairly confident that we are  
13 shut down.

14 MR. JORDAN: As long as you are below the heating  
15 range.

16 MR. CONWAY: Correct and it was reported to me  
17 that we were on SRMs, about ten to the third.


18 MR. KAUFFMAN: We are probably interested in  
19 seeing that procedure. Do you happen to know the number of  
20 it? No?

21 MR. CONWAY: I don't remember the number of it,  
22 not specifically.

23 It gives that kind of guidance in there though.

24 MR. KAUFFMAN: Okay.

25 MR. CONWAY: It's not specific but we have been




1 trained on saying, yes, we can say that. Same thing with  
2 one rod is out. We know that our shutdown margin test covers  
3 the fact that our most reactive rod is fully withdrawn so if  
4 we had all but one rod full then we know we could still say  
5 we're shut down, fairly confident.

6           So he pointed that out to me and at that time we  
7 still had to stay in the power level control because it  
8 doesn't give me an out until all rods indicate in, so we  
9 were still in there for level control and it gives me a  
10 pretty wide band, minus 14 to 202 I think is my band at that  
11 point and I gave them the band. I changed the level band  
12 with the booster starting, 165 to 180, so that we didn't  
13 refill too rapidly and I told him to feed slowing and he  
14 said he was feeding as fast as he could anyway. The level  
15 was still coming up slow.

16           At that point things were starting to shape up a  
17 lot better. We had a lot more people in. Jerry Helker was  
18 in. He's -- I was asking him for advice and between he,  
19 myself and Mike Eron and Al DeGracia, who is head of the Op  
20 Support Department for us -- he was in also.

21           We were formulating a plan to where we were going  
22 to go and what we were going to do next and since we were  
23 now able to cool down, we could start lowering our pressure  
24 band and enable conditions to even get better.

25           MR. KAUFFMAN: About what time was this?



1 MR. CONWAY: This was right around the time I got  
2 relieved by Martin McCormick of the TSC, so it was about  
3 7:38.


4 It's written down here. Let's see -- 0630 I had  
5 all rods in except for six, the six control rods and 0700 we  
6 had finally got the indication that all rods were in and we  
7 had done stuff interim to that, trying to -- we hadn't  
8 gotten RNC techs in yet. We were working at EOP 6,  
9 Attachment 14, and one of the things we can do is reset the  
10 scram.

11 I think it was Dave Rathbun we felt that one of  
12 the reasons we may not have had indication of these rods is  
13 they may be over-driven in, and that by resetting the scram  
14 it may allow them to settle out to 00 and get an indication  
15 back so I said very well, let's take those actions.

16 Well, one of the things that we needed to do is  
17 then install the RFS jumpers. I said make it so, and he  
18 installed it. We reset the scram and we got our rod  
19 indication back at that point.

20 MR. JORDAN: And that is what you were looking for  
21 before you started cooling down, was the rod indication for  
22 the six rods?

23 MR. CONWAY: No. We didn't need that specifically  
24 because the RP leg says if you are shut down and no boron  
25 has been injected and the determination was mine that since



1 we were below the heating range on IRMs we were in fact shut  
2 down and that, you know, when I made that call and made the  
3 announcement that we were transitioning here to be conscious  
4 of power rising on SRMs, notify me immediately, I told Mark  
5 Bodoh, who was over on 603 panel.

6           Once we installed the RFS jumpers and reset the  
7 scram we did finally get an indication of all rods in and  
8 then it took a while for them to confirm that also, but they  
9 checked it on several sources and the rad` waste minimizer  
10 was showing still one rod and we had full-in on full core  
11 display and full-in on RSCS but our rad waste minimizer was  
12 still in and out whether or not whether that rod was in or  
13 not.


14           We had it at least confirmed on two different  
15 indications.

16           In any case, one rod is definitely within our  
17 shutdown margin requirement.

18           Shortly after that, the process computer got  
19 restored; the computer techs came in and restored the  
20 process computer.

21           MR. JORDAN: So you're saying you started cooling  
22 down around 7; is that what you said? I was just curious.

23           MR. CONWAY: Specifics as far as time? I don't  
24 remember a specific time that I gave that. Let me think  
25 here a minute.





1 I remember Mike had planned that out to me, Mike  
2 Eron. I don't remember specifically when that was, time-  
3 wise. I know it was before we had all the rods indicating  
4 full in, though.

5 MR. JORDAN: Okay.


6 MR. CONWAY: And that was at 0700. It had to have  
7 been 6:30, after we got our power back to the UPS's, and  
8 7:00, which is when all rods were indicated full in, except  
9 for -- yes, all rods were indicated full in at 0700.

10 MR. JORDAN: Okay.

11 MR. CONWAY: It had to have been fairly close to  
12 that time period, because we logged here we started the  
13 booster pump at 0640, and that was right after we had  
14 restored power. We had worked on getting that back; we had  
15 people out in the plant to do that.


16 We restored power to the UPS's at 0622.

17 Then, at 0738, I got relieved by Marty McCormick.  
18 I turned over to him where we were, what my intention were  
19 on what we do with the plant, and my feelings that things  
20 had stabilized fairly well and that I was interested in  
21 turning the site emergency directorate over to him. He  
22 said, Yes, he was ready, and we conducted a turnover over  
23 the phone. He relieved me of that function, and I made the  
24 announcement to everybody in the control room. We continued  
25 to cool down the plant.



1           You know, we placed RCIC in standby after making  
2           sure the booster pumps were running. We lowered our  
3           pressure band; we waited a full hour maintaining 500 to 600  
4           pounds so we'd ensure we didn't exceed our cool-down rate.  
5           I think at quarter after 7 I lowered the pressure band 300  
6           to 400 pounds.

7           Over the next couple hours, we just worked with  
8           getting things going. One of those things was trying to  
9           work with the OSC, ops support center, to get people in and  
10          out of the plant and get damage control teams out looking at  
11          UPS's. I discussed early with Marty McCormick about his  
12          interest in trying to get the UPS's back on their normal  
13          power supply and have the maintenance and DC available again  
14          as a backup. We formulated a plan, and we discussed this  
15          with Jerry Helker and Al de Gracia, Mike Eron -- the group  
16          of us in the control room, the senior management guys. We  
17          got together and came up with a plan of doing this, going  
18          from the Charlie and Delta, Bravo, Alpha, and Gulf, in that  
19          order, to minimize the possibility of losing one of them in  
20          the interim. We didn't know the status of the UPS's, other  
21          than that they were on a maintenance power. Doing the  
22          lighting ones first, Charlie and Delta were the minimum  
23          impact, other than that we would have lost half our  
24          Gaitronics system, our alarm announcement system, if one of  
25          them failed to transfer successfully. But we successfully



1 transferred all of them, except for the Alpha and Bravo,  
2 which were the major instrument bus suppliers.

3 My concern, of course, with those two was that at  
4 that time feedwater level control was in automatic on the  
5 LV-137, feeding with a booster pump, and the impact was that  
6 we could have lost that feedwater level control function.  
7 Everybody was aware of when we were doing that, and we were  
8 keeping TSC updated and posted.

9 Then we started shutting down our auxiliary  
10 systems, off-gas, steam generator-injectors. I got a report  
11 that the vent GEMS -- or, no, the stack GEMS -- had given us  
12 an alarm, saying it was inop, and we notified the dose  
13 assessment advisor, and he was going to get grab samples  
14 arranged for. We got results back.

15 MR. KAUFFMAN: Who is responsible for the samples?


16 MR. CONWAY: The chemistry department does it  
17 through the dose assessment advisor. They send out teams  
18 from the OSC to do that.

19 MR. JORDAN: Information like that gets fed  
20 through the control room, and then you feed it from the  
21 control room to the TSC; is that how that works?

22 MR. CONWAY: Correct.

23 MR. JORDAN: Okay.

24 MR. CONWAY: Of course, during this time, I was  
25 doing updates with Al Denny, the shift emergency plant




1 coordinator, 30-minute updates on where we were and where we  
2 were going, as far as further notification purposes.

3 Let's see. Did I forget anything?

4 We continued to shut down the auxiliary systems  
5 that we no longer needed that were part of the steam plant.  
6 During that time period where I was concerned about cooling  
7 down. I had ordered Jim Emery to work on using OP-101-  
8 Charlie, which is our shutdown procedure, to start closing  
9 off aux steam loads and steam drains to lower our pressure  
10 reduction. That helped stabilize things, too, finally, as  
11 far as pressure. That was back early on, though, before we  
12 got power restored.

13 Other things we did: We started our shift checks  
14 for -- we call them S et al., which covers all our  
15 different modes and assures we have the required  
16 instrumentation available to monitor the plant in all five  
17 modes of operation. It covers all those things. We started  
18 those to start checking our instruments.

19 Also, early on, it started the OSP-RCS at 001,  
20 which monitors your cool-down rate. Earlier on, we were  
21 concerned -- it was like shortly after we had declared the  
22 site area emergency, and I wanted somebody watching that  
23 specifically. I think it was Rich DeLong. He was watching  
24 that specifically and keeping me informed of what our rate  
25 was.





1 MR. JORDAN: He was monitoring the cool-down rate  
2 based on --

3 MR. CONWAY: He was using steam pressure and  
4 saturation tables to monitor the cool-down rate.

5 MR. JORDAN: Okay. That's what his function was,  
6 though.


7 MR. CONWAY: Yes.

8 MR. JORDAN: Okay.

9 MR. CONWAY: He ended up turning that over to  
10 somebody else, I believe, later on, but initially he was the  
11 one keeping track of that.

12 We also began restoring the things we had  
13 overridden -- ADS -- placed those back in normal -- ADS  
14 inhibits, which is back into normal -- and removed the RPS  
15 jumpers we had installed to reset the scram once we had  
16 risen above 159, the low scram setpoint, or reactor water  
17 scram setpoint.

18 During this time, Mike Eron was trying to get me  
19 to start a cool-down, and I was hesitant to do that, because  
20 my level was still low. I felt that, if I had started a  
21 cool-down and begun lowering, I was going to cook my level  
22 off, and then I would have less inventory. With lower  
23 pressure, granted, I might be able to get a little more  
24 injection flow, but I wanted to make sure level was back in  
25 a stable band. Once level got back up to 180 inches, I



1 directed the pressure band to be changed at that time --  
2 that in conjunction with the time period that all this  
3 occurred. So like at quarter after 7, I said, Okay, we have  
4 water level now, and now we can lower our pressure band 300  
5 to 400 at that time.

6 Eventually -- and it seemed like forever -- I got  
7 relieved.

8 MR. KAUFFMAN: What time was that?

9 MR. CONWAY: I want to say 11 o'clock, pretty  
10 close to 11 o'clock. I don't have the exact time written  
11 down in my log here, but right around 11 o'clock -- 10 of,  
12 something like that. We started a turnover. George Moyer  
13 was my relief.

14 MR. KAUFFMAN: You had an exciting morning.

15 MR. CONWAY: Yes. Then I went home and had a  
16 cocktail.

17 [Laughter.]

18 MR. KAUFFMAN: And had to get back in at midnight.


19 MR. CONWAY: That's right.

20 MR. KAUFFMAN: We won't get into how much shift  
21 work he's allowed to work.

22 [Laughter.]

23 MR. CONWAY: I met the requirement. You mean the  
24 eight hours off and all that?

25 MR. KAUFFMAN: Yes.



1 MR. CONWAY: I had the eight hours off. Is that  
2 what you mean by the shift work requirement? No more than  
3 16 hours, eight hours on the panel.

4 MR. JORDAN: So, during your time up until 11  
5 o'clock, was it the suction valves for the feedwater that  
6 were closed, so that you could not equal-pressurize around,  
7 so that you could get -- You were just using your -- You  
8 were feeding with your condensate booster through the --

9 MR. CONWAY: LV-137 valve.

10 MR. JORDAN: LV-137?

11 MR. CONWAY: That's correct.

12 MR. JORDAN: Okay.

13 So when you left, they were still feeding through  
14 LV-137? Was that the level?


15 MR. CONWAY: Startup valve, low-flow, low-  
16 pressure, feedwater control valve.

17 MR. JORDAN: Okay.

18 MR. CONWAY: I may have missed a few things here  
19 and there in my recollection of what happened, but a lot of  
20 things were happening at once.

21 MR. JORDAN: We're here for 10 days, trying to  
22 figure out what happened and reconstruct the event.

23 MR. CONWAY: I think the best reconstruction  
24 occurred at the initial debriefing, to tell you the truth,  
25 where we had everybody that was there inputting all the



1 information. That was all we did, and we ran it like our  
2 simulator critiques that we have at training. We don't tell  
3 people what we saw; we just ask -- what did you see, you  
4 know, and just poll everybody that was there. People supply  
5 everything. It pulls a picture together a lot better.

6 MR. KAUFFMAN: This question probably has been  
7 asked before, because Gene was here and it's Gene's favorite  
8 question: Were there any things that you would like to have  
9 had? Obviously, you'd like to have the UPS's.

10 MR. CONWAY: The UPS's would have been a nice  
11 thing to have back.

12 MR. KAUFFMAN: But do you have any ideas of things  
13 that could have made the response better or that you would  
14 like to have had that would have helped, or, for the things  
15 that you felt happened good, is there a reason that you  
16 think is important enough that everybody should have?

17 MR. CONWAY: The fact that we had a separation  
18 between normal instrumentation and, of course, divisional  
19 safety-related instrumentation was a major factor in helping  
20 figure out what we had now. When the event first occurred,  
21 we were scrambling to find out what we did have.

22 All our balance-of-plant equipment continued to  
23 run. The fact that we couldn't monitor it -- it still ran  
24 fine. That was, of course, a plus. We didn't have to deal  
25 with any major losses like loss of our condenser. That kind

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100




1 of thing would have really complicated things. I mean, it  
2 would have made it more difficult to stabilize the plant,  
3 but it could have been done, in my opinion.

4 That, alone, helped us grasp control, to assess  
5 what we had, take the necessary actions initially, and grab  
6 control of what we had and stabilize the plant with the  
7 minimum number of people we had there, until we could get  
8 more people coming in. It worked.

9 RCIC worked. There were little problems with  
10 control. The oil has to heat up, and we don't run it  
11 routinely; quarterly is about all we ever run it.

12 Those kinds of things all help pull it all  
13 together to tie it up.

14 We had, still, all our drywell parameter  
15 indications available from the divisional meters. We knew  
16 there was no concern with the drywell. Although drywell  
17 temperature was starting to rise, one of the reports I got  
18 was that drywell unit coolers had tripped off. Mike Eron  
19 specifically brought that to my attention, that temperatures  
20 were rising, pressure was slowly rising. I think the  
21 pressure got to 0.7 psig, and the highest temperature was  
22 reported at 165 by Jay Lawrence. He said he had one at 165,  
23 one at 150, and the other four were at about the 130- to  
24 140-degree range. I assessed that and felt that I didn't  
25 need to enter the primary containment EOPs. I knew that the




1 reason they were rising was that drywell cooling was off.

2           The fans had tripped. The cooling water valves  
3 were still lined up, which are primary containment isolation  
4 valves; they were still lined up. We didn't get an  
5 isolation. That would have been another thing. They come  
6 off another, separate UPS, the 3-series UPS, for all that  
7 primary containment logic and scram logic and all that. I'm  
8 thankful we didn't have a problem -- if primary containment  
9 had bottled up, with MSIVs shut, that would have pretty  
10 much sent us into using SRVs as pressure control and the  
11 suppression pool as our heat sink. That would have made  
12 things a little bit more difficult still, but I think we  
13 would have had it all under control eventually.

14           Other things that helped: having people  
15 knowledgeable enough to know how to re-energize the UPS's  
16 available at the time. That was a plus. There was a  
17 certain --

18           MR. KAUFFMAN: Is that normal, that people know  
19 how to do that, or was that some expertise that just  
20 happened to be there that day?

21           MR. CONWAY: I think there are enough people that  
22 know that, because of the way they have the shifts  
23 complemented out -- I want to say that the people of my  
24 vintage, for instance, we had some training on doing that  
25 because we were involved extensively in the start-up program



1 here. There were enough of us that were involved or working  
2 with marking these things up for maintenance that, I think,  
3 the diversification of enough people were on each shift that  
4 knew how to do it -- I guess I'm just pointing out that I  
5 was lucky enough to have one on my shift at the time.

6 MR. JORDAN: Do you know if it's the normal  
7 training program to have people know how to do that?

8 MR. CONWAY: I don't believe it is.


9 MR. JORDAN: In your normal routine, refresher  
10 training or anything like that, there's not a normal --

11 MR. CONWAY: We don't cover how to restore from a  
12 loss of all UPS, no. I mean, that's something you don't  
13 even conceive of happening.

14 MR. JORDAN: Okay.

15 MR. CONWAY: We talk about transfers back and  
16 forth, what causes them, that kind of thing, and how they  
17 work. Of course, that how-they-work type thing, coupled  
18 with the way the failure looked, we didn't observe it as a  
19 load problem, because all of them went. All but that one  
20 series -- every one of them -- had tripped. For that  
21 reason, we didn't feel it was a load problem; it was just a  
22 matter of getting the power back. Whether or not it was  
23 available was -- [Pause]

24 MR. JORDAN: I'm just curious about what  
25 parameters you were monitoring. You stated you had an



1 individual at the -- was it 603?

2 MR. CONWAY: The 601.

3 MR. JORDAN: The 601?

4 MR. CONWAY: Yes.

5 MR. JORDAN: -- that was looking at the level and  
6 pressure and maintaining the level with the RCIC.

7 MR. CONWAY: Correct.

8 MR. JORDAN: You mentioned you had somebody that  
9 at least -- You got reports back on a continuous basis; you  
10 said once every minute or some period of time.


11 MR. CONWAY: Three minutes, sure.

12 MR. JORDAN: Well, you felt comfortable knowing  
13 your knowledge of at least level and pressure. What other  
14 parameters did you have a feedback or a person that, while  
15 you were in the condition, for the 30 minutes or  
16 whatever --

17 MR. CONWAY: I was getting parameters on drywell,  
18 primary containment conditions --

19 MR. JORDAN: On a continuous basis?

20 MR. CONWAY: Not on a continuous basis. When I  
21 got the initial set of parameters for the containment, I  
22 felt that there was no cause for concern in the containment,  
23 other than the slowly rising temperature; we started taking  
24 action to correct that. Once we got power back, of course,  
25 I know Mike Eron was looking into the printers to try to





1 figure out how to get some jumpers in, to get the unit  
2 coolers back running, because ultimately we would have ended  
3 up in those.

4 We tried our LOCA bypass, which is our normal way  
5 of --

6 MR. JORDAN: Oh, they didn't come back on as soon  
7 as you got power back to them?


8 MR. CONWAY: When we got power back on, we then  
9 had power to allow the LOCA bypass switch relays -- the  
10 switch is actually relays to bypass the contacts. Those  
11 relays were de-energized when the UPS's went down, so, even  
12 with our LOCA bypass switches on, we could not restart the  
13 fans; the valves were fine, but we couldn't tell the fans,  
14 Hey, the valves are really open, because the relays wouldn't  
15 pick to allow that function to occur. Once we got the UPS's  
16 re-energized, it was just a matter of going back and  
17 restarting the fans to get drywell cooling restored, and  
18 that's exactly what we did.

19 MR. JORDAN: Did you have somebody go out locally  
20 to reset the relays?

21 MR. CONWAY: The control switches are on one of  
22 the panels in the back of the control room.

23 MR. JORDAN: Okay.

24 What other parameters did you have somebody  
25 stationed at to give you some type of a feedback? Level,




1 pressure, containment --

2 MR. CONWAY: After we got our power back to the  
3 UPS's, somebody was monitoring power at 603.

4 MR. JORDAN: Did you have somebody monitoring  
5 power before that?

6 MR. CONWAY: Prior to that, no. After the initial  
7 report Mike Eron gave us that EPRMs were down-scale -- I  
8 think Dave Hanczyk was back there with him, too -- Mark  
9 Davis, I think, was driving in detectors at that time. I  
10 think, as a matter of fact, Dave Hanczyk asked, Well, how  
11 are we going to know what power is if we're coming down? I  
12 said, Well, we can always look at the meters, the IRM meters  
13 on the back panels, on the drawers. He says, All right;  
14 I'll go check those. I know he went and looked at them -- I  
15 believe he did. I don't know specifically that he did. He  
16 never gave me a report back that he did, but Mark Davis was  
17 telling me that we had down-scale indications on IRMs when  
18 they would come in, so he was giving me feedback from that  
19 aspect -- that, yes, power was tracking down -- and then,  
20 when we got our front-panel meters restored, we got reports  
21 that we're on SRMs now and that they're trending down, also.

22 MR. JORDAN: I'm somewhat confused. You  
23 originally went back and looked at the EPRMs that were  
24 indicated down-scale, the LPRMs that were indicated down-  
25 scale, which indicated that the reactor power was down.



1 MR. CONWAY: Less than 4 percent, yes.

2 MR. JORDAN: Less than 4.

3 And that was early in the program.

4 MR. CONWAY: That was one of the first things we  
5 did.

6 MR. JORDAN: Okay.

7 MR. CONWAY: We knew where pressure was; we knew  
8 where level was; we needed to plan where power was.

9 MR. JORDAN: Okay. Then, from that time until you  
10 got power back, with your 601 panel -- is that what it is,  
11 the main panel? Is that 601 or 603?

12 MR. CONWAY: It's 603, where the full-core  
13 displays are.

14 MR. JORDAN: Okay, the 603 panel.


15 -- until you got power back to your NIs from the  
16 603, who was doing what as far as power goes?

17 MR. CONWAY: I didn't assign somebody specifically  
18 to monitor power.

19 MR. JORDAN: Okay.

20 MR. CONWAY: I believe Mark Davis was doing that,  
21 when he could. I know he was driving in detectors, and I  
22 don't know if he was going back and checking it or not. I  
23 didn't get any further reports until after we got power  
24 restored, and that we were on SRMs.

25 MR. JORDAN: Okay.




1           MR. CONWAY: I believe he had driven the detectors  
2 in and he was ranging down on the range switches, because he  
3 had down-scale alarms in on that 603 panel. So I believe  
4 he was monitoring it, and I believe one time he also  
5 reported to me that IRMs down-scales are in, but, until the  
6 chart recorders got power back, we couldn't track them on  
7 the front panel, and I don't think he felt comfortable  
8 enough to leave the front to go to the back to check, but  
9 you can ask him.

10           MR. JORDAN: Okay.

11           MR. KAUFFMAN: I guess I have a couple more  
12 follow-up questions.

13           This one I brought with me from Washington,  
14 because of the 50.72 report that initially came in. It said  
15 that pressure control was lost at the start of the event,  
16 and I was wondering where that came from, if you guys said  
17 that or we got it wrong on our end or I have a  
18 misunderstanding.

19           MR. CONWAY: I have never said that, and up to  
20 this point I have never heard we had lost pressure control.  
21 I've got to believe that, based on the load reject that we  
22 took because of the main transformer fault, yes, in fact,  
23 pressure did go high enough to pick up two SRVs on pressure-  
24 relief function. If that constitutes loss of pressure  
25 control then that's why they said that, but I don't believe





1 at any time I had lost control of pressure, and I was taking  
2 actions, if I felt I was getting that way, to control it,  
3 and I did.

4 MR. KAUFFMAN: Who made the red phone calls here?

5 MR. CONWAY: Our communicator. Initially it's  
6 done from the control room by our rad waste operators, who  
7 are trained as communicators. Basically, they read the fact  
8 sheet that's prepared by our shift emergency plant  
9 coordinator and authorized by myself as the SED. They read  
10 that to the red phone line.

11 MR. KAUFFMAN: You don't recall signing anything  
12 like that.

13 MR. CONWAY: That might have come from the TSC,  
14 but no.


15 MR. KAUFFMAN: Okay.

16 MR. CONWAY: All we made mention of was loss of  
17 annunciators and that all rods weren't in and that kind of  
18 stuff. The rod position was unknown, and level and pressure  
19 were stabilized.

20 I'm not sure where that came from. That's  
21 interesting, though. I wouldn't even perceive it that way.

22 MR. KAUFFMAN: Ultimately I can go back to  
23 Washington, I guess, and if need comes up we can have them  
24 play the tape, because those are all taped.

25 This week has all been kind of hectic for me, too.



1 In fact, I had a good Tuesday. I was not working Tuesday.  
2 When I came in, I grabbed the reports that were there and  
3 talked to people about what happens. I may have, in haste,  
4 misread it, or it might not have been a report from when you  
5 were there. I don't recall the specifics of the 50.72 phone  
6 call.

7 MR. CONWAY: It was approximately three hours in,  
8 I believe, that TSC called over and had one of the -- I  
9 think it was, as a matter of fact, Tom Tuttle at the time --  
10 asked him to check on a few indications. One of the things  
11 he was looking at was SRV temperatures. As soon as he read  
12 the recorder, he said he showed two that had spiked  
13 significantly higher than the rest, or showed two spikes, I  
14 should say. He said that may have indicated an SRV. He  
15 reported that to me, and I said, Well, keep the TSC informed  
16 and let them know what happened.

17 At that time, we suspected that those two had  
18 lifted, so we initiated our procedure for cycling our  
19 drywell vacuum breakers, which is supposed to be done within  
20 two hours. Of course, we didn't even think that we actually  
21 had an SRV. We had no way of telling that; no one had seen  
22 the valve actuate, as far as indication of the change. And  
23 our annunciation was lost. That first ten minutes was a lot  
24 of unknowns in there.

25 One of the things we didn't think to look at was

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50  
 51  
 52  
 53  
 54  
 55  
 56  
 57  
 58  
 59  
 60  
 61  
 62  
 63  
 64  
 65  
 66  
 67  
 68  
 69  
 70  
 71  
 72  
 73  
 74  
 75  
 76  
 77  
 78  
 79  
 80  
 81  
 82  
 83  
 84  
 85  
 86  
 87  
 88  
 89  
 90  
 91  
 92  
 93  
 94  
 95  
 96  
 97  
 98  
 99  
 100



1 that recorder. There was no power to that recorder, anyway;  
2 it wouldn't have shown anything. At least I don't believe  
3 there was power to it. Obviously there was something, or  
4 the residuals were still there from when they opened, to  
5 show the spikes. I'm not sure.

6 MR. KAUFFMAN: I guess another question I had was  
7 what you've said and what we've heard from other places:  
8 that the RO recommended a scram, and I guess my basic  
9 question is just the background and what's the policy on  
10 when ROs initiate scram, when they recommend scram.

11 MR. CONWAY: Well, I had already come to that  
12 conclusion and was basically waiting to hear what power was.

13 MR. JORDAN: At your ASSS?

14 MR. CONWAY: That's correct.

15 MR. JORDAN: That's the assistant?


16 MR. CONWAY: The assistant station shift  
17 supervisor.

18 MR. JORDAN: Your assistant. Okay.

19 MR. CONWAY: He becomes the legal STA once we  
20 enter the emergency plan.

21 MR. JORDAN: All right.

22 MR. CONWAY: He had just come from the back panel.  
23 I was at the 601 panel, looking at the level and pressure.  
24 I recognized that some event had occurred, other than just  
25 the loss of the annunciators, and, when I had turned my head



1 to look at the 603 panel, on 602 recirc pumps had down-  
2 shifted and I had come in at that point. At that minute, he  
3 said, I recommend we scram. I said, I agree.

4 It's ultimately my call to direct that, unless one  
5 of the reactor operators -- or senior reactor operators, for  
6 that matter -- feels that conditions warrant that, and they  
7 don't need to wait to be told to do that.

8 MR. KAUFFMAN: My question was really, is it a  
9 requirement they do it? Is it a courtesy? Is it something  
10 that, if they're not really sure, they tell you what they  
11 think and let you make the decision?

12 MR. CONWAY: That's correct, and they're always  
13 told that: if they're not sure, they're supposed to raise  
14 that question, of course, to the SSS, and he makes that  
15 decision. That's why I get the big bucks, right?

16 MR. JORDAN: Right.

17 [Laughter.]

18 MR. KAUFFMAN: You got the big bucks for what  
19 happened on Tuesday.

20 MR. CONWAY: Right.

21 MR. KAUFFMAN: Another question I had is, I guess  
22 a lot of people eventually came up to the control room, and  
23 I guess the question of crowd control and how you maintain  
24 control of the people and how you got them to do what you  
25 wanted without losing control of them and having all those






1 people running around doing things you didn't want to do --  
2 just how you handled that whole thing.

3 MR. CONWAY: Congestion in the control room -- it  
4 started building a couple times. What I did is, I just  
5 grabbed the first person I saw, and I would say, Clear  
6 everybody out of here that isn't actively doing something  
7 right now. The control room is getting very congested and  
8 noisy. I could have yelled out, Hey, everybody shut;  
9 anybody that doesn't belong here, get out of here. But I  
10 know Mark Davis had assigned people to do certain functions,  
11 as to the CSO, because I had given him tasks to perform.  
12 Rather than just clear everybody out and then find that  
13 those people were actually doing something over here, I  
14 wanted to let this person -- I had to do that twice, and  
15 the person that I did assign that to, they would walk; they  
16 would ask somebody, Do you have business here, or are you  
17 just hanging -- because that's our assembly area, also, and  
18 that promotes that congestion. If they said no, then they  
19 were asked to move someplace else in the control room; the  
20 noise was becoming a bit much, and the congestion.

21 That's how I ended up clearing the control room  
22 twice.

23 MR. KAUFFMAN: It was really two parts. It's how  
24 just basically you can manage it, how you control the crowd  
25 and then to some degree how you kept track of what




1 everybody was doing and --

2 MR. CONWAY: Through Mark Davis -- I would  
3 continually check with him on what's the progress on the  
4 board, the hoppers, who's working on it, you know, and he  
5 would say so-and-so is working on that, so-and-so on this,  
6 this and that. He knew who was doing what where and of  
7 course the people in the control room that I had assigned  
8 positions I kept aware of them.

9 You know, like I assigned one of the other CSOs  
10 they had coming in the duty of following along with what we  
11 are doing here and OP-101-C, our shutdown procedure, and  
12 verify, try to parallel it and confirm and one of the things  
13 he pointed out was our cooldown rate is limited from normal  
14 temperature down to 450 degrees because they're worried  
15 about crudburst and complicated chemistry controlling the  
16 core and he pointed that out to me after I had R.J.  
17 Reynolds, who was controlling pressure and at that point we  
18 had started a cooldown rate that I told him 100 degrees an  
19 hour was his rate and don't exceed that. He had just -- I  
20 don't think he had even started yet. He was still in the  
21 pressure stabilization type process when Bob Spooner had  
22 pointed that out to me, that 25 is the limit and then of  
23 course at that time I corrected, made the correction to my  
24 order to limit down to 25 down to 450.

25 MR. KAUFFMAN: If the people in the plant ran into



1 problems or had questions they were dealing with the CSO?

2 MR. CONWAY: Yes, unless there was something that  
3 they felt needed to be brought specifically to my attention  
4 or Mark would bring them over to me and say this and this  
5 and this and we would make the necessary decisions.


6 A lot of them were done as a group like that. We  
7 would get together and talk as a group -- here's what our  
8 plan, here's how we're going. We've got a lot of  
9 contingency backup in case this fails or this fails. We  
10 look like we are in good shape here.

11 MR. KAUFFMAN: Can you recall any problems that  
12 the people out in the plant had that needed to be brought up  
13 and resolved?

14 MR. CONWAY: One of the those problems was after  
15 the TSC got mad and the OSC everything had to go through the  
16 OSC as far as for accountability process, right?

17 That as far as I am concerned bottlenecked our  
18 recovery. I mean it slowed it right down because we had to  
19 physically at first send people over to the OSC, which is at  
20 Unit One and then they would be dispatched as part of a  
21 damage control team out to the plant, which later on we got  
22 them to change that into just notifying them who was going  
23 out and where but initially that's how they were running it.  
24 Boy, that slowed it down a lot!

25 MR. JORDAN: How did you communicate with the OSC



1 in Unit One?

2 MR. CONWAY: Through our communicator. Gus had a  
3 phone number we could dial. We found out what the phone  
4 number was.

5 MR. JORDAN: Was communications available? I mean  
6 was --

7 MR. CONWAY: We don't have a direct line to the  
8 OSC. To the TSC we do and basically we would tell people,  
9 you know, the TSC, that we are sending people out to go do  
10 this and then they would notify the OSC and then the OSC  
11 would call and say, hey, you need to send them over here.  
12 We'd say "Aw-w-w."

13 MR. JORDAN: How about just normal communications.  
14 I mean you'd use the telephone, okay. Is that because the  
15 communications was lost or that is the normal method you  
16 would have done it like to the TSC or the OSC?

17 MR. CONWAY: TSC is done by phone.


18 MR. JORDAN: Okay, how about the OSC?

19 MR. CONWAY: OSC we do not have a dedicated line  
20 for that but of course any phone in the control room could  
21 have called them.

22 MR. JORDAN: So that is how your normal  
23 communications --

24 MR. CONWAY: With the OSC.

25 MR. JORDAN: If you hadn't lost your power





1 supplies, okay, you would still have had the problem with  
2 the communications that you had with the TSC -- not the TSC  
3 but the OSC.

4 MR. CONWAY: I don't know if I would call it a  
5 problem, other than the fact that it was more of a  
6 procedural type thing.

7 MR. JORDAN: Okay.

8 MR. CONWAY: Right? They were saying, oh, you've  
9 got to come over here to do it. It wasn't really a  
10 communication type thing.

11 MR. JORDAN: Okay.

12 MR. CONWAY: Initially the only communication  
13 problems were okay, we couldn't make an announcement to  
14 everybody on the site, in the Two site, right?

15 Unit One had to make that call and the Gaitronics  
16 merge when either stations makes, sounds one of the station  
17 alarms -- the fire alarm, the station alarm or the  
18 evacuation alarm, both systems merge and the announcements  
19 are heard at both stations simultaneously, but we lost our  
20 Gaitronics and so their station announcement -- they heard  
21 it at their station but nobody at our station did.

22 MR. KAUFFMAN: Was there some kind of a  
23 contingency or backup to deal with that?

24 MR. CONWAY: Not that I am aware of.

25 I was asked to speculate on that the other day and



1 my answer to that was I would have probably contacted  
2 security and had them dispatched to various locations of the  
3 plant and make sure people were kept informed that they were  
4 supposed to be at their assembly areas.

5 Of course there were very few people on site at  
6 that time anywhere so when Security was notified that that  
7 was occurring they stopped everybody from coming in and that  
8 helped for accountability purposes and notification of  
9 people.

10 The Gaitronics of course -- one half is powered  
11 off of one UPS and the other half is powered off the other  
12 UPS and then our radio system, Leaky Wire, is powered off a  
13 third UPS, so chances of losing all three simultaneously  
14 were pretty --


15 MR. JORDAN: -- remote but it happened.

16 MR. CONWAY: -- remote but it happened, yes.

17 MR. JORDAN: So you don't know when you notified  
18 Unit One to notify the plant whether or not that  
19 notification actually went into Unit Two or not? Or you do  
20 know?

21 MR. CONWAY: We did not hear any announcement over  
22 the Gaitronics in the control room, let me put it that way,  
23 and we would have heard it -- we routinely hear it every  
24 Friday they test their station alarms and we test ours.

25 MR. JORDAN: Okay.



1 MR. CONWAY: And we usually hear theirs in the  
2 control room and I didn't hear it, so I've got to believe it  
3 did not go out.

4 MR. KAUFFMAN: I've got some more good questions  
5 here.


6 One of the questions I have was as the UPS's got  
7 re-powered and started getting their annunciators back, how  
8 did you go about I guess looking at them and figuring out if  
9 there are more problems. How did you just handle the  
10 situation of the alarms coming back.

11 MR. CONWAY: The people on those boards handled  
12 it.

13 For instance, Brian Hilliker was assigned a 601  
14 panel. He was over there running RCI and then I had him  
15 relieve Eric Hoffman for moderating level and pressure  
16 because he is a reactor operator and Eric was just non-LOP  
17 initially. He was all I had so I stationed him there. I  
18 wanted my ROs doing other things.

19 He responded accordingly by the procedure to the  
20 alarms that were in. If he felt that something needed to be  
21 brought to my attention he was going to do that.

22 I did not give any specific directions on, you  
23 know, if there are any abnormal alarms, let me know.  
24 Everybody knows. If it's abnormal, they're going to let me  
25 know. They have to. The procedure will even say notify the



1 SSS right in it and so as the alarms came back in, of course  
2 some of them were fast flash, some slow flash, which means  
3 the condition had been an alarm and cleared, they would have  
4 kept me notified.

5 I didn't get any notification of anything abnormal  
6 from annunciators that were received or cleared, that I  
7 recall.

8 MR. KAUFFMAN: I guess these two are kind of tied  
9 together here. It just occurred to me now and it might have  
10 been a good thing to write them all down since -- I guess  
11 the printer and stuff wasn't working then but --

12 MR. CONWAY: Oh, I see, yes. Hindsight.

13 MR. KAUFFMAN: It just occurred to me too, but  
14 that's like one of our assistant SSS's was -- he had gotten  
15 there early also and he was walking around with a pad of  
16 paper, keeping a rough log of what was going on.

17 MR. KAUFFMAN: That was my next question --


18 MR. CONWAY: When I saw this log --

19 MR. KAUFFMAN: That's where a lot of this  
20 information came from. No offense to -- I guess it is your  
21 writing in here early on --

22 MR. CONWAY: This is me, yes!

23 MR. KAUFFMAN: It's kind of sloppy and then when  
24 the event happened it gets neat and --

25 MR. CONWAY: What we did was, this log was





1 generated from I've got to say three sets of notes, one that  
2 was kept by Jerry Hilliker, who had come in after the event  
3 had occurred. I am not sure specifically what time he came  
4 in.

5 He and I together worked out the site emergency  
6 director checklist to make sure we were doing everything we  
7 had to do prior to being relieved by the TSC.

8 Don Bosnick, who was the Assistant SSS that was  
9 oncoming, who had come in early to start a turnover, he had  
10 kept some notes, and then Mike Garbus, who is one of our  
11 CSOs on relief shift who had also started keeping a rough  
12 log from approximately seven o'clock on when he came in.


13 In between all those three notes, basically  
14 between Mike Eron, Mark Davis and myself, we read through  
15 what they had written down and filled in blanks where they  
16 weren't sure of what was going on when and then I told Don,  
17 put in a log, Don, and that is where this log came from.

18 So it is not like we were writing during the whole  
19 thing. I personally -- the only place I was writing was on  
20 the EOP boards. That's where I was doing my writing.

21 MR. KAUFFMAN: We would be asking other questions  
22 I think if the reactor melted but you kept a really good  
23 log!

24 [Laughter.]

25 MR. KAUFFMAN: So -- this is kind of an EP



1 question again that just occurred to me. Do you know what  
2 you would do if say you hadn't restored the UPS's and the  
3 TSC is now up and activated, right, and they want  
4 information on point parameters and this, that and the other  
5 and your SPDS is down, your computer is down -- well, I'm  
6 guessing. I would guess in the E-Plan there is some way to  
7 get information to the other emergency response facilities  
8 that need if the primary means are down.

9 MR. CONWAY: The communicator, the communications  
10 aide who is in the control room, of course is in direct  
11 communication with the TSC the whole time and with the  
12 communicator on the other end and they have I believe a data  
13 sheet they ask for parameters for and basically he would say  
14 ask me or someone else -- I think Don Bosnick who as a  
15 matter of fact was taking care of a lot of that because I  
16 wasn't aware of them asking for anything --

17 MR. KAUFFMAN: What about the old paper method?

18 MR. CONWAY: Basically the paper method, yes.  
19 They had a checksheet and for different parameters and they  
20 would have asked for those and if we had the  
21 instrumentation available we would have given them what  
22 they wanted. If not, then it would have been sorry, not  
23 available or we would have tried to figure out how to get  
24 that information for them, if it was important.

25 You would be reading it to them and they would



1 have a similar sheet on the other end of the phone and  
2 writing it all down and that's how they would get it.

3 MR. KAUFFMAN: I used to run drills. We'd break  
4 these sort of things to force the communications channels  
5 because that is a real good way to check the effectiveness  
6 of the communications in the organization if you are a drill  
7 controller is to interject something and see how long it  
8 takes to come out the other end.

9 MR. CONWAY: There is also another method. Of  
10 course they have the remote video camera that is controlled  
11 from the TSC.

12 MR. KAUFFMAN: Oh, I didn't see those up there.

13 MR. CONWAY: It's in the control room and I don't  
14 know when they pull the lens cap off but of course from  
15 that they can -- zoom in, zoom out and they can get a lot of  
16 the front panel information themselves. They can watch me  
17 pull my hair out, do anything they want, so that was  
18 available as another information-gathering device.

19 MR. KAUFFMAN: Where is that --

20 MR. CONWAY: I have no idea.

21 MR. KAUFFMAN: That's a rhetorical question.

22 MR. CONWAY: I understand. That didn't need an  
23 answer, eh?

24 MR. KAUFFMAN: Well, let's see. Anything on my  
25 list that we didn't cover? We might let Mike talk about




1 this one.

2 MR. JORDAN: Maybe we've already explored this and  
3 I have missed the concern, and that's if you didn't get the  
4 UPS back in a half an hour and it would have continued to be  
5 out, what was the major problems that you had? I mean  
6 you're into this thing half an hour and the adrenalin now is  
7 down to the point where you are doing something that is  
8 pretty stable, hopefully stable. What were your major  
9 problems that you had as far as if this thing went on for a  
10 long period of time that you had to overcome?

11 MR. CONWAY: The level was fairly well under  
12 control. The pressure was under control. Establishing a  
13 permanent form of heat sink would have been difficult. For  
14 instance, no vacuum indication would have been -- they had  
15 no idea what was going on in condenser vacuum and that was  
16 another thing I did. Somebody said, well, we don't know  
17 what the condenser vacuum is doing right now and we had  
18 half, that was when we had half a bypass valve open, right,  
19 so I'm like -- yeah, we better send somebody out to look at  
20 that, so I dispatched a non-LOP -- well, actually I think I  
21 told Jim Graff send somebody out to check condenser vacuum  
22 locally and get back to us on what we have.

23 MR. JORDAN: And did they do that?

24 MR. CONWAY: Because Gaitronics was down, the  
25 Leaky Wire system is down, they had to go out to the plant





1 and then get their reading and then come back to the control  
2 room.

3 MR. JORDAN: Did they have problems in doing that?  
4 Do you know?

5 MR. CONWAY: Did they?

6 MR. JORDAN: Yes.

7 MR. CONWAY: I didn't receive a report that there  
8 was difficulty doing it other than they were breathing hard  
9 when they got back.

10 I think that may have been the guy that reported  
11 the CAMs were alarming out in the turbine building, you  
12 know, and of course one of his responsibilities is to see if  
13 it is reading anything and get out of the area.

14 MR. JORDAN: Okay. We had some indication there  
15 were some lighting problems and I think you alluded to it  
16 earlier, that there was some lighting problems.

17 MR. CONWAY: I wasn't aware of any in the control  
18 room.

19 MR. JORDAN: As far as the control room lighting  
20 you noticed no degradation of the lighting system?

21 MR. CONWAY: I don't recall ever noticing it.

22 MR. JORDAN: Do you know what kind of lighting  
23 problems they had out in the plant?

24 MR. CONWAY: I understand that --

25 MR. JORDAN: What reports did you get?



4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24



25



1 MR. CONWAY: -- that control building lighting was  
2 out. I didn't receive any reports during it. Afterwards, in  
3 the debriefing it came out that lighting was out.

4 MR. JORDAN: As far as these guys who went out and  
5 coming back to you --

6 MR. CONWAY: No one said anything about the lights  
7 were out or anything like that.

8 MR. JORDAN: -- their access to and from to get  
9 this information, they didn't report anything to you about  
10 problems with lighting being out?

11 MR. CONWAY: No, they didn't.

12 MR. JORDAN: And the difficulty of transversing  
13 from one point to another?

14 MR. CONWAY: No, they didn't, not until the  
15 debriefing. It came out in the debriefing. Luckily  
16 everybody had their trusty flashlight though that we are not  
17 really required to carry but everybody does, at least the  
18 plant operators.

19 Most plant operators don't leave the control room  
20 without a flashlight or to go out in the plant so everybody  
21 had their flashlights.

22 MR. JORDAN: Okay.

23 MR. CONWAY: I don't know if I fully answered your  
24 question.

25 MR. JORDAN: You did. I was just curious.

W

5

8

v

12

3

.

1 2 3 4 5 6 7 8 9 10 11 12

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



1 MR. CONWAY: If it took longer we would to have  
2 come up with other contingencies and we were working on  
3 that. We were working on getting steam condensing available  
4 on RHR Alpha. That was going to be our secondary backup  
5 method, right, for if we couldn't tell what was going on in  
6 the main condenser and bypass valves.

7 MR. KAUFFMAN: Some plants aren't analyzed because  
8 of piping or whatever to use it, steam condensing mode.

9 MR. JORDAN: Have you ever used it?

10 MR. CONWAY: Yes. We used it during the startup  
11 and test program, I know that.

12 MR. JORDAN: Do you train on it?

13 MR. CONWAY: Yes. In the simulator we train on  
14 how to use that.

15 MR. JORDAN: Okay.


16 MR. CONWAY: So I think it would have taken a  
17 little bit longer to finally get to a stable, a more stable  
18 condition -- I don't want to say -- because it was stable  
19 during that time period anyway.

20 MR. JORDAN: But your main concern, you lost --

21 MR. CONWAY: As far having problems?

22 MR. JORDAN: You had eventually lost your heat  
23 sink and you recognized that so you are addressing the loss  
24 of heat?

25 MR. CONWAY: Alternate methods of heat sink.



1 MR. JORDAN: Of heat sink and as one of the  
2 concerns if this thing would have gone for a long period --

3 MR. CONWAY: We had to look at long term, right.  
4 We also had talked about making the high pressure core  
5 spray pump injection valves available and that was always  
6 available the whole time as a make-up source, high pressure  
7 make-up source.

8 We always had that available also. This was  
9 before, you know, we got control with the booster pumps and  
10 stuff, always had that available as an option for a make-up  
11 source so we had an option for heat sink and pressure  
12 control and an option for inventory make-up source.


13 MR. JORDAN: So what were we going to use for an  
14 option for pressure control?

15 MR. CONWAY: Steam condensing. Steam condensing  
16 does both.

17 MR. JORDAN: Does both.

18 MR. CONWAY: It will take steam off the reactor  
19 and condenses it and you can control your cool down rate on  
20 and off, just raise or lower level and that would have  
21 helped as our pressure control and ultimately the service  
22 water system is the heat sink.

23 MR. JORDAN: Okay. Any other things you have got  
24 as far as long term concerns? What you are saying is the  
25 communications, you circumvented that by sending people





1 running in and out, okay? And so that got to be less of a  
2 problem. It was a difficult problem but that was taken care  
3 of and I understand you were going to be using the RHR for  
4 the ultimate heat sink as well as pressure control and you  
5 are going to use HPCS or HPCI, HPCS I guess is what you have  
6 here --

7 MR. CONWAY: As a backup to RCIC.

8 MR. JORDAN: As a backup to RCIC once RCIC's  
9 pressure gets down too low or RCIC is no longer functioning.  
10 Can you throttle the injection valve?


11 MR. CONWAY: We did not make it throttle-able. At  
12 the time we had discussed it, Mike Eron and I, had talked  
13 about that and Mark Davis that it was always available the  
14 whole time and we talked about it was always available. We  
15 could have started it and injected at any time --

16 MR. JORDAN: And you could throttle that valve?

17 MR. CONWAY: And we have a procedure in our EOP  
18 support procedure, the EOP-6, that allows us to make that,  
19 tells us how to make it throttle-able. We have to lift a  
20 lead out and a panel.

21 MR. JORDAN: Maybe you covered this also and I  
22 missed it.

23 Did the scenario of loss of annunciators and  
24 without the loss of your full core display -- have your  
25 people been trained on that?



1 MR. CONWAY: No. We have not. We have not trained  
2 on loss of annunciators.


3 MR. JORDAN: You lost a bunch of annunciators.  
4 Did you get any in?

5 MR. CONWAY: Yes. There were six alarms that were  
6 in and would not acknowledge. They were on the 601 panel,  
7 the 100 block, the first block there. There were four in a  
8 row and then the two below it were I think the 630, P-630,  
9 annunciator power supply failure -- I think that's what  
10 those read, those two, and the four directly above it which  
11 deal with service water were flashing and why those four  
12 above it came in I have no idea. I don't know how they  
13 related.

14 MR. JORDAN: And the two below? What do they  
15 mean? .

16 MR. CONWAY: They mean that panel 630, one of our  
17 major annunciator panels down in the relay room, had lost  
18 power or they wouldn't acknowledge. We tried acknowledging  
19 them but they still wouldn't acknowledge and of course no  
20 audible alarm for them at all.

21 MR. JORDAN: Okay. As far as taking action  
22 outside of the EOPs, was there any actions that you took  
23 that says this -- or your procedures that you felt that in  
24 order to not do this you would just as soon not do it and  
25 chose not to do it?



1           Was there any actions that were required to be  
2 done by your EOPs or by your procedures that you had  
3 difficulty in doing? You said this procedure requires this  
4 but we are not quite in this condition and therefore we want  
5 to do this instead?


6           MR. CONWAY: No. I can't recall a single one.

7           MR. JORDAN: So you didn't have to use the 5054.X  
8 or anything else as far as your directing your people, that  
9 says, hey, I'm outside my tech specs --

10          MR. CONWAY: No. I guess the only thing that  
11 would have been along that line would have been get me the  
12 UPS's back. That was the direction I gave the operators I  
13 sent out. You know, once I got the report back that all the  
14 UPS's had tripped I sent Dave Hanczyk and a couple other  
15 guys out in the plant, you know, I need to get those UPS's  
16 back, do what you have to do.

17          That was the only other direction I gave that was  
18 not proceduralized per se. Everything else through the  
19 EOPs and our normal procedures that we were trying to  
20 parallel through the whole time. Everything worked well.  
21 You know, like the condensate booster pumps startup  
22 procedure complicated feedwater because we could not get  
23 that suction valves open and get flows through --

24          MR. JORDAN: You couldn't get the section valve  
25 open because of the --



1 MR. CONWAY: -- the DP on the valves.

2 MR. JORDAN: And you couldn't get the DP opened  
3 because of the fact that --

4 MR. CONWAY: One of the problems we had there --

5 MR. JORDAN: Why didn't go ahead and open them  
6 anyway?


7 MR. CONWAY: They tried that. They physically  
8 would not open but there is a large DP on it and those  
9 valves just don't operate against a large DP.

10 MR. JORDAN: They just wouldn't open.

11 MR. CONWAY: Correct. The other thing that  
12 probably complicated this was the fact that we lost the DRMS  
13 computer, which is like our rad monitoring computer and when  
14 we had these CAMs alarming we couldn't go to that and say,  
15 hey, here's what we really got -- we don't have anything  
16 else going on there, and they were the little portable ones  
17 out there, right, that they have out monitoring the building  
18 that were in alarm.

19 They probably went on rate of change because the  
20 rad levels changed or something. I never did get a report  
21 back why they were alarming but it was probably something  
22 simple -- all the rad levels dropped off.

23 MR. KAUFFMAN: Were there any places in the EOPs  
24 where the EOP put you in a loop and it was on something that  
25 maybe didn't seem important or good and you said, boy, the





1 EOP here has got me stuck and wasting my people and time on  
2 things that I could be better using elsewhere?

3 MR. CONWAY: The only time I felt even close to  
4 that was when I was in C-5 and I got the little override in  
5 RP that says the reactor's shutdown and no boron has been  
6 injected; start a cooldown.


7 Then there is also a precaution there that says if  
8 power starts to right or something, return it, B or  
9 something like that, and that brings you back in as a  
10 different form -- tells you to stop the cooldown, basically.

11 I read that and I wanted to apply it over here  
12 over on C-5 also but I couldn't because that particular  
13 permission was not given there. Because of that, you know,  
14 it didn't complicate things but that was the only time I  
15 felt that it would have been nice to have that over here  
16 too. I would have got out of C-5 and gone right into RL and  
17 normal water level control, but it didn't gain me anything  
18 and I didn't lose anything by doing that.

19 MR. JORDAN: The loop was the -- what was the  
20 loop? What was that? What was the restriction on C-5 that  
21 you were --

22 MR. CONWAY: It didn't give me the out I guess you  
23 could say, the permission to leave that, similar to the RP.

24 MR. JORDAN: I guess I don't understand what  
25 portion of it you were in that was difficulty. I mean



1 you're talking about rod control and we're talking about  
2 pressure. We're talking about level.

3 MR. CONWAY: Our C-5 is the power level control  
4 procedure.

5 MR. JORDAN: Okay.

6 MR. CONWAY: It gives me instructions on what I  
7 can use for injection, how I can inject, and what my band  
8 is.

9 MR. JORDAN: Okay.

10 MR. CONWAY: And once you get through the  
11 instructional type stuff you go down to the stop sign type  
12 device at the bottom and that basically says either all rods  
13 in or --

14 MR. JORDAN: All rods in? Is that what the loop  
15 was?


16 MR. CONWAY: That was down in there and that was  
17 what was keeping me in C-5. I knew I was already shut down  
18 and no boron had gone in and that was allowing me to cool  
19 down by RP but I still had to maintain a C-5 for level  
20 control purposes.

21 MR. JORDAN: And all rods in is what kept you in  
22 C-5?

23 MR. CONWAY: Correct.

24 MR. JORDAN: For level control.

25 MR. CONWAY: Correct.



1 MR. JORDAN: Even though you had your sufficient  
2 indication that the power was done --


3 MR. CONWAY: Correct.

4 MR. JORDAN: What you are saying is that you  
5 couldn't get out of C-5 because of --

6 MR. CONWAY: I'm saying that was the only thing  
7 that really boggled -- I don't want to say boggled me or it  
8 seemed -- I mean obviously if you are over in the RPB  
9 control ones those are formatted and you are very  
10 comfortable with that.

11 Here I am in a C-5 which we have routinely, you  
12 know always -- it seems like I always get the ATWS in  
13 training. I don't know why but it just seemed funny that  
14 that was not there and of course we have covered it in  
15 training before and there are purposes that you can cool  
16 down but in the event that you do start having a recovery of  
17 power because you are not fully shut down as you are cooling  
18 down you are already in C-5 and that can give you direction  
19 to lower level.

20 Now the leg of C-5 that I was in, of course,  
21 almost parallels with the exception of a few notes and  
22 restrictions and the systems you are allowed to inject with,  
23 the RL leg for the level condition I was at so there was no  
24 impact other than the fact that I felt more restricted  
25 because I couldn't use that in this case to get out of C-5.



1 MR. JORDAN: So there were systems but besides the  
2 fact of the no rods you felt there were systems you could  
3 use for injection that weren't allowed on -- I am trying to  
4 figure out what the restrictions were, the difference  
5 between two.

6 MR. CONWAY: The ones in C-5 are all the systems  
7 inject outside the shroud, so you always get pre-heating,  
8 RCIC, condensate feed water, CRD and boron, right?

9 MR. JORDAN: Okay.

10 MR. CONWAY: Whereas over in RL you can use those  
11 things plus it gives you HPCS and LPCS and all these other  
12 ones that of course are major distributors.

13 MR. JORDAN: Because you were in C-5 you were  
14 restricted? You couldn't use HPCS?

15 MR. CONWAY: Correct.

16 MR. JORDAN: Because you were in C-5.

17 MR. CONWAY: That's correct.


18 MR. JORDAN: You couldn't use LPCS, you were in C-  
19 5.

20 MR. CONWAY: Correct.

21 MR. JORDAN: Because they inject inside of the  
22 shroud, is that what it is?

23 MR. CONWAY: That's correct.

24 MR. JORDAN: Okay, and that's the restriction that  
25 you said because I've got these systems and I would like to





1 use them if I could and you were in a condition that you  
2 felt -- of course they were available the whole time anyway  
3 and ultimately if it became a problem you would end up using  
4 them anyway. It was by the way you routed around in C-5 --

5 MR. KAUFFMAN: I don't have any more.

6 MR. JORDAN: I don't have any more.

7 MR. KAUFFMAN: We would like to thank you for your  
8 time.

9 MR. CONWAY: Okay.

10 [Whereupon, at 2:05 p.m., the taking of the  
11 investigative interview was concluded.]

12

13

14

15

16

17

18

19

20

21

22

23

24

25

11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

THE UNIVERSITY OF CHICAGO

PHYSICS DEPARTMENT

5720 S. UNIVERSITY AVE.



REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: 'Int. of MIKE CONWAY

DOCKET NUMBER:

PLACE OF PROCEEDING: Scriba, N.Y.

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

  
\_\_\_\_\_

JON HUNDLEY

Official Reporter  
Ann Riley & Associates, Ltd.

12

