



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE MILE POINT NUCLEAR STATION UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 141
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated November 24, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

9306110308 930603
PDR ADOCK 05000220
P PDR



(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.141 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 3, 1993



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 141 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

Remove Pages

251
252
256

Insert Pages

251
252
256



..
.
.

4 .

1
2
3
4

4

4

4

6.3 Facility Staff Qualifications

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for the Manager Radiation Protection who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975 and the Shift Technical Advisor who shall have a bachelor's degree in a physical science or engineering or a professional engineer license issued by examination and shall have received specific training in plant design, and response and analysis of the plant for transients and accidents.

6.4 Training

6.4.1 A retraining and replacement training program for the facility staff shall be maintained under the direction of the Manager Training and shall meet or exceed the recommendations and requirements of Section 5.5 of ANSI N18.1-1971 and of 10CFR Part 55, and shall include familiarization with relevant industry operational experience.

6.4.2 A training program for the Fire Brigade shall be maintained under the direction of the Manager Training and Supervisor-Fire Protection, Nuclear and shall meet or exceed the requirements of Appendix R to 10CFR50.

6.5 Review and Audit

6.5.1 Station Operations Review Committee (SORC)

Function

6.5.1.1 The Station Operations Review Committee shall function to advise the Plant Manager on all matters related to nuclear safety.

Composition

6.5.1.2 The SORC shall be composed of the :

Chairman:	Plant Manager
Vice-Chairman/Member:	Manager Operations
Vice-Chairman/Member:	Manager Technical Support
Member:	Manager QA Operations
Member:	Manager Maintenance
Member:	Manager Chemistry
Member:	Manager Radiation Protection



Alternates

- 6.5.1.3 All alternate members shall be appointed in writing by the SORC Chairman or Vice-Chairman to serve on a temporary basis; however, no more than two alternates shall participate as voting members in SORC activities at any one time.

Meeting Frequency

- 6.5.1.4 The SORC shall meet at least once every calendar month and as convened by the SORC Chairman, Vice-Chairman, or a designated alternate.

Quorum

- 6.5.1.5 The quorum of the SORC necessary for the performance of the SORC responsibility and authority provisions of these Technical Specifications shall consist of the Chairman, or a Vice-Chairman and four members including alternates.

Responsibilities

- 6.5.1.6 The SORC shall be responsible for:
- a. Review of all REPORTABLE EVENTS.
 - b. Review of unit operations to detect potential safety hazards.
 - c. Performance of special reviews, investigations or analyses and reports thereon as requested by the Plant Manager or the Safety Review and Audit Board.
 - d. Investigation of violations of the Technical Specifications and shall prepare and forward a report covering evaluation and recommendations to prevent recurrence to the Vice President - Nuclear Generation and to the Safety Review and Audit Board.



Composition

6.5.3.2 The Safety Review and Audit Board shall be composed of the:

- Chairman: Staff Engineer or Manager or Vice President
- Member: Plant Manager or Designee
- Member: Staff Engineer - Nuclear
- Member: Staff Engineer - Mechanical or Electrical
- Member: Consultant (See 6.5.3.4)

Alternates

6.5.3.3 Alternate members shall be appointed in writing by the SRAB Chairman to serve on a temporary basis; however, no more than two alternates shall participate in SRAB activities at any one time.

Consultants

6.5.3.4 Consultants shall be utilized as determined by the SRAB Chairman to provide expert advice to the SRAB.

Meeting Frequency

6.5.3.5 The SRAB shall meet at least once per six months.

Quorum

6.5.3.6 The quorum of the SRAB necessary for the performance of the SRAB review and audit functions of these Technical Specifications shall consist of not less than a majority of the members including alternates. The quorum requires the presence of the Chairman or the Chairman's designated alternate and no more than a minority of the quorum shall have line responsibility for operation of the facility.

