



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-410

NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 45  
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated May 26, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:

9308260088 930809  
PDR ADDCK 05000410  
P PDR




1

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 45 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 9, 1993



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO.45 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410

Revise Appendix A as follows:

Remove Page  
6-16

Insert Page  
6-16



## ADMINISTRATIVE CONTROLS

---

### 6.8 PROCEDURES AND PROGRAMS

#### PROCEDURES

##### 6.8.1 (Continued)

- d. Surveillance and test activities of safety-related equipment
- e. Security Plan implementation
- f. Emergency Plan implementation
- g. Fire Protection Program implementation
- h. PROCESS CONTROL PROGRAM implementation
- i. OFFSITE DOSE CALCULATION MANUAL implementation and
- j. Quality Assurance for effluent and environmental monitoring.

#### REVIEW AND APPROVAL

6.8.2 Each procedure of Specification 6.8.1, and changes thereto, shall be reviewed in accordance with Specification 6.5.2 and approved prior to implementation by the branch manager for the functional area of the procedure or higher levels of management as governed by administrative procedures. Each procedure of Specification 6.8.1 shall be reviewed periodically as set forth in administrative procedures.

#### TEMPORARY CHANGES

6.8.3 Temporary changes to procedures of Specification 6.8.1 may be made provided:

- a. The intent of the original procedure is not altered;
- b. The change is approved by two members of the unit management staff, at least one of whom holds a Senior Operator license on the unit affected; and
- c. The change is documented, reviewed in accordance with Specification 6.5.2 and approved within 14 days of implementation by the branch manager for the functional area of the procedure or higher levels of management as governed by administrative procedures.

