# NINE MILE POINT NUCLEAR STATION - UNIT 1 SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT JANUARY - JUNE 1993

NIAGARA MOHAWK POWER CORPORATION





\*

۰ ۰

,

,

# NINE MILE POINT NUCLEAR STATION - UNIT 1

# SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

# **JANUARY - JUNE 1993**

# SUPPLEMENTAL INFORMATION

Facility: Nine Mile Point Unit #1

÷. •

Licensee: Niagara Mohawk Power Corporation

## 1. TECHNICAL SPECIFICATION LIMITS

- A) FISSION AND ACTIVATION GASES
  - 1. The dose rate limit of noble gases from the site to areas at and beyond the site boundary shall be less than or equal to 500 mrems/year to the total body and less than or equal to 3000 mrems/year to the skin.
  - 2. The air dose due to noble gases released in gaseous effluents from the Nine Mile Point 1 Station to areas at and beyond the site boundary shall be limited during any calendar quarter to less than or equal to 5 milliroentgen for gamma radiation and less than or equal to 10 mrads for beta radiation, and during any calendar year to less than or equal to 10 milliroentgen for gamma radiation and less than or equal to 20 mrads for beta radiation.

## B&C) TRITIUM, IODINES AND PARTICULATES, HALF LIVES > 8 DAYS

- 1. The dose rate limit of lodine-131, lodine-133, Tritium and all radionuclides in particulate form with half-lives greater than eight days, released to the environs as part of the gaseous wastes from the site, shall be less than or equal to 1500 mrems/year to any organ.
- 2. The dose to a member of the public from lodine-131, lodine-133, Tritium and all radionuclides in particulate form with half lives greater than eight days as part of gaseous effluents released from the Nine Mile Point 1 Station to areas at and beyond the site boundary shall be limited during any calendar quarter to less than or equal to 7.5 mrems to any organ and, during any calendar year to less than or equal to 15 mrems to any organ.

-

• -

## D) LIQUID EFFLUENTS

- The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gas, the concentration shall be limited to 2E-04 microcuries/ml total activity.
- 2. The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released from Nine Mile Point Unit 1 to unrestricted areas shall be limited during any calendar quarter to less than or equal to 1.5 mrems to the total body and to less than or equal to 5 mrems to any organ, and during any calendar year to less than or equal to 3 mrems to the total body and to less than or equal to 1 mrems to any organ.

#### 2. MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

Described below are the methods used to measure or approximate the total radioactivity and radionuclide composition in effluents.

## A) FISSION AND ACTIVATION GASES

Noble gas effluent activity is determined by on-line gamma spectroscopic monitoring (intrinsic germanium crystal) or gross activity monitoring (calibrated against gamma isotopic analysis of a 4.0L Marinelli grab sample) of an isokinetic stack sample stream.

#### B) IODINES

lodine effluent activity is determined by gamma spectroscopic analysis (at least weekly) of charcoal cartridges sampled from an isokinetic stack sample stream.

#### C) PARTICULATES

Activity released from main stack is determined by gamma spectroscopic analysis (at least weekly) of particulate filters sampled from an isokinetic sample stream.

For emergency condenser vent batch releases, effluent curie quantities are estimated by subtracting activity remaining in the shell side of the emergency condenser after batch release from activity delivered to the shell from Make-Up sources. Actual isotopic concentrations are found via gamma spectroscopy. Batch release activities of Sr-89, Sr-90 and Fe-55 are estimated by applying scaling factors to activity concentrations of gamma emitters. The activity of tritium released during normal operation or during batch releases is conservatively estimated by multiplying recent condensate storage tank H-3 activity by assumed steaming rates out the vents.

#### D) TRITIUM

Tritium effluent activity is estimated by liquid scintillation or gas proportional counting of monthly samples taken with an air sparging/water trap apparatus.

• ~ x • .

,

## E) LIQUID EFFLUENTS

Isotopic analysis of a representative sample of each batch and composite analysis of non-gamma emitters.

## F) SOLID EFFLUENTS

Isotopic contents of waste shipments are determined by gamma spectroscopy, gross alpha and water content analyses of a representative sample of each batch. Scaling factors established from primary composite sample analyses conducted off-site are applied, where appropriate, to find estimated concentration of non-gamma emitters. For low activity trash shipments, curie content is estimated by dose rate measurement and application of appropriate scaling factors. ¥ . .

\*



٦

Unit 1 <u>X</u>	Unit 2		Reporting Period January - June 1993
Liquid Effluer	nts:		
	10CFR20, Appendix B, Table II, Column 2		
	Average MPC (Qtr. 1)= $N/A$ Average MPC (Qtr. 2)= $N/A$		
	Average Energy (Fission and Activation gases - N	/lev):	
	Qtr. 1       : $E_Y = 8.91E-02$ Qtr. 2       : $E_Y = 4.54E-02$	E, Ē,	, = <u>1.59E-01</u> , = <u>1.35E-01</u>
Liquid: The	re were no liquid releases during the reporting period.		
			_
	Number of batch releases	:	<u>.</u>
	Total time period for batch releases (hrs.)	:	<u>_N/A_</u>
	Maximum time period for a batch release (hrs.)	:	<u>_N/A_</u>
	Average time period for a batch release (hrs.)	:	<u>N/A</u>
	Minimum time period for a batch release (hrs.)	:	<u>_N/A</u>
	Total volume of water used to dilute the liquid effluent during release period (L)	:	<u>N/A</u>
· · · ·	Total volume of water available to dilute the liquid effluent during reporting period (L)	:	<u>1.50E+11</u>
UNIT 1 (ONL	Y)		
Gaseous (Em	ergency Condenser Vent): There were no releases fr vent.	om t	he operation of the emergency condenser
	Number of batch releases	:	<u> </u>
	Total time period for batch releases (hrs.)	:	<u>_N/A_</u>
	Maximum time period for a batch release (hrs.)	:	<u>_N/A_</u>
	Average time period for a batch release (hrs.)	:	<u>_N/A_</u>
	Minimum time period for a batch release (hrs.)	:	<u>_N/A_</u>
Gaseous (Pri	mary Containment Purge):		
	Number of batch releases	:	<u>1</u>
	Total time period for batch releases (hrs.)	:	_8_
	Maximum time period for a batch release (hrs.)	:	_8
	Average time period for a batch release (hrs.)	:	.8_
	Minimum time period for a batch release (hrs.)	:	.8.

.

.

•

. .

•

· · ·

э

Uni	t 1 <u>X</u> Unit 2		Reporting Period <u>January - June 1993</u>
АЪ	normal Releases: There were no abn	ormal releases during the reporting period	1.
Α.	Liquids:		
	Number of releases	<u>_0</u>	
	Total activity released	<u>N/A</u> Ci	
в.	Gaseous:		
	Number of releases		
	Total activity released	<u>_N/A_</u> Ci	

.

.

.

ĸ

• . . . .

,

61

Unit 1 X	Unit 2		Reporting	Period <u>Janua</u>	r <u>y - June 1993</u>
	GASEOUS EFFLUENTS - SUMMATION OF AL	L RELEASES EL	EVATED AND G	ROUND LEVEL	
			<u>1"</u> <u>OUARTER</u>	<u>2</u>	EST. TOTAL ERROR, %
Α.	Fission & Activation Gases 1. Total release 2. Average release rate	Ci µCi/sec.	<u>2.22E+02</u> 2.84E+01	<u>4.22E+00</u> <u>5.37E-01</u>	5.00E+01
В.	<u>lodines</u> 1. Total iodine-131 2. Average release rate for period	Сі µСі/зес.	<u>4.21E-03</u> <u>5.36E-04</u>	<u>5.68E-05</u> <u>7.74E-06</u>	3.00E+01
С.	Particulates <sup>1</sup> <ol> <li>Particulates with half-lives &gt;8 days</li> <li>Average release rate for period</li> <li>Gross alpha radioactivity</li> </ol>	Ci µCi/sec. Ci	<u>9.47E-04</u> <u>1.20E-04</u> <u>8.69E-05</u>	<u>6.58E-04</u> <u>8.97E-05</u> <u>4.82E-05</u>	3.00E+01 2.50E+01
D.	<u>Tritium</u> 1. Total release 2. Average release rate for period	Ci µCi/sec.	<u>4.54E+00</u> <u>5.78E-01</u>	<u>1.50E+01</u> 2.05E+00	5.00E+01
Ε.	Percent of Tech. Spec. Limits Fission and Activation Gases Percent of Quarterly Gamma Air Dose Limit (5 mrem) Percent of Quarterly Beta Air Dose Limit (10 mrem) Percent of Annual Gamma Air Dose Limit to Date (10 mrem) Percent of Annual Beta Air Dose Limit to Date (20 mrem) Percent of Whole Body Dose Rate Limit (500 mrem/yr) Percent of Skin Dose Rate Limit (3000 mrem/yr)	% % % %	<u>1.13E-01</u> <u>2.09E-01</u> <u>5.67E-02</u> <u>1.04E-01</u> <u>4.23E-03</u> <u>1.98E-03</u>	3.02E-03 3.37E-03 5.82E-02 1.06E-01 7.11E-05 2.89E-05	
	<u>Tritium, lodines, and Particulates</u> <sup>1</sup> (with half-lives greater than 8 days) Percent of Quarterly Dose Limit (7.5 mrem)	%	<u>1.85E+00</u>	<u>3.31E-01</u>	

<sup>1</sup> Tritium, Iron-55, and Strontium results were not received from the off-site vendor at the time of this report. These numbers include estimates and actual numbers will be provided in the next Semi-Annual Report.

%

%

<u>9,31E-01</u>

<u>3.72E-02</u>

5.47E-01

7.13E-03

Percent of Annual Dose Limit

Percent of Organ Dose Rate Limit

(15 mrem)

(1500 mrem/yr)

. 1 ł

.

•

. . •

.



Unit 1 X

Reporting Period January - June 1993

GASEOUS EFFLUENTS - ELEVATED RELEASE					
			CONTINUO	US MODE <sup>3</sup>	
			<u>1"</u>	2-4	
	Nuclides Released		OUARTER	QUARTER	
1.	Fission Gases <sup>1</sup> Argon-41 Krypton-85 Krypton-85 Krypton-87 Krypton-88 Xenon-127 Xenon-133 Xenon-135 Xenon-135 Xenon-135 Xenon-137 Xenon-138		2.55E-04 3.90E+00 9.96E-01 2.71E+00 <u>••</u> 1.97E+02 3.46E-01 1.62E+01 <u>1.49E-01</u> •• ••	4.22E+00      	
2.	<u>lodines</u> 1 Iodine-131 Iodine-133 Iodine-135	Ci Ci Ci	<u>4.21E-03</u> <u>3.91E-03</u> <u>3.18E-02</u>	<u>5.68E-05</u> <u>5.68E-05</u> <u>1.02E-05</u>	
З.	Particulates <sup>1,2</sup> Strontium-89 Strontium-90 Cesium-134 Cesium-137 Cobalt-60 Cobalt-58 Manganose-54 Barium-Lanthanum-140 Antimony-125 Niobium-95 Cerium-141 Cerium-144 Iron-59 Cesium-136 Chromium-51 Zinc-65 Iron-55 Molybdenum-99		4.73E-05 ** ** 8.00E-04 ** ** ** ** ** ** ** ** ** *	2.75E-04 3.06E-05  2.09E-04         	
4.	Tritium	Ci	<u>1.43E+00</u>	<u>9,76E+00</u>	

<sup>1</sup> Concentrations less than the lower limit of detection of 1.00E-04 μCi/ml for Noble Gases, 1.00E-11 μCi/ml for particulates, 1.00E-12 μCi/ml for lodines, and 1.00E-06 μCi/ml for Tritium as required by Technical Specifications are indicated with a double asterisk.

<sup>2</sup> Tritium, Iron-55, and Strontium results were not received from the off-site vendor at the time of this report. These numbers include estimates and actual numbers will be included in the next Semi-Annual Report.

<sup>3</sup> No batch mode release occurred during the reporting period.

•

ч

Unit 1 <u>X</u>	Unit 2				Reporting	Period January	<u> - June 1993</u>
		GASEOUS EFFLU	ENTS - C		RELEASES		•
There were no releases via the emergency condenser vent operation. Only leakage from the vents results in an assumed H-3 release based on the concentration in the condensate storage tanks.			CONTINUO	US MODE	BATCH No Rel	MODE eases	
		Nuclides Released		<u>1"</u> QUARTER	<u>2"</u> QUARTER	<u>1"</u> QUARTER	<u>2</u> <sup></sup> QUARTER
	1.	Fission Gases <sup>1</sup>					
		Argon-41 Krypton-85 Krypton-85m Krypton-87 Krypton-88 Xenon-133 Xenon-135 Xenon-135 Xenon-135 Xenon-137 Xenon-138 Xenon-127	000000000000	: : : : : : : : : : :	*  *  *  *  *  *  *  *  *  *  *  *		
	2.	<u>lodines</u> <sup>1</sup> Iodine-131 Iodine-133 Iodine-135	Ci Ci Ci	::::	: : :		
	3.	Particulates <sup>1</sup>					
		Strontium-89 Strontium-90 Cesium-134 Cesium-137 Cobalt-60 Cobalt-59 Manganese-54 Barium-Lanthanum-140 Antimony-125 Niobium-95 Cerium-141 Cerium-144 Iron-59 Cesium-136 Chromium-51 Zinc-65 Iron-55 Molybedenum-99	00000000000000000000000	*   *   *   *   *   *   *   *   *   *	: : : : : : : : : : : : : : : : : :		
	4.	Tritium	Ci	<u>3.11E+00</u>	<u>5.26E+00</u>		
					·	·····	

<sup>1</sup> Concentrations less than the lower limit of detection of 1.00E-04 µCi/ml for Noble Gases, 1.00E-11 µCi/ml for particulates, 1.00E-12 µCi/ml for lodines, and 1.00E-06 µCi/ml for Tritium as required by Technical Specifications are indicated with a double asterisk.

,

٠

٠

•

ب ۲ ۲ •

•

**、** 

	Unit	1_X_	Unit 2 _
--	------	------	----------

.

•

Reporting Period January - June 1993

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES					
There were no liq	uid releases during the reporting period.		<u>1"</u> OUARTER	<u>2"</u> QUARTER	EST. TOTAL ERROR, %
Α.	<ul> <li>Fission &amp; Activation Products</li> <li>1. Total release (not including tritium, gases, alpha)</li> <li>2. Average diluted concentration during reporting period</li> </ul>	Ci µCi/ml	No Releases No Releases	No Releases No Releases	5.00E+01
В.	<u>Tritium</u> 1. Total release 2. Average diluted concentration during reporting period	Ci µCi/ml	No Releases No Releases	No Releases No Releases	5.00E+01
c.	Dissolved and Entrained Gases 1. Total release 2. Average diluted concentration during reporting period	Ci µCi/ml	No Releases No Releases	No Releases No Releases	5.00E+01
D.	<u>Gross Alpha Radioactivity</u> 1. Total release	Ci	No Releases	No Releases	5.00E+01
E.	<ol> <li>Volumes</li> <li>Prior to dilution</li> <li>Volume of dilution water used during release period</li> <li>Volume of dilution water available during reporting period</li> </ol>	Liters Liters Liters	No Releases No Releases <u>3.35E+10</u>	No Releases No Releases <u>1.16E+11</u>	5.00E+01 5.00E+01 5.00E+01
F.	Percent of Technical Specification Limits Percent of Quarterly Whole Body Dose Limit (1.5 mrem) Percent of Quarterly Organ Dose Limit (5 mrem) Percent of Annual Whole Body Dose Limit to Date (3 mrem) Percent of Annual Organ Dose Limit to Date (10 mrem) Percent of 10CFR20 Concentration Limit Percent of Dissolved or Entrained Noble Gas Limit (1.00E-5 µCi/ml)	% % % %	No Releases No Releases No Releases No Releases No Releases No Releases	No Releases No Releases No Releases No Releases No Releases No Releases	

.

.

.

4 1 81 1 5. 5. 7.

.

,

a

Unit 1 <u>X</u> Unit 2 \_

.

•

Reporting Period January - June 1993

1

LIQUID EFFLUENTS RELEASED					
	BATCH MODE				
		1*	2 <sup>nd</sup>		
Nuclides Released		QUARTER	QUARTER		
Strontium-89	Ci	No Releases	No Releases		
Strontium-90	Ci	No Releases	No Releases		
Cesium-134	Ci	No Releases	No Releases		
Cesium-137	Ci	No Releases	No Releases		
lodine-131	Ci	No Releases	No Releases		
Cobalt-58	Ci	No Releases	No Releases		
Cobalt-60	Ci	No Releases	No Releases		
Iron-59	Ci	No Releases	No Releases		
Zinc-65	Ci	No Releases	No Releases		
Manganese-54	Ci	No Releases	No Releases		
Chromium-51	Ci	No Releases	No Releases		
Zirconium-Niobium-95	Ci	No Releases	No Releases		
Molybdenum-99	Ci	No Releases	No Releases		
Technetium-99m	Ci	No Releases	No Releases		
Barium-Lanthanum-140	Ci	No Releases	No Releases		
Cerium-141	Ci	No Releases	No Releases		
Tungsten-187	Ci	No Releases	No Releases		
Arsenic-76	Ci	No Releases	No Releases		
lodine-133	Ci	No Releases	No Releases		
Iron-55	Ci	No Releases	No Releases		
Neptunium-239	Ci	No Releases	No Releases		
Praseodymium-144	Ci	No Releases	No Releases		
lodine-135	Ci	No Releases	No Releases		
Dissolved or Entrained Gases	Ci	No Releases	No Releases		
Tritium					
	Ci	No Releases	No Releases		

.

• • ,

. . .

.

.

×

• •

١

Unit 1 <u>X</u> Unit 2 \_\_\_\_

.

Reporting Period January - June 1993

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS						
A.1 TYPE		<u>Volume</u> (m³)		<u>Activity</u> 1 (Ci)		
		<u>Class</u>			<u>Class</u>	
	А	В	С	A	B	с
1 Spent Besin						
	<u>4.79E+01</u>	<u>0</u>	<u>0</u>	<u>3,50E+02</u>	<u>0</u>	<u>0</u>
Filter Sludge	<u>1.65E+01</u>	<u>0</u>	<u>0</u>	<u>2.10E+02</u>	<u>0</u>	<u>0</u>
Concentrated Waste Evaporator Bottoms	<u>0</u>	<u>1.10E+01</u>	<u>0</u>	<u>0</u>	<u>3.06E+01</u>	<u>0</u>
Total	<u>6.44E+01</u>	<u>1.10E+01</u>	<u>0</u>	<u>5.60E+02</u>	<u>3.06E+01</u>	<u>0</u>
· · · ·						
2. Dry Compressible Waste,						
Waste (Contaminated Equipment)	<u>1.14E+01</u>	<u>o</u>	<u>0</u>	<u>3,81E+00</u>	<u>0</u>	<u>0</u>
	**************************************			·····	<u></u>	
3. Irradiated Components	There were no irradiated components shipped for burial during the reporting period.					
<sup>1</sup> The estimated total error is 5	<sup>1</sup> The estimated total error is 5.00E+01%.					

1

L.

t

•

.

\*

\*

, V

4

,

٠

Γ

Uni	t 1 <u>X</u> Unit 2	Report	ting Period <u>Janu</u>	<u> Jary - June 1993</u>	
	SOLID WASTE AND IRRADIATED FUEL SHIPMENTS				
A.1	ТҮРЕ	<u>Container</u>	Package	Solidification	
1.	Spent Resin	ніс	<u>Түре А</u>	<u>None</u>	
	Filter Sludge	HIC	<u>Түре А</u>	Cement	
	Concentrated Waste	HIC	<u>Түре В</u>	<u>Cement</u>	
2.	Dry Compressible Waste, Dry Non-Compressible Waste (Contaminated Equipment)	<u>Steel_Box</u>	<u>Түре А</u>	None	
3.	Irradiated Components	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	

.

,

.

٣

٩

Unit 1 <u>X</u>	Unit 2	Reporting Period <u>January - June 1993</u>			
	SOLID WA	ASTE AND IRRADIATED FUEL SHIPMENTS			
A.2 ESTIN	ATE OF MAJOR NUCLIDE COMP	POSITION (BY TYPE OF WASTE)			
a. Spent R	a. Spent Resins, Filter Sludges, Concentrated Waste:				
	Nuclide	Percent			
(1)	Co-60	6.40E+01			
(2)	Mn-54	1.21E+01			
(3)	Fe-55	1.17E+01			
(4)	Cs-137	8.50E+00			
(4)	Co-58	1 105+00			
	Other	2 505 + 00			
(0)	Other	2,302+00			
b. Dry Cor	npressible Waste, Dry Non-Comp	ressible Waste (Contaminated Equipment):			
	Nuclide	Percent			
(1)	Co.60	5 905+01			
	Co-137	2 145+01			
(2)					
(3)	Mn-54	9.900 + 00			
(4)	Co-58	5.30E+00			
(5)	Fe-59	1.90E+00			
(6)	Fe-55	1.00E+00			
(7)	Other	1.50E+00			
c. Irradiate	ed Components: There were no	shipments.			
1					
	· · · · · · · · · · · · · · · · · · ·				
d. Other:	There were no shipments.				

.

.

•

'n ·

\$

a - 1

L.

٠

•

Unit 1 <u>X</u> Unit 2		Reporting Period January - June 1993		
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS				
A.3. SOLID WASTE DISPOSITION				
Number of Shipments	Mode of Transportation	Destination		
	Truck	Barnwell, SC		
B. IRRADIATED FUEL SHIPMENTS (DISI	POSITION)			
There were no shipments.				
Number of Shipments	Mode of Transportation	Destination		
	_N/A	<u>_N/A</u>		

÷

ų,

1.

٠

•

Ī

50 g.

ı

.

-

**X** 

•

.

Unit 1	<u>x</u>	Unit 2			Reportin	g Period <u>Janua</u>	ry - June 1993				
	SOLID WASTE AND IRRADIATED FUEL SHIPMENTS										
C. SOLID WASTE SHIPPED OFF-SITE TO VENDORS FOR PROCESSING AND SUBSEQUENT BURIAL											
Below is a summary of Dry Active Waste that was shipped off-site for processing and burial by vendor facilities (i.e., ALARON, QUADREX, and/or SCIENTIFIC ECOLOGY GROUP) during <u>January - June 1993</u> . These totals were reported separately from "10CFR61 Solid Waste Shipped for Burial" (i.e., Section A of Table 3A) since (a) waste classification and burial was performed by the vendors, and (b) Technical Specification 6.9.1 requires reporting of "information for each class of solid waste (as defined by 10CFR61) shipped off-site during the reporting period". The information provided in this section, therefore, is in addition to that required by the Technical Specifications. The following data represents the actual shipments made from the off-site vendors of our non-compacted commingled trash that was processed prior to burial.											
C.1.	TYPE OF WASTE - noncompacted commingled trash and contaminated fuel pool equipment shipped to Oakridge, TN for processing prior to burial at Barnwell, SC				Burial Volum <del>o</del> (m³)	Activity (Ci)	Est. Total <u>Error, %</u>				
					<u>2.11E+01</u>	<u>5.35E-01</u>	<u>5.00E+01</u>				
C.2. ESTIMATE OF MAJOR NUCLIDE COMPOSITION											
	N	uclide	Percent								
(1) (2) (3) (4) (5) (6)	C C M C F	0-60 3-137 In-54 0-58 0-59 Dther	5.94E+01 2.21E+01 9.71E+00 5.20E+00 1.91E+00 1.68E+00								
C.3.	so	LID WASTE DISP	OSITION								
	Number of Shipments Mode of Transportati				1	Destinatio	n				
		5Truck			<u>Barnwell, SC</u>						
		6			<u>Richland, WA</u>						
<sup>1</sup> The number of shipments reported here represents the total number that was shipped from the offsite vendor for burial. This does not represent the number of shipments Niagara Mohawk sent to be processed.											

.

÷

,

.

•

\* \*

、

, ,

). 6 10

• •

Unit 1 X Unit 2		Reporting Period <u>January - June 1993</u>								
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS										
D. SEWAGE SLUDGE SHIPPED TO A TREATMENT FACILITY CENTER FOR PROCESSING AND BURIAL										
Below is a summary of the sewage sludge which was removed from the site sanitary treatment facility and transferred to a municipal sewage treatment facility, for subsequent drying and disposal to a landfill. This is a site release, and therefore includes the results from Unit 1 activities, also.										
D.1. TYPE OF WASTE - sewage sludge	Burial Volume         Activity           (L)         (Ci)           3.03E+04         2.4E-07									
D.2. ESTIMATE OF MAJOR NUCLI	D.2. ESTIMATE OF MAJOR NUCLIDE COMPOSITION									
<u>Nuclide</u> <u>Percent</u> Co-60 1.00E+02										
D.3. SOLID WASTE DISPOSITION	D.3. SOLID WASTE DISPOSITION									
Number of Shipments	Mode_of_Transportation Des	tination								
•	<u> </u>	.andfill_								
<u>Note</u> : There were two shipments of sewage sludge with quantified Co-60 that were sent by vendor vacuum tank truck from NMP to the treatment facility. The number of shipments sent from NMP does not reflect the number of shipments to the ultimate destination (i.e., landfill). Sludge is mixed with municipal sludge, dried, and subsequently transferred to a state approved landfill by municipal personnel.										

.

•

р • •

`

.



Unit 1 X Unit 2

2

.

Reporting Period January - June 1993

## SUMMARY OF CHANGES TO THE OFF-SITE DOSE CALCULATION MANUAL

There were two revisions to the Unit 1 ODCM during the reporting period. These Revisions 11 and 12 are attached along with a summary of changes presented to and approved by the Site Operations Review Committee. The summary, also, includes a justification for each change.

and a server

7 1 1 r 1. . . . .

.

1

I.

.

•



Unit 1 X Unit 2 \_\_\_\_

\*

¥

.

Reporting Period January - June 1993

# SUMMARY OF CHANGES TO THE PROCESS CONTROL PROGRAM

There were no changes to the Process Control Program during the reporting period.

. . .

•



Unit 1 X Unit 2

.

.

Reporting Period January - June 1993

SUMMARY OF INOPERABLE MONITORS

Monitor

Dates of Inoperability

Cause and Corrective Actions

There were no inoperable monitors for a period greater than 30 days during the reporting period.

. ø

٠

•

.

#### UPDATE TO THE PREVIOUS REPORTS

.

ч

1

•

.

μ

é

ŝ



# SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1992) NINE MILE POINT NUCLEAR STATION #1 RADIATION DOSES TO THE LIKELY MOST EXPOSED MEMBER OF THE PUBLIC OUTSIDE THE SITE BOUNDARY

## **JANUARY - DECEMBER 1992**

Radiation doses to the likely most exposed member of the public outside of the site boundary are evaluated relative to 40CFR190 requirements. The dose limits of 40CFR190 are 25 mRem (whole body or organ) per calendar year and 75 mRem (thyroid) per calendar year. The intent of 40CFR190 also requires that the effluents of NMP2 as well as other nearby uranium fuel cycle facilities be considered. In this case, the effluents of NMP1, NMP2 and the James A. FitzPatrick (JAF) facilities must be considered.

Doses to the likely most exposed member of the public as a result of effluents from the site can be evaluated by using calculated dose modeling based on the accepted methodologies of the facilities' Offsite Dose Calculation Manuals or may, in some cases, be calculated from the analysis results of actual environmental samples. Acceptable methods for calculating doses from environmental samples are also found in the facilities' Offsite Dose Calculation Manuals. These methods are based on Regulatory Guide 1.109 methodology.

Dose calculations from actual environmental samples are, at times, difficult to perform for some pathways. Some pathway doses should be estimated using calculational dose modeling. These pathways include noble gas air dose, inhalation dose, etc. Other pathway doses may be calculated directly from environmental sample concentrations using Regulatory Guide 1.109 methodology.

Since the effluents from the generating facilities are low, the resultant gaseous and liquid effluent doses are anticipated to be low. In view of this, doses can be based on calculated data. Doses are not based on actual environmental data for 1992 with the exception of doses from direct radiation, fish consumption and shoreline sediment. In addition, in order to be conservative and for the sake of simplicity, it is assumed in the dose calculations that the likely most exposed member of the public is positioned in the maximum receptor location for each pathway at the same time. This approach is utilized because the doses are very low and the computations are greatly simplified.

The following pathways are considered:

- 1. The inhalation dose is calculated at the critical residence because of the high occupancy factor. In order to be conservative, the maximum whole body and organ dose assumes no correction for residing inside a residence.
- 2. The milk ingestion dose is calculated utilizing the maximum milk cow location. As noted previously, in order to be conservative and for the sake of simplicity, the likely most exposed member of the public is assumed to be at all critical receptors at one time. In this case, the member of the public at the critical residence is assumed to consume milk from the critical milk location.

\*

,

.

·

,



# SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1992) NINE MILE POINT NUCLEAR STATION #1 RADIATION DOSES TO THE LIKELY MOST EXPOSED MEMBER OF THE PUBLIC OUTSIDE THE SITE BOUNDARY

# **JANUARY - DECEMBER 1992**

- 3. The maximum dose from the milk ingestion pathway as a result of consuming goat's milk is based on the same criteria established for item 2 above (ingestion of cow's milk).
- 4. The maximum dose associated from consuming meat is based on the critical meat animal. The likely most exposed member at the critical residence is assumed to consume meat from the critical meat animal location.
- 5. The maximum site dose associated with the consumption of vegetables is calculated from the critical vegetable garden location. As noted previously, the likely most exposed member of the public is assumed to be located at the critical residence and is assumed to consume vegetables from the critical garden location.
- 6. The dose as a result of direct gamma radiation from the site encompasses doses from direct "shine" from the generating facilities, direct radiation from any over head gaseous plumes, plume submersion and from ground deposition. This total dose is measured by environmental TLD. The critical location is based on the closest year round residence from the generating facilities as well as the closest residence in the critical downwind sector in order to evaluate both direct radiation from the generating facilities and gaseous plumes as determined by the local meteorology. During 1992, the closest residence and the critical downwind residence are at the same location.

The measured average dose for 1992 at the critical residence was 53.0 mRem. The average control dose (average of five locations) was 50.3 mRem. The average dose at the critical residence is slightly greater than the average control location dose. The net increase in dose is due to the differences between doses from naturally occurring radionuclides in the soil and rock at the different locations and due to the standard deviation in TLD measurements. This difference in dose rate can be demonstrated by observing the 1992 average dose for an environmental TLD located near the critical residence TLD, but approximately 700 feet closer to the generating facilities. The annual average dose for this TLD location was 49.6 mRem. The dose for this location is lower than the critical residence location even though they are close to one another and even though the TLD location with the lowest dose is closer to the generating facilities.

7. The dose, as a result of fish consumption, is considered as part of the aquatic pathway. The dose for 1992 is calculated from actual results of the analysis of environmental fish samples. For the sake of being conservative, the average plant related radionuclide concentrations were utilized from fish samples taken near the site discharge points. The average concentration was adjusted to account for any background concentrations using average control sample data. Only Cs-137 was detected during 1992 at a net concentration of 1.3E-3 pCi/g-wet. The calculated maximum adult organ dose was 3.0E-3 mRem to the liver. The maximum whole body dose is 1.9E-03 mRem to an adult.

r •



# SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1992) NINE MILE POINT NUCLEAR STATION #1 RADIATION DOSES TO THE LIKELY MOST EXPOSED MEMBER OF THE PUBLIC OUTSIDE THE SITE BOUNDARY

# JANUARY - DECEMBER 1992

- 8. The shoreline sediment pathway is considered relative to recreational activities. The dose due to recreational activities from shoreline sediment is based on the methodology in the Offsite Dose Calculation Manual as adapted from Regulatory Guide 1.109. The Offsite Dose Calculation Manual gives the total dose to the whole body and skin from the sum of plant related radionuclides detected in shoreline sediment samples. The plant related radionuclide concentration is adjusted for background sample results, as applicable. The total whole body and skin dose from shoreline recreational activities is 1.04E-03 mRem whole body and 1.21E-03 mRem skin dose for the period.
- 9. In summary, the maximum dose to the most likely exposed member of the public is 5.38E-02 mRem to the thyroid (maximum organ dose) and 8.41E-03 mRem to the whole body. It should be noted that the maximum organ dose and maximum whole body doses are based on the sum of the maximum doses observed for all three facilities regardless of age group. This results in some conservatism. The maximum organ and whole body doses were a result of gaseous effluents. Doses as a result of liquid effluents were secondary. The total whole body, maximum organ and skin dose from shoreline recreational activities and fish consumption are 2.94E-03 mRem whole body, 3.00E-03 mRem to the liver, and 1.21E-03 mRem skin dose for the period. The direct radiation dose to the critical residence from the generating facilities was insignificant or zero. These maximum total doses are a result of operations at the Nine Mile Point Unit 1, Nine Mile Point Unit 2 and the James A. Fitzpatrick facilities. The maximum organ dose and whole body dose are below the 40CFR190 criteria of 25 mRem per calendar year to the maximum exposed organ or the whole body, and below 75 mRem per calendar year to the thyroid.

.

,

,

Unit 1 X Unit 2 Reporting Period January - June 1993										
UPDATE OF RELEASE AND DOSE DATA FOR GASEOUS (ELEVATED AND GROUND LEVEL) AND LIQUID EFFLUENTS										
Update of data using actual results from the off-site vendors for Strontium, Tritium, and Iron-55										
		GASEOUS (Quarter) 4*		LIQUID (Quarter) 4 <sup>th</sup>						
<u>Nuclide</u>		Activity (Ci)		<u>Activity (Ci)</u>						
Sr-89		<u>1.11E-04</u>		No Releases						
Sr-90		<u>1.40E-06</u>		<u>No Releases</u>						
H-3		<u>8.34E+00</u>		No Releases						
Fe-55		<u>4.42E-05</u>		<u>No Releases</u>						
Particulates				GASEOUS	LIQUID					
	1. Particula	ites with	Ci	<u>6.71E-04</u>	<u>N/A</u>					
	half-live: 2. Average for perio	₃ >8 days ⊧release rate id	µCi/sec	<u>8.53E-05</u>	<u>N/A</u>					
Tritium										
	<ol> <li>Total rel</li> <li>Average for period</li> </ol>	ease release rate d	Ci µCi/sec	<u>8.34E+00</u> <u>1.06E+00</u>	<u>N/A</u> N/A					
Tritium, lodines, and Particulates (with half- lives greater than 8 days)				<u>GASEOUS</u>	LIQUID					
	1. Percent	of Quarterly	%	4.12E-01	N/A					
	Dose Limit' 2. Percent of Annual		%	(Quartery) 5.74E-01	(Quarteriy) <u>N/A</u>					
	Dose Lir 3. Percent - Dose F (Gaseou - Dose L (Annual	nit to Date' of Organ ate Limit s)(Quarterly) imit (Liquid) & Quarterly)	%	(Annual) <u>8.29E–03</u> (Quarterly) <u>N/A</u> (Annual)	(Annual) <u>N/A</u> (Quarterly) <u>N/A</u> (Annual)					
	4. Percent Concent (Liquid)	of 10CFR20 ration Limit	%	<u>N/A</u>	<u>N/A</u>					
	5. Percent or Entrai Gas (Liq	of Dissolved ned Noble uid)	%	<u>N/A</u>	<u>N/A</u>					
<sup>1</sup> The dose is to the whole body for liquid effluents and the the maximally exposed organ for gaseous effluents.										

.

•

,