

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9312070202 DOC.DATE: 93/11/30 NOTARIZED: NO DOCKET #
 FACIL:50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220

AUTH.NAME AUTHOR AFFILIATION
 TERRY, C.D. Niagara Mohawk Power Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards responses to NRC questions on Condensation
 Oscillation load reduction for Unit 1 re 931105-16 telcon.
 Diagram encl.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: OR Submittal: General Distribution

NOTES:


	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD1-1 LA		1	1		PD1-1 PD		1	1
	BRINKMAN, D.		2	2					
INTERNAL:	ACRS		6	6		NRR/DE/EELB		1	1
	NRR/DORS/OTSB		1	1		NRR/DRCH/HICB		1	1
	NRR/DRPW		1	1		NRR/DSSA/SPLB		1	1
	NRR/DSSA/SRXB		1	1		NUDOCS-ABSTRACT		1	1
	OC/LEDCB		1	0		OGC/HDS1		1	0
	REG ELLE 01		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20

R
I
D
S
/
A
D
S
/
A
D
S
/
A
D
S



November 30, 1993
NMP1L 0791

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Gentlemen:

During the telephone conversations on November 5 and 16, 1993, our staffs discussed the Condensation Oscillation load reduction associated with the Nine Mile Point Unit 1 Torus. The specific matter related to the assumed load to be used in any subsequent analysis of the Torus shell in the vicinity of the mitre joint/ring girder between the four and eight downcomer bays should such an analysis become warranted. Attachment 1 to this letter provides documentation of Niagara Mohawk's position with respect to this issue.

Very truly yours,



C. D. Terry
Vice President
Nuclear Engineering

MJJ/lmc

Attachment

xc: Regional Administrator, Region I
Mr. R. A. Capra, Director, Project Directorate I-1, NRR
Mr. B. S. Norris, Senior Resident Inspector
Mr. D. S. Brinkman, Senior Project Manager, NRR
Records Management

0300A

9312070202 931130
PDR ADOCK 05000285
P PDR

ADD 1

100

THE UNIVERSITY OF CHICAGO

PHYSICS DEPARTMENT

PHYSICS 551

LECTURE 10

ATTACHMENT 1

*Nine Mile Point Unit 1
Torus Load Reduction Submittal of May 14, 1993
(TAC No. M85003)*

Question:

Define the Condensation Oscillation loads to be used for Torus shell evaluation in the vicinity of the ring girder/mitre joint.

Response:

Teledyne Engineering Services (TES) Technical Report TR-7353-1 (Reference 1) differentiates between the Condensation Oscillation loads to be used for the free shell evaluations in the four and eight downcomer bays but is silent on the loads to be used for the local region near the ring girder. Should evaluation of the Torus shell in the "immediate vicinity" of the ring girder and mitre joint be necessary in the future, Niagara Mohawk will conservatively use Condensation Oscillation loads associated with the bays containing eight downcomers rather than the four downcomers regardless of whether the evaluation is on the eight downcomer or four downcomer side of the ring girder.

The term "immediate vicinity" will be defined as one-square-root-of-mean radius-times-thickness ($1.0\sqrt{Rt}$) from the intersection of the ring girder or mitre joint measured longitudinally along the Torus bay. This is the ASME Code definition of a local region caused by a structural discontinuity and is the region used in TR-6801-2 (Reference 2). Attached Figure 1 depicts this region.

The Mark I Containment Program minimum thickness requirements at the midbay (free-shell) location of the torus shell are governed by the primary membrane stress (P_M) obtained from the one-fortieth Stardyne model considering the various Mark I Containment Program event combinations. For the Torus shell adjacent to the ring girder (local shell), a gross structural discontinuity, the minimum thickness requirements are governed by the primary local stress (P_L). The primary local stress region extends for a distance of 8.6325 inches or $1.0\sqrt{Rt}$ from the intersection of the ring girder longitudinally along the eight downcomer torus bays. In addition, on the mitre side of the ring girder, i.e., the bays containing four downcomers, the local region extends 8.6325 inches beyond the mitre away from the ring girder. The remainder of the Torus shell is governed by the midbay thickness requirements.

References:

1. TES Technical Report TR-7353-1, Revision 2, "Nine Mile Point Unit 1, Reduction in Mark I Torus Program Condensation Oscillation Load Definition and Resulting Effect on Minimum Shell Thickness Requirements," dated January 14, 1992.
2. TES Technical Report TR-6801-2, Revision 1, "Mark I Torus Shell and Vent System Thickness Requirements, Nine Mile Point Unit 1 Nuclear Station," dated January 19, 1988.

27031-10000 11/10/1950
ALBERT MALOUA 11/10/1950

ALBERT MALOUA

LOCAL TORUS SHELL STRESS REGIONS
NINE MILE POINT UNIT 1 NUCLEAR STATION




FIGURE 1



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300

301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400

401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500

501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600