



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE MILE POINT NUCLEAR STATION UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 148
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated November 18, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

9404180291 940407
PDR ADDCK 05000220
P PDR




(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 148, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented prior to startup from the next refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION


for Robert A. Capra, Director
Project Directorate-I-111
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 7, 1994



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 148 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

Remove Page

238

Insert Page

238



TABLE 3.6.2i (cont'd)

DIESEL GENERATOR INITIATION

Limiting Condition for Operation

<u>Parameter</u>	<u>Set Point (Inverse Time Undervoltage Relays)</u>	
	<u>Relay Dropout</u>	<u>Operating Time</u>
Loss of Power		
a. 4.16kV PB 102/103 Emergency Bus Undervoltage (Loss of Voltage)	≥ 3200 volts	0 volts ≤ 3.2 seconds ^(a)
b. 4.16kV PB 102/103 Emergency Bus Undervoltage (Degraded Voltage)	≥ 3705 volts	> 3.4 seconds ^(b) < 60 seconds ^(c)

- (a) The operating time indicated in the table is the time required for the relay to operate its contacts when the voltage is suddenly decreased from operating voltage level values to the voltage level listed in the table above.
- (b) The operating time indicated in the table is the minimum time required to clear voltage transients due to load sequencing to avoid spurious separation from offsite power.
- (c) The operating time indicated in the table is the maximum time allowable to preclude load damage or trip device actuation at voltages below the degraded voltage setpoint of 3705 volts.



14