



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE MILE POINT NUCLEAR STATION UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 151
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated August 26, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

9501090326 941229
PDR ADOCK 05000220
P PDR




(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 151, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION


Michael J. Case, Acting Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 29, 1994



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 151 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

Remove Page

134

Insert Page

134

134



LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

(3) When adding the leakage rate measured during a Type C test to the results of a Type A test, the leakage rate shall be determined using minimum pathway analysis.

c. Frequency

(1) Three Type A tests shall be conducted during each ten year service interval at approximately equal intervals. The third test will be conducted when the plant is shutdown for the 10 year inservice inspections.*

(2) Retesting

(a) If a Type A test fails to meet the acceptance criteria of 4.3.3.b.(1), a Corrective Action Plan that focuses attention on the cause of the problem shall be developed and implemented. A Type A test that meets the requirements of 4.3.3.a.(3) and 4.3.3.b.(2) is required prior to plant start-up. A report of the Corrective Action following the failed Type A shall be submitted to the NRC for review and approval with the Containment Leak Test Report.

* The duration of the second ten year service interval will be extended to correspond with the end of the ISI interval.

