

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-410


NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 62 License No. NPF-69

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated November 14, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:

9502040099 950131 PDR ADDCK 05000410 PDR



(2) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 62 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION


Ledyard B. Marsh, Director Project Directorate I-1

LB Marsh

Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: January 31, 1995



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 62 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410


Revise Appendix A as follows:

Remove Page

Insert Page

3/4 5-6

3/4 5-6



EMERGENCY CORE COOLING SYSTEMS

ECCS - OPERATING

SURVEILLANCE REQUIREMENTS

4.5.1 (Continued)

- e) Performing a leak rate test for the safety related ADS accumulator pneumatic supply system (including special emergency tube trailer supply piping) up to SRV actuators/operators. \With the SRV's actuated by either of the ADS solenoids and with ADS accumulators at 178 psig and with ADS nitrogen receiving tanks at 365 psig (high pressure alarm), the leakage rates shall not exceed the following limits:
 - 1. For the ADS SRV actuators, supply header and accumulators, and the nitrogen receiving tank for the SRV's 2MSS*PSV 121, 126 & 127, maximum allowable leakage is 3 SCFH.
 - 2. For the ADS SRV actuators, supply header and accumulators, and the nitrogen receiving tank for the SRV's 2MSS*PSV 129, 130, 134, & 137, maximum allowable leakage is 4 SCFH.

