

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9503100126 DOC.DATE: 95/02/28 NOTARIZED: NO DOCKET #
 FACIL:50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH.NAME AUTHOR AFFILIATION
 TERRY,C.D. Niagara Mohawk Power Corp.
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to request for addl info re core shroud repair.
 Suppl 1 to GE-NE-B13-01739-04, "Suppl 1 to Nine Mile Unit 1
 Shroud" encl.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR ENCL SIZE: 15 + 17
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD1-1 LA BRINKMAN, D.	1 1 1 1	PD1-1 PD	1 1
INTERNAL:	ACRS	6 6	<u>FILE CENTER 01</u>	1 1
	NRR/DRCH/HICB	1 1	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
	OGC/HDS3	1 0		
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 16

MAY

P
R
I
O
R
I
T
Y

1
D
O
C
U
M
E
N
T



3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

CARL D. TERRY
Vice President
Nuclear Engineering

February 28, 1995
NMP1L 0910

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Subject: *Response to Request for Additional Information Regarding the Nine Mile Point Unit 1 Core Shroud Repair (TAC No. M90102)*

Gentlemen:

By letter dated February 23, 1995, the Commission made a request for additional information concerning the Nine Mile Point Unit 1 Core Shroud Repair. Our letter dated February 24, 1995, provided responses to the requested information except for requests 2, 3, 4, 5, and 7. Attachment 1 to this letter provides responses to these remaining items.

Niagara Mohawk Power Corporation has completed an inspection of the core shroud H8 weld. The inspection utilized ultrasonic examination supplemented by enhanced visual examination in areas where access was not possible for the ultrasonic inspection tool. A total of approximately 260 degrees of the weld circumference was inspected by the combination of ultrasonic and visual examination. Two areas containing indications are being evaluated. At this time, Niagara Mohawk Power Corporation believes none of the indications is of structural significance and that Niagara Mohawk Power Corporation's acceptance screening criteria is met with significant margin. Niagara Mohawk Power Corporation, therefore, has decided that repair of the H8 weld by installation of brackets is not necessary. Future reinspection of the areas containing indications will be addressed at a later time consistent with the ongoing BWRVIP work on reinspection scope and frequency.

Very truly yours,



C. D. Terry
Vice President - Nuclear Engineering

CDT/JMT/kab
Enclosure

100022
9503100126 950228
PDR ADCK 05000220
P PDR

Adol
1/11



Page 2

xc: Regional Administrator, Region I
Mr. L. B. Marsh, Director, Project Directorate I-1, NRR
Mr. D. S. Brinkman, Senior Project Manager, NRR
Mr. B. S. Norris, Senior Resident Inspector
Records Management



ATTACHMENT 1

Information Request 2

The summary of the hardware stresses provided with the repair hardware analysis, General Electric (GE) Report No. GE-NE-B13-01739-04, indicates that the stresses in the toggle and lower support are at or near the allowable values for the steamline break and design-basis earthquake (DBE) events. Provide the details of these calculations to demonstrate that the bending stresses in the toggle due to postulated failures of welds H₇ and H₈ have been considered in the evaluations.

Response 2

The details of the lower support (Drawing 112D6585) stress calculations are attached (Attachment 2). The analysis of the lower support includes both tensile and bending stresses and is found acceptable.

The depth of the toggle (Drawing 112D6581) is 3.83 inches, which is large compared to the 7.13 inch span across the hole in the cone, and the traditional beam bending equations are not applicable. "Formulas for Stress and Strain," by R. J. Roark and W. C. Young, Fifth Edition, assume a span to depth ratio of 8 or more for the beam equations to be applicable.

$$\text{The span to depth ratio of the toggle} = 7.13/3.83 = 1.86$$

The loads on the toggle were evaluated for shear or tearout stresses which are found to be acceptable.

If one considers the loading on the toggles to be in bending, the following calculations show the calculated bending stresses are acceptable.

$$\text{Bending stress} = Mc/I$$

M = moment

c = distance from centroid to surface

I = section modulus

Assume the toggle is a simply supported beam that pivots about the edge of the hole through the cone and with the load applied at the center of the span. The maximum moment occurs at the center of the span.

$$M_{\max} = Pl/4$$

P = applied load

l = span length



The section modulus at the center of the toggle is at the same location as the pin. The section modulus at this location is that of the toggle less that of the pin.

$$I = 2 \times [(b \times h^3/12) - (b \times D^3/12)]$$

b = width of the toggle

h = depth of toggle

D = pin diameter

The bending stresses calculated are tabulated below.

<u>EVENT</u>	<u>CALC STRESS, PSI</u>	<u>ALLOWABLE STRESS, PSI</u>
Normal	30,500	71,250
Upset	62,100	71,250*
Emergency	83,000	106,875
Faulted	119,384	142,500

* The actual Code allowable where the pressure differences for Level B Service (Upset) exceed those for Level A Service (Normal) is 110% of the Level A allowables (Ref. NG-3223). Upset Allowable = 110% x 71,250 psi = 78,375 psi.

Information Request 3

The assessment to determine the impact of the tie rod assembly on the stresses at the H₈ weld, provided in Report No. GE-NE-B13-01739-04, Appendix A, is based on an uncracked shroud condition. What would be the impact of the tie rod assembly on the H₈ weld stresses if it were postulated to be cracked through wall in the vicinity of the attachment points of the tie rod assembly?

Response 3

Crack propagation analysis is based on stresses calculated for material in the noncracked condition. Once the uncracked stress is known, the crack propagation is calculated using the appropriate stress intensity factor. The crack growth is entirely determined by the stress in the uncracked condition.

The condition stated where the H8 weld is assumed cracked throughwall in the vicinity of the tie rod location was not specifically analyzed. The crack propagation stress intensity factor was defined for the H8 weld uncracked condition. This analysis is documented in Appendix A of GENE-B13-01739-04 and demonstrated that the tie rods have no significant effect on the stresses in the H8 weld. Since the H8 weld inspection



Small, faint, illegible marks or characters in the top right corner.

has demonstrated that the H8 weld has no significant cracking, a detailed analysis of the impact of tie rods on postulated partial throughwall cracking at the tie rod attachment points is not considered required.

Information Request 4

The postulated 360° through wall failures of H₂, H_{6A}, H₇, and H₈ was judged to be the most representative for including gaps in the finite element model as stated in Section 3.5.14 of Report No. GE-NE-B13-01739-04. Provide the rationale for not including postulated failures of welds H₃ and H_{6B} in the analytical model. Also, provide the magnitudes of the calculated gaps at the postulated failed weld locations H₂, H₃, H_{6A}, H_{6B}, H₇, and H₈ for both normal operating and accident conditions.

Response 4

Our intent was to assume a worst case scenario for cracking in all the circumferential welds from H1 through H7. Since cracking at welds H2 and H3 could affect the shroud stiffness, and therefore the preload, additional stress analysis was performed as a supplement to the referenced stress analysis (GE-NE-B13-01739-04) (Attachment 3). The results confirm that there is no gap for normal conditions for welds H1 through H7. For upset conditions, conservative assumptions predict a maximum separation of .030 inches. Realistic assumptions regarding the H2 and H3 fillet weld integrity demonstrate that no separation would occur for bounding 100% rated core flow upset condition pressures. For accident conditions, gaps are predicted and were addressed in the safety evaluation previously submitted. The existence of gaps during conditions other than normal operation does not violate the generic VIP shroud repair guidelines.

The potential crack separation for upset event conditions is temporary and will close following the event. The tie rod assembly stresses remain within elastic limits. The weld separation will close following the upset event since the thermal preload is recovered and the rod will remain tight. The mechanical pre-load is not affected. No inspection of the tie rod or weld is required following an upset event above the normal tie rod and refuel outage shroud ISI plan which is under development.

The supplemental stress report has been prepared to specifically address the issue of weld crack separation during normal/upset operation and accident conditions. The conditions considered include throughwall 360° cracking simultaneously at H2 and H3. The analysis does not postulate cracking at H8, but covers cracking at all other welds (H1 - H7). The results of the H8 weld inspections validate the assumption that the H8 weld is not 360° throughwall cracked. An ANSYS finite element model was prepared that includes details at the top guide support ring and at the conical support. The stabilizer stiffness and the stiffness of the lower support are also included in the preload calculations and the supplemental stress evaluation.

Since welds H2 and H3 affect the shroud stiffness, they are specifically addressed in the supplemental analysis. Welds H2 and H3 are full penetration welds with a 0.63 fillet on the ring side. Fillet welds with 0.6 inch legs are modeled for conservatism.



Small, faint, illegible markings or text in the top right corner.

Four cases were analyzed which bound the stiffness at the top guide ring are listed below. The K_s term is the shroud stiffness including the top ring and conical support.

Case 1. Welds H2 and H3 have a 360° throughwall crack on the ring side of the fillet weld ($K_s = 6.76 \times 10^6$ lb/in).

Case 2. Welds H2 and H3 have a 360° throughwall crack on the shroud shell side of the fillet weld ($K_s = 6.33 \times 10^6$ lb/in).

Case 3. Welds H2 and H3 have a 360° throughwall cracks and there is no fillet weld ($K_s = 2.70 \times 10^6$ lb/in).

Case 4. Welds H2 and H3 are not cracked ($K_s = 68.7 \times 10^6$ lb/in).

Metallurgical evidence from reactor weld failures analysis suggest Case 1 is the most likely to occur for cracks extending greater than 180°. Cases 1 through Case 3 bound the ring stiffness for the postulated crack scenarios.

The compressive load at welds H6B and H7 are calculated for each case and are shown in the table below. The combined stiffness of the four stabilizers, including the lower supports, is 1.978×10^6 lb/in.

COMPRESSIVE LOAD AT WELDS H7B AND H7

CASE NUMBER	THERMAL PRELOAD, LB	NET WEIGHT, LB	TOTAL LOAD, LB
1	237,188	174,910	412,098
2	233,596	174,910	408,506
3	176,954	174,910	351,864
4	298,010	174,910	472,920

During normal operation at 105% core flow, the core support pressure drop, ΔP_{cs} , is 15.9 psi and the shroud head pressure drop ΔP_{sh} , is 5.9 psi. The calculated lift load is 339,836 lb.

The results show there is no crack separation for all the cases considered. The compressive thermal preload plus weight of the internals exceeds the 339,836 lb. load tending to separate the welds for all load cases.

During a main steam line break accident condition, the loads on the stabilizers can exceed the thermal preload and there may be separation at postulated crack locations. The most severe conditions are 360° throughwall cracks at welds H6B, H7 or H8. Failure at one or more of these welds transfers the core ΔP loads to the stabilizers which, when combined with a seismic event results in the 311, 710 lb. stabilizer load. The



1000

1000

1000

1000

1000

1

maximum separation during this event is 0.63 inches. This displacement is temporary and the stabilizer springback and weight of the internals will close the gap once the event is over.

Information Request 5

Identify the most adverse combination of postulated weld failures and loading conditions in evaluating the shroud conical support deformations and provide documentation to demonstrate that the limiting deformations have been factored in the calculation of the tie rod preloads and the gap calculations requested in question #4 above.

Response 5

A 360° throughwall crack at welds H2 and H3 is the most adverse condition for shroud stiffness and results in the lowest thermal preloads. The analysis does not postulate cracking at H8, but covers cracking at all other welds. The results of the H8 weld inspections validate the assumption that the H8 weld is not 360° throughwall cracked. The cone stiffness is included in the analytical model used to calculate shroud stiffness in the supplemental stress report. As shown in Number 4, there is no crack separation during normal operating conditions. The minimum compressive load at the welds occurs if H6A or H7 is failed and the core ΔP load is restrained by the stabilizer assemblies.

From the viewpoint of applied loads, an infinitely stiff shroud results in the highest thermal loads. The thermal loads calculated in the original stress report are based on the assumption of an infinitely stiff shroud. The shroud and stabilizer thermal stresses, based on the high thermal loads, are shown in the original stress report to meet the required stress limits.

Information Request 7

During a combined steamline break and DBE event, the tie rod load has been determined to be in excess of 300,000 lbs. With postulated failures of welds H₇ and H₈, the H₈ lower weld bracket would impose a bending moment on the H₈ upper weld bracket in the vicinity of the adjustable foot. Provide calculations to demonstrate the structural integrity of the bracket under these loading conditions.

Response 7

The tie rods are restrained by the cone which carries the load to the reactor pressure vessel wall. The H8 weld brackets rest on the cone at different locations from the stabilizer assemblies and are not loaded by the tie rods. In the faulted event referenced where the tie rod loads exceed 300,000 lb., weld separation is predicted below the core support. Since the upper bracket is attached to the shroud below the core support, the brackets become unloaded and the upper bracket is unrestrained in the vertical direction (free to lift). Any postulated cone deflections would not produce significant load on the brackets.



The H8 weld brackets are designed to carry the downward load produced by a recirculation line pipe break. Each bracket is designed for a 418,833 lb. vertical load and a 42,715 lb. horizontal load during this event. The bearing, shear and bending stresses produced by these loads have been calculated and found acceptable.



Handwritten marks and scribbles in the top right corner.



DRF NO./SECTION B13-01739

Subject: LOWER SUPPORT / Toggle

1 VERIFICATION REQUIREMENT Designated Verifier Robert Hill

1A APPLICATION. (System/Project/Program)

NMP-1 SHROUD REPAIR

1B METHOD OF VERIFICATION. Checking, Alternate Calc. Indiv. Design Review, Team Design Review, Test (circle as needed); Other (describe)

1C SCOPE. (Identify what is to be verified (e.g., level of detail).

Verify stress calculations for lower support 112D6585 and the toggle per 112D6581

1D INPUTS. Identify any GE and external interfaces and requirements, assumptions, input documents, test analyses, reasons for changes. 112D6581, 112D6585

1E OUTPUTS. Identify output document(s) or analysis results to be verified.

1F Responsible Engineer T. Gleason Date 2/27/85 Comp. 771
(Print name and Sign)

2 INDEPENDENT VERIFICATION

Comments: No Yes (See Attached)

2A VERIFICATION STATEMENT: The method and scope of verification as stated in 1B and 1C are appropriate. The inputs as identified in 1D. All comments and technical issues are resolved. The verification establishes that the output identified in 1E is correct and is adequate for its intended application as identified in 1A.

2B Independent Verifier Robert Hill Date 2/27/85 Comp. 345
(Print name and Sign)


3 APPROVAL OF VERIFICATION

3A MANAGER'S APPROVAL: All design requirements have been identified and all technical issues are adequately resolved. The verification described in the above sections 1 and 2 is sufficient to issue/apply the results.

3B Resp. Manager or Delegate: _____ Date _____ Comp. _____
(Print name and Sign)

4A Are there attached sheets for 1A,1B,1C,1D,1E,2A,3A? (circle as applicable)





- NOTES:
- UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES.
 - GEOMETRIC DIMENSIONING AND TOLERANCING PER ANSI Y14.5M-1982.
 - FABRICATE PER SPEC 25A5584.
- ⚠ MARK PART IDENTIFICATION "11206585P001" OR "11206585P002" AND SERIAL NO. "SXXXX" IN .25±.06 HIGH CHARACTERS IN LOCATION SHOWN USING INTERRUPTED DOT LOW STRESS STAMP.

11206585		1
REVIEWS		
A	FOR PRIMARY ISSUE	
B	30 NOV 1994 R. MOHLER	RJA
11206585P001		
11206585P002		
OK BY: R. MOHLER		
1	DEC 12 1994 R. MOHLER	RJA
REMOVED LOG CUSSETS ADDED 1.00 X 1.50 OUTLOTS TO BASE PLATE ADDED PT. NO. 2 WITH TABULATION 2X 4.750 WAS 2X 5.000 PW-0778		
OK BY: T. GLEASON		

SECTION A-A

PT. NO.	"E"	"F"	"G"	"H"	MATERIAL
1	14.00	8.25	6.015	1.50	ASTM B637, UNS N07750 TYPE 3
2	12.70	8.00	5.765	.50	ASTM B637, UNS N07750 TYPE 3

DESIGN/CHK/APPR		SAFETY CLASS IF	
THIS ITEM IS OR BECOMES A SAFETY RELATED ITEM		NUCLEAR SAFETY RELATED	
YES () NO (X)		YES (X) NO ()	
SCHEDULE		Nuclear Energy	
BY: R. MOHLER 14 10 94		GENERAL ELECTRIC COMPANY	
BY: R. MOHLER 24 10 94		Schenectady, NY 12302-3200	
BY: R. ABRAHAM 24 10 94		SEAL	
BY: T. GLEASON 24 10 94		LOWER SUPPORT	
APPLIED PRACTICES Y100A3		PART NUMBER 11206585	
UNLESS OTHERWISE SPECIFIED		DRAWN BY T. GLEASON	
TOLERANCES DIM 1		DATE 25 OCT 1994	
2 PLACE DECIMALS 2.00 FRACTIONS 2		11206585	
3 PLACE DECIMALS 2.00 ANGLES 2.5		C 1 1 1	
11206585		DST TO	







Subject <i>NMP-1</i>	Originator <i>[Signature]</i>	Date
Number <i>Lower Support</i>	Verifier	Date

LOWER SUPPORT

112D6585 rev 1
Inconel X-750




NOTE: The toggle bolts are lightly torqued (40ft-lb per 107E5679) and the supports are assumed as pivots.



MAX SHEAR = $P/2$

P = TIE ROD LOAD

MAX MOMENT = $P/2(4.10)$





Subject	NMP-1	Originator	JGK	Date	
Number	Lower Support	Verifier		Date	

MINIMUM SECTION WIDTH = $8.00 - 0.02 = 7.98$ in

MINIMUM SECTION THICKNESS = $(2.5 - 0.02) - 0.26 = 2.22$ in

Bending Stress = $\frac{6M}{bh^2} = \frac{6(P)(4.10)}{(7.98\text{in})(2.22\text{in})^2} = 0.3127 P$

Shear Stress = $\frac{P}{2A} = \frac{P}{2(7.98)(2.22)} = 0.0282 P$

NOTE: Bending and shear stress act in different directions and are evaluated separately.

EVENT	TIE ROD LOAD (P), LB	STRESS, PSI BENDING / SHEAR	ALLOWABLE BENDING / SHEAR
Normal	79,670	24,912 / 2246	71,250 (1.55m) / 28,500 (0.65m)
THERMAL UPSET	188,638	58,986 / 5319 $\times 10,638$	142,500 (3.5m) / 142,500 (3.5m)
SEISMIC UPSET	162,076	50,681 / 4570	71,250 (1.55m) / 28,500 (0.65m)
EMERGENCY	216,520	67,705 / 6106	106,806 (2.255m) / 42,750 (1.5x.65m)
FAULTED	311,710	97,471 / 8800	142,500 (3.5m) / 57,000 (2x.65m)




2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Subject	NMP-1	Originator	QEA	Date	11/16/84
Number	Lower Support	Verifier		Date	1-18-95

LOWER SUPPORT (11206585 Rev. 1)
INCONEL X-750



$$M = (P/2)(3.637) =$$

$$\sigma_B = \frac{6M}{bh^2} = \frac{6(P/2)(3.637)}{(1.68)(4.225)^2}$$

$$\sigma_B = 0.364P$$

$$\sigma_P = \frac{P}{2A} = \frac{P}{2(1.68)(4.225)} = 0.0704P$$

$$\sigma_P + \sigma_B = 0.4344P$$

<u>EVENT</u>	<u>TIE ROD LOAD</u>	<u>$\sigma_P + \sigma_B$</u>	<u>ALLOWABLE</u>
Normal	79,670	34,617	71,250 (1.5Sm)
THERMAL UPSET	188,670	81,966	142,500 (3Sm)
SEISMIC UPSET	162,076	70,412	71,250 (1.5Sm)
Emergency	216,520	94,065	106,875 (2.25Sm)
Faulted	311,717	135,423	142,500 (3Sm)



.. . . .

..

..

..

..

..

..

..

..

..




..

..

..

120551		1
REVISED		
A	20 JAN 1984	1
B	2 FEB 1984	2
DESIGNED BY: J. W. WILSON		
CHECKED BY: J. W. WILSON		
DATE: 12 OCT 1984		
DRAWN BY: J. W. WILSON		
SCALE: 1:1		
MATERIAL: 304 STAINLESS STEEL		

- NOTES:
- UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES.
 - GEOMETRIC DIMENSIONING AND TOLERANCING PER ANSI Y14.5M-1982.
 - FABRICATE PER SPEC 25A3504.
 - MARK PART IDENTIFICATION "120551P001" AND SERIAL NO. "SXXXX" IN .252.03 HIGH CHARACTERS IN LOCATION SHOWN USING INTERRUPTED DOT LOW STRESS STAMP.



① MATL: ASTM A667, UNS M07750 TYPE 3

DESIGNED BY: J. W. WILSON		CHECKED BY: J. W. WILSON	
DATE: 12 OCT 1984		SCALE: 1:1	
MATERIAL: 304 STAINLESS STEEL		PART NO: 120551	
REVISED		REVISED	
A	20 JAN 1984	1	
B	2 FEB 1984	2	
TOGGLE 120551 2			




1000



Subject	IVMP-1	Originator	DTG	Date
Number	Toggle	Verifier		Date

TOGGLE

112D6581 rev. 1
INCONEL X-750



$$\text{MIN. SHEAR AREA} = 2(1.83)(1.40) = 5.124$$

$$\text{LOAD} = \frac{\text{TIE ROD LOAD}}{2(0.74)}$$

$$\text{Shear stress} = P/A = \frac{P_{TR}}{(2)(0.74)(5.124)} = \frac{P_{TR}}{7.5835}$$

EVENT	LOAD LB	SHEAR STRESS, PSI	ALLOWABLE STRESS, PSI
NORMAL	79,670	10,505	28,500 (0.6Sm)
THERMAL UPSET	188,638	24,874 X 2 = 49,749	142,500 (3.5Sm)
SEISMIC UPSET	162,076	21,372	28,500 (0.6Sm)
EMERGENCY	216,520	28,551	42,750 (1.5 x 0.6Sm)
FAULTED	311,710	41,100	57,000 (2 x 0.6Sm)

DESCRIPTIONS - DESIGN TABLES - REFERENCES - TABLE OF CONTENTS - INDEX

... the design of the toggle is based on the analysis of the toggle and the analysis of the toggle is based on the design of the toggle.

