

PRIORITY 1
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9505110068 DOC. DATE: 95/05/03 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 TERRY, C.D. Niagara Mohawk Power Corp.
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Advises that lab & engineering analysis of coupons removed during 1995 refueling outage resulted in corrosion rate of 0.3216 mils per year.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR / ENCL 0 SIZE: /
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-1 LA	1	PD1-1 PD	1
	EDISON, G	1		1
INTERNAL:	ACRS	6	<u>FILE CENTER 01</u>	1
	NRR/DE/EMCB	1	NRR/DRCH/HICB	1
	NRR/DSSA/SPLB	1	NRR/DSSA/SRXB	1
	NUDOCS-ABSTRACT	1	OGC/HDS3	1
EXTERNAL:	NOAC	1	NRC PDR	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 18 ENCL 0

MAY

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



NM NIAGARA MOHAWK

NIAGARA MOHAWK POWER CORPORATION/NINE MILE POINT NUCLEAR STATION, P.O. BOX 63, LYCOMING, N.Y. 13093 /TEL. (315) 349-7263
FAX (315) 349-4753

CARL D. TERRY
Vice President
Nuclear Engineering

May 3, 1995
NMP1L 0945

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Subject: Torus Shell and Coupon Corrosion Rate Determination

Gentlemen:

In accordance with the Nuclear Regulatory Commission's (NRC) Safety Evaluation Reports (SERs) of August 24, 1992 and August 11, 1994, Niagara Mohawk installed sample coupons of the same material as that of the torus shell during the 1993 refueling outage. These coupons were placed at the water level with approximately one-half above and one-half below the water line. The SERs require that the corrosion rates obtained from the coupons be compared once per refueling outage to that obtained from the UT measurements of the shell with the most conservative corrosion rate being used to make future corrosion rate determinations.

Laboratory and engineering analysis of the coupons removed during the 1995 refueling outage resulted in a corrosion rate of 0.3216 mils per year including one standard deviation. The average corrosion rate as determined from UT measurements of the torus shell is 0.8809 mils per year including one standard deviation. Thus, the most conservative corrosion rate does not exceed the assumed maximum corrosion rate of 1.26 mils per year. Therefore, UT thickness measurements of all torus bays will be repeated after approximately 10 years in accordance with the NRC SER. In the meantime, Niagara Mohawk will continue to measure torus wall thickness for the six (6) thinnest bays every six months as identified in the August 11, 1994 SER.

Very truly yours,



C. D. Terry

Vice President - Nuclear Engineering

950511006B 950503
PDR ADCK 05000220
P PDR

CDT/MGM/lmc

xc: Regional Administrator, Region I
Mr. L. B. Marsh, Director, Project Directorate I-1, NRR
Mr. G. E. Edison, Senior Project Manager, NRR
Mr. B. S. Norris, Senior Resident Inspector
Records Management

090147

A001
1/0



10/10/10

10

10/10/10

10/10/10