



UNITED STATES
 NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 15, 1995

LICENSEE: Niagara Mohawk Power Corporation
 FACILITY: Nine Mile Point Nuclear Station Unit No. 1
 SUBJECT: MEETING SUMMARY - MEETING BETWEEN NIAGARA MOHAWK POWER CORPORATION AND THE NRC TO DISCUSS PLANT-SPECIFIC CHARPY SHIFT MODEL FOR NINE MILE POINT NUCLEAR STATION UNIT NO. 1 (TAC NO. M90288)

On October 19, 1995, the NRC staff met with representatives of the Niagara Mohawk Power Corporation (NMPC) to discuss the methodology employed by NMPC in their proposal to revise Pressure/Temperature (P/T) limits. The proposal to revise P/T limits was submitted September 1, 1994, and disapproved by the NRC staff in a letter dated September 22, 1995. Attendance at the meeting is listed in Enclosure 1. The licensee's summary of the information presented at the meeting was submitted in a letter dated November 15, 1995, and is provided in Enclosure 2.

The purpose of the meeting, requested by the licensee, was to focus on the technical issues regarding the P/T limits submittal, and to discuss the basis for denial of the amendment. The licensee described the Charpy shift model, and presented details that led to the model's refinement. The model pertains solely to plates since Nine Mile Point Nuclear Station Unit No. 1 (NMP1) is a plate limited plant. The extensive literature searches and mechanistic studies that went into understanding the proposed model were discussed.

The main issues on which the licensee and the NRC have differing opinions are the standard deviation that should be used with the model, and the dependence of copper (Cu) in neutron radiation embrittlement. The standard deviation (σ_A) for the model is 32 °F. The licensee proposed to use the Regulatory Guide (RG) 1.99, Revision 2, value of 17 °F. The NRC staff commented that the standard deviation for the proposed model is much larger than the RG value, and the (σ_A) resulting from the model should be used. The licensee stated that the large scatter in the data is due to the nature of the Charpy test (i.e., uncertainty in the fracture test is the sole source of the scatter). The staff pointed out that several other factors, including fluence and chemistry, contribute to scatter and cannot be ignored.

The licensee could not see a Cu trend in the data graphed in the staff's Safety Evaluation (SE). New Atom Probe-Field Ion Microscopy (APFIM) data was presented in support of the model, specifically the lack of Cu dependence on embrittlement for low fluences. The licensee also stated that the NUREGs referenced in the staff's SE are not applicable since the fluences used in the studies were higher than fluences that NMP1 will experience. The licensee

9512200029 951215
 PDR ADOCK 05000220
 P PDR

NRC FILE CENTER COPY

Memo 4
 DFOI 1/1

concluded by stating that all micro and macro mechanisms studied suggested that there is no Cu trend for the fluence range that is applicable for the model.

At the conclusion of the meeting:

- a) The licensee was complimented on the extensive mechanistic and literature reviews that were conducted in support of the model.
- b) The standard deviation to be used with the model and the Cu dependence were still characterized by NRC staff as a problem. The licensee was told that they had not made a compelling case for the lack of Cu dependence for their model.
- c) The point was made that new data could be acquired; however, it may not change the conclusion. In addition, if the conclusion does change, it may change in the negative direction.

Suggestions as to possible actions that the licensee can take as a result of this meeting included doing a more rigorous assessment of the data to show that they fit the model. It was also suggested that the standard deviation may not go down with the addition of more data, which reinforces the need for a rigorous assessment of the data that exist. An important point was made with regard to the conclusions drawn by the licensee from the analysis of the data. Specifically, the NRC staff feels that the licensee should not take the trend line from a proposed model and apply the RG standard deviation. The staff mentioned that the Office of Research is currently assessing a potential revision to RG 1.99, and that behavior at low fluence is an issue that will be addressed in the revision.



Gordon E. Edison, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-220

Enclosures: 1. List of Attendees
2. Summary of Presentation

cc w/encs: See next page



H

Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit No. 1

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Ms. Denise J. Wolniak
Manager Licensing
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Richard B. Abbott
Vice President - Nuclear Generation
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Paul D. Eddy
State of New York
Department of Public Service
Power Division, System Operations
3 Empire State Plaza
Albany, NY 12223

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 126
Lycoming, NY 13093

Mr. Martin J. McCormick, Jr.
Vice President
Nuclear Safety Assessment
and Support
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
2 Rockefeller Plaza
Albany, NY 12223-1253

Mr. Norman L. Rademacher
Unit 1 Plant Manager
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093



LIST OF ATTENDANCE

10/19/95 MEETING

WITH NIAGARA MOHAWK POWER CORP.

NAME

GORDON EDISON
MICHAEL P. MANAHAN, SR.
B. RALPH SYLVIA
CARL TERRY
W. DAVID BAKER
DENISE WOLNIAK
BILL YAEGER
GARY WILSON
GEORGE INCH
CHING H. CHIEN
SHAH N. MALIK
ANDREA LEE
JACK STROSNIDER
KEITH WICHMAN
CINDI CARPENTER
BARRY NORRIS
BARRY ELLIOT
ED HACKETT
GLENN DENTEL
CATHERINE MARCO
L. B. MARSH
JOHN A. ZWOLINSKI

ORGANIZATION

NRC
MPM RESEARCH AND CONSULTING
EXEC V.P NIAGARA MOHAWK
V.P NUCLEAR ENG NIAGARA MOHAWK
LICENSING SUPVR NIAGARA MOHAWK
LICENSING MANAGER NIAGARA MOHAWK
MGR NMPI ENGRG - NMPC
MANAGING COUNSEL - NMPC
NMPC NUCLEAR ENGINEERING
NIAGARA MOHAWK
NRC/RES/EMMEB
NRC/EMCB
NRC/EMCB
NRC/EMCB
NRC/EDO
NRC/REGION I/DRP
NRC/EMCB
NRC/EMCB
NRC/EMCB
NRC/OGC
NRC/DRPE
NRC/DRPE



ATTACHMENT A

TECHNICAL BASIS FOR THE DEVELOPMENT OF THE NMP-1 PLANT-SPECIFIC CHARPY SHIFT MODEL (SUMMARY)

This presentation documents the development of a plant-specific Charpy shift model for Nine Mile Point Unit 1 (NMP-1). The plant-specific model is physically based and incorporates the important microstructural damage mechanisms which are now known and well understood. At fluences below $\sim 2 \times 10^{18}$ n/cm² (typical Boiling Water Reactor (BWR) end-of-license (EOL) fluence), it is shown that there is no correlation of yield strength elevation or Charpy shift with bulk Cu content for the NMP-1 beltline materials. The analyses and data trends demonstrate that most BWRs operate below the fluence threshold for significant Cu precipitation. This results in a different functional form for the Charpy shift (ΔT_{30}) model than currently used in Regulatory Guide 1.99 (Revision 2) (RG1.99(2)). The Nuclear Regulatory Commission (NRC) model was based primarily on high fluence Pressurized Water Reactor (PWR) data and there were very few surveillance data available in the BWR range when the NRC model was developed. Matrix damage is expected to be the primary damage component for BWRs. Since neutron induced defects are predominantly shearable defects, the Charpy shift has been shown to be proportional to the square root of fluence.

Based on knowledge of the important radiation damage mechanisms operating in the NMP-1 reactor pressure vessel (RPV) steel, criteria were established for defining the NMP-1 plant-specific data set from the larger NRC Power Reactor-Embrittlement Data Base (PR-EDB). Application of these criteria to the PR-EDB resulted in a data set containing 37 power reactor surveillance data points in addition to the 3 from NMP-1. Regression analyses yielded an accurate linear model of ΔT_{30} as a function of the square root of fluence. Application of the plant-specific model to NMP-1 will reduce the leakage/hydrostatic test temperature by $\sim 41^\circ\text{F}$. This will reduce the in-service leak test duration by approximately eight hours for each future startup. In addition, outage scheduling flexibility will be increased as a result of the in-service leak tests being conducted below 212°F .



concluded by stating that all micro and macro mechanisms studied suggested that there is no Cu trend for the fluence range that is applicable for the model.

At the conclusion of the meeting:

- a) The licensee was complimented on the extensive mechanistic and literature reviews that were conducted in support of the model.
- b) The standard deviation to be used with the model and the Cu dependence were still characterized by NRC staff as a problem. The licensee was told that they had not made a compelling case for the lack of Cu dependence for their model.
- c) The point was made that new data could be acquired; however, it may not change the conclusion. In addition, if the conclusion does change, it may change in the negative direction.

Suggestions as to possible actions that the licensee can take as a result of this meeting included doing a more rigorous assessment of the data to show that they fit the model. It was also suggested that the standard deviation may not go down with the addition of more data, which reinforces the need for a rigorous assessment of the data that exist. An important point was made with regard to the conclusions drawn by the licensee from the analysis of the data. Specifically, the NRC staff feels that the licensee should not take the trend line from a proposed model and apply the RG standard deviation. The staff mentioned that the Office of Research is currently assessing a potential revision to RG 1.99, and that behavior at low fluence is an issue that will be addressed in the revision.

Original signed by:

Gordon E. Edison, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-220

- Enclosures: 1. List of Attendees
- 2. Summary of Presentation


cc w/encls: See next page

DOCUMENT NAME: G:\NMP1\NM101995.MTS

To receive a copy of this document, indicate in the box: C = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDI-1	PM:PDI-1	D:PDI-1				
NAME	SLittle	GEEdison:smm	LMarsh				
DATE	12/15/95	12/15/95	12/15/95		12/ /95		12/ /95

OFFICIAL RECORD COPY



Meeting Summary Memoranda

HARD COPY: w/both enclosures

Docket File

PUBLIC

PDI-1 Reading

GE Edison

RConte, RGN-I

CCowgill, RGN-I

EMAIL: w/enclosure 1 only

W. Russell/F. Miraglia

R. Zimmerman

S. Varga

J. Zwolinski

L. Marsh

G. Edison (3)

S. Little

OGC

E. Jordan

S. Malik

A. Lee

J. Strosnider

K. Wichman

C. Carpenter

B. Norris


B. Elliot

G. Dentel

C. Marco

ACRS

W. Dean, RGN-I



Y