

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9606110094 DOC. DATE: 96/06/03 NOTARIZED: NO DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moho 05000410
 AUTH. NAME AUTHOR AFFILIATION
 VIERLING, A. Niagara Mohawk Power Corp.
 CONWAY, J. T. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: LER 96-006-00: on 960502, incorrect safety limit caused by inadequate calculational procedure. Increased OLMCPR in core monitoring computer to reflect increase in SLMCPR for two-loop operation. W/960603 ltr.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD1-1 PD		1	1		HOOD, D		1	1
INTERNAL:	ACRS		1	1		AEOD/SPD/RAB		2	2
	AEOD/SPD/RRAB		1	1		<u>FILE CENTER</u>		1	1
	NRR/DE/ECGB		1	1		NRR/DE/EELB		1	1
	NRR/DE/EMEB		1	1		NRR/DRCH/HHFB		1	1
	NRR/DRCH/HICB		1	1		NRR/DRCH/HOLB		1	1
	NRR/DRCH/HQMB		1	1		NRR/DRPM/PECB		1	1
	NRR/DSSA/SPLB		1	1		NRR/DSSA/SRXB		1	1
	RES/DSIR/EIB		1	1		RGN1 FILE 01		1	1
EXTERNAL:	L ST LOBBY WARD		1	1		LITCO BRYCE, J H		2	2
	NOAC MURPHY, G. A		1	1		NOAC POORE, W.		1	1
	NRC PDR		1	1		NUDOCS FULL TXT		1	1

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

FULL TEXT CONVERSION REQUIRED
 TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 26

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



2

44



NIAGARA MOHAWK

GENERATION
BUSINESS GROUP

NINE MILE POINT NUCLEAR STATION/LAKE ROAD, P.O. BOX 63, LYCOMING, NEW YORK 13093

June 3, 1996
NMP2L 1636


U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: LER 96-06
Docket No. 50-410

Gentlemen:

In accordance with 10 CFR 50.73 (a)(2)(v)(D), we are submitting LER 96-06, "Incorrect Safety Limit Caused by Inadequate Calculational Procedure."

Very truly yours,


John T. Conway
Plant Manager - Unit 2

JTC/AFZ/lmc
Enclosure

xc: Mr. Thomas T. Martin, Regional Administrator, Region I
Mr. Barry S. Norris, Senior Resident Inspector

100123

9606110094 960603
PDR ADOCK 05000410
S PDR

30 12
1/1



LICENSEE EVENT REPORT (LER)

ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS INFORMATION COLLECTION REQUEST: 50.0 HRS. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE RECORDS AND REPORTS MANAGEMENT BRANCH (P-530), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503

FACILITY NAME (1) Nine Mile Point Unit 2	DOCKET NUMBER (2) 5000410	PAGE (3) 01 OF 04
---	------------------------------	----------------------

TITLE (4) Incorrect Safety Limit Caused by Inadequate Computational Procedure

EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)	
05	02	96	96	06	00	06	03	96	N/A	05000	
									N/A	05000	

OPERATING MODE (9) 1 THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

POWER LEVEL (10) 100	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.405(c)	<input type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)
	<input type="checkbox"/> 20.405(a)(1)(i)	<input type="checkbox"/> 50.36(c)(1)	<input checked="" type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)
	<input type="checkbox"/> 20.405(a)(1)(ii)	<input type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(vii)	<input type="checkbox"/> OTHER
	<input type="checkbox"/> 20.405(a)(1)(iii)	<input type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)	<i>(Specify in Abstract below and in Text, NRC Form 366A)</i>
	<input type="checkbox"/> 20.405(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)	
	<input type="checkbox"/> 20.405(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(x)	

LICENSEE CONTACT FOR THIS LER (12)

NAME Mr. A. Vierling, Manager Fuels and Analysis	TELEPHONE NUMBER (315) 349-1582
---	------------------------------------

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14)	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO			

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

On May 2, 1996 at approximately 1500 hours, General Electric (GE) informed Nine Mile Point Unit 2 (NMP2) that they had performed a cycle specific two-loop Safety Limit Minimum Critical Power Ratio (SLMCPR) calculation and had determined that the existing 1.07 limit was nonconservative for the Peak Hot Excess (PHE) and End-of-Cycle (EOC) exposure points for Cycle 5. Based on this analysis, GE advised that a SLMCPR of 1.10 must be implemented. NMP2 increased the Operating Limit MCPR (OLMCPR) in the core monitoring computer to reflect the increase in the SLMCPR for two-loop operation. At the time of GE's notification, the reactor mode switch was in the "RUN" position (Operational Condition 1) with the plant operating at approximately 100 percent rated thermal power. Because the cycle specific calculation indicated that the SLMCPR value specified in Technical Specification Section 2.1.2 was nonconservative, this condition was reported under 10 CFR 50.72(b)(2)(iii)(D) and is being reported in accordance with 10 CFR 50.73 (a)(2)(v)(D) as a condition that could have prevented the fulfillment of the safety function of systems needed to mitigate the consequences of an accident.

The apparent cause of this event is that the GE generic SLMCPR calculation that was performed in 1991 was based on a procedure that did not adequately bound all boiling water reactors (BWRs) for all plant operating parameters.

The immediate corrective actions were to increase the OLMCPR in the core monitoring computer to reflect the increase in the SLMCPR for two-loop operation.



LICENSEE EVENT REPORT (LER)
TEXT CONTINUATION

ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS INFORMATION COLLECTION REQUEST: 30.0 HRS. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE RECORDS AND REPORTS MANAGEMENT BRANCH (P-330), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	
Nine Mile Point Unit 2	05000410	96	06	00	02 OF 04

TEXT (If more space is required, use additional NRC Form 366A's) (17)

I. DESCRIPTION OF EVENT

Nine Mile Point Unit 2 (NMP2) was first notified by General Electric (GE) by letter received on April 9, 1996, that the GE calculation for cycle specific Safety Limit MCPR (SLMCPR) may be more limiting than the previously performed generic calculations. As such, the procedure for calculating the SLMCPR was suspect and GE was evaluating these calculations. The notification was preliminary and no actions were recommended at that time.

On April 10, 1996, Niagara Mohawk contacted GE to discuss the information provided in their letter. GE stated that a potential nonconservatism in the SLMCPR calculational methodology had been identified at several plants and that this may be applicable to NMP2. GE recommended administrative controls be implemented immediately to limit the Maximum Fraction Limit Critical Power Ratio (MFLCPR) to < 0.985 since preliminary information indicated that the SLMCPR could be 1.09. Consequently, NMP2 implemented an administrative limit on MFLCPR of < 0.985 .

On April 16, 1996 additional information from GE indicated that the preliminary cycle specific NMP2 analysis showed that the SLMCPR could be as high as 1.10. Therefore, the MFLCPR administrative limit was further reduced to < 0.975 .

On May 2, 1996 at approximately 1500 hours, GE informed NMP2 that they had completed a cycle specific two-loop SLMCPR calculation and had determined that the existing 1.07 limit was nonconservative for the Peak Hot Excess (PHE) and End-of-Cycle (EOC) exposure points for Cycle 5. Based on this analysis, GE advised that a SLMCPR of 1.10 must be implemented. NMP2 increased the Operating Limit MCPR (OLMCPR) in the core monitoring computer to reflect the increase in the SLMCPR for two-loop operation and the previous administrative restriction was removed. Additionally, it was concluded that the K_f OLMCPR multiplier curve did not require revision and the single loop operation SLMCPR was confirmed to be 0.01 higher than the revised two-loop SLMCPR. At the time of notification, the reactor mode switch was in the "RUN" position (Operational Condition 1) with the plant operating at approximately 100 percent rated thermal power.

II. CAUSE OF EVENT

The apparent cause of this event is that the GE generic SLMCPR calculation that was performed in 1991 was based on a procedure that did not adequately bound all boiling water reactors (BWRs) for all plant operating parameters. GE has committed to perform a root cause evaluation for this event, and Niagara Mohawk will review the conclusions of this evaluation.



LICENSEE EVENT REPORT (LER)
TEXT CONTINUATIONESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS INFORMATION COLLECTION
REQUEST: 30.0 HRS. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE
RECORDS AND REPORTS MANAGEMENT BRANCH (P-330), U.S. NUCLEAR REGULATORY
COMMISSION, WASHINGTON, DC 20555, AND TO THE PAPERWORK REDUCTION PROJECT
(0150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)				PAGE (3)
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
Nine Mile Point Unit 2	05000410	96	06	00	03 OF 04	

TEXT (If more space is required, use additional NRC Form 366A's) (17)

III. ANALYSIS OF EVENT

Since the newly calculated SLMCPR is greater than the values specified in Technical Specification Section 2.1.2 (1.07 with two recirculation loop operation or 1.08 with single loop operation), this condition is reportable in accordance with 10 CFR 50.73 (a)(2)(v)(D) as a condition that could have prevented the fulfillment of the safety function of systems that are needed to mitigate the consequences of an accident.

In the course of developing a process for evaluating cycle specific SLMCPR values, GE has discovered that the procedure used for determination of generic SLMCPR values may not always yield the most conservative result. GE is currently evaluating the adequacy of the procedure to bound the actual expected plant operating states.

Following this discovery, GE examined the adequacy of the generic SLMCPR (1.07) for a plant having a large reload batch fraction (37%). When the NRC-approved licensing basis conditions and uncertainties were used with the core specific loading and rod patterns selected to place the plant on limits, preliminary results showed a SLMCPR of 1.08 for both PHE and EOC.

Niagara Mohawk has evaluated core performance for the current operating cycle, and determined that, even with the .03 increase in the SLMCPR, neither the Safety Limit nor the Operating Limit would have been exceeded for any analyzed plant transient.

This situation is being reported to the NRC by GE under the 10 CFR 21 reporting requirements, and GE has initiated actions to evaluate the adequacy of the generic SLMCPR values for all plants operating with GE fuel.

IV. CORRECTIVE ACTIONS

In response to GE's verified calculation of the NMP2 cycle specific SLMCPR, immediate corrective actions were taken to increase the OLMCPR in the core monitoring computer to reflect a .03 increase in the SLMCPR for two-loop operation.

GE is currently performing calculations to confirm the .01 SLMCPR adder for single-loop operation (SLO) and will be providing NMP2 with a revised Supplemental Reload Licensing Report. When this report is received from GE, the Reload Safety Evaluation will be revised to incorporate any necessary changes to the Core Operating Limits Report, the Updated Safety Analysis Report (USAR), and the Technical Specifications.



LICENSEE EVENT REPORT (LER)
TEXT CONTINUATION

ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS INFORMATION COLLECTION REQUEST: 50.0 HRS. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE RECORDS AND REPORTS MANAGEMENT BRANCH (P-330), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)				PAGE (3)
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
Nine Mile Point Unit 2	05000410	96	- 00	- 00	04 OF 04	

TEXT (If more space is required, use additional NRC Form 366A's) (17)

V. **ADDITIONAL INFORMATION**

- A. Failed components: None
- B. Previous similar events: None
- C. Identification of components referred to in this LER:

COMPONENT	IEEE 803 FUNCTION	IEEE 805 SYSTEM ID
Core Monitoring Computer	CPU	ID

