

Mr. B. Ralph Sylvia
 Executive Vice President
 and Chief Nuclear Officer
 Niagara Mohawk Power Corporation
 Generation Business Group D-2
 300 Erie Boulevard West
 Syracuse, NY 13202

June 24, 1996

SUBJECT: STAFF REVIEW OF MODIFICATIONS TO REVISION 4 OF THE BOILING WATER REACTOR (BWR) EMERGENCY PROCEDURE GUIDELINES

Dear Mr. Sylvia:

The NRC staff has issued its safety evaluation (SE) on the recent Boiling Water Reactor Owners Group proposed modifications to the BWR Emergency Procedure Guidelines. The staff is providing this information to ensure that licensees are aware of the conclusions of the staff's review. Both the staff and the Advisory Committee for Reactor Safeguards (ACRS) agree that, for BWRs injecting standby liquid control through a standpipe below the core, maintenance of level above top-of-active fuel (TAF) is the superior water control strategy in an anticipated transient without scram (ATWS) event. The staff recommends a level around TAF +5 feet (1.52 m), or as high as possible while still maintaining the level at least 2 feet (0.61 m) below the feedwater sparger. Although control at any level between the minimum steam cooling water level and 2 feet below the feedwater sparger was found to be acceptable, both the staff and ACRS urge that a high-water-level control strategy be adopted. Additional details are provided in the enclosed SE.

You should also note the staff's position on bypassing the Main Steam Isolation Valve (MSIV) high radiation closure interlock during ATWS. The staff agrees with the BWROG's qualitative arguments that keeping the MSIVs open significantly reduces containment loading and makes level control much simpler. However, the acceptability of this change is conditional on a plant-specific evaluation by each licensee to assure that, in the event of gross fuel failures, consideration has been given to such items as equipment accessibility, potential off-site radiological doses, and the appropriate time to manually close the MSIVs.

Sincerely,

ORIGINAL SIGNED BY:

Darl S. Hood, Senior Project Manager
 Project Directorate I-1
 Division of Reactor Projects - I/II
 Office of Nuclear Reactor Regulation

9606280169 960624
 PDR ADOCK 05000220
 F PDR

Docket Nos. 50-220 and
 50-410

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

| | | | |
|---------------|------------|---------|-----------------|
| Docket File | SVarga | SLittle | ACRS |
| PUBLIC | JZwolinski | DHood | CCowgill, RGN-I |
| PDI-1 Reading | JMitchell | OGC | |

DOCUMENT NAME: PIBWROG.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

| | | | | | | |
|--------|----------|---|----------|-----------|---------|---------|
| OFFICE | PDI-1/LA | E | PDI-1/PH | PDI-1/D | | |
| NAME | SLittle | | DHood:mw | JMitchell | | |
| DATE | 06/20/96 | | 06/24/96 | 06/24/96 | 06/ /96 | 06/ /96 |

280127

Official Record Copy

NRC FILE CENTER COPY

111
 OFD





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 24, 1996

Mr. B. Ralph Sylvia
Executive Vice President
and Chief Nuclear Officer
Niagara Mohawk Power Corporation
Generation Business Group D-2
300 Erie Boulevard West
Syracuse, NY 13202

SUBJECT: STAFF REVIEW OF MODIFICATIONS TO REVISION 4 OF THE BOILING WATER REACTOR (BWR) EMERGENCY PROCEDURE GUIDELINES

Dear Mr. Sylvia:

The NRC staff has issued its safety evaluation (SE) on the recent Boiling Water Reactor Owners Group proposed modifications to the BWR Emergency Procedure Guidelines. The staff is providing this information to ensure that licensees are aware of the conclusions of the staff's review. Both the staff and the Advisory Committee for Reactor Safeguards (ACRS) agree that, for BWRs injecting standby liquid control through a standpipe below the core, maintenance of level above top-of-active fuel (TAF) is the superior water control strategy in an anticipated transient without scram (ATWS) event. The staff recommends a level around TAF +5 feet (1.52 m), or as high as possible while still maintaining the level at least 2 feet (0.61 m) below the feedwater sparger. Although control at any level between the minimum steam cooling water level and 2 feet below the feedwater sparger was found to be acceptable, both the staff and ACRS urge that a high-water-level control strategy be adopted. Additional details are provided in the enclosed SE.

You should also note the staff's position on bypassing the Main Steam Isolation Valve (MSIV) high radiation closure interlock during ATWS. The staff agrees with the BWROG's qualitative arguments that keeping the MSIVs open significantly reduces containment loading and makes level control much simpler. However, the acceptability of this change is conditional on a plant-specific evaluation by each licensee to assure that, in the event of gross fuel failures, consideration has been given to such items as equipment accessibility, potential off-site radiological doses, and the appropriate time to manually close the MSIVs.

Sincerely,

Darl S. Hood, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-220 and
50-410

Enclosure: Safety Evaluation

cc w/encl: See next page



3

B. Ralph Sylvia
Niagara Mohawk Power Corporation

cc:

Mr. Richard B. Abbott
Vice President and General Manager -
Nuclear
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Martin J. McCormick, Jr.
Vice President
Nuclear Safety Assessment
and Support
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Ms. Denise J. Wolniak
Manager Licensing
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Kim A. Dahlberg
General Manager - Projects
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Norman L. Rademacher
Plant Manager, Unit 1
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. John T. Conway
Plant Manager, Unit 2
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U. S. Nuclear Regulatory Commission
P.O. Box 126
Lycoming, NY 13093

Nine Mile Point Nuclear Station
Unit Nos. 1 and 2

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Paul D. Eddy
State of New York Department of
Public Service
Power Division, System Operations
3 Empire State Plaza
Albany, NY 12223

Mr. Richard M. Kessel
Chair and Executive Director
State Consumer Protection Board
99 Washington Avenue
Albany, NY 12210

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
2 Rockefeller Plaza
Albany, NY 12223-1253

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, NY 12223

Mr. John V. Vinquist, MATS Inc.
P.O. Box 63
Lycoming, NY 13093

