

LICENSEE: Niagara Mohawk Power Corporation

January 6, 1997

FACILITY: Nine Mile Point Nuclear Station Unit No. 1

SUBJECT: SUMMARY OF TELEPHONE CONVERSATION OF DECEMBER 18, 1996, ON REACTOR AND TURBINE BUILDING BLOWOUT PANELS (TAC NO. M94858)

On December 18, 1996, the NRC staff discussed, via telephone, the licensee's letter of November 15, 1996, "Response to Trip Report of August 20, 1996, Audit of Reactor and Turbine Building Blowout Panels" (Response). Participants for Niagara Mohawk Power Corporation were Messrs. C. Stroup and D. Baker. Participants for NRC were Messrs. D. Jeng and D. Hood.

The licensee's Response provided the results of revised Reactor and Turbine Building superstructure calculations, resulting from steam line breaks outside primary containment. The calculations for building pressure capacities were revised by eliminating the use of the 1.05 dynamic load factor (i.e., strain rate factor for increasing Fy of material) and adjusting the dead load scaling factor. The reduction factor was also changed from 0.95 ϕ to 0.90 ϕ . The resulting lower bound failure internal pressures for the Reactor Building were 117 psf for the secondary member (roof bracing) and 124 psf for the primary member (critical column). The resulting lower bound failure internal pressures for the Turbine Building were 135 psf for the secondary member (roof truss) and 150 psf for the primary member (critical column).

During the telephone call, the NRC staff requested additional information regarding the principal inputs and assumptions used in these calculations. The staff also asked if the revised reduction factor that was applied in the revised structural capacity calculation had also been used in the blowout panel capacity calculation, and if so, what were the effects?

The licensee responded to the staff's request by faxing the enclosed additional pages from the engineering calculations, and two notes of explanation.

/s/

Darl S. Hood, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-220

Enclosure: As stated

cc w/encl: See next page

NRC FILE CENTER COPY

DFOI 1/1

Distribution:

Docket File	SVarga	SLittle	ACRS	MHartzman
PUBLIC	JZwolinski	DHood	CCowgill, RI	GBagchi
PDI-1 Reading	SBajwa	OGC	DJeng	

MEMO

DOCUMENT NAME: G:\NMP1\TELECON.NMP

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM: PDI-1	LA: PDI-1	D: PDI-1		
NAME	DHood/rs1 <i>DCIF</i>	SLittle	SBajwa <i>SB</i>		
DATE	1/6/96	12/31/96	1/7/97		

OFFICIAL RECORD COPY

100091
 9701100218 970106
 PDR ADOCK 05000220
 P PDR

10/10/10



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 6, 1997

LICENSEE: Niagara Mohawk Power Corporation

FACILITY: Nine Mile Point Nuclear Station Unit No. 1

SUBJECT: SUMMARY OF TELEPHONE CONVERSATION OF DECEMBER 18, 1996, ON REACTOR AND TURBINE BUILDING BLOWOUT PANELS (TAC NO. M94858)

On December 18, 1996, the NRC staff discussed, via telephone, the licensee's letter of November 15, 1996, "Response to Trip Report of August 20, 1996, Audit of Reactor and Turbine Building Blowout Panels" (Response). Participants for Niagara Mohawk Power Corporation were Messrs. C. Stroup and D. Baker. Participants for NRC were Messrs. D. Jeng and D. Hood.

The licensee's Response provided the results of revised Reactor and Turbine Building superstructure calculations resulting from steam line breaks outside primary containment. The calculations for building pressure capacities were revised by eliminating the use of the 1.05 dynamic load factor (i.e., strain rate factor for increasing F_y of material) and adjusting the dead load scaling factor. The reduction factor was also changed from 0.95 ϕ to 0.90 ϕ . The resulting lower bound failure internal pressures for the Reactor Building were 117 psf for the secondary member (roof bracing) and 124 psf for the primary member (critical column). The resulting lower bound failure internal pressures for the Turbine Building were 135 psf for the secondary member (roof truss) and 150 psf for the primary member (critical column).

During the telephone call, the NRC staff requested additional information regarding the principal inputs and assumptions used in these calculations. The staff also asked if the revised reduction factor that was applied in the revised structural capacity calculation had also been used in the blowout panel capacity calculation, and if so, what were the effects?

The licensee responded to the staff's request by faxing the enclosed additional pages from the engineering calculations and two notes of explanation.

Darl S. Hood

Darl S. Hood, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-220

Enclosure: As stated

cc w/encl: See next page



[The text in this section is extremely faint and illegible. It appears to be a large block of text, possibly a list or a series of entries, but the characters are too light to be read.]

Niagara Mohawk Power Corporation

cc:

Mr. B. Ralph Sylvia
Executive Vice President
Generation Business Group
and Chief Nuclear Officer
Niagara Mohawk Power Corporation
Nuclear Learning Center
450 Lake Road
Oswego, NY 13126

Mr. Richard B. Abbott
Vice President and General Manager -
Nuclear
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Martin J. McCormick, Jr.
Vice President
Nuclear Safety Assessment
and Support
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Kim A. Dahlberg
General Manager - Projects
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Norman L. Rademacher
Plant Manager, Unit 1
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Ms. Denise J. Wolniak
Manager Licensing
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Nine Mile Point Nuclear Station
Unit No. 1

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 126
Lycoming, NY 13093

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Paul D. Eddy
State of New York
Department of Public Service
Power Division, System Operations
3 Empire State Plaza
Albany, NY 12223

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202





NINE MILE POINT NUCLEAR STATION
P.O. BOX 63, LYCOMING, NEW YORK 13093

FAX COVER LETTER

NINE MILE POINT UNIT 2

FROM: FAX TELEPHONE NUMBER: (315) 349-1400

NAME: *Dave Baker*

DEPARTMENT: LICENSING/ENVIRONMENTAL

TELEPHONE NUMBER:

FAX #

TO: *Daryl Wood NRC*

TOTAL NUMBER OF PAGES FAXED (INCLUDING COVER LETTER): 29

DATE: 12/19/96 TIME: _____

MESSAGE: Calculation extracts as requested
in telecon of 12/18/96 with 1 note of explanation
on calc 54RX34DBLDG 01, page 6; and 1 dimension
point on message of reduction or overcapacity factors
in calculation 57RX340W 01



10

10

ORIGINAL

	<h2>DISPOSITION COVER SHEET</h2>	Page 1 (Next) <u>2</u>
		Total <u>393</u>
		Last <u>D-379</u>

Project: NINE MILE POINT NUCLEAR STATION Unit (1,2 or 0=Both): 1 Discipline: STRUCTURAL

Title: <u>EVALUATION OF TURBINE BUILDING ABOVE EL. 300 FOR 125 PSF INTERNAL PRESSURE</u>		Calculation No. <u>SATB300 BLDG-01</u>	Rev <u>ΦΦ</u>	Disp <u>ΦΦB</u>
(Sub)System(s) <u>N/A</u>		Index No. <u>S4</u>	Originator <u>CE STROOP</u>	Date <u>8-30-96</u>
Design Change No. <u>N/A</u>		Checker <u>C.R. AGOSTA</u>	Date <u>9/6/96</u>	
		Approver <u>Mohammed Alvi</u>	Date <u>9-10-96</u>	

Superseded Document(s): NONE NMPC Acceptance/Date: N/A

Description of Change
INCORPORATE NRC NRR COMMENTS OF REVISION 0.

Resolution
SEE ATTACHED PAGES 2-14

Cross Reference Change(s):
NONE

Confirmation Required (Yes/No): <u>NO</u>	Final Issue Status (APP/FIO/VOI): <u>APP</u>	File Location (Calculation/Hold): <u>C</u>	Operations Accepted on Issue (Yes/No): <u>YES</u>
---	--	--	---

Safety Evaluation Number(s)/Revision: _____
 Copy of Applicability Review Attached? Yes N/R ✓

Component ID(s)/EPN(s)/Line Numbers:
N/A

Key Words: PRESSURE RELIEF PANELS, TURBINE BUILDING, INTERNAL PRESSURE, STRUCTURAL, NMPI, COSMOSH



T

...

...

...

...

NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>2</u>
--	---------------------------------------	---------------

Project: NINE MILE POINT NUCLEAR STATIONUnit: 1

Originator/Date C E STROUP 8-27-96	Calc. No. SATB300BLD601.	Rev 0
--	-----------------------------	----------

Checked A	Date 9/4/96	Disposition ΦΦB
--------------	----------------	--------------------

Ref.	<p>OBJECTIVE:</p> <p>1) Revision 0 extrapolated the internal pressure which would cause structure failure using linear extrapolation of results [member forces and moments], which included both deadweight and pressure loadings.</p> <p>This Calc removed the effect of dead weight when extrapolating the 125psf upwards (or down) to obtain the pressure loading causing failure.</p> <p>2) Revision 0 included a 1.05 increase factor of the internal pressure based on a strain rate effect.</p> <p>This Calc eliminates this factor for the governing structural members.</p>
------	--



NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>3</u>
--	---------------------------------------	---------------

Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date <p style="text-align: center;">CES 8-27-96</p>	Calc. No. <p style="text-align: center;">SATB300BLDGO1</p>	Rev <p style="text-align: center;">0</p>
---	---	---

Checked <p style="text-align: center;">A</p>	Date <p style="text-align: center;">9/5/96</p>	Disposition <p style="text-align: center;">ΦΦB</p>
---	---	---

Ref.

Member 3491 [page 62] Top Chord Member

From page 70, use $F_y = 37.59 \text{ ksi}$ (Mill Cert's Minimum)

For Tensile Loading & Moment Combined:

$$\frac{P_u}{\phi_t P_n} + \frac{8}{9} \left(\frac{M_y + M_z}{\phi_b M_{n1}} + \frac{M_z}{\phi_b M_{n2}} \right) \leq 1.0 \quad \text{LRFD} \quad \text{H1-1a}$$

Since $\frac{P}{\phi_t P_n} \geq 0.2$

$$\phi_t P_n = \overset{\text{LRFD}}{\phi_t = 0.75} \underbrace{A_g}_{\text{Net area}} (37.59 \text{ ksi}) = 518.74 \text{ k}$$

For double-angles, M_n is given by LRFD EQ F1-15:

(Note: $\frac{b}{t} = \frac{8}{3/4} = 10.667 \leq \lambda_r = \frac{76}{\sqrt{37.59}} = 12.4$)

$$M_n = C_b \pi \sqrt{E I_y G J} \cdot [B + \sqrt{1+B^2}] \leq \phi F_y$$


$G = 11,200 \text{ ksi}; \quad E = 29,000 \text{ ksi}; \quad B = \pm 2.3 \frac{d}{L_b} \sqrt{\frac{I_y}{J}}$



NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>4</u>
--	---------------------------------------	---------------

Project: NINE MILE POINT NUCLEAR STATION		Unit: <u>L</u>
Originator/Date <u>LES</u> <u>8-27-96</u>	Calc. No. <u>54TB300BLD601</u>	Rev <u>0</u>

Checked <u>CA</u>	Date <u>9/5/96</u>	Disposition <u>ΦΦB</u>
----------------------	-----------------------	---------------------------

Ref.	$I_y = 127.4$ $J = 2 * 1.90 = 3.8$ $C_w = 2 * 7.28 = 14.56$	 <p>TOP CHORD</p> <p>LRFD Torsion Properties 1-142 For double angle, sum individual J & C_w per (CR) page 1-83</p>
	<p>NOTE: SKETCH ON PAGE 62 IS INCORRECT. ANGLES ARE LHV AS CORRECTLY MODELLED IN COSMOSM</p>	
	$L_b = 8' - 7\frac{1}{2}$ About z-z axis $L_b = 8' - 7\frac{1}{2}$ About y-y axis USE $L_b = 8' - 7\frac{1}{2} = 103.5$	<p>Top chord only Braced by Purlins (Drawing C-15349-C)</p>
	$B = 2.3 \frac{(8")}{103.5} \sqrt{\frac{127.4}{3.8}} = 1.029$	
	Stern in Compression (- sign on Moments M _t)	
	$M_n = \frac{C_b \pi \sqrt{(29,000)(127.4)(11,200)(3.8)}}{103.5} = 12,036 C_b$	
	$M_n = 12,036 C_b \left[-1.029 + \sqrt{1 + 1.029^2} \right] = 4,885 C_b \text{ k-in}$	
	Use C _b = 1.0 conservative However, note that $M_y = S F_y = (23.3 \text{ in}^3)(36 \text{ ksi}) = 838.8 \text{ k-in}$	



NY NIAGARA MUMOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>5</u>
---	---------------------------------------	---------------

Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date CES 8-27-96	Calc. No. 54TB300BLD001	Rev 0
-----------------------------------	----------------------------	----------

Checked <i>ph</i>	Date 9/5/96	Disposition 406
-------------------	----------------	--------------------

Therefore use $M_n = 0.9 * 838.8 = 754.926 \text{ k-in}$

Likewise for Y-Y axis

$$M_y = (15.44 \text{ in}^3)(36 \text{ ksi}) = 555.84 \text{ k-in}$$

$$M_n = 0.9 (555.84) = 500 \text{ k-in}$$

NOTE: We have used $S F_y$ instead of $Z F_y$ for both directions
 Since $I_S < I_Z$, this approach is conservative as recommended by LRFD for double-angle beams.

Interaction

$$\frac{319.6}{518.74} + \frac{0}{9} \left(\frac{73.3}{500} + \frac{122.6}{754.92} \right) = 0.891 \leq 1.0$$

For Failure Pressure of 125psf + dead weight

Extrapolate to Failure pressure considering dead weight.
 (SEE PAGE D-326 FOR DW FORCES & MOMENTS)

	<u>125psf + DW</u>	<u>DW</u>	<u>125psf ONLY</u>
Axial	219.6 kT	$= 114.1 \text{ k}$	$+ 433.7 \text{ k (T)}$
M_y	$+ 73.3 \text{ k-in (end)}$	$= -21.26 \text{ k-in (end)}$	$+ 94.56 \text{ k-in}$
M_z	$- 122.6 \text{ k-in (end)}$	$= -3.173 \text{ k-in (end)}$	$+ -119.43 \text{ k-in}$

Keeping close track of signs.

<u>125psf + DW / 0.891</u>	<u>DW</u>	<u>X psf</u>
AXIAL 358.7 kT	$= 114.1 \text{ k}$	472.8

X, psf FAILURE Pressure = $\frac{472.8}{433.7} * 125 = 136.3 \text{ psf}$



NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>6</u>
--	---------------------------------------	---------------

Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date CES 8-27-96	Calc. No. 54TB300BLDG-01	Rev 0
-----------------------------------	-----------------------------	----------

Checked A	Date 9/5/96	Disposition φφB
--------------	----------------	--------------------

Ref.

Check 136 psf: [All Moments are at same location]

136 PSF ONLY

$$\frac{136}{125} \times 433.7 = 471.9 \text{ k}(\tau) \quad + \quad \frac{Du}{119.1} \text{ c} = \frac{136 \text{ psf} \times Du}{357.8 \text{ k}(\tau)}$$

$$\frac{136}{125} \times 99.56 = 102.88 \text{ k-in} \quad + \quad -21.26 \text{ k-in} = 81.62 \text{ k-in}$$

$$\frac{136}{125} \times -119.43 = -130 \text{ k-in} \quad + \quad -3.173 \text{ k-in} = -133.173 \text{ k-in}$$

AUD

$$\frac{357.8}{518.74} + \frac{8}{9} \left(\frac{81.62}{500} + \frac{133.123}{754.92} \right) = 0.992$$

OK


The Failure Internal Pressure is 136 PSF
(Based on Member 3491)

Member 3745: [φ60] L6X4X $\frac{7}{16}$ LLV
LRFD D1-2 NET AREA

$$\phi_{E_n} P_n = (0.75)(4.18 - 0.44)(36) = 100.98 \text{ k}$$

Mn is defined for single angles: as not to exceed φ Fy As ksi. LRFD Appendix B

$$\frac{b}{t} = \frac{6}{7/16} = 13.714 \quad \frac{76}{\sqrt{F_y}} = \frac{76}{6} = 12.67$$



NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>7</u>
--	---------------------------------------	---------------

Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date C25 8-27-96	Calc. No. 54TB300 BLDG-01	Rev 0
-----------------------------------	------------------------------	----------

Checked <i>MB</i>	Date <u>9/5/96</u>	Disposition <u>ΦΦB</u>
-------------------	--------------------	------------------------

Ref.

$$\frac{155}{\sqrt{F_y}} = 25.833 \quad \text{Since} \quad \frac{76}{\sqrt{F_y}} < \frac{b}{E} < \frac{155}{\sqrt{F_y}}$$

$$\phi_s = 1.340 - 0.00447 \frac{b}{E} \sqrt{F_y} \quad \text{LRFD A-B5-1}$$

$$\phi_s = 1.340 - 0.00447(13.714) \sqrt{36} = 0.972$$

$$M_n = \phi \phi_s F_y S = (0.9)(0.972)(36) S = 31.5 S$$

Where S should be determined about appropriate axis.

$A = 4.18 \text{ in}^2$ $I_y = 15.5 \text{ in}^4$ $S_y = 3.83 \text{ in}^3$ $r_y = 1.92$
 $I_z = 5.6 \text{ in}^4$ $S_z = 1.85 \text{ in}^3$ $r_z = 1.16 \text{ in}$
 $r_{z'} = 0.873$ $\text{Tan } d = 0.443$

$$I_{z'} = A r_{z'}^2 = 4.18 \text{ in}^2 (0.873)^2 = 3.186 \text{ in}^4$$

NOTE: Page 60 M_z and M_y are interchanged. $M_z = 34.99 \text{ k-ft}$
 $M_z = 0.38$. Local axis Y is major axis.

$$M_{ny} = (31.5)(3.83 \text{ in}^3) = 120.6 \text{ k-in} \quad \left[\begin{array}{l} \text{COSMOS/M LOCAL} \\ \text{Member Y-axis} \end{array} \right]$$

$$M_{nz} = (31.5)(1.85) = 58.3 \text{ k-in} \quad \left[\begin{array}{l} \text{COSMOS/M LOCAL} \\ \text{Member Z-axis} \end{array} \right]$$

$$\frac{61.02}{100.48} + \frac{34.99}{120.66} + \frac{0.38}{58.3} = 0.901$$

Failure Pressure
125 PSF + DW

1-0-36
17-1

**NY NIAGARA
MOHAWK**
NUCLEAR ENGINEERING

CALCULATION CONTINUATION SHEET

Page 8

Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Data <u>CSST/DP</u> <u>8-27-96</u>	Calc. No. <u>54TB300 BLDG01</u>	Rev <u>0</u>
---	------------------------------------	-----------------

Checked <u>A</u>	Date <u>9/5/96</u>	Disposition <u>ΦΦB</u>
---------------------	-----------------------	---------------------------

Ref.

Extrapolate to Failure pressure Considering dead weight.
[SEE PAGE D-351 FOR DW FORCES & MOMENTS]

	<u>125 PSF + DW</u>	=	<u>DW</u>	+	<u>125 PSF ONLY</u>
AXIAL	61.02 ^k (T)	=	0.255 ^k (C)	+	61.28
M _z	0.38 k-in	=	-0.0289		0.409
M _y	34.99 k-in	=	34.96		0.036-in

Moment terms are all due to dead weight only.

<u>125 PSF + DW / 0.901</u>	=	<u>DW</u>	+	<u>X₁ PSF ONLY</u>
67.72 ^k (T)	=	0.257 ^k (C)	+	67.98 ^k (T)

X₁ PSF Failure Pressure = $\frac{67.98}{61.28} \times 125 = 138.67$ PSF



17

.

.

NY NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET		Page <u>9</u>
	Project: <u>NINE MILE POINT NUCLEAR STATION</u> Unit: <u>1</u>		

Originator/Date <u>CSJ</u> <u>8-28-96</u>	Calc. No. <u>S4TB300BLDG-01</u>	Rev <u>0</u>
Checked <u>A</u>	Date <u>9/6/96</u>	Disposition <u>008</u>

Ref.	<p> <u>Member 136 [Page 38] Col. 24 WF14</u> </p> <p> $M_{max} = 6,800 \text{ k-in} \quad P = 5^k (C)$ </p> <p> <u>Flexure</u> As explained in page 32, the column is fully braced along its length by the siding on the outside which prevents twist of the cross-sections. </p> <p> Therefore $M_u = \phi M_n = \phi M_p = \phi Z F_y$ [LRFD Chapter F] </p> <p> $M_u = (0.9)(253 \text{ in}^3)(36 \text{ ksi}) = 8,197.2 \text{ k-in}$ </p> <p> Where F_y has been conservatively used as 36 ksi. [Page 71 shows that F_y from mill certs is a minimum of $(0.955)42,680 = 40,760 \text{ ksi}$.] </p> <p> <u>Compression</u> $k = 1.2$ [Table C-C2.1, pg. 6-151 LRFD] </p> <p> $\lambda_c = \frac{(1.2)(204.56")}{(1.98)\pi} \sqrt{\frac{36}{29,000}}$ EQ. E2-4 LRFD { Where $L = 204.56"$ $r = 1.98"$ per page 31. </p> <p> $\lambda_c = 1.390 \leq 1.5$ EQ. E2-2 LRFD </p> <p> $P_n = A_g F_{cr} = A_g (0.658 \lambda_c^2) F_y = (27.7 \text{ in}^2)(0.658)(1.390)^2 36$ </p> <p> $P_n = 1,268.4^k$ </p> <p> $\phi P_n = 0.85(1268.4) = 1,078.2^k$ E2-1 LRFD </p>
------	---



NY NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>10</u>
--	---------------------------------------	----------------

Project: <u>NINE MILE POINT NUCLEAR STATION</u>		Unit: <u>1</u>
Originator/Date <u>CS5</u> <u>8-18-96</u>	Calc. No. <u>54TR300BLDG-01</u>	Rev <u>0</u>
Checked <u>A</u>	Date <u>9/6/96</u>	Disposition <u>ΦΦΦ</u>

Ref.

Since $\frac{P}{\Phi P_n} = \frac{5}{1,078.2} = 0.0046 < 0.2$

Then interaction equation is:

$$\frac{P}{2\Phi P_n} + \frac{M_y}{\Phi_b M_y} + \frac{M_z}{\Phi_b M_z} \leq 1.0 \quad \text{LRFD} \quad 4-1-16$$

M_y may be neglected. Then,

$$\frac{5}{2(1,078)} + \frac{6,800}{8,197.2} = 0.830 \quad \text{For } 125 \text{ psf} + \text{DW}$$

[SEE PAGE D-155 FOR DEADWEIGHT FORCES & MOMENTS]
 Extrapolate to Failure Pressure considering deadweight;
 NOTE: MAX. MOMENT IS NOT AT EITHER END.

<u>125 psf + DW</u>	<u>DW</u>	+	<u>125 psf ONLY</u>
AXIAL $5^k (c)$	$24.85^k (c)$	+	$19.85^k (t)$
$M_z - 6,668 \text{ k-in (start)}$	12.74 k-in	+	$-6,680.7 \text{ k-in}$
$M_z + 4,362 \text{ k-in (end)}$	-23.67 k-in	+	$4,385.67 \text{ k-in}$
$V_y 29.34^k (end)$	0.0534	+	$+29.34^k$
$V_z 6.840^k (start)$	-0.0534	+	$+6.843^k$
<u>$(125 \text{ psf} + \text{DW}) / 0.830$</u>	<u>DW</u>		<u>X psf</u>
$M_z - 8,034 \text{ k-in}$	12.74		$-8,046 \text{ k-in}$

$X, \text{ psf FAILURE} = \frac{8,046}{6,680.7} + 125 = 150 \text{ psf}$



NY NIAGARA MOHAWK
NUCLEAR ENGINEERING

CALCULATION CONTINUATION SHEET

Page 11

Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date: CES
8-25-96

Calc. No. 54TB300BLD6Φ1

Rev Φ

Checked A Date 9/6/96 Disposition ΦΦB


Ref.

This result is identical to the previous result on page 38. This is because dead weight moments are very small and the member design is governed by moments.

Check for 150 psf (Previous governing pressure).

	<u>150 PSF (ONLY)</u>	<u>DW</u>	<u>150PSF + DW</u>
AXIAL	$150/125 \times 19.85^k = 23.82^k (\tau)$	$+ 24.85^k (\epsilon) =$	-7.03^k
Mz: START	$150/125 \times -6,680.7 = -8,016.8 \text{ k-in}$	$+ 12.74 \text{ k-in} =$	$-8,004.2 \text{ k-in}$
Mz: END	$150/125 \times 4,386 = 5,263.2 \text{ k-in}$	$+ -23.67 \text{ k-in} =$	$5,240 \text{ k-in}$
Vy: Start	$150/125 \times 6.842 = 8.308^k$	$+ -.0534^k =$	8.155^k
Vy: end	$150/125 \times 29.39 = 35.27^k$	$+ .0534^k =$	35.32^k

Determine Max. Moments:



$\frac{150}{125} \times 0.1771 \text{ k/in} = 0.2125 \text{ k/in}$

$M = 8,004 + 8.155x - 0.2125x^2$
 $M_{max} = 8,160.5 \text{ k-in}$
 $\text{at } x = 38.38''$

$\frac{dM}{dx} = 0 = 8.155 - 0.425x$
 $x = 38.38''$




NY NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>12</u>
---	---------------------------------------	----------------

Project: *NINE MILE POINT NUCLEAR STATION*Unit: 1

Originator/Date <i>CCS</i> <i>8-25-96</i>	Calc. No. <i>S4TB300BLD6-01</i>	Rev <i>0</i>
---	------------------------------------	-----------------

Checked <i>A</i>	Date <i>9/6/96</i>	Disposition <i>QAB</i>
---------------------	-----------------------	---------------------------

Ref.	<p><i>Then using page 10 of this Disposition:</i></p> $\frac{5^k}{2(1078)} + \frac{8,140.5}{8,197.2} = 0.998 \leq 1.0 \quad \underline{OK}$ <p><i>2AWF95. Columns Failure Load 150 PSF</i></p>
------	--




NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>13</u>
--	---------------------------------------	----------------

Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date <p style="text-align: center;"><i>C. Stoney</i> 8-28-96</p>	Calc. No. <p style="text-align: center;">SATB300BLDG01</p>	Rev <p style="text-align: center;">0</p>
--	---	---

Checked <p style="text-align: center;"><i>A</i></p>	Date <p style="text-align: center;">9/6/96</p>	Disposition <p style="text-align: center;">ΦΦΦ</p>
--	---	---

Ref.	<p>Member <u>4229</u> [Page 58]</p> <p>From page 58 $P_{cr} = 123^k (C)$, $P = -88.1^k$ ^{125psf} _{DW}</p> <p>[SEE page D-378 FOR DEADWEIGHT FORCE]</p> <p>AXIAL $\frac{125psf + DW}{88.1^k (C)} = \frac{DW}{33.73^k (T)} + \frac{125psf \text{ ONLY}}{121.83^k (C)}$</p> <p>NOTE that DW is <u>tension</u> ; Pressure Compression</p> <p>So ∴ Failure Pressure = $123^k (C) + \frac{DW}{33.73^k} = 156.73^k (C)$</p> <p style="margin-left: 20px;">↑ pressure which yields this Force will fail 4229</p> <p>$\frac{156.73^k}{125psf} \times 125psf = 160psf$</p> <p>→ 121.83^k _{125psf ONLY}</p> <p>Check this result:</p> <p>$\frac{160psf \text{ ONLY}}{125} \times 121.83^k (C) = 155.94^k (C) + \frac{DW}{33.73^k (T)} = \frac{160psf + DW}{122.21^k (C)}$</p> <p style="text-align: center;">$\frac{122.21}{123^k} = 0.994 \leq 1.0$ <u>OK</u></p> <p>∴ Failure Pressure For 4229 is 160psf</p>
------	--




NY NIAGARA MMOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>14</u>
--	---------------------------------------	----------------

Project: *NINE MILE POINT NUCLEAR STATION* Unit: 1

Originator/Data <i>CSSTOUP</i> <i>8-28-96</i>	Calc. No. <i>S4TB300BLDG01</i>	Rev <i>0</i>
---	-----------------------------------	-----------------


Checked <i>A</i>	Date <i>9/6/96</i>	Disposition <i>QQB</i>
---------------------	-----------------------	---------------------------

Ref.	<p><u>Conclusion</u></p> <p>The Turbine Building Main Hall (Above EL.300) Internal Pressure = <u>135PSF</u> \approx Failure</p> <p>This 135 psf is in compliance with the Functional Failure Criteria of the FSAR: 0.9 F_y or 0.9 Peritectal.</p>
------	---



**ATTACHMENT D
CALC S4TB300BLDG01
DISPOSITION 00B**

Vs=-.6057E+02	0.6057E+02	Msa=-.2503E+03	-.1094E+03	(Ms/Ss)=0.1041E+02	-.4548E+01	
Vt=0.1758E+01	-.1758E+01	Mt=0.1436E+05	-.2675E+05	(Mt/St)=-.6463E+02	-.1204E+03	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.8473E+03	-.7396E+03
				Smin =-.9973E+03	-.9895E+03	
129 [52 , 53]						
Fr=0.1811E+05	-.1643E+05	Tr=-.6627E+00	0.6627E+00	(P/A) =-.6539E+03	-.5931E+03	
Vs=-.6148E+02	0.6148E+02	Msa=0.1094E+03	-.4508E+03	(Ms/Ss)=-.4548E+01	-.1874E+02	
Vt=0.1585E+01	-.1585E+01	Mt=0.2674E+05	-.3999E+05	(Mt/St)=-.1204E+03	-.1800E+03	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.5289E+03	-.3943E+03
				Smin =-.7788E+03	-.7919E+03	
130 [38 , 54]						
Fr=0.2538E+05	-.2379E+05	Tr=-.6361E+01	0.6361E+01	(P/A) =-.9164E+03	-.8587E+03	
Vs=-.3796E+02	0.3796E+02	Msa=-.1087E+04	-.4127E+04	(Ms/Ss)=0.4519E+02	-.1716E+03	
Vt=0.2549E+02	-.2549E+02	Mt=0.9140E+04	-.1690E+05	(Mt/St)=-.4115E+02	-.7610E+02	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.8301E+03	-.6110E+03
				Smin =-.1003E+04	-.1106E+04	
131 [54 , 55]						
Fr=0.1754E+05	-.1585E+05	Tr=0.2484E+01	-.2484E+01	(P/A) =-.6331E+03	-.5723E+03	
Vs=-.1113E+02	0.1113E+02	Msa=-.3876E+04	-.2241E+04	(Ms/Ss)=0.1612E+03	-.9318E+02	
Vt=0.2839E+02	-.2839E+02	Mt=0.1690E+05	-.1930E+05	(Mt/St)=-.7610E+02	-.8690E+02	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.3958E+03	-.3923E+03
				Smin =-.8704E+03	-.7524E+03	
132 [40 , 56]						
Fr=0.2448E+05	-.2289E+05	Tr=-.1192E+02	0.1192E+02	(P/A) =-.8839E+03	-.8262E+03	
Vs=-.2323E+02	0.2323E+02	Msa=-.1163E+04	-.4210E+04	(Ms/Ss)=0.4835E+02	-.1751E+03	
Vt=0.2626E+02	-.2626E+02	Mt=0.5583E+04	-.1034E+05	(Mt/St)=-.2513E+02	-.4653E+02	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.8104E+03	-.6046E+03
				Smin =-.9574E+03	-.1048E+04	
133 [56 , 57]						
Fr=0.1673E+05	-.1505E+05	Tr=0.4180E+01	-.4180E+01	(P/A) =-.6040E+03	-.5432E+03	
Vs=0.1033E+02	-.1033E+02	Msa=-.3918E+04	-.2361E+04	(Ms/Ss)=0.1629E+03	-.9817E+02	
Vt=0.2915E+02	-.2915E+02	Mt=0.1033E+05	-.8108E+04	(Mt/St)=-.4652E+02	-.3650E+02	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.3945E+03	-.4085E+03
				Smin =-.8134E+03	-.6779E+03	
134 [41 , 58]						
Fr=0.2412E+05	-.2252E+05	Tr=0.8306E+00	-.8306E+00	(P/A) =-.8707E+03	-.8130E+03	
Vs=-.3502E+02	0.3502E+02	Msa=-.2748E+03	-.1211E+03	(Ms/Ss)=0.1143E+02	-.5035E+01	
Vt=0.1935E+01	-.1935E+01	Mt=0.8310E+04	-.1547E+05	(Mt/St)=-.3741E+02	-.6966E+02	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.8219E+03	-.7383E+03
				Smin =-.9196E+03	-.8877E+03	
135 [58 , 59]						
Fr=0.1666E+05	-.1497E+05	Tr=0.2017E+00	-.2017E+00	(P/A) =-.6013E+03	-.5405E+03	
Vs=-.3559E+02	0.3559E+02	Msa=0.1211E+03	-.4837E+03	(Ms/Ss)=-.5035E+01	-.2011E+02	
Vt=0.1683E+01	-.1683E+01	Mt=0.1547E+05	-.2314E+05	(Mt/St)=-.6966E+02	-.1042E+03	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.5266E+03	-.4163E+03
				Smin =-.6760E+03	-.6648E+03	
136 [42 , 60]						
Fr=0.2485E+05	-.2325E+05	Tr=0.4295E+00	-.4295E+00	(P/A) =-.8969E+03	-.8392E+03	
Vs=-.5341E+02	0.5341E+02	Msa=-.1559E+03	-.3011E+03	(Ms/Ss)=0.6482E+01	-.1252E+02	
Vt=0.2234E+01	-.2234E+01	Mt=0.1274E+05	-.2367E+05	(Mt/St)=-.5735E+02	-.1065E+03	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.8331E+03	-.7202E+03
				Smin =-.9608E+03	-.9583E+03	
137 [60 , 61]						
Fr=0.1705E+05	-.1537E+05	Tr=0.4295E+00	-.4295E+00	(P/A) =-.6157E+03	-.5549E+03	
Vs=-.5341E+02	0.5341E+02	Msa=0.3011E+03	0.5422E+03	(Ms/Ss)=-.1252E+02	0.2255E+02	
Vt=-.3915E+01	0.3915E+01	Mt=0.2367E+05	-.3517E+05	(Mt/St)=-.1065E+03	-.1583E+03	
(Tr*CTOR/Jp)=0.0000E+00				0.0000E+00	Smax =-.4966E+03	-.3740E+03
				Smin =-.7347E+03	-.7358E+03	
138 [43 , 62]						
Fr=0.2503E+05	-.2343E+05	Tr=-.1977E+00	0.1977E+00	(P/A) =-.9037E+03	-.8460E+03	



**ATTACHMENT D
CALC S4TB300BLDG01
DISPOSITION 00B**

3483 [1107 , 1106]

Fr=0.6759E+05 -.6755E+05 Tr=-.2234E+02 0.2234E+02
Vs=-.2356E+02 0.2346E+02 Ms=-.1248E+04 -.1007E+04
Vt=0.3006E+03 0.2551E+03 Mt=-.8736E+03 -.1459E+04
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

Smin =0.1321E+04 0.1510E+04

(P/A) =-.3396E+04 -.3394E+04
(Ms/Ss)=0.5945E+02 -.4795E+02
(Mt/St)=0.4294E+02 -.7169E+02
Smax =-.3294E+04 -.3275E+04
Smin =-.3498E+04 -.3514E+04

3484 [1108 , 1050]

Fr=-.6204E+05 0.6204E+05 Tr=0.2896E+02 -.2896E+02
Vs=0.4034E+00 -.4034E+00 Ms=0.2363E+04 -.1998E+04
Vt=0.2697E+03 0.2772E+03 Mt=0.7812E+02 -.3881E+02
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.3117E+04 0.3117E+04
(Ms/Ss)=-.1125E+03 -.9515E+02
(Mt/St)=-.3840E+01 -.1908E+01
Smax =0.3234E+04 0.3214E+04
Smin =0.3001E+04 0.3020E+04

3485 [1106 , 1100]

Fr=0.8874E+05 -.8870E+05 Tr=-.2451E+02 0.2451E+02
Vs=0.3179E+02 -.3177E+02 Ms=0.9771E+03 -.4403E+04
Vt=0.3086E+03 0.2384E+03 Mt=0.1458E+04 0.1645E+04
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =-.4459E+04 -.4457E+04
(Ms/Ss)=-.4653E+02 -.2097E+03
(Mt/St)=-.7164E+02 0.8086E+02
Smax =-.4341E+04 -.4167E+04
Smin =-.4577E+04 -.4748E+04

3486 [1050 , 1101]

Fr=-.8316E+05 0.8316E+05 Tr=0.2896E+02 -.2896E+02
Vs=0.4034E+00 -.4034E+00 Ms=0.1998E+04 -.1430E+05
Vt=0.3999E+03 0.1477E+03 Mt=0.3881E+02 0.5497E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.4179E+04 0.4179E+04
(Ms/Ss)=-.9515E+02 -.6810E+03
(Mt/St)=-.1908E+01 0.2702E-01
Smax =0.4276E+04 0.4860E+04
Smin =0.4082E+04 0.3498E+04

3487 [1100 , 1099]

Fr=0.1031E+06 -.1031E+06 Tr=-.2639E+02 0.2639E+02
Vs=-.3778E+02 0.3772E+02 Ms=0.4376E+04 -.1270E+05
Vt=0.3589E+03 0.1887E+03 Mt=-.1644E+04 -.2045E+04
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =-.5183E+04 -.5181E+04
(Ms/Ss)=-.2084E+03 -.6047E+03
(Mt/St)=0.8083E+02 -.1005E+03
Smax =-.4894E+04 -.4476E+04
Smin =-.5472E+04 -.5886E+04

3488 [1101 , 1049]

Fr=-.9445E+05 0.9445E+05 Tr=0.2173E+02 -.2173E+02
Vs=-.3136E+01 0.3136E+01 Ms=0.1210E+05 -.8453E+04
Vt=0.2456E+03 0.3182E+03 Mt=-.5497E+00 -.3144E+03
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.4746E+04 0.4746E+04
(Ms/Ss)=-.5762E+03 -.4026E+03
(Mt/St)=0.2702E-01 -.1546E+02
Smax =0.5322E+04 0.5164E+04
Smin =0.4170E+04 0.4328E+04

3489 [1099 , 1093]

Fr=0.1113E+06 -.1113E+06 Tr=-.2772E+02 0.2772E+02
Vs=0.4447E+02 -.4450E+02 Ms=0.1268E+05 -.8694E+04
Vt=0.2423E+03 0.3215E+03 Mt=0.2043E+04 0.2434E+04
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =-.5592E+04 -.5591E+04
(Ms/Ss)=-.6037E+03 -.4140E+03
(Mt/St)=-.1004E+03 0.1196E+03
Smax =-.4888E+04 -.5057E+04
Smin =-.6297E+04 -.6124E+04

3490 [1049 , 1094]

Fr=-.1026E+06 0.1026E+06 Tr=0.2173E+02 -.2173E+02
Vs=-.3136E+01 0.3136E+01 Ms=0.8453E+04 -.1570E+05
Vt=0.3543E+03 0.2102E+03 Mt=0.3144E+03 -.6298E+03
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.5155E+04 0.5155E+04
(Ms/Ss)=-.4026E+03 -.7478E+03
(Mt/St)=-.1546E+02 -.3096E+02
Smax =0.5573E+04 0.5934E+04
Smin =0.4737E+04 0.4377E+04

3491 [1093 , 1092]


Fr=0.1141E+06 -.1141E+06 Tr=-.3042E+02 0.3042E+02
Vs=-.5567E+02 0.5561E+02 Ms=0.8680E+04 -.2126E+05
Vt=0.4071E+03 0.1574E+03 Mt=-.2433E+04 -.3173E+04
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =-.5735E+04 -.5733E+04
(Ms/Ss)=-.4134E+03 -.1012E+04
(Mt/St)=0.1196E+03 -.1560E+03
Smax =-.5202E+04 -.4565E+04
Smin =-.6268E+04 -.6902E+04

3492 [1094 , 1048]

Fr=-.1015E+06 0.1015E+06 Tr=-.9360E+01 0.9360E+01
Vs=0.1924E+00 -.1924E+00 Ms=0.1513E+05 0.3521E+04
Vt=0.1101E+03 0.4706E+03 Mt=0.6298E+03 -.6099E+03
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.5100E+04 0.5100E+04
(Ms/Ss)=-.7203E+03 0.1677E+03
(Mt/St)=-.3096E+02 -.2998E+02
Smax =0.5852E+04 0.5298E+04



ATTACHMENT D
CALC S4TB300BLDG01
DISPOSITION 00B

3742 [61 , 1058]

Fr=-.3791E+04 0.3791E+04 Tr=-.4941E+02 0.4941E+02
Vs=0.1369E-15 -.1369E-15 Ms=0.0000E+00 0.0000E+00
Vt=-.9336E+02 -.9336E+02 Mt=0.0000E+00 0.0000E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

Smin =0.9091E+03 0.9091E+03
(P/A) =0.9077E+03 0.9077E+03
(Ms/Ss)=0.0000E+00 0.0000E+00
(Mt/St)=0.0000E+00 0.0000E+00
Smax =0.9077E+03 0.9077E+03
Smin =0.9077E+03 0.9077E+03

3743 [49 , 1761]

Fr=-.3303E+04 0.3303E+04 Tr=0.4492E+01 -.4492E+01
Vs=0.1066E+01 -.1066E+01 Ms=0.0000E+00 0.3607E+05
Vt=-.3092E+03 0.1032E+03 Mt=0.0000E+00 0.1865E+03
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.7911E+03 0.7911E+03
(Ms/Ss)=0.0000E+00 0.7043E+04
(Mt/St)=0.0000E+00 0.1348E+03
Smax =0.7911E+03 0.7969E+04
Smin =0.7911E+03 -.6387E+04

3744 [1763 , 1761]

Fr=-.3305E+04 0.3305E+04 Tr=0.1596E+01 -.1596E+01
Vs=0.1067E+01 -.1067E+01 Ms=0.0000E+00 -.3600E+05
Vt=0.3089E+03 -.1029E+03 Mt=0.0000E+00 0.1865E+03
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.7915E+03 0.7915E+03
(Ms/Ss)=0.0000E+00 -.7029E+04
(Mt/St)=0.0000E+00 0.1348E+03
Smax =0.7915E+03 0.7955E+04
Smin =0.7915E+03 -.6372E+04

3745 [1773 , 1749]

Fr=0.2547E+03 -.2547E+03 Tr=-.6077E+01 0.6077E+01
Vs=-.1675E+00 0.1675E+00 Ms=0.0000E+00 0.3496E+05
Vt=-.3044E+03 0.1014E+03 Mt=0.0000E+00 -.2886E+02
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =-.6100E+02 -.6100E+02
(Ms/Ss)=0.0000E+00 0.6826E+04
(Mt/St)=0.0000E+00 -.2086E+02
Smax =-.6100E+02 0.6786E+04
Smin =-.6100E+02 -.6908E+04

3746 [1771 , 1725]

Fr=-.2404E+04 0.2404E+04 Tr=-.5610E+01 0.5610E+01
Vs=-.1419E+00 0.1419E+00 Ms=0.0000E+00 0.3462E+05
Vt=-.3029E+03 0.1009E+03 Mt=0.0000E+00 -.2433E+02
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.5756E+03 0.5756E+03
(Ms/Ss)=0.0000E+00 0.6759E+04
(Mt/St)=0.0000E+00 -.1759E+02
Smax =0.5756E+03 0.7352E+04
Smin =0.5756E+03 -.6201E+04

3747 [1763 , 1718]

Fr=-.3798E+04 0.3798E+04 Tr=-.3651E+01 0.3651E+01
Vs=-.1332E-02 0.1332E-02 Ms=0.0000E+00 0.3532E+05
Vt=-.3059E+03 0.1019E+03 Mt=0.0000E+00 -.2307E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.9096E+03 0.9096E+03
(Ms/Ss)=0.0000E+00 0.6896E+04
(Mt/St)=0.0000E+00 -.1668E+00
Smax =0.9096E+03 0.7805E+04
Smin =0.9096E+03 -.5986E+04

3748 [1759 , 1711]

Fr=-.5766E+04 0.5766E+04 Tr=-.5628E+01 0.5628E+01
Vs=-.4827E-02 0.4827E-02 Ms=0.0000E+00 0.3604E+05
Vt=-.3090E+03 0.1030E+03 Mt=0.0000E+00 -.8445E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.1381E+04 0.1381E+04
(Ms/Ss)=0.0000E+00 0.7036E+04
(Mt/St)=0.0000E+00 -.6104E+00
Smax =0.1381E+04 0.8418E+04
Smin =0.1381E+04 -.5656E+04

3749 [1757 , 1703]

Fr=-.6762E+04 0.6762E+04 Tr=-.3178E+01 0.3178E+01
Vs=0.9014E-02 -.9014E-02 Ms=0.0000E+00 0.3532E+05
Vt=-.3059E+03 0.1019E+03 Mt=0.0000E+00 0.1561E+01
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00


(P/A) =0.1619E+04 0.1619E+04
(Ms/Ss)=0.0000E+00 0.6896E+04
(Mt/St)=0.0000E+00 0.1128E+01
Smax =0.1619E+04 0.8516E+04
Smin =0.1619E+04 -.5278E+04

3750 [1755 , 1697]

Fr=-.4831E+04 0.4831E+04 Tr=-.4894E+01 0.4894E+01
Vs=0.1354E+00 -.1354E+00 Ms=0.0000E+00 0.3462E+05
Vt=-.3029E+03 0.1009E+03 Mt=0.0000E+00 0.2322E+02
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00

(P/A) =0.1157E+04 0.1157E+04
(Ms/Ss)=0.0000E+00 0.6759E+04
(Mt/St)=0.0000E+00 0.1678E+02
Smax =0.1157E+04 0.7933E+04
Smin =0.1157E+04 -.5619E+04

ELEMENT NUMBER	FORCES		MOMENTS		STRESSES	
	NODE1	NODE2	NODE1	NODE2	NODE1	NODE2
3751	[71	, 1730]				
	Fr=-.1947E+04	0.1947E+04	Tr=-.4286E+01	0.4286E+01	(P/A) =0.4662E+03	0.4662E+03




**ATTACHMENT D
CALC S4TB300BLDG01
DISPOSITION 00B**

ELEMENT NUMBER	FORCE	STRESS	ENERGY	ENERGY DENSITY
4211	-0.247069E+05	-0.361212E+04	0.1894E+03	0.2175E+00
4212	0.329197E+05	0.481283E+04	0.4112E+03	0.3861E+00
4213	0.330113E+05	0.482622E+04	0.4133E+03	0.3882E+00
4214	-0.247912E+05	-0.362444E+04	0.1907E+03	0.2189E+00
4215	-0.248083E+05	-0.362694E+04	0.1910E+03	0.2192E+00
4216	0.330497E+05	0.483183E+04	0.4144E+03	0.3891E+00
4217	0.317647E+05	0.464396E+04	0.3826E+03	0.3594E+00
4218	-0.238375E+05	-0.348502E+04	0.1763E+03	0.2024E+00
4219	-0.238389E+05	-0.348522E+04	0.1764E+03	0.2024E+00
4220	0.317821E+05	0.464650E+04	0.3832E+03	0.3598E+00
4221	0.317616E+05	0.464350E+04	0.3826E+03	0.3594E+00
4222	-0.238351E+05	-0.348466E+04	0.1763E+03	0.2024E+00
4223	-0.238377E+05	-0.348505E+04	0.1763E+03	0.2024E+00
4224	0.317805E+05	0.464628E+04	0.3832E+03	0.3598E+00
4225	0.324659E+05	0.474648E+04	0.3997E+03	0.3755E+00
4226	-0.243677E+05	-0.356253E+04	0.1843E+03	0.2115E+00
4227	-0.243516E+05	-0.356018E+04	0.1840E+03	0.2112E+00
4228	0.324610E+05	0.474576E+04	0.3998E+03	0.3754E+00
4229	<u>0.337326E+05</u>	0.493167E+04	0.4315E+03	0.4054E+00
4230	-0.253534E+05	-0.370663E+04	0.1995E+03	0.2290E+00
4231	-0.253722E+05	-0.370938E+04	0.1998E+03	0.2293E+00
4232	0.337733E+05	0.493762E+04	0.4328E+03	0.4063E+00
4233	0.561802E+05	0.480172E+04	0.6620E+03	0.3843E+00
4234	0.561719E+05	0.480102E+04	0.6618E+03	0.3842E+00
4235	0.561782E+05	0.480156E+04	0.6620E+03	0.3842E+00
4236	0.561777E+05	0.480152E+04	0.6620E+03	0.3842E+00
4237	0.590182E+05	0.504429E+04	0.7306E+03	0.4241E+00
4238	0.589890E+05	0.504179E+04	0.7299E+03	0.4237E+00
4239	0.578866E+05	0.494757E+04	0.7029E+03	0.4080E+00
4240	0.579159E+05	0.495008E+04	0.7036E+03	0.4084E+00
4241	0.561770E+05	0.480145E+04	0.6620E+03	0.3842E+00
4242	0.561808E+05	0.480177E+04	0.6620E+03	0.3843E+00
4243	0.561766E+05	0.480142E+04	0.6619E+03	0.3842E+00
4244	0.561822E+05	0.480189E+04	0.6621E+03	0.3843E+00
4245	0.561771E+05	0.480146E+04	0.6620E+03	0.3842E+00
4246	0.561766E+05	0.480142E+04	0.6619E+03	0.3842E+00
4247	0.584098E+05	0.499229E+04	0.7156E+03	0.4154E+00
4248	0.583587E+05	0.498792E+04	0.7144E+03	0.4147E+00
4249	0.584965E+05	0.499970E+04	0.7177E+03	0.4166E+00
4250	0.585392E+05	0.500335E+04	0.7188E+03	0.4172E+00
4251	0.561787E+05	0.480160E+04	0.6620E+03	0.3843E+00
4252	0.561755E+05	0.480132E+04	0.6619E+03	0.3842E+00
4253	0.561748E+05	0.480126E+04	0.6619E+03	0.3842E+00
4254	0.561735E+05	0.480115E+04	0.6619E+03	0.3842E+00
4255	0.576819E+05	0.493008E+04	0.6979E+03	0.4051E+00
4256	0.576949E+05	0.493119E+04	0.6982E+03	0.4053E+00
4257	0.596827E+05	0.510108E+04	0.7472E+03	0.4337E+00
4258	0.596620E+05	0.509932E+04	0.7466E+03	0.4334E+00

SOLUTION TIME LOG IN SEC FOR STRESS CALCULATIONS

READING GENERAL INFORMATION AND ELEMENT DATA. . . = 56
 STRESS CALCULATION AND PRINTOUT = 26
 UPDATING DATABASE = 0



ORIGINAL

	<h2>DISPOSITION COVER SHEET</h2>	Page 1 (Next) <u>2</u>
		Total <u>134</u>
		Last <u>G-128</u>

Project: NINE MILE POINT NUCLEAR STATION Unit (1,2 or 0=Both): 1 Discipline: STRUCTURAL

Title <u>EVALUATION OF REACTOR BUILDING SUPERSTRUCTURE FOR 93 PSF INTERNAL PRESSURE</u>		Calculation No. <u>SARX340BLDG01</u>	Rev <u>02</u>	Disp <u>02B</u>
(Sub)System(s) <u>N/A</u>		Originator <u>C.E. STROUP</u>	Date <u>9-10-96</u>	
Index No. <u>54</u>	Checker <u>C.R. AGOSTA</u>	Date <u>9/10/96</u>		
Design Change No. <u>N/A</u>	Approver <u>Mohammed Alvi</u>	Date <u>9-10-96</u>		

Superseded Document(s): NONE NMPC Acceptance/Date: N/A

Description of Change
INCORPORATION OF NRC NRR COMMENTS ON REVISION 2.


Resolution
SEE ATTACHED PAGES 2-6

Cross Reference Change(s):
LDCR 1-96-UFS-035

Confirmation Required (Yes/No): <u>N</u> See Page(s): _____	Final Issue Status (APP/FIO/VOI): <u>APP</u>	File Location (Calculation/Hold): <u>C</u>	Operations Accepted on Issue (Yes/No): <u>Y</u>
--	--	--	---

Safety Evaluation Number(s)/Revision: Copy of Applicability Review Attached? Yes <u>N/R</u> <input checked="" type="checkbox"/>	Component ID(s)/EPN(s)/Line Numbers: <u>N/A</u>
--	--


Key Words: PRESSURE RELIEF PANELS, NMPI, REACTOR BUILDING, INTERNAL PRESSURE, COSMOSM



NY NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET		Page <u>2</u>
	Project: <u>NINE MILE POINT NUCLEAR STATION</u> Unit: <u>1</u>		

Originator/Data <u>CE STOMP</u> <u>8-28-96</u>	Calc. No. <u>SARX340 BLDG 01</u>	Rev <u>2</u>
Checked <u>A</u>	Date <u>9/3/96</u>	Disposition <u>02B</u>

Ref.	<p>OBJECTIVE:</p> <p>1) Revision 2 extrapolated the internal pressure which would cause structure failure using linear extrapolation of results [member forces and moments], which included both dead weight and pressure loadings.</p> <p>This Calc removes the effect of dead weight when extrapolating the 93 psf upwards to the failure pressure.</p> <p>2) Revision 2 included a 1.05 increase factor of the internal pressure based on a strain-rate effect.</p> <p>This Calc eliminates this factor for the governing structural members.</p>
------	--



NIAGARA
MOHAWK
NUCLEAR ENGINEERING

CALCULATION CONTINUATION SHEET

Page 3

Project: NINE MILE POINT NUCLEAR STATION Unit: L

Originator/Date CES 9-10-86	Calc. No. 54RX340 BLDG-01	Rev 2
-----------------------------------	------------------------------	----------

Checked A	Date 9/10/96	Disposition Φ 2 B
--------------	-----------------	----------------------

Ref.

Member 3288 SEE PAGE C-126 FOR DEADWEIGHT FORCE

Deadweight + 93 psf : $-27.3^k (C)$
 Deadweight only : $21.69^k (T)$
 93 PSF ONLY: $48.99^k (C)$

From Page 48B : $P_{critical} = 39.79^k (C)$
 Dead weight = $+21.69^k$
 $61.48^k (C)$

NOTE: The P_{crit} on page 48B is multiplied by 0.9 instead of 0.95 to conform with FSAR Functional Failure


$61.48 \times 0.9 = 55.33^k$
 $55.33 + 93 = 148.33^k$
 $148.33 / 3 = 49.44^k$

42^k from page 48B times 0.9/0.85

Note that the 1.05 strain-rate factor was not used here.

$P = 140.71^k$ psf
 ≈ 117 psf

0.9 FCR USED IN COMPUTING THE FAILURE LOAD.



NIAGARA MOHAWK
NUCLEAR ENGINEERING

CALCULATION CONTINUATION SHEET

Page 4


Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date <u>CS</u> <u>9-10-96</u>	Calc. No. <u>SARX340 BLDG 01</u>	Rev <u>2</u>
--	-------------------------------------	-----------------

Checked <u>A</u>	Date <u>9/10/96</u>	Disposition <u>02B</u>
---------------------	------------------------	---------------------------

Ref.

Member 29: 14WF78
 Determine dead weight forces and moments @ 14.25" from bottom to match page 83 results for 93 psf + Dead weight:



SEE PAGE G-61
 FOR DEAD WEIGHT
 FORCES & MOMENTS


AXIAL @ 14.25" = $43.94\text{ k} - (14.25") \left(\frac{6.5\text{ lb/in}}{1000} \right) = 43.85\text{ k (c)}$

Moment @ 14.25" = $84.43\text{ k-in} - (0.436\text{ k})(14.25") = 78.21\text{ k-in}$

From page 84: $M = 3354\text{ k-in}$ @ 14.25" } 93 psf +
 $P = 4.33\text{ k (T)}$ } DEAD WEIGHT

$F_y = 37.3\text{ ksi}$ [Page 82, With No Strain Rate Increase]

$\phi_t P_n = (0.9)(22.9\text{ in}^2)(37.3\text{ ksi}) = 768.75\text{ k}$ [LRFD Chapter H]
 (Tension)



**NIAGARA
MUNICIPALITY**
NUCLEAR ENGINEERING

CALCULATION CONTINUATION SHEET

Page 5

Project: NINE MILE POINT NUCLEAR STATION

Unit: 1

Originator/Date

CES
9-10-96

Calc. No.

54RX340 BLDG-φ1

Rev

2

Checked

CA

Date

9/10/96

Disposition

φ2B

Ref.

$$\phi_b M_n = (\phi_b)^z (134 \text{ in}^3) (37.3 \text{ ksi}) = 4,498.38 \text{ k-in}$$

[Full lateral support as concluded on Page 73]

$$\begin{array}{l} \text{AXIAL} \\ \text{M} \end{array} \quad \begin{array}{l} \text{93 PSF + DW} \\ 4.33^{\text{k}} (\text{T}) \\ +3,354 \text{ k-in} \end{array} = \begin{array}{l} \text{DW} \\ 43.85^{\text{k}} (\text{C}) \\ +78.21 \text{ k-in} \end{array} + \begin{array}{l} \text{93 PSF ONLY} \\ 48.18 (\text{T}) \\ +3,275.79 \text{ k-in} \end{array}$$

USE LRFD EQ H1-16 since $\frac{P_u}{\phi P_n} < 0.2$

$$\text{For 93 PSF + Deadweight: } \frac{4.33^{\text{k}}}{768.75^{\text{k}}} = 0.0056 < 0.2$$


$$\frac{4.33}{768.75} + \frac{3,354}{4,498.38} = 0.751 \leq 1.0 \quad \text{93 PSF + Deadweight}$$

$$\begin{array}{l} \text{93 PSF + DW} / 0.751 \\ \text{M: } 4,464.6 \end{array} = \begin{array}{l} \text{DW} \\ 78.21 \text{ k-in} \end{array} + \begin{array}{l} \text{X, PSF ONLY} \\ 4,386.44 \end{array}$$

$$\begin{array}{l} \text{X, PSF Failure} \\ \text{Pressure} \end{array} = \frac{4,386.44}{3,275.79} \times 93 = 124.53 \text{ PSF}$$

Check results:

$$\begin{array}{l} \text{AXIAL} \\ \text{M} \end{array} \quad \begin{array}{l} \frac{124.53 \text{ PSF ONLY} + \text{DW}}{(124.53/93) 48.18 = 64.52^{\text{k}} (\text{T}) + 43.85^{\text{k}} (\text{C})} \\ (124.53/93) 3,275.79 = 4,386.44 + 78.21 \text{ k-in} \end{array} = \begin{array}{l} \frac{124.53 \text{ PSF + DW}}{20.67^{\text{k}} (\text{T})} \\ 4,464.65 \text{ k-in} \end{array}$$




NY NIAGARA MOHAWK NUCLEAR ENGINEERING	CALCULATION CONTINUATION SHEET	Page <u>6</u>
---	---------------------------------------	---------------

 Project: NINE MILE POINT NUCLEAR STATION Unit: 1

Originator/Date <u>CS</u> <u>9-10-96</u>	Calc. No. <u>SARX342BLDG01</u>	Rev <u>2</u>
--	-----------------------------------	-----------------

Checked <u>A</u>	Date <u>9/10/96</u>	Disposition <u>02B</u>
---------------------	------------------------	---------------------------

Ref.	<p> Eq. H1-16: $\frac{P_u}{2\phi_e P_n} + \frac{M_u}{\phi_b M_n} \leq 1.0$ $\frac{20.67}{2(768.75)} + \frac{4,464.65}{4,498.38} = 1.006 \text{ OK}$ </p> <p> USE 124 PSF </p> <p> This result does not use strain-rate factor and is in compliance with FSAR FUNCTIONAL FAILURE CRITERIA OF $0.9 F_y$ & $0.9 P_{critical}$. </p> <p> CONCLUSION: Reactor Building Internal Pressure Failure = 117 PSF </p>
------	--



ATTACHMENT G
CALC SARX340BLDG01
DISPOSITION 02B

29 [233 , 244]
Fr=0.4394E+05 -.4270E+05 Tr=0.4508E-02 -.4508E-02 (P/A)=-.1919E+04 -.1865E+04
Vs=0.4366E+03 -.4366E+03 Ms=0.3831E+04 0.4593E+04 (Ms/Ss)=-.1110E+03 0.1331E+03
Vt=-.4413E+02 0.4413E+02 Mt=0.8443E+05 -.1104E+04 (Mt/St)=-.6975E+03 -.9120E+01
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =-.1110E+04 -.1722E+04
Smin =-.2727E+04 -.2007E+04

39 [5 , 12]
Fr=-.4076E+04 0.4076E+04 Tr=0.0000E+00 0.0000E+00 (P/A)=0.4606E+03 0.4606E+03
Vs=-.1502E+04 -.1502E+04 Ms=0.0000E+00 0.0000E+00 (Ms/Ss)=0.0000E+00 0.0000E+00
Vt=0.4204E-16 -.4204E-16 Mt=0.0000E+00 0.0000E+00 (Mt/St)=0.0000E+00 0.0000E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =0.4606E+03 0.4606E+03
Smin =0.4606E+03 0.4606E+03

40 [12 , 23]
Fr=-.3793E+04 0.3793E+04 Tr=0.0000E+00 0.0000E+00 (P/A)=0.4286E+03 0.4286E+03
Vs=-.1502E+04 -.1502E+04 Ms=0.0000E+00 0.0000E+00 (Ms/Ss)=0.0000E+00 0.0000E+00
Vt=0.8892E-16 -.8892E-16 Mt=0.0000E+00 0.0000E+00 (Mt/St)=0.0000E+00 0.0000E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =0.4286E+03 0.4286E+03
Smin =0.4286E+03 0.4286E+03

41 [23 , 24]
Fr=-.2361E+04 0.2361E+04 Tr=0.0000E+00 0.0000E+00 (P/A)=0.2667E+03 0.2667E+03
Vs=-.1502E+04 -.1502E+04 Ms=0.0000E+00 0.0000E+00 (Ms/Ss)=0.0000E+00 0.0000E+00
Vt=0.2614E-15 -.2614E-15 Mt=0.0000E+00 0.0000E+00 (Mt/St)=0.0000E+00 0.0000E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =0.2667E+03 0.2667E+03
Smin =0.2667E+03 0.2667E+03

42 [24 , 56]
Fr=-.2400E+03 0.2400E+03 Tr=0.0000E+00 0.0000E+00 (P/A)=0.2712E+02 0.2712E+02
Vs=-.1502E+04 -.1502E+04 Ms=0.0000E+00 0.0000E+00 (Ms/Ss)=0.0000E+00 0.0000E+00
Vt=0.4701E-15 -.4701E-15 Mt=0.0000E+00 0.0000E+00 (Mt/St)=0.0000E+00 0.0000E+00
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =0.2712E+02 0.2712E+02
Smin =0.2712E+02 0.2712E+02


43 [66 , 31]
Fr=0.3085E+05 -.2951E+05 Tr=0.0000E+00 0.0000E+00 (P/A)=-.1244E+04 -.1190E+04
Vs=-.4447E+03 0.4447E+03 Ms=0.2645E+04 0.2082E+04 (Ms/Ss)=-.1242E+03 0.9783E+02
Vt=-.2476E+02 0.2476E+02 Mt=-.3715E+05 -.4772E+05 (Mt/St)=0.1741E+03 -.2236E+03
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =-.9455E+03 -.8685E+03
Smin =-.1542E+04 -.1511E+04

44 [31 , 39]
Fr=0.2114E+05 -.1981E+05 Tr=0.0000E+00 0.0000E+00 (P/A)=-.8524E+03 -.7988E+03
Vs=0.2709E+03 -.2709E+03 Ms=-.2082E+04 -.3683E+04 (Ms/Ss)=0.9783E+02 -.1730E+03
Vt=0.3035E+02 -.3035E+02 Mt=0.4772E+05 0.3738E+04 (Mt/St)=-.2236E+03 0.1752E+02
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =-.5310E+03 -.6083E+03
Smin =-.1174E+04 -.9894E+03

45 [39 , 68]
Fr=0.1228E+05 -.1123E+05 Tr=0.0000E+00 0.0000E+00 (P/A)=-.4953E+03 -.4530E+03
Vs=0.5733E+03 -.5733E+03 Ms=0.3683E+04 0.6774E+04 (Ms/Ss)=-.1730E+03 0.3182E+03
Vt=-.6968E+02 0.6968E+02 Mt=-.3738E+04 0.8977E+05 (Mt/St)=0.1752E+02 0.4207E+03
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =-.3048E+03 0.2859E+03
Smin =-.6859E+03 -.1192E+04

46 [68 , 56]
Fr=0.6342E+04 -.5579E+04 Tr=0.0000E+00 0.0000E+00 (P/A)=-.2557E+03 -.2250E+03
Vs=-.8236E+03 0.8236E+03 Ms=-.6774E+04 0.7276E-11 (Ms/Ss)=0.3182E+03 0.3418E-12
Vt=0.6215E+02 -.6215E+02 Mt=-.8977E+05 -.8731E-10 (Mt/St)=0.4207E+03 -.4091E-12
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =0.4832E+03 -.2250E+03
Smin =-.9946E+03 -.2250E+03

47 [69 , 70]
Fr=0.4584E+05 -.4460E+05 Tr=-.1204E-02 0.1204E-02 (P/A)=-.2002E+04 -.1948E+04
Vs=0.2720E+03 -.2720E+03 Ms=0.3040E+04 0.3596E+04 (Ms/Ss)=-.8813E+02 0.1042E+03
Vt=-.3477E+02 0.3477E+02 Mt=0.5237E+05 -.6443E+03 (Mt/St)=-.4343E+03 -.5323E+01
(Tr*CTOR/Jp)=0.0000E+00 0.0000E+00 Smax =-.1479E+04 -.1838E+04



**ATTACHMENT G
CALC S4RX340BLDG01
DISPOSITION 02B**

3286	0.115067E+05	0.324133E+04	0.1070E+03	0.1751E+00
3287	-0.109220E+05	-0.307662E+04	0.9639E+02	0.1578E+00
3288	0.216882E+05	0.610934E+04	0.4279E+03	0.6221E+00
3302	-0.216744E+04	-0.355902E+03	0.2379E+01	0.2111E-02
3303	-0.421811E+04	-0.823849E+03	0.8394E+01	0.1131E-01
3304	0.655591E+04	0.128045E+04	0.2511E+02	0.2733E-01
3305	-0.120792E+05	-0.198346E+04	0.5501E+02	0.6557E-01
3306	0.175173E+05	0.342135E+04	0.1738E+03	0.1951E+00
3307	-0.201720E+05	-0.285722E+04	0.1254E+03	0.1361E+00
3308	0.288445E+05	0.421703E+04	0.3419E+03	0.2964E+00
3309	-0.294537E+05	-0.407946E+04	0.2471E+03	0.2774E+00
3310	0.456081E+05	0.480085E+04	0.5966E+03	0.3841E+00
3311	-0.407286E+05	-0.428722E+04	0.3381E+03	0.3063E+00
3312	0.605314E+05	0.838385E+04	0.1340E+04	0.1171E+01
3326	-0.312857E+04	-0.513723E+03	0.4956E+01	0.4399E-02
3327	-0.342635E+04	-0.669208E+03	0.5539E+01	0.7464E-02
3328	0.552446E+04	0.107900E+04	0.1783E+02	0.1940E-01
3329	-0.100607E+05	-0.165200E+04	0.3816E+02	0.4548E-01
3330	0.170467E+05	0.332944E+04	0.1646E+03	0.1848E+00
3331	-0.197734E+05	-0.280076E+04	0.1205E+03	0.1307E+00

ELEMENT NUMBER	FORCE	STRESS	ENERGY	ENERGY DENSITY
3332	0.282931E+05	0.413641E+04	0.3290E+03	0.2852E+00
3333	-0.289153E+05	-0.400490E+04	0.2381E+03	0.2673E+00
3334	0.424881E+05	0.447244E+04	0.5177E+03	0.3334E+00
3335	-0.383997E+05	-0.404208E+04	0.3006E+03	0.2723E+00
3336	0.571664E+05	0.791778E+04	0.1195E+04	0.1045E+01
3345	0.180644E+03	0.508857E+02	0.2799E-01	0.4316E-04
3346	0.354101E+03	0.997469E+02	0.1075E+00	0.1658E-03
3347	0.294566E+03	0.829763E+02	0.7011E-01	0.1148E-03
3348	0.243322E+03	0.685413E+02	0.4784E-01	0.7830E-04
3362	-0.296532E+04	-0.486917E+03	0.4452E+01	0.3951E-02
3363	-0.345021E+04	-0.673869E+03	0.5616E+01	0.7568E-02
3364	0.551598E+04	0.107734E+04	0.1777E+02	0.1934E-01
3365	-0.783491E+04	-0.128652E+04	0.2314E+02	0.2759E-01
3366	0.119253E+05	0.232916E+04	0.8054E+02	0.9042E-01
3367	-0.156540E+05	-0.221728E+04	0.7553E+02	0.8194E-01
3368	0.226163E+05	0.330648E+04	0.2102E+03	0.1822E+00
3369	-0.229850E+05	-0.318351E+04	0.1505E+03	0.1689E+00
3370	0.368323E+05	0.387708E+04	0.3891E+03	0.2505E+00
3371	-0.341060E+05	-0.359010E+04	0.2371E+03	0.2148E+00
3372	0.509147E+05	0.705190E+04	0.9482E+03	0.8288E+00
3381	0.212281E+04	0.597975E+03	0.3865E+01	0.5960E-02
3382	-0.158289E+04	-0.445885E+03	0.2149E+01	0.3314E-02
3383	0.207740E+03	0.585183E+02	0.3487E-01	0.5707E-04
3384	0.335266E+03	0.944410E+02	0.9082E-01	0.1487E-03
3398	-0.451136E+04	-0.740782E+03	0.1031E+02	0.9146E-02
3399	-0.206576E+04	-0.403469E+03	0.2013E+01	0.2713E-02
3400	0.367320E+04	0.717421E+03	0.7881E+01	0.8578E-02
3401	-0.889695E+03	-0.146091E+03	0.2984E+00	0.3557E-03
3402	0.562968E+04	0.109955E+04	0.1795E+02	0.2015E-01
3403	-0.105122E+05	-0.148897E+04	0.3406E+02	0.3695E-01
3404	0.155286E+05	0.227027E+04	0.9910E+02	0.8590E-01
3405	-0.127808E+05	-0.177019E+04	0.4652E+02	0.5223E-01
3406	0.197956E+05	0.208375E+04	0.1124E+03	0.7237E-01
3407	-0.212486E+05	-0.223670E+04	0.9203E+02	0.8338E-01
3408	0.322330E+05	0.446441E+04	0.3800E+03	0.3322E+00

Page 10



[Faint, illegible text covering the majority of the page]

NOTE OF EXPLANATION ON CALCULATION S4RX340BLDG01, PAGE 6:

The result on page 6 for Member 29 shows a stress interaction of 1.006 for an internal pressure of 124psf. This result was denoted as "OK". Stress ratio interactions must be less than or equal to 1.000 for acceptability. This result was accepted because it is not the controlling member. Member 3288 is the controlling member with an internal pressure of 117psf. At 117psf, the Member 29 stress ratio interaction is less than 1.000.



22-107

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

USAGE OF REDUCTION OR OVERCAPACITY FACTORS (ϕ) IN CALCULATION
S7RX340W01 - PRESSURE RELIEF PANELS

A review of Calculation S7RX340W01 indicates that no reduction or overcapacity factors were used in calculating the internal building pressure which would cause the panels to release. The panel components are designed to have relatively low stresses in the elastic range with the exception of the panel shear bolts which are designed to fail when the internal building pressure reaches the reported limits. The failure load of the shear bolts is based on ultimate failure determined by load tests on the bolts as described in the calculation. No reduction or overcapacity factor was applied to the bolt failure loads. The reduction factor of $\phi=0.90$ is not applicable for this calculation as it is based on ultimate failure load of the bolts and not the bolt yield strength. No reduction factor was used as this calculation determined the upper bound values of the panel release pressures.

