

Mr. B. Ralph Sylvia
 Executive Vice President, Generation Business
 Group and Chief Nuclear Officer
 Niagara Mohawk Power Corporation
 Nuclear Learning Center
 450 Lake Road
 Oswego, NY 13126

February 10, 1997

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING SYSTEM
 LEAKAGE/HYDROSTATIC TESTING AND SCRAM TIME TESTING TECHNICAL
 SPECIFICATION CHANGES, NINE MILE POINT NUCLEAR STATION UNIT NO. 1
 (TAC NO. M96907)

Dear Mr. Sylvia:

The NRC staff is reviewing your submittal of September 26, 1996, regarding the proposed technical specification change to various surveillances performed during a refueling outage. We find that additional information is necessary to complete our review.

Your response to the enclosure is requested as soon as possible to support your current outage schedule. If you have questions regarding the enclosure or are unable to meet the requested response date, please call me at (301) 415-3049, or e-mail me at dsh@nrc.gov.

Sincerely,

/S/

Darl S. Hood, Senior Project Manager
 Project Directorate I-1
 Division of Reactor Projects - I/II
 Office of Nuclear Reactor Regulation

Docket No. 50-220

Enclosure: Request for Additional
 Information

cc w/encl: See next page

DISTRIBUTION:

Docket File	SBajwa	OGC
PUBLIC	SLittle	ACRS
PDI-1 R/F	DHood	CCowgill, RI
SVarga	GGolub	RPelton
JZwolinski		

NRC FILE CENTER COPY

DOCUMENT NAME: G:\NMP1\96907.RAI

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PH:PDI-1	E	LA:PDI-1	D:PDI-1			
NAME	DHood/rsl		SLittle	SBajwa			
DATE	02/10/97		02/10/97	02/10/97			

130046 Official Record Copy

1/1
DF01

9702130228 970210
 PDR ADOCK 05000220
 P PDR

1948-1949

1948-1949



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 10, 1997

Mr. B. Ralph Sylvia
Executive Vice President Generation Business
Group and Chief Nuclear Officer
Niagara Mohawk Power Corporation
Nuclear Learning Center
450 Lake Road
Oswego, NY 13126

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING SYSTEM
LEAKAGE/HYDROSTATIC TESTING AND SCRAM TIME TESTING TECHNICAL
SPECIFICATION CHANGES, NINE MILE POINT NUCLEAR STATION UNIT NO. 1
(TAC NO. M96907)

Dear Mr. Sylvia:

The NRC staff is reviewing your submittal of September 26, 1996, regarding the proposed technical specification change to various surveillances performed during a refueling outage. We find that additional information is necessary to complete our review.

Your response to the enclosure is requested as soon as possible to support your current outage schedule. If you have questions regarding the enclosure or are unable to meet the requested response date, please call me at (301) 415-3049, or e-mail me at dsh@nrc.gov.

Sincerely,

A handwritten signature in cursive script that reads "Darl S. Hood".

Darl S. Hood, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-220

Enclosure: Request for Additional
Information

cc w/encl: See next page



B. Ralph Sylvia
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit No. 1

cc:

Mr. Richard B. Abbott
Vice President and General Manager -
Nuclear
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Martin J. McCormick, Jr.
Vice President
Nuclear Safety Assessment
and Support
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Paul D. Eddy
State of New York
Department of Public Service
Power Division, System Operations
3 Empire State Plaza
Albany, NY 12223

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Ms. Denise J. Wolniak
Manager Licensing
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Mr. Kim A. Dahlberg
General Manager - Projects
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093


Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

Mr. Norman L. Rademacher
Plant Manager, Unit 1
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 126
Lycoming, NY 13093



REQUEST FOR ADDITIONAL INFORMATION
REGARDING TECHNICAL SPECIFICATION AMENDMENTS
NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION UNIT NO. 1
OPERATING LICENSE NUMBER DPR-63
DOCKET NO. 50-220

1. Pages 164, 165, 168, 170, and 174 add hot shutdown to the list of plant modes for which the respective secondary containment LCO is required. Is the addition of the hot shutdown condition a change to the plant design bases, as the secondary containment LCO's (3.4.1 through 3.4.4) will now be applicable during the hot shutdown mode? This change appears to go beyond requiring the secondary containment LCO's for TS 3.7.2 only. Do these changes represent a change to the plant design bases? Also, comment on whether note (a) on page 246 may be similarly affected.
2. Special Test Exception 3.7.2 provides a number of additional requirements involving LCOs in 3.4.1, 3.4.2, 3.4.3, 3.4.4 and 3.4.5. However, proposed TS 3.7.2 does not mention the individual action statements in 3.4.1 through 3.4.5. Confirm that if individual LCOs in 3.4.1 through 3.4.5 cannot be met, then the 3.7.2 action statement will be enforced, requiring the plant to immediately abort system leakage or hydrostatic testing and scram time testing activities and reduce the average reactor coolant temperature to $\leq 212^{\circ}\text{F}$ within 10 hours.
3. LCO 3.4.2.a, "Reactor Building Integrity - Isolation Valves" specifies ventilation system valves only. Are there other valves that are used to ensure reactor building integrity which are not ventilation system valves? If so, how are they covered during 3.7.2 operations?
4. LCO 3.4.4.a, "Emergency Ventilation System" is included under proposed LCO 3.7.2. However, parts b, c and d are not included. Will these sections of LCO 3.4.4 also be in effect during operation under LCO 3.7.2? If not, justify.
5. LCO 3.4.5.a, "Control Room Air Treatment System" is included under proposed LCO 3.7.2. However, parts b, c and d are not included. Will these sections of LCO 3.4.5 also be in effect during operation under LCO 3.7.2? If not, justify.
6. Confirm that all surveillance requirements for TS 3.4.1 through 3.4.5 and for tables 3.6.2j and 3.6.2l will be in effect during TS 3.7.2 operation.
7. From table 3.6.2j, will the High Radiation Refueling Platform LCO be applicable during 3.7.2 operation?
8. Which systems normally are used for shutdown cooling? Will any TS LCO's be bypassed due to isolation of shutdown cooling during the hydrostatic test?

Enclosure

