December 16

LICENSEE: Niagara Mohawk Power Corporation

FACILITY: Nine Mile Point Nuclear Station, Unit No. 2

SUBJECT: SUMMARY OF TELEPHONE CONVERSATION OF DECEMBER 11, 1997, REQUESTING ADDITIONAL INFORMATION ON PROPOSED INSTALLATION OF NUCLEAR MEASUREMENT ANALYSIS AND CONTROL POWER RANGE NEUTRON MONITOR SYSTEM (TAC NO. MA0150)

On December 11, 1997, I called Ms. L. Otman of Niagara Mohawk Power Corporation (NMPC) and stated that the NRC staff needed additional information to complete the review of the application for amendment, dated October 31, 1997, for Nine Mile Point, Unit 2. Under the proposed amendment, NMPC would install the General Electric Nuclear Measurement Analysis and Control power range neutron monitor system, consistent with NMPC's response to Generic Letter 94-02, "Long-Term Solutions and Upgrade of Interim Operating Recommendations for Thermal-Hydraulic Instabilities in Boiling Water Reactors."

Accordingly, I faxed the enclosure to Ms. Otman, who subsequently acknowledged receiving it.

Sincerely,

Original Signed by:

Darl S. Hood, Senior Project Manager Project Directorate I-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosures: Request for Additional Information

cc w/encls: See next page

DISTRIBUTION:


S. Little
D. Hood
OGC
ACRS
C. Hehl, Region I

MBC FUE CEMMER FOR

DOCUMENT NAME:G:\NMP2\MA0150.RAI

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	E LA:PDI-	D:PDI-1	ei		
NAME	DHood DS/+	SLittle	SBajwa X Ka	1		
DATE	12//6/97	12/10/97	× 12//6/97			
			Official Record Copy			
9 P P	712310013 971 DR ADUCK 050	216 000410 PDR			1	
	6			1		4




3 **c %**

o

4 .

•



.

×





UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 16, 1997

LICENSEE: Niagara Mohawk Power Corporation

FACILITY: Nine Mile Point Nuclear Station, Unit No. 2

SUBJECT: SUMMARY OF TELEPHONE CONVERSATION OF DECEMBER 11, 1997, REQUESTING ADDITIONAL INFORMATION ON PROPOSED INSTALLATION OF NUCLEAR MEASUREMENT ANALYSIS AND CONTROL POWER RANGE NEUTRON MONITOR SYSTEM (TAC NO. MA0150)

On December 11, 1997, I called Ms. L. Otman of Niagara Mohawk Power Corporation (NMPC) and stated that the NRC staff needed additional information to complete the review of the application for amendment, dated October 31, 1997, for Nine Mile Point, Unit 2. Under the proposed amendment, NMPC would install the General Electric Nuclear Measurement Analysis and Control power range neutron monitor system, consistent with NMPC's response to Generic Letter 94-02, "Long-Term Solutions and Upgrade of Interim Operating Recommendations for Thermal-Hydraulic Instabilities in Boiling Water Reactors."

Accordingly, I faxed the enclosure to Ms. Otman, who subsequently acknowledged receiving it.

Sincerely,

Darl & Hord

Darl S. Hood, Senior Project Manager Project Directorate I-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosure: Request for Additional Information

cc w/encl: See next page

· · ·

, ,

. ۰. ۲۰ ۲

> н Полония Пол .

. .

B. Ralph Sylvia Niagara Mohawk Power Corporation

CC:

Mr. Richard B. Abbott Vice President and General Manager Nuclear Niagara Mohawk Power Corporation Nine Mile Point Nuclear Station P.O. Box 63 Lycoming, NY 13093

Mr. Carl D. Terry Vice President Nuclear Safety Assessment and Support Niagara Mohawk Power Corporation P.O. Box 63 Lycoming, NY 13093

Ms. Denise J. Wolniak Manager Licensing Niagara Mohawk Power Corporation Nine Mile Point Nuclear Station P.O. Box 63 Lycoming, NY 13093

Mr. Kim A. Dahlberg Vice President-Nuclear Operations Acting Unit 2 Plant Manager Nine Mile Point Nuclear Station P.O. Box 63 Lycoming, NY 13093

Mr. John T. Conway Vice President-Nuclear Engineering Nine Mile Point Nuclear Station Niagara Mohawk Power Corporation P.O. Box 63 Lycoming, NY 13093

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Resident Inspector Nine Mile Point Nuclear Station P.O. Box 126 Lycoming, NY 13093 Nine Mile Point Nuclear Station Unit No. 2

Charles Donaldson, Esquire Assistant Attorney General New York Department of Law 120 Broadway New York, NY 10271

Mr. Richard M. Kessel Chair and Executive Director State Consumer Protection Board 99 Washington Avenue Albany, NY 12210

Mark J. Wetterhahn, Esquire Winston & Strawn 1400 L Street, NW. Washington, DC 20005-3502

Gary D. Wilson, Esquire Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, NY 13202

Mr. F. William Valentino, President New York State Energy, Research, and Development Authority Corporate Plaza West 286 Washington Avenue Extension Albany, NY 12203-6399

Supervisor Town of Scriba Route 8, Box 382 Oswego, NY 13126

Mr. Richard Goldsmith Syracuse University College of Law E. I. White Hall Campus Syracuse, NY 12223

Mr. John V. Vinquist, MATS Inc. P.O. Box 63 Lycoming, NY 13093

. . • • • . . . • • . · · · · · .

-

B. Ralph Sylvia Niagara Mohawk Power Corporation

cc:

Mr. Jim Rettberg New York State Electric & Gas Corporation Corporate Drive Kirkwood Industrial Park P.O. Box 5224 Binghamton, NY 13902-5224 Nine Mile Point Nuclear Station Unit No. 2

• . • • •

•

· · ·

N , .

•

REQUEST FOR ADDITIONAL INFORMATION

The following questions address the General Electric (GE) Nuclear Measurement Analysis and Control Power Range Neutron Monitor (NUMAC-PRNM) system upgrade in Nine Mile Point Unit 2:

References:

۰. ...

- 1. "Application for Amendment to Nine Mile Point Unit 2 (NMP2) Operating License NPF-69," Niagara Mohawk Power Corporation, October 31, 1997.
- 2. "Nuclear Measurement Analysis and Control Power Range Neutron Monitor (NUMAC-PRNM) Retrofit Plus Option III Stability Trip Function," NEDC-32410P-A, October 1995.

Request 1: Indicate the specific period for operating the OPRM before activating the OPRM function and implementing the OPRM technical specification changes. For example, NEDC-32410P-A (Ref 2) allows one fuel cycle for testing the OPRM functions before implementing amended OPRM technical specifications.

Devide the fallester device the transformer states and the second states of the second states

Request 2: Provide the following	j design basis environmental conditions for NWP2:	

	NMP2 (Ref 1)	NUMAC-PRNMS (Ref 2)
Temperature	24°C to 32°C (reported) (75°F nominal to 90°F) Design Basis: ?	5°C to 50°C (41°F to 122°F)
Humidity	20% to 50% RH (reported) • Design Basis: ?	10% to 90% RH (noncondensing)
Pressure	14.7 psia (acceptable)	13psia to 16 psia
Radiation	<0.2mRem/hr dose rate (reported) 70 Rem TID (reported) Design Basis: ?	1E-4 Gy(Carbon)/hr dose rate 1E+2 Gy (Carbon) TID

Note: The radiation limits should be expressed in rads/hr or Grays/hr dose rate, and total integrated dose in rads or Grays, instead of units of rem/hr and rem TID.

Enclosure

• • •

.