

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Niagara Mohawk Power Corporation) Docket No. 50-410
)
Nine Mile Point Nuclear Station Unit No. 2)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation (NMPC), holder of Facility Operating License No. NPF-69, hereby requests that Table 3.6.1.2-1 of the Technical Specifications (TS) set forth in Appendix A to that license be amended. The proposed changes have been reviewed in accordance with Section 6.5, "Review and Audit," of the TS.

The proposed changes to the Nine Mile Point Unit 2 (NMP2) TS revise Table 3.6.1.2-1, titled "Allowable Leak Rates Through Valves in Potential Bypass Leakage Paths" by adding two relief valves and associated leak rate criteria to this table. These relief valves will be installed on the drywell equipment and drywell floor drain lines during Refueling Outage No. 7.

The proposed changes will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analyses which demonstrate no significant hazards considerations pursuant to 10CFR50.92 are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By John T. Conway
John T. Conway
Vice President Nuclear Generation

Subscribed and sworn to before me
on this 31 day of March, 1999

Theresa S. Clark
NOTARY PUBLIC

THERESA S. CLARK
NOTARY PUBLIC, STATE OF NEW YORK
OSWEGO COUNTY REG. NO. 0101471068
MY COMMISSION EXPIRES 12/31/2000

9904120217 990331
PDR ADOCK 05000410
P PDR

MY COMMISSION EXPIRES _____
OSWEGO COUNTY REG. NO. 010421108
ROTARY PUBLIC STATE OF NEW YORK
THERESA S. CLARK