

NINE MILE POINT NUCLEAR STATION - UNIT 2
SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY - JUNE 1999

NIAGARA MOHAWK POWER CORPORATION

9909070197 990630
PDR ADOCK 05000410
R PDR



NINE MILE POINT NUCLEAR STATION - UNIT 2
SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

JANUARY - JUNE 1999

SUPPLEMENTAL INFORMATION

Facility: Nine Mile Point Unit #2

Licensee: Niagara Mohawk Power Corporation

1. TECHNICAL SPECIFICATION LIMITS

A) FISSION AND ACTIVATION GASES

1. The dose rate limit of noble gases released in gaseous effluents from the site to areas at or beyond the site boundary shall be less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin.
2. The air dose from noble gases released in gaseous effluents from Nine Mile Point Unit 2 to areas at or beyond the site boundary shall be limited during any calendar quarter to less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and during any calendar year to less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

B&C) TRITIUM, IODINES AND PARTICULATES, HALF LIVES > 8 DAYS

1. The dose rate limit of Iodine-131, Iodine-133, Tritium and all radionuclides in particulate form with half-lives greater than eight days, released in gaseous effluents from the site to areas at or beyond the site boundary shall be less than or equal to 1500 mrem/year to any organ.
2. The dose to a member of the public from Iodine-131, Iodine-133, Tritium and all radionuclides in particulate form with half-lives greater than eight days in gaseous effluents released from Nine Mile Point Unit 2 to areas at or beyond the site boundary shall be limited during any calendar quarter to less than or equal to 7.5 mrem to any organ and, during any calendar year to less than or equal to 15 mrem to any organ.

D) LIQUID EFFLUENTS

1. The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 2E-04 microcurie/ml total activity.
2. The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released from Nine Mile Point Unit 2 to unrestricted areas shall be limited during any calendar quarter to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ, and during any calendar year to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.



2. MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

Described below are the methods used to measure or approximate the total radioactivity and radionuclide composition in effluents.

A) FISSION AND ACTIVATION GASES

Noble gas effluent activity is determined by on-line gamma spectroscopic monitoring (intrinsic germanium crystal) of an isokinetic sample stream.

B) IODINES

Iodine effluent activity is determined by gamma spectroscopic analysis (at least weekly) of charcoal cartridges sampled from an isokinetic sample stream.

C) PARTICULATES

Activity released from the main stack and the combined Radwaste/Reactor Building vent is determined by gamma spectroscopic analysis (at least weekly) of particulate filters sampled from an isokinetic sample stream and composite analysis of the filters for non-gamma emitters.

D) TRITIUM

Tritium effluent activity is measured by liquid scintillation or gas proportional counting of monthly samples taken with an air sparging/water trap apparatus.

E) LIQUID EFFLUENTS

Isotopic contents of liquid effluents are determined by isotopic analysis of a representative sample of each batch and composite analysis of non-gamma emitters.

F) SOLID EFFLUENTS

Isotopic contents of waste shipments are determined by gamma spectroscopy analyses of a representative sample of each batch. Scaling factors established from primary composite sample analyses conducted off-site are applied, where appropriate, to find estimated concentration of non-gamma emitters. For low activity trash shipments, curie content is estimated by dose rate measurement and application of appropriate scaling factors.



**ATTACHMENT 1
Summary Data**

Unit 1 <u> </u> Unit 2 <u>X</u>	Reporting Period <u>January - June 1999</u>	
Liquid Effluents:		
10CFR20, Appendix B, Table II, Column 2		
Average MPC - $\mu\text{Ci/ml}$ (Qtr. 1) = <u>2.94E-03</u>		
Average MPC - $\mu\text{Ci/ml}$ (Qtr. 2) = <u>2.05E-03</u>		
Average Energy (Fission and Activation gases - Mev):		
Qtr. 1	: E_{γ}	= <u>1.29E+00</u> E_{β} = <u>4.64E-01</u>
Qtr. 2	: E_{γ}	= <u>7.98E-01</u> E_{β} = <u>1.01E+00</u>
Liquid: ¹		
Number of batch releases	:	<u>19</u>
Total time period for batch releases (hrs)	:	<u>6.26E+01</u>
Maximum time period for a batch release (hrs)	:	<u>3.35E+00</u>
Average time period for a batch release (hrs)	:	<u>3.29E+00</u>
Minimum time period for a batch release (hrs)	:	<u>3.22E+00</u>
Total volume of water used to dilute the liquid effluent during release period (L)	:	<u>5.56E+07</u> <u>3.55E+08</u>
		<u>1st Qtr</u> <u>2nd Qtr</u>
Total volume of water available to dilute the liquid effluent during reporting period (L)	:	<u>1.16E+10</u> <u>1.34E+10</u>
		<u>1st Qtr</u> <u>2nd Qtr</u>
Gaseous (Emergency Condenser Vent): Not Applicable for Unit 2		
Number of batch releases	:	<u>N/A</u>
Total time period for batch releases (hrs)	:	<u>N/A</u>
Maximum time period for a batch release (hrs)	:	<u>N/A</u>
Average time period for a batch release (hrs)	:	<u>N/A</u>
Minimum time period for a batch release (hrs)	:	<u>N/A</u>
Gaseous (Primary Containment Purge):		
Number of batch releases	:	<u>6</u>
Total time period for batch releases (hrs)	:	<u>3.28E+01</u>
Maximum time period for a batch release (hrs)	:	<u>1.46E+01</u>
Average time period for a batch release (hrs)	:	<u>5.46E+00</u>
Minimum time period for a batch release (hrs)	:	<u>2.00E-01</u>



ATTACHMENT 1
Summary Data

Unit 1 <u> </u> Unit 2 <u>X</u>	Reporting Period <u>January - June 1999</u>
Abnormal Releases: There were no abnormal releases during the reporting period.	
A. Liquids:	
Number of releases	<u>0</u>
Total activity released	<u>N/A</u> Ci
B. Gaseous:	
Number of releases	<u>0</u>
Total activity released	<u>N/A</u> Ci



ATTACHMENT 2

Unit 1 <input type="checkbox"/> Unit 2 <input checked="" type="checkbox"/>		Reporting Period <u>January - June 1999</u>			
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES, ELEVATED AND GROUND LEVEL					
		<u>1st</u> <u>QUARTER</u>	<u>2nd</u> <u>QUARTER</u>	<u>EST. TOTAL</u> <u>ERROR, %</u>	
A.	<u>Fission & Activation gases</u>				
	1. Total release	Ci	<u>8.79E-02</u>	<u>1.15E+01</u>	5.00E+01
	2. Average release rate	μ Ci/sec	<u>1.13E-02</u>	<u>1.46E+00</u>	
B.	<u>Iodines</u>				
	1. Total Iodine-131	Ci	<u>9.83E-06</u>	<u>1.40E-04</u>	3.00E+01
	2. Average release rate for period	μ Ci/sec	<u>1.25E-06</u>	<u>1.78E-05</u>	
C.	<u>Particulates¹</u>				
	1. Particulates with half-lives >8 days	Ci	<u>4.79E-05</u>	<u>2.81E-04</u>	3.00E+01
	2. Average release rate for period	μ Ci/sec	<u>6.09E-06</u>	<u>3.58E-05</u>	
	3. Gross alpha radioactivity	Ci	<u>1.65E-05</u>	<u>3.01E-05</u>	2.50E+01
D.	<u>Tritium¹</u>				
	1. Total release	Ci	<u>4.40E+00</u>	<u>4.95E+00</u>	5.00E+01
	2. Average release rate for period	μ Ci/sec	<u>5.59E-01</u>	<u>6.29E-01</u>	
E.	<u>Percent of Tech. Spec. Limits</u>				
	<u>Fission and Activation Gases</u>				
	Percent of Quarterly Gamma Air Dose Limit (5 mrad)	%	<u>2.80E-04</u>	<u>2.12E-02</u>	
	Percent of Quarterly Beta Air Dose Limit (10 mrad)	%	<u>4.11E-06</u>	<u>1.28E-03</u>	
	Percent of Annual Gamma Air Dose Limit to Date (10 mrad)	%	<u>1.40E-04</u>	<u>1.08E-02</u>	
	Percent of Annual Beta Air Dose Limit to Date (20 mrad)	%	<u>2.06E-06</u>	<u>6.41E-04</u>	
	Percent of Whole Body Dose Rate Limit (500 mrem/yr)	%	<u>1.09E-05</u>	<u>8.20E-04</u>	
	Percent of Skin Dose Rate Limit (3000 mrem/yr)	%	<u>2.13E-06</u>	<u>1.74E-04</u>	
	<u>Tritium, Iodines, and Particulates¹</u> <u>(with half-lives greater than 8 days)</u>				
	Percent of Quarterly Dose Limit (7.5 mrem)	%	<u>3.53E-03</u>	<u>3.68E-02</u>	
Percent of Annual Dose Limit (15 mrem)	%	<u>1.78E-03</u>	<u>2.02E-02</u>		
Percent of Organ Dose Rate Limit (1500 mrem/yr)	%	<u>7.11E-05</u>	<u>7.40E-04</u>		

¹ Tritium, Iron-55 and Strontium 89 and 90 results for the second quarter were not received from the off-site vendor at the time of this report. These numbers include estimates. Actual numbers will be provided in the next Semi-Annual Report.



ATTACHMENT 3

Unit 1 <input type="checkbox"/> Unit 2 <input checked="" type="checkbox"/>		Reporting Period <u>January - June 1999</u>	
GASEOUS EFFLUENTS - ELEVATED RELEASE			
CONTINUOUS MODE ³			
Nuclides Released		1 st QUARTER	2 nd QUARTER
1. Fission Gases¹			
Argon-41	CI	<u>8.79E-02</u>	<u>1.19E-02</u>
Krypton-85	CI	**	**
Krypton-85m	CI	**	**
Krypton-87	CI	**	<u>2.16E-01</u>
Krypton-88	CI	**	<u>1.82E+00</u>
Xenon-127	CI	**	**
Xenon-133	CI	**	**
Xenon-133m	CI	**	**
Xenon-135	CI	**	<u>1.73E-01</u>
Xenon-135m	CI	**	<u>7.05E-01</u>
Xenon-137	CI	**	<u>5.09E+00</u>
Xenon-138	CI	**	<u>3.47E+00</u>
2. Iodines¹			
Iodine-131	CI	<u>9.83E-06</u>	<u>1.40E-04</u>
Iodine-133	CI	<u>1.04E-04</u>	<u>1.21E-03</u>
Iodine-135	CI	**	**
3. Particulates^{1,2}			
Strontium-89	CI	**	<u>1.73E-05</u>
Strontium-90	CI	**	<u>4.57E-07</u>
Cesium-134	CI	**	<u>4.14E-05</u>
Cesium-137	CI	**	**
Cobalt-60	CI	**	**
Cobalt-58	CI	**	**
Manganese-54	CI	**	**
Barium-Lanthanum-140	CI	**	**
Antimony-125	CI	**	**
Niobium-95	CI	**	**
Cerium-141	CI	**	**
Cerium-144	CI	**	**
Iron-59	CI	**	**
Cesium-136	CI	**	**
Chromium-51	CI	**	**
Zinc-65	CI	**	<u>3.77E-05</u>
Iron-55	CI	**	<u>7.05E-06</u>
Molybdenum-99	CI	**	**
4. Tritium²	CI	<u>3.43E+00</u>	<u>3.99E+00</u>

¹ Concentrations less than the lower limit of detection of the counting system used are indicated with a double asterisk. A lower limit of detection of 1.00E-04 µCi/ml for required noble gases, 1.00E-11 µCi/ml for required particulates, 1.00E-12 µCi/ml for required Iodines, and 1.00E-06 µCi/ml for Tritium, as required by Technical Specifications, has been verified.

² Tritium, Iron-55 and Strontium 89 and 90 results for the first and second quarters were not received from the off-site vendor at the time of this report. These numbers include estimates. Actual numbers will be included in the next Semi-Annual Report.

³ Contributions from purges are included.



ATTACHMENT 4

Unit 1 Unit 2 X

Reporting Period January - June 1999

GASEOUS EFFLUENTS - GROUND LEVEL RELEASES

		CONTINUOUS MODE		BATCH MODE There were no batch Releases during the Reporting period.	
		1 st QUARTER	2 nd QUARTER	1 st QUARTER	2 nd QUARTER
1.	<u>Fission Gases</u> ¹				
	Argon-41	Ci **	**		
	Krypton-85	Ci **	**		
	Krypton-85m	Ci **	**		
	Krypton-87	Ci **	**		
	Krypton-88	Ci **	**		
	Xenon-133	Ci **	**		
	Xenon-133m	Ci **	**		
	Xenon-135	Ci **	**		
	Xenon-135m	Ci **	**		
	Xenon-137	Ci **	**		
	Xenon-138	Ci **	**		
	Xenon-127	Ci **	**		
2.	<u>Iodines</u> ¹				
	Iodine-131	Ci **	**		
	Iodine-133	Ci **	**		
	Iodine-135	Ci **	**		
3.	<u>Particulates</u> ^{1,2}				
	Strontium-89	Ci **	7.68E-06		
	Strontium-90	Ci **	1.05E-06		
	Cesium-134	Ci **	**		
	Cesium-137	Ci **	**		
	Cobalt-60	Ci 1.12E-05	3.07E-05		
	Cobalt-58	Ci **	**		
	Manganese-54	Ci 7.94E-06	5.04E-05		
	Barium-Lanthanum-140	Ci **	**		
	Antimony-125	Ci **	**		
	Niobium-95	Ci **	**		
	Cerium-141	Ci **	**		
	Cerium-144	Ci **	**		
	Iron-59	Ci **	**		
	Cesium-136	Ci **	**		
	Chromium-51	Ci **	**		
	Zinc-65	Ci **	4.72E-05		
	Iron-55	Ci 2.87E-05	4.05E-05		
	Molybdenum-99	Ci **	**		
	Silver-110m	Ci **	**		
4.	<u>Tritium</u> ²	Ci 9.68E-01	9.52E-01		

¹ Concentrations less than the lower limit of detection of the counting system used are indicated with a double asterisk. A lower limit of detection of 1.00E-04 µCi/ml for required noble gases, 1.00E-11 µCi/ml for required particulates, 1.00E-12 µCi/ml for required Iodines, and 1.00E-06 µCi/ml for Tritium, as required by Technical Specifications, has been verified.

² Tritium, Iron-55 and Strontium 89 and 90 results for the first and second quarters were not received from the off-site vendor at the time of this report. These numbers include estimates, and actual numbers will be included in the next Semi-Annual Report.



Unit 1 Unit 2 Reporting Period January - June 1999

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

		<u>1st</u> <u>QUARTER</u>	<u>2nd</u> <u>QUARTER</u>	<u>EST.</u> <u>TOTAL</u> <u>ERROR,</u> <u>%</u>	
A.	<u>Fission & Activation Products</u> ¹				
	1. Total release (not including Tritium, gases, alpha)	Ci	<u>4.25E-04</u>	<u>3.20E-02</u>	5.00E+01
	2. Average diluted concentration during reporting period	$\mu\text{Ci/ml}$	<u>3.66E-11</u>	<u>2.39E-09</u>	
B.	<u>Tritium</u> ¹				
	1. Total release	Ci	<u>9.36E-01</u>	<u>2.93E+00</u>	5.00E+01
	2. Average diluted concentration during reporting period	$\mu\text{Ci/ml}$	<u>8.10E-08</u>	<u>2.19E-07</u>	
C.	<u>Dissolved and Entrained Gases</u> ³				
	1. Total release	Ci	<u>**</u>	<u>**</u>	5.00E+01
	2. Average diluted concentration during reporting period	$\mu\text{Ci/ml}$	<u>**</u>	<u>**</u>	
D.	<u>Gross Alpha Radioactivity</u> ³				
	1. Total release	Ci	<u>**</u>	<u>1.16E-05</u>	5.00E+01
E.	<u>Volumes</u>				
	1. Prior to dilution	Liters	<u>3.60E+05</u>	<u>1.35E+06</u>	1.00E+01
	2. Volume of dilution water used during release period	Liters	<u>5.56E+07</u>	<u>3.55E+08</u>	5.00E+01
	3. Volume of dilution water available during reporting period	Liters	<u>1.16E+10</u>	<u>1.34E+10</u>	5.00E+01
F.	<u>Percent of Technical Specification Limits</u>				
	Percent of Quarterly Whole Body Dose Limit (1.5 mrem)	%	<u>3.22E-02</u>	<u>6.02E-01</u>	
	Percent of Quarterly Organ Dose Limit (5 mrem)	%	<u>1.96E-02</u>	<u>3.77E-01</u>	
	Percent of Annual Whole Body Dose Limit to Date (3 mrem)	%	<u>1.61E-02</u>	<u>3.18E-01</u>	
	Percent of Annual Organ Dose Limit to Date (10 mrem)	%	<u>9.78E-03</u>	<u>1.99E-01</u>	
	Percent of 10CFR20 Concentration Limit ²	%	<u>2.75E-03</u>	<u>1.08E-02</u>	
	Percent of Dissolved or Entrained Noble Gas Limit (2.00E-04 $\mu\text{Ci/ml}$)	%	<u>**</u>	<u>**</u>	

¹ Iron-55, Strontium 89 and 90 and Tritium results for the second quarter were not received from the off-site vendor at the time of this report. These numbers include estimates, and actual numbers will be included in the next Semi-Annual Report.

² The percent of 10CFR20 concentration limit is based on the average concentration during the quarter.

³ Concentrations less than the lower limit of detection of the counting system used are indicated with a double asterisk. A lower limit of detection of 5.00E-07 $\mu\text{Ci/ml}$ for required gamma emitting nuclides, 1.00E-05 $\mu\text{Ci/ml}$ for required dissolved and entrained noble gases and Tritium, 5.00E-08 $\mu\text{Ci/ml}$ for Sr-89/90, 1.00E-06 $\mu\text{Ci/ml}$ for Fe-55 and 1.00E-07 $\mu\text{Ci/ml}$ for gross alpha radioactivity, as required by Technical Specifications, has been verified.



Unit 1 <u> </u> Unit 2 <u>X</u>		Reporting Period <u>January - June 1999</u>	
LIQUID EFFLUENTS RELEASED			
BATCH MODE ³			
Nuclides Released ^{1,2}		<u>1st</u> <u>QUARTER</u>	<u>2nd</u> <u>QUARTER</u>
Strontium-89	CI	**	<u>6.75E-06</u>
Strontium-90	CI	**	<u>1.89E-06</u>
Cesium-134	CI	**	**
Cesium-137	CI	**	**
Iodine-131	CI	**	**
Cobalt-58	CI	**	<u>2.93E-04</u>
Cobalt-60	CI	<u>7.75E-05</u>	<u>6.01E-03</u>
Iron-59	CI	**	<u>2.53E-03</u>
Zinc-65	CI	<u>3.23E-04</u>	<u>1.16E-02</u>
Manganese-54	CI	<u>2.43E-05</u>	<u>8.08E-03</u>
Chromium-51	CI	**	<u>2.53E-03</u>
Zirconium-Niobium-95	CI	**	**
Molybdenum-99	CI	**	**
Technetium-99m	CI	**	**
Barium-Lanthanum-140	CI	**	**
Cerium-141	CI	**	**
Tungsten-187	CI	**	**
Arsenic-76	CI	**	**
Iodine-133	CI	**	**
Iron-55	CI	**	<u>7.20E-04</u>
Neptunium-239	CI	**	**
Praseodymium-144	CI	**	**
Iodine-135	CI	**	**
Silver-110m	CI	**	<u>2.78E-04</u>
Dissolved or Entrained Gases	CI	**	**
Tritium ²	CI	<u>9.36E-01</u>	<u>2.93E+00</u>

¹ Concentrations less than the lower limit of detection of the counting system used are indicated with a double asterisk. A lower limit of detection of 5.00E-07 $\mu\text{Ci/ml}$ for required gamma emitting nuclides, 1.00E-05 $\mu\text{Ci/ml}$ for required dissolved and entrained noble gases and Tritium, 5.00E-08 $\mu\text{Ci/ml}$ for Sr-89/90, 1.00E-06 $\mu\text{Ci/ml}$ for Fe-55 and 1.00E-07 $\mu\text{Ci/ml}$ for gross alpha radioactivity, as required by Technical Specifications, has been verified.

² Iron-55, Strontium 89 and 90 and Tritium results for the second quarter were not received from the off-site vendor at the time of this report. These numbers include estimates, and actual numbers will be included in the next Semi-Annual Report.

³ No continuous mode releases occurred during the reporting period.



Unit 1 Unit 2

Reporting Period January - June 1999

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS:

A.1 TYPE	Volume (m ³)			Activity ¹ (Ci)		
	Class			Class		
	A	B	C	A	B	C
1. Spent Resin Spent Bead Resin (Dewatered)	2.77E+01	0	0	1.43E+01	0	0
Filter Sludge	0	0	0	0	0	0
Concentrated Waste Evaporator Bottoms	0	0	0	0	0	0
Total	2.77E+01	0	0	1.43E+01	0	0
2. Dry Compressible Waste	6.80E+01	0	0	6.42E-02	0	0
3. Irradiated Components	0	0	0	0	0	0
4. Other: Waste Oil/EHC	2.04E+02	0	0	3.82E-03	0	0

¹ The estimated total error is 5.00E+01%.



Unit 1 <input type="checkbox"/> Unit 2 <input checked="" type="checkbox"/>		Reporting Period <u>January - June 1999</u>	
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS			
A.1 TYPE	Container	Package	Solidification Agent
1. Spent Resin Spent Bead Resin (Dewatered)	<u>Poly HIC</u>	<u>STP</u>	<u>None</u>
Filter Sludge	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Concentrated Waste	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
2. Dry Compressible Waste (Compactible Trash)	<u>Metal Box</u>	<u>STP</u>	<u>None</u>
3. Irradiated Components	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
4. Other: Waste Oil/EHC	<u>Metal Box</u>	<u>STP</u>	<u>None</u>



Unit 1 Unit 2

Reporting Period January - June 1999

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A.2 ESTIMATE OF MAJOR NUCLIDE COMPOSITION (BY TYPE OF WASTE)

a. Spent Resins, Filter Sludges, Concentrated Waste:

<u>Nuclide</u>	<u>Percent</u>
(1) Zn-65	7.94E+01
(2) Co-60	1.31E+01
(3) Mn-54	3.92E+00
(4) Other	3.58E+00

b. Dry Compressible Waste:

<u>Nuclide</u>	<u>Percent</u>
(1) Zn-65	4.44E+01
(2) Co-60	3.45E+01
(3) Mn-54	1.55E+01
(4) Fe-55	3.16E+00
(5) Cr-51	1.45E+00
(6) Other	9.90E-01

c. Irradiated Components: There were no shipments.

<u>Nuclide</u>	<u>Percent</u>

d. Other: Waste Oil/EHC

<u>Nuclide</u>	<u>Percent</u>
(1) Cs-137	5.37E+01
(2) Co-60	4.29E+01
(3) Mn-54	1.86E+00
(4) Zn-65	1.46E+00
(5) Other	8.00E-02



Unit 1 Unit 2

Reporting Period January - June 1999

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A.3. SOLID WASTE DISPOSITION

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
<u>5</u>	<u>Truck</u>	<u>Chem-Nuclear Barnwell, SC</u>
<u>1</u>	<u>Truck</u>	<u>GTS Duratek Oak Ridge, TN</u>
<u>3</u>	<u>Truck</u>	<u>ATG Richland Richland, VA</u>

B. IRRADIATED FUEL SHIPMENTS (DISPOSITION): There were no shipments.

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
<u>0</u>	<u>N/A</u>	<u>N/A</u>



Unit 1 Unit 2 X

Reporting Period January - June 1999

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

C. **SOLID WASTE SHIPPED OFF-SITE TO VENDORS FOR PROCESSING AND SUBSEQUENT BURIAL**
 Below is a summary of NMP-2 radwaste buried by vendor facilities during January - June 1999. These totals were reported separately from "10CFR61 Solid Waste Shipped for Burial" since (a) waste classification and burial was performed by the vendors, and (b) Technical Specification 6.9.1 requires reporting of "information for each class of solid waste (as defined by 10CFR61) shipped off-site during the reporting period." The following data represents the actual shipments made from the off-site vendors of our radwaste (e.g., non-compacted trash, dry non-compressible waste) that was processed and commingled prior to burial.

C.1.	TYPE OF WASTE - noncompacted trash and/or dry non-compressible waste, spent resins, non-combustible components processed by vendor facilities prior to burial.	Burial Volume (m ³) <u>9.51E+00</u>	Activity (Ci) <u>3.03E+01</u>	Est. Total Error, % <u>5.00E+01</u>
------	--	---	-------------------------------------	---

C.2. ESTIMATE OF MAJOR NUCLIDE COMPOSITION

Nuclide	Percent
(1) Zn-65	<u>4.41E+01</u>
(2) Co-60	<u>3.42E+01</u>
(3) Mn-54	<u>1.56E+01</u>
(4) Fe-55	<u>3.21E+00</u>
(5) Cr-51	<u>1.54E+00</u>
(6) Other	<u>1.35E+00</u>

C.3. SOLID WASTE DISPOSITION

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
<u>11</u>	<u>Truck</u>	<u>Barnwell, SC</u>
<u>16</u>	<u>Truck</u>	<u>Clive, UT</u>



Unit 1 Unit 2

Reporting Period January - June 1999

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

D. SEWAGE WASTES SHIPPED TO A TREATMENT FACILITY FOR PROCESSING AND BURIAL

There were no shipments of sewage sludge with detectable quantities of plant-related nuclides from NMP to the treatment facility during the reporting period.



ATTACHMENT 7

Unit 1 Unit 2

Reporting Period January - June 1999

SUMMARY OF CHANGES TO THE OFF-SITE DOSE CALCULATION MANUAL

The Unit 2 Off-Site Dose Calculation Manual (ODCM) was revised during the reporting period to support Technical Specification Amendment #85. The ODCM changes will not reduce the accuracy or reliability of the dose calculations or setpoint determinations in accordance with Technical Specifications. A copy of the ODCM, revision 15 is attached and a summary of the changes presented to and approved by the Station Operations Review Committee in February and June 1999 is provided below. The summary also includes the justification for the changes.

Old Page #	New Page #	Section #	Change	Reason for Change
I	i	Table of Contents	To remove Meteorological Monitoring	Part I contents are for information only.
III	III	Table of Contents	Instrumentation pages from Part I,	This relocation supports Technical Specification Amendment #85. This is an administrative change.
I 3/4 3-74	I 3/4 3-74	3.3.7.3	Radiological Controls, and note in the	
I 3/4 3-75	I 3/4 3-75	Table 3.3.7.3-1	Table of Contents that the	
I 3/4 3-76	I 3/4 3-76	Table 4.3.7.3-1	Meteorological Monitoring	
IB 3/4 3-5	IB 3/4 3-5	Bases 3/4.3.7.3	Instrumentation requirements have	
ix	ix	List of Tables	been relocated from Technical	
xi	xi	Introduction	Specifications to the USAR in accordance with the Technical Specification Amendment #85.	



ATTACHMENT 8

Unit 1 Unit 2

Reporting Period January - June 1999

SUMMARY OF CHANGES TO THE PROCESS CONTROL PROGRAM

There were no changes to the Unit 2 Process Control Program during the reporting period.



ATTACHMENT 9

Unit 1 Unit 2

Reporting Period January - June 1999

SUMMARY OF INOPERABLE MONITORS

There were no inoperable monitors for a period greater than 30 days during the reporting period.



ATTACHMENT 10

Update of Actual Data for the Fourth Quarter 1998



UPDATE OF RELEASE AND DOSE DATA FOR GASEOUS (ELEVATED AND GROUND LEVEL) AND LIQUID EFFLUENTS

Update of data using actual results from the off-site vendors for Strontium, Tritium, and Iron-55 for the fourth quarter 1998.

Nuclide ¹	GASEOUS 4 th QUARTER 1998		LIQUID 4 th QUARTER 1998	
	Activity (Ci)		Activity (Ci)	
Sr-89	<u>2.48E-05</u>		<u>**</u>	
Sr-90	<u>**</u>		<u>**</u>	
H-3	<u>3.71E+00</u>		<u>1.71E+00</u>	
Fe-55	<u>4.66E-05</u>		<u>2.30E-04</u>	
<u>Particulates</u>	1. Particulates with half-lives >8 days	Ci	<u>2.52E-04</u>	<u>9.39E-03</u>
	2. Average release rate (gaseous) or diluted concentration (liquid) for reporting period	μCi/sec (gaseous) μCi/ml (liquid)	<u>3.22E-05</u>	<u>6.81E-10</u>
<u>Tritium</u>	1. Total release	Ci	<u>3.71E+00</u>	<u>1.71E+00</u>
	2. Average release rate for period (gaseous) or diluted concentration (liquids) for the reporting period	μCi/sec (gaseous) μCi/ml (liquid)	<u>4.73E-01</u>	<u>1.24E-07</u>
<u>Tritium, Iodines, and Particulates (with half-lives greater than 8 days)¹</u>	1. Percent of Quarterly ² Dose Limit	%	<u>3.85E-03</u> (Quarterly)	<u>1.16E-01</u> (Quarterly)
	2. Percent of Annual ² Dose Limit to Date	%	<u>1.44E-02</u> (Annual)	<u>1.13E+00</u> (Annual)
	3. Percent of Organ - Dose Rate Limit (Gaseous) (Quarterly) - Dose Limit (Liquid) (Quarterly & Annual)	%	<u>7.78E-05</u> (Quarterly) N/A (Annual)	<u>1.01E-01</u> (Quarterly) <u>7.17E-01</u> (Annual)
	4. Percent of 10CFR20 ³ Concentration Limit (Liquid)	%	N/A	<u>5.11E-03</u>
	5. Percent of Dissolved or Entrained Noble Gas (Liquid)	%	N/A	<u>**</u>

¹ Concentrations less than the lower limit of detection, as required by Technical Specifications are indicated with a double asterisk.
² The dose is to the whole body for liquid effluents and to the maximally exposed organ for gaseous effluents.
³ The percent of the 10CFR20 concentration limit is based on the average concentration during the quarter.



ATTACHMENT 11

Off-Site Dose Calculation Manual, Rev 15

