



Technical Specification 6.9.1.5.b

LR-N17-0050

FEB 28 2017

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington DC 20555-001

Hope Creek Generating Station
Renewed Facility Operating License No. NPF-57
Docket No. 50-354

Subject: Technical Specification 6.9.1.5.b
2016 Annual Report of SRV Challenges

This report is being submitted in accordance with Hope Creek Technical Specification 6.9.1.5.b, which requires the documentation of all challenges to main steam line safety/relief valves (SRVs) be provided on an annual basis.

For 2016, the SRVs were not challenged by any over pressurization events or transients that would have required the valves to respond automatically.

There are no regulatory commitments contained in this letter.

If you have any questions or require additional information, please contact Ms. Alysse K. Ochoa at 856-339-2742.

Sincerely

A handwritten signature in black ink, appearing to read "E. Casulli", written over a white background.

Edward T. Casulli
Plant Manager
Hope Creek Generating Station

ako

cc: Mr. Daniel Dorman, Regional Administrator - NRC Region 1
Ms. Carleen Parker, Project Manager - USNRC
Mr. Justin Hawkins, USNRC Senior Resident Inspector - Hope Creek
Mr. Patrick Mulligan, Manager IV, NJBNE
Mr. Lee Marabella, Corporate Commitment Tracking Coordinator
Mr. Thomas MacEwen, Hope Creek Commitment Tracking Coordinator
