



Rancho Seco
Final Status Survey Summary Report
October 21, 2016
IOSB Storage Cell A-2
Survey Unit F8300173

Prepared By:  Date: 11.21.16
FSS Engineer

Reviewed By:  Date: 11-21-16
Lead FSS Engineer

Approved By:  Date: 11/23/16
Manager, Rancho Seco Assets

FINAL STATUS SURVEY F8300173

Survey Unit:

F8300173, Interim Onsite Storage Building (IOSB) Storage Cell A-2

Survey Unit Description:

Operating History: Designed primarily to store packaged radioactive waste containers safely, protected from the elements, and maintain radiological dose as low as reasonably achievable (ALARA), each storage cell possibly stored media of many types, including filters, resins, contaminated chemicals, DAW, activated reactor components, contaminated plant components and other contaminated items.

Site Characterization: Static measurements were made of the interior surfaces of the storage cell, to confirm the absence or presence of plant-derived radionuclides. Static measurements showed a mean gross activity level of 2,125 dpm/100 cm² and a maximum value of 2,528 dpm/100 cm². Based on the levels of gross activity reported, the area was determined to be a Class 3 area.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in **Table 1** below. The survey unit and measurement locations are depicted on the maps in **Attachment 1**. Static measurement locations were randomly determined and approximately 27% of the area scanned. The instrumentation used for the survey along with the MDC values are listed in **Table 2-1 Attachment 2**.

FINAL STATUS SURVEY F8300173

Table 1, Survey Unit Design Parameters

Evaluation Input Values		Comments
Survey Package:	F830	Storage Cell A-2
Survey Unit:	17	
Class	03	
SU Area (m ²)	28.3	
Evaluator:	JR	
DCGL _w :	43,000	Gross Activity DCGL
Area Factor	N/A	Class 3
Design DCGL _{emc} (dpm/100cm ²):	N/A	Class 3
DCGL _{emc} :	N/A	Class 3
LBGR:	21,500	Default = 50% DCGL
Sigma:	170	Scoping Survey Data
Type I error:	0.05	
Type II error:	0.05	
Predominant Nuclide	Cs-137	
Sample Area (m ²)	N/A	
Total Instrument Efficiency:	0.129	
Total Area Scanned (m ²):	7.51	
Scan Coverage (%)	27%	Class 3
Material Type:	N/A	Choosing 'N/A' sets material background to "0"
Calculated Values		Comments
Z _{1-α} :	1.645	
Z _{1-β} :	1.645	
Sign p:	0.99865	
Calculated Relative Shift:	126.4	
Relative Shift Used:	3.0	Uses 3.0 if Relative Shift >3
N-Value:	11	
N-Value+20%:	14	

FINAL STATUS SURVEY F8300173

Survey Results:

A total of 15 direct measurements were made in F8300173. The results of the static measurements are shown in **Table 2**. All of the static measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Swipe data did not indicate elevated activity levels above the MDA.

Table 2, Static Measurement Results

Number	Sample #	Beta (cpm)	Beta (dpm)
1	F8300173X0001	237	1,837
2	F8300173X0002	303	2,349
3	F8300173X0003	261	2,023
4	F8300173X0004	250	1,938
5	F8300173X0005	251	1,946
6	F8300173X0006	279	2,163
7	F8300173X0007	250	1,938
8	F8300173X0008	237	1,837
9	F8300173X0009	279	2,163
10	F8300173X0010	262	2,031
11	F8300173X0011	261	2,023
12	F8300173X0012	262	2,031
13	F8300173X0013	228	1,767
14	F8300173X0014	291	2,256
15	F8300173X0015	239	1,853

Table 3 contains the statistical summary of the static measurement data for the Storage Cell A-2.

Table 3, Beta Summary Statistics

<i>Beta Static Cell A-2</i>	
Mean	2,010
Median	2,023
Standard Deviation	165
Minimum	1,767
Maximum	2,349
Count	15

FINAL STATUS SURVEY F8300173

Survey Unit Data Assessment:

The survey design required 14 static measurements for the Sign Test. A total of 15 static measurements were collected. The critical value and the results of the Sign Test are presented in **Table 4**. The sample mean and median values were less than the DCGL.

Table 4, Data Assessment Results

Static Data Values		Comments
Number of Samples:	15	
Median:	2,023	
Mean:	2,010	
Static Data Standard Deviation:	165	
Maximum:	2,349	
Sign Test Results		Comments
Adjusted N Value:	14	
S+ Value:	15	
Critical Value:	10	
Criteria Satisfaction		Comments
Sufficient samples collected:	Pass	
Maximum value <DCGL _w :	Pass	
Median value <DCGL _w :	Pass	
Mean value <DCGL _w :	Pass	
Maximum value <DCGL _{emc} :	N/A	
Sign test results:	Pass	
Final Status		Comments
The survey unit passes all conditions:	Pass	

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL, the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 3 survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

FINAL STATUS SURVEY F8300173

Conclusion:

The FSS of this survey unit was properly designed as a Class 3 survey based on the results of the scoping survey. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. All of the static measurements were less than the DCGL. No investigations were required.

The static measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8300173 meets the release criteria of 10CFR20.1402.



Attachment 1

Maps


September 26, 2016

Survey Unit F8300173

A-1	A-2	A-3
B-1	B-2	B-3
Cell Storage		
C-1	C-2	C-3
D-1	D-2	D-3
E-1	E-2	E-3



INTERIM ONSITE STORAGE BUILDING (IOSB)	
Contract No.:	4500091426
Location:	Rancho Seco
Task:	Final Status
Drawing No.:	IOSB Final Status Survey
Description:	Cell A-2 Upper Wall Results
Drawn By:	C Gray
QC'd:	J Reese
Date:	271016
Rev No.:	1
SMUD	
Approved by:	
Approval date:	



Attachment 2

Instrumentation

September 26, 2016

Survey Unit F8300173

Table 2-1. Survey Unit Instrumentation

Measurement Type	Instrument Type	Minimum Detectable Activity ^a	Detector Efficiencies	Calibration Due Date ^b
Beta Static Measurement	Ludlum Model 2350-1 Ludlum Model 44-116 B Detector	Beta – 523 dpm/100 cm ²	12.9%	317899/331973 2/10/17
Swipe Measurements	Ludlum Model 2929 Ludlum Model 44-10-1	Alpha – 25 dpm/100 cm ² Beta – 81 dpm/100 cm ²	36.9% 42.8%	166716/170380 11/3/16

^a Minimum detectable activities for the count rate instrumentation were calculated in accordance with NUREG-1507, "Minimum Detectable Concentrations with Typical Radiation Survey Instruments for Various Contaminants and Field Conditions" (U.S. NRC, 1997).

^b Detectors are required to be calibrated once every 12 months. Calibration due date indicates the date by which the detector must be calibrated again.

cm² = square centimeters

cpm = counts per minute

dpm = disintegrations per minute

Static Measurement MDA

Variables

Beta Survey Type
317899 Detector Number
195 Background count rate (cpm)
1 Count Time (min)
0.130 Efficiency
100 Area of Detector (cm²)

Constants

60 sec/min
2.54 cm/in

Assumptions

Background count time and sample count time are equivalent

Calculate Static MDA

Static MDA = $3 + 4.65(B_r * t)^{0.5} / t * E * A / 100$ (NUREG 1507)

Where: B_r Background Countrate
 t Count Time (min)
 E Efficiency
 A Area of detector (cm²)

Static MDA 523 dpm/100 cm²

Attachment 3

Investigation

September 26, 2016

Survey Unit F8300173


(none required)


Attachment 4

Data Assessment

September 26, 2016

Survey Unit F8300173





IOSB Final Status Survey																																								
	LC1	LC2	LC3	LC4	LC6	LC5		β CPM	β dpm	Date/Time of Count		Sample Comments																												
1	F830	017	3	X	00001	SM	Cell A-2	44	-16	09/07/16	12:56																													
2	F830	017	3	X	00002	SM	Cell A-2	47	-9	09/07/16	12:58																													
3	F830	017	3	X	00003	SM	Cell A-2	56	12	09/07/16	13:00																													
4	F830	017	3	X	00004	SM	Cell A-2	33	-42	09/07/16	13:02																													
5	F830	017	3	X	00005	SM	Cell A-2	44	-16	09/07/16	13:03																													
6	F830	017	3	X	00006	SM	Cell A-2	50	-2	09/07/16	13:05																													
7	F830	017	3	X	00007	SM	Cell A-2	53	5	09/07/16	13:07																													
8	F830	017	3	X	00008	SM	Cell A-2	53	5	09/07/16	13:08																													
9	F830	017	3	X	00009	SM	Cell A-2	50	-2	09/07/16	13:10																													
10	F830	017	3	X	00010	SM	Cell A-2	60	21	09/07/16	13:11																													
11	F830	017	3	X	00011	SM	Cell A-2	53	5	09/07/16	13:12																													
12	F830	017	3	X	00012	SM	Cell A-2	51	0	09/07/16	13:13																													
13	F830	017	3	X	00013	SM	Cell A-2	59	19	09/07/16	13:14																													
14	F830	017	3	X	00014	SM	Cell A-2	49	-4	09/07/16	13:15																													
15	F830	017	3	X	00015	SM	Cell A-2	54	7	09/07/16	13:16																													
Comments								9-7-16																																
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Ludlum 2929 Benchtop Instrument</th> </tr> <tr> <th></th> <th>efficiency</th> <th>bkg rate</th> <th>bkg count time</th> <th>MDA</th> </tr> </thead> <tbody> <tr> <td>2929 S/N: 166716</td> <td rowspan="2">0.369</td> <td>3</td> <td>1</td> <td>24.8</td> </tr> <tr> <td>44-10-1 S/N: 170380</td> <td>cpm</td> <td>min</td> <td>dpm per area</td> </tr> <tr> <td>Cal Due Date: 11/3/2016</td> <td rowspan="2">0.428</td> <td>50.9</td> <td>1</td> <td>80.5</td> </tr> <tr> <td></td> <td>cpm</td> <td>min</td> <td>dpm per area</td> </tr> </tbody> </table>													Ludlum 2929 Benchtop Instrument						efficiency	bkg rate	bkg count time	MDA	2929 S/N: 166716	0.369	3	1	24.8	44-10-1 S/N: 170380	cpm	min	dpm per area	Cal Due Date: 11/3/2016	0.428	50.9	1	80.5		cpm	min	dpm per area
Ludlum 2929 Benchtop Instrument																																								
	efficiency	bkg rate	bkg count time	MDA																																				
2929 S/N: 166716	0.369	3	1	24.8																																				
44-10-1 S/N: 170380		cpm	min	dpm per area																																				
Cal Due Date: 11/3/2016	0.428	50.9	1	80.5																																				
		cpm	min	dpm per area																																				
Tech A Sign/ Date		<i>Alan White</i>		10/13/16																																				
Tech B Sign/ Date		N/A																																						