



Rancho Seco  
Final Status Survey Summary Report  
October 3, 2016  
IOSB ROOF  
Survey Unit F8300153

Prepared By:  Date: 1.12.17

FSS Engineer

Reviewed By:  Date: 1.12.17

Lead FSS Engineer

Approved By:  Date: 1/30/2017

Manager, Rancho Seco Assets

## FINAL STATUS SURVEY F8300153

### Survey Unit:

F8300153, Interim Onsite Storage Building (IOSB) Roof

### Survey Unit Description:

Operating History: The current roof of the IOSB is not the original surface material. The roof surface material has been replaced since construction. The roof is occasionally exposed to high wind conditions and damage has occurred as a result. Additionally, a portion the roof is the closest horizontal surface to the IOSB ventilation stack. However, no records indicating measurable releases of radioactivity had been discovered. In March of 2016, the center section of the roof was replaced following a wind storm that removed most of the original material. The removed material was surveyed as material and equipment in accordance with SMUD's procedures and released for disposal.

Site Characterization: Static measurements were made of the surface of the roof, to confirm the absence or presence of plant-derived radionuclides. Static measurements showed a mean gross beta activity level of 2,496/100 cm<sup>2</sup> and a maximum value of 3,766 dpm/100 cm<sup>2</sup>. Based on the levels of gross activity reported, the area was determined to be a Class 3 area.

### Survey Unit Design Information:

The Survey Unit Design Parameters are presented in **Table 1** below. The survey unit and measurement locations are depicted on the maps in **Attachment 1**. Static measurement locations were randomly determined and approximately 1% of the area scanned. The instrumentation used for the survey along with the MDC values are listed in **Table 2-1 Attachment 2**.

**FINAL STATUS SURVEY F8300153**

**Table 1, Survey Unit Design Parameters**

<b>Evaluation Input Values</b>		<b>Comments</b>
Survey Package:	<b>F830</b>	IOSB Roof
Survey Unit:	<b>015</b>	
Class	<b>3</b>	
SU Area (m <sup>2</sup> )	<b>1735</b>	
Evaluator:	JR	
DCGL <sub>w</sub> :	43,000	Gross Activity DCGL
Area Factor	N/A	Class 3
Design DCGL <sub>emc</sub> (dpm/100cm <sup>2</sup> ):	N/A	Class 3
DCGL <sub>emc</sub> :	N/A	Class 3
LBGR:	21,500	Default = 50% DCGL
Sigma:	707	Scoping Survey Data for Roof
Type I error:	0.05	
Type II error:	0.05	
Predominant Nuclide	Cs-137	
Sample Area (m <sup>2</sup> )	N/A	
Total Instrument Efficiency:	0.129	
Total Area Scanned (m <sup>2</sup> ):	22.85	
Scan Coverage (%)	1%	Class 3
Material Type:	N/A	Choosing 'N/A' sets material background to "0"
<b>Calculated Values</b>		<b>Comments</b>
Z <sub>1-α</sub> :	1.645	
Z <sub>1-β</sub> :	1.645	
Sign p:	0.99865	
Calculated Relative Shift:	30.4	
Relative Shift Used:	3.0	Uses 3.0 if Relative Shift >3
N-Value:	11	
N-Value+20%:	14	

**FINAL STATUS SURVEY F8300153**

**Survey Results:**

A total of 15 direct measurements were made in F8300153. The results of the static measurements are shown in **Table 2**. All of the static measurements were less than the DCGL. The western roof is an asphalt surface versus the membrane surface for the center and eastern roofs. The asphalt portion results in higher activity (locations 1 – 3) than the membrane sections. None of the scan measurements indicated areas of elevated activity.

**Table 2, Static Measurement Results**

Number	Sample #	Beta (cpm)	Beta (dpm)
1	F8300153Z00001	288	2,233
2	F8300153Z00002	302	2,341
3	F8300153Z00003	297	2,302
4	F8300153Z00004	171	1,326
5	F8300153Z00005	171	1,326
6	F8300153Z00006	253	1,961
7	F8300153Z00007	176	1,364
8	F8300153Z00008	171	1,326
9	F8300153Z00009	171	1,326
10	F8300153Z00010	184	1,426
11	F8300153Z00011	169	1,310
12	F8300153Z00012	143	1,109
13	F8300153Z00013	184	1,426
14	F8300153Z00014	162	1,256
15	F8300153Z00015	161	1,248

**Table 3** contains the statistical summary of the static measurement data for the IOSB Roof.

**Table 3, Beta Summary Statistics**

<i>Beta Static IOSB Roof</i>	
Mean	1,552
Median	1,326
Standard Deviation	425
Minimum	1,109
Maximum	2,341
Count	15

**FINAL STATUS SURVEY F8300153**

**Survey Unit Data Assessment:**

The survey design required 14 static measurements for the Sign Test. A total of 15 static measurements were collected. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL.

**Table 4, Data Assessment Results**

<b>Static Data Values</b>		<b>Comments</b>
Number of Samples:	15	
Median:	1,326	
Mean:	1,552	
Static Data Standard Deviation:	425	
Maximum:	2,341	
<b>Sign Test Results</b>		<b>Comments</b>
Adjusted N Value:	14	
S+ Value:	15	
Critical Value:	10	
<b>Criteria Satisfaction</b>		<b>Comments</b>
Sufficient samples collected:	Pass	
Maximum value <DCGL <sub>w</sub> :	Pass	
Median value <DCGL <sub>w</sub> :	Pass	
Mean value <DCGL <sub>w</sub> :	Pass	
Maximum value <DCGL <sub>emc</sub> :	N/A	
Sign test results:	Pass	
<b>Final Status</b>		<b>Comments</b>
The survey unit passes all conditions:	Pass	

**Survey Unit Investigations and Results:**

No investigations were required for either direct or scan measurements and no investigation results are reported.

**ALARA Statement:**

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL, the ALARA criterion has been met.

**Changes in Initial Survey Unit Assumptions:**

The survey unit was designed as a Class 3 survey and the sample results are consistent with that classification. The variability of the survey results was higher than the characterization data used for survey design. However the relative shift exceeded 3 and had to be adjusted. No potential areas of elevated activity were detected.

## FINAL STATUS SURVEY F8300153

### **Conclusion:**

The FSS of this survey unit was properly designed as a Class 3 survey based on the results of the scoping survey. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. All of the static measurements were less than the DCGL. No investigations were required.

The static measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8300153 meets the release criteria of 10CFR20.1402.

**Attachment 1**

**Maps**

**October 3, 2016**

**Survey Unit F8300153**



IO SB ROOF	
Contract No.:	450000114.06
Location:	Rancho Santa
Task:	Scoping Survey
Drawing No.:	IO SB Scoping Survey
Description:	Roof
Drawn By:	C. Gray
QC'd:	J. Rivera
Date:	01/27/17
Rev No.:	
Approved by:	
Approval date:	



**Attachment 2**

**Instrumentation**

**October 3, 2016**

**Survey Unit F8300153**

**Table 2-1. Survey Unit Instrumentation**

Measurement Type	Instrument Type	Minimum Detectable Activity <sup>a</sup>	Detector Efficiencies	Calibration Due Date <sup>b</sup>
Beta Static Measurement	Ludlum Model 2350-1 Ludlum Model 44-116 B Detector	Beta – 512 dpm/100 cm <sup>2</sup>	12.9%	317899/331973 2/10/17

<sup>a</sup> Minimum detectable activities for the count rate instrumentation were calculated in accordance with NUREG-1507, "Minimum Detectable Concentrations with Typical Radiation Survey Instruments for Various Contaminants and Field Conditions" (U.S. NRC, 1997).

<sup>b</sup> Detectors are required to be calibrated once every 12 months. Calibration due date indicates the date by which the detector must be calibrated again.

cm<sup>2</sup> = square centimeters

cpm = counts per minute

dpm = disintegrations per minute

## Static Measurement MDA

### Variables

Beta Survey Type  
PR331973 Detector Number  
184 Background count rate (cpm)  
1 Count Time (min)  
0.129 Efficiency  
100 Area of Detector (cm<sup>2</sup>)

### Constants

60 sec/min  
2.54 cm/in

### Assumptions

Background count time and sample count time are equivalent

### Calculate Static MDA

Static MDA =  $3 + 4.65(B_r * t)^{0.5} / t * E * A / 100$  (NUREG 1507)

Where:  $B_r$  Background Countrate  
 $t$  Count Time (min)  
 $E$  Efficiency  
 $A$  Area of detector (cm<sup>2</sup>)

Static MDA 512 dpm/100 cm<sup>2</sup>

**Attachment 3**  
**Investigation**  
**October 3, 2016**  
**Survey Unit F8300153**

**(none required)**

**Attachment 4**

**Data Assessment**

**October 3, 2016**

**Survey Unit F8300153**

