



Rancho Seco
Final Status Survey Summary Report
January 6, 2017
IOSB DAW Staging Bay Class 2
Survey Unit F8300042

Prepared By:  Date: 1.6.17

FSS Engineer

Reviewed By:  Date: 1.6.17
Lead FSS Engineer

Approved By:  Date: 1/10/17
Manager, Rancho Seco Assets

FINAL STATUS SURVEY F8300042

Survey Unit:

F8300042, Interim Onsite Storage Building (IOSB) DAW Staging Bay Class 2

Survey Unit Description:

Operating History: Designed primarily to store packaged radioactive waste containers safely, protected from the elements, and maintain radiological dose as low as reasonably achievable (ALARA), the IOSB contained and possibly stored media of many types, including filters, resins, contaminated chemicals, DAW, activated reactor components, contaminated plant components and other contaminated items.

Site Characterization: Based upon the scanning results of the DAW Staging Bay two elevated areas were identified on the floor. One of these areas exceeded the $DCGL_w$ but not the $DCGL_{EMC}$. This area required remediation. The other area did not exceed the $DCGL_w$. The DAW Staging bay was divided into a small Class 1 Survey Unit, buffered by a Class 2 Survey Unit.

Survey Unit Design Information:

In accordance with MARSSIM Section 4.6, special considerations may be necessary for survey units with structure surface areas less than 10 m^2 or land areas less than 100 m^2 . In this case, the number of data points obtained from the statistical tests is unnecessarily large and not appropriate for smaller survey unit areas. The data generated from these smaller survey units should be obtained based on judgment, rather than on systematic or random design, and compared individually to the DCGLs. This survey unit meets this criterion as the size is less than ten square meters (2.22 m^2).

The Survey Unit Design Parameters are presented in **Table 1** below. The survey unit and measurement locations are depicted on the maps in **Attachment 1**. Static measurement locations were randomly determined and approximately 100% of the area scanned. The instrumentation used for the survey along with the MDC values are listed in **Table 2-1 Attachment 2**.

FINAL STATUS SURVEY F8300042

Table 1, Survey Unit Design Parameters

Evaluation Input Values		Comments
Survey Package:	F830	DAW Staging Bay Class 2
Survey Unit:	004	
Class	2	
SU Area (m ²)	2	
Evaluator:	JR	
DCGL _w :	43,000	Gross Activity DCGL
Area Factor	5	DTBD-05-003 for 4 m ²
Design DCGL _{emc} (dpm/100cm ²):	215,860	
DCGL _{emc} :	215,860	
LBGR:	21,500	Default = 50% DCGL
Sigma:	598	Scoping Survey Data
Type I error:	0.05	
Type II error:	0.05	
Predominant Nuclide	Cs-137	
Sample Area (m ²)	N/A	
Total Instrument Efficiency:	0.132	From 10/26/16 Survey
Total Area Scanned (m ²):	2.22	
Scan Coverage (%)	100%	Class 2
Material Type:	N/A	Choosing 'N/A' sets material background to "0"
Calculated Values		Comments
Z _{1-α} :	1.645	
Z _{1-β} :	1.645	
Sign p:	0.99865	
Calculated Relative Shift:	35.9	
Relative Shift Used:	3.0	Uses 3.0 if Relative Shift >3
N-Value:	10	Values selected based upon Judgement
N-Value+20%:	10	Values selected based upon Judgement

FINAL STATUS SURVEY F8300042

Survey Results:

A total of 10 direct measurements were made in F8300042. The results of the static measurements are shown in **Table 2**. All of the static measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Swipe data did not indicate elevated activity levels above the MDA.

Table 2, Static Measurement Results

Number	Sample #	Beta (cpm)	Beta (dpm)
1	F8300042C00001	300	2,326
2	F8300042C00002	300	2,326
3	F8300042C00003	280	2,171
4	F8300042C00004	304	2,357
5	F8300042C00005	269	2,085
6	F8300042C00006	281	2,178
7	F8300042C00007	261	2,023
8	F8300042C00008	296	2,295
9	F8300042C00009	287	2,225
10	F8300042C00010	294	2,279

Table 3 contains the statistical summary of the static measurement data for the DAW Staging Bay Class 2.

Table 3, Beta Summary Statistics

<i>Beta Static DAW Staging Bay Class 2</i>	
Mean	2,226
Median	2,252
Standard Deviation	111
Minimum	2,023
Maximum	2,357
Count	10

Survey Unit Data Assessment:

The survey design required 10 static measurements based upon the size of the survey unit (2.22 m²). Following the guidance in MARSSIM Section 4.6, these values are compared directly to the DCGL_w. The comparison and the results are presented in **Table 4**. The sample mean and median values were less than the DCGL.

FINAL STATUS SURVEY F8300042

Table 4, Data Assessment Results

Static Data Values		Comments
Number of Samples:	10	
Median:	2,252	
Mean:	2,226	
Static Data Standard Deviation:	111	
Maximum:	2,357	
Criteria Satisfaction		Comments
Sufficient samples collected:	Pass	
Maximum value <DCGL _w :	Pass	
Median value <DCGL _w :	Pass	
Mean value <DCGL _w :	Pass	
Maximum value <DCGL _{emc} :	Pass	
Sign test results:	N/A	
Final Status		Comments
The survey unit passes all conditions:	Pass	

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL, the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 2 survey and the sample results are consistent with that classification. The variability of the survey results was greater than the characterization data used for survey design. However, no individual measurement exceeded the DCGL. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 2 survey based on the results of the scoping survey. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. All of the static measurements were less than the DCGL. No investigations were required.

The static measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8300042 meets the release criteria of 10CFR20.1402.



Attachment 1

Maps

January 6, 2017

Survey Unit F8300042



 	
STAGING BAY CLASS 2	
Contract No.: 450093426	SMUD
Location: Rancho Seco	Approved by:
Task: Scoping Survey	
Drawing No.: 1058 Scoping Survey	
Description: Staging bay	
Drawn By: C. Gray	
QC'd: J. Reese	Approval date:
Date: 01/06/17	
Rev No.:	

Attachment 2
Instrumentation
January 6, 2017
Survey Unit F8300042

Table 2-1. Survey Unit Instrumentation

Measurement Type	Instrument Type	Minimum Detectable Activity ^a	Detector Efficiencies	Calibration Due Date ^b
Beta Static Measurement	Ludlum Model 2350-1	Beta – 424 dpm/100 cm ²	12.9%	317899/331973 2/10/17
	Ludlum Model 44-116 B Detector			
Swipe Measurements	Ludlum Model 2929 Ludlum Model 44-10-1	Beta – 78 dpm/100 cm ²	43.4%	182597/188736 5/13/17

^a Minimum detectable activities for the count rate instrumentation were calculated in accordance with NUREG-1507, "Minimum Detectable Concentrations with Typical Radiation Survey Instruments for Various Contaminants and Field Conditions" (U.S. NRC, 1997).

^b Detectors are required to be calibrated once every 12 months. Calibration due date indicates the date by which the detector must be calibrated again.

cm² = square centimeters
 cpm = counts per minute
 dpm = disintegrations per minute

Static Measurement MDA

Beta Survey Type
PR331973 Detector Number
143 Background count rate (cpm)
1 Count Time (min)
0.129 Efficiency
100 Area of Detector (cm²)

Constants

60 sec/min
2.54 cm/in

Assumptions

Background count time and sample count time are equivalent

Calculate Static MDA

Static MDA = $3 + 4.65(B_r * t)^{0.5} / t * E * A/100$ (NUREG 1507)

Where: B_r Background Countrate
t Count Time (min)
E Efficiency
A Area of detector (cm²)

Static MDA 454 dpm/100 cm²

Attachment 3
Investigation
January 6, 2017
Survey Unit F8300042


(none required)


Attachment 4

Data Assessment

January 6, 2017

Survey Unit F8300042





Smear_Data_Calculation_Sheet_101316

IOSB Final Status Survey																											
	LC1	LC2	LC3	LC4	LC6	LC5		β CPM	β dpm	Date/Time of Count		Sample Comments															
1	F830	004	2	C	00001	SM	Stage Bay Flr Buffr	49	1	11/29/16	1056																
2	F830	004	2	C	00002	SM	Stage Bay Flr Buffr	40	-20	11/29/16	1057																
3	F830	004	2	C	00003	SM	Stage Bay Flr Buffr	45	-8	11/29/16	1058																
4	F830	004	2	C	00004	SM	Stage Bay Flr Buffr	45	-8	11/29/16	1100																
5	F830	004	2	C	00005	SM	Stage Bay Flr Buffr	42	-15	11/29/16	1101																
6	F830	004	2	C	00006	SM	Stage Bay Flr Buffr	43	-13	11/29/16	1102																
7	F830	004	2	C	00007	SM	Stage Bay Flr Buffr	45	-8	11/29/16	1104																
8	F830	004	2	C	00008	SM	Stage Bay Flr Buffr	43	-13	11/29/16	1105																
9	F830	004	2	C	00009	SM	Stage Bay Flr Buffr	51	6	11/29/16	1106																
10	F830	004	2	C	00010	SM	Stage Bay Flr Buffr	34	-33	11/29/16	1108																
11	F830	004	2	C	00011	SM	Stage Bay Flr Buffr																				
12	F830	004	2	C	00012	SM	Stage Bay Flr Buffr																				
13	F830	004	2	C	00013	SM	Stage Bay Flr Buffr																				
14	F830	004	2	C	00014	SM	Stage Bay Flr Buffr																				
15	F830	004	2	C	00015	SM	Stage Bay Flr Buffr																				
Comments By signature below, the required source check and background checks were satisfactorily performed prior to use of the instrument identified below.																											
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p>Tech A Sign/ Date <i>Joe Nava</i> 12-2-16</p> <p>Tech B Sign/ Date N/A</p> </div> <div style="width: 50%; border: 1px solid black; padding: 5px;"> <p style="text-align: center;">Ludlum 2929 Benchtop Instrument</p> <p>2929 S/N: 182597</p> <p>43-10-1 S/N: 188736</p> <p>Cal Due Date: 5/13/2017</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>efficiency</th> <th>bkg rate</th> <th>bkgr count time</th> <th>MDA</th> </tr> </thead> <tbody> <tr> <td>α</td> <td>0.364</td> <td>cpm</td> <td>min</td> <td>#DIV/0!</td> </tr> <tr> <td>β</td> <td>0.434</td> <td>48.5 cpm</td> <td>1 min</td> <td>77.6 dpm per area</td> </tr> </tbody> </table> </div> </div>														efficiency	bkg rate	bkgr count time	MDA	α	0.364	cpm	min	#DIV/0!	β	0.434	48.5 cpm	1 min	77.6 dpm per area
	efficiency	bkg rate	bkgr count time	MDA																							
α	0.364	cpm	min	#DIV/0!																							
β	0.434	48.5 cpm	1 min	77.6 dpm per area																							