



Rancho Seco
Final Status Survey Summary Report
February 1, 2017
IOSB Office Area
Survey Unit F8300133

Prepared By:  Date: 2.1.17

FSS Engineer

Reviewed By:  Date: 2.3.17

Lead FSS Engineer

Approved By:  Date: 2/24/17

Manager, Rancho Seco Assets

FINAL STATUS SURVEY F8300133

Survey Unit:

F8300133, Interim Onsite Storage Building (IOSB) Office Area

Survey Unit Description:

Operating History: Designed primarily to store packaged radioactive waste containers safely, protected from the elements, and maintain radiological dose as low as reasonably achievable (ALARA), the IOSB possibly stored media of many types, including filters, resins, contaminated chemicals, DAW, activated reactor components, contaminated plant components and other contaminated items. The office area was outside the radiologically controlled area during operations at the facility.

Site Characterization: Static measurements were made of the floor, walls, and ceiling, to confirm the absence or presence of plant-derived radionuclides. Static measurements showed a mean gross beta activity level of 2,047 dpm/100 cm² and a maximum value of 2,742 dpm/100 cm². Based on the levels of gross activity reported, the area was determined to be a Class 3 area.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in **Table 1** below. The survey unit and measurement locations are depicted on the maps in **Attachment 1**. Static measurement locations were randomly determined and approximately 3% of the area scanned by beta scanning. The instrumentation used for the survey along with the MDC values are listed in **Table 2-1 Attachment 2**.

FINAL STATUS SURVEY F8300133

Table 1, Survey Unit Design Parameters

| Evaluation Input Values | | Comments |
|---|---------|--|
| Survey Package: | F830 | Office |
| Survey Unit: | 13 | |
| Class | 03 | |
| SU Area (m ²) | 370 | |
| Evaluator: | JR | |
| DCGL _w : | 43,000 | Gross Activity DCGL |
| Area Factor | NA | Class 3 |
| Design DCGL _{emc} (dpm/100cm ²): | NA | Class 3 |
| DCGL _{emc} : | NA | Class 3 |
| LBGR: | 21,500 | Default = 50% DCGL |
| Sigma: | 334 | Scoping Survey |
| Type I error: | 0.05 | |
| Type II error: | 0.05 | |
| Predominant Nuclide | Cs-137 | |
| Sample Area (m ²) | N/A | |
| Total Instrument Efficiency: | 0.132 | |
| Total Area Scanned (m ²): | 11.1 | |
| Scan Coverage (%) | 3% | Class 3 |
| Material Type: | N/A | Choosing 'N/A' sets material background to "0" |
| Calculated Values | | Comments |
| Z _{1-α} : | 1.645 | |
| Z _{1-β} : | 1.645 | |
| Sign p: | 0.99865 | |
| Calculated Relative Shift: | 64.3 | |
| Relative Shift Used: | 3.0 | Uses 3.0 if Relative Shift >3 |
| N-Value: | 11 | |
| N-Value+20%: | 14 | |

Survey Results:

A total of 30 direct measurements were made in F8300133 floor, ceiling, and walls. The results of the static measurements are shown in **Table 2**. All of the static measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Swipe data did not indicate elevated activity levels above the MDA.

FINAL STATUS SURVEY F8300133

Table 2, Static Measurement Results

| Number | Sample # | Beta (cpm) | Beta (dpm) |
|--------|----------------|------------|------------|
| 1 | F8300313C00001 | 269 | 1,795 |
| 2 | F8300313C00002 | 272 | 1,848 |
| 3 | F8300313C00003 | 240 | 2,182 |
| 4 | F8300313C00004 | 237 | 2,152 |
| 5 | F8300313C00005 | 270 | 1,652 |
| 6 | F8300313C00006 | 262 | 1,932 |
| 7 | F8300313C00007 | 251 | 2,402 |
| 8 | F8300313C00008 | 211 | 2,038 |
| 9 | F8300313C00009 | 297 | 2,061 |
| 10 | F8300313C00010 | 267 | 1,818 |
| 11 | F8300313C00011 | 275 | 1,795 |
| 12 | F8300313C00012 | 297 | 2,045 |
| 13 | F8300313C00013 | 246 | 1,985 |
| 14 | F8300313C00014 | 239 | 1,902 |
| 15 | F8300313C00015 | 229 | 1,598 |
| 16 | F8300313C00016 | 318 | 2,250 |
| 17 | F8300313C00017 | 263 | 2,023 |
| 18 | F8300313C00018 | 217 | 2,083 |
| 19 | F8300313C00019 | 254 | 2,250 |
| 20 | F8300313C00020 | 263 | 1,864 |
| 21 | F8300313C00021 | 290 | 1,811 |
| 22 | F8300313C00022 | 223 | 1,735 |
| 23 | F8300313C00023 | 277 | 2,409 |
| 24 | F8300313C00024 | 269 | 1,992 |
| 25 | F8300313C00025 | 272 | 1,644 |
| 26 | F8300313C00026 | 240 | 1,924 |
| 27 | F8300313C00027 | 237 | 1,992 |
| 28 | F8300313C00028 | 270 | 2,197 |
| 29 | F8300313C00029 | 262 | 1,689 |
| 30 | F8300313C00030 | 251 | 2,098 |

FINAL STATUS SURVEY F8300133

Table 3 contains the statistical summary of the static measurement data for the office area.

Table 3, Beta Summary Statistics

| <i>Beta Static Office</i> | |
|---------------------------|-------|
| Mean | 1,972 |
| Median | 1,989 |
| Standard Deviation | 215 |
| Minimum | 1,598 |
| Maximum | 2,409 |
| Count | 30 |

Survey Unit Data Assessment:

The survey design required 14 static measurements for the Sign Test. A total of 30 static measurements were collected. The critical value and the results of the Sign Test are presented in **Table 4**. The sample mean and median values were less than the DCGL. The sample standard deviation was greater than the design standard deviation but both values of sigma resulted in a relative shift greater than three (3), no additional samples were required.

Table 4, Data Assessment Results

| Static Data Values | | Comments |
|--|-------|----------|
| Number of Samples: | 30 | |
| Median: | 1,989 | |
| Mean: | 1,972 | |
| Static Data Standard Deviation: | 215 | |
| Maximum: | 2,409 | |
| Sign Test Results | | Comments |
| Adjusted N Value: | 14 | |
| S+ Value: | 30 | |
| Critical Value: | 10 | |
| Criteria Satisfaction | | Comments |
| Sufficient samples collected: | Pass | |
| Maximum value <DCGL _w : | Pass | |
| Median value <DCGL _w : | Pass | |
| Mean value <DCGL _w : | Pass | |
| Maximum value <DCGL _{emc} : | NA | |
| Sign test results: | Pass | |
| Final Status | | Comments |
| The survey unit passes all conditions: | Pass | |

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

FINAL STATUS SURVEY F8300133

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL, the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 3 survey and the sample results are consistent with that classification. No individual measurement exceeded the DCGL. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 3 survey based on the results of the investigation survey. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. All of the static measurements were less than the DCGL. No investigations were required.

The static measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8300133 meets the release criteria of 10CFR20.1402.


Attachment 1

Maps

February 3, 2017

Survey Unit F8300133





Attachment 2

Instrumentation

February 3, 2017

Survey Unit F8300133

Table 2-1. Survey Unit Instrumentation

| Measurement Type | Instrument Type | Minimum Detectable Activity ^a | Detector Efficiencies | Calibration Due Date ^b |
|-------------------------|---|--|-----------------------|-----------------------------------|
| Beta Static Measurement | Ludlum Model 2350-1 Ludlum Model 44-116 B Detector | Beta – 502 dpm/100 cm ² | 13.2% | <u>317897/331972</u> 2/10/17 |
| Swipe Measurements | Ludlum Model 2929 Ludlum Model 44-10-1 | Beta – 78dpm/100 cm ² | 36.9% 42.8% | <u>166716/170380</u> 5/13/17 |

^a Minimum detectable activities for the count rate instrumentation were calculated in accordance with NUREG-1507, "Minimum Detectable Concentrations with Typical Radiation Survey Instruments for Various Contaminants and Field Conditions" (U.S. NRC, 1997).

^b Detectors are required to be calibrated once every 12 months. Calibration due date indicates the date by which the detector must be calibrated again.

cm² = square centimeters

cpm = counts per minute

dpm = disintegrations per minute

Static Measurement MDA

Beta Survey Type
PR331972 Detector Number
185 Background count rate (cpm)
1 Count Time (min)
0.132 Efficiency
100 Area of Detector (cm²)

Constants

60 sec/min
2.54 cm/in

Assumptions

Background count time and sample count time are equivalent

Calculate Static MDA

Static MDA = $3 + 4.65(B_r * t)^{0.5} / t * E * A_{/100}$ (NUREG 1507)

Where: B_r Background Countrate
 t Count Time (min)
 E Efficiency
 A Area of detector (cm²)

Static MDA 502 dpm/100 cm²

Attachment 3
Investigation
February 1, 2017
Survey Unit F8300133


(none required)


Attachment 4

Data Assessment

February 3, 2017

Survey Unit F8300133





Swipe sheet office

| IOSB Final Status Survey | | | | | | | | | | | |
|--------------------------|------|-----|-----|------|-------|-----|--------------|-------------|-------------|--------------------|-----------------|
| | LC1 | LC2 | LC3 | LC4* | LC6 | LC5 | | β CPM | β dpm | Date/Time of Count | Sample Comments |
| 1 | F830 | 013 | 3 | | 00001 | SM | IOSB Offices | 56 | 17 | | |
| 2 | F830 | 013 | 3 | | 00002 | SM | IOSB Offices | 51 | 5 | | |
| 3 | F830 | 013 | 3 | | 00003 | SM | IOSB Offices | 36 | -29 | | |
| 4 | F830 | 013 | 3 | | 00004 | SM | IOSB Offices | 37 | -27 | | |
| 5 | F830 | 013 | 3 | | 00005 | SM | IOSB Offices | 35 | -32 | | |
| 6 | F830 | 013 | 3 | | 00006 | SM | IOSB Offices | 58 | 21 | | |
| 7 | F830 | 013 | 3 | | 00007 | SM | IOSB Offices | 44 | -11 | | |
| 8 | F830 | 013 | 3 | | 00008 | SM | IOSB Offices | 59 | 24 | | |
| 9 | F830 | 013 | 3 | | 00009 | SM | IOSB Offices | 46 | -6 | | |
| 10 | F830 | 013 | 3 | | 00010 | SM | IOSB Offices | 40 | -20 | | |
| 11 | F830 | 013 | 3 | | 00011 | SM | IOSB Offices | 44 | -11 | | |
| 12 | F830 | 013 | 3 | | 00012 | SM | IOSB Offices | 49 | 1 | | |
| 13 | F830 | 013 | 3 | | 00013 | SM | IOSB Offices | 55 | 15 | | |
| 14 | F830 | 013 | 3 | | 00014 | SM | IOSB Offices | 44 | -11 | | |
| 15 | F830 | 013 | 3 | | 00015 | SM | IOSB Offices | 34 | -34 | | |

Comments: By signature below, the required source check and background checks were satisfactorily performed prior to use of the instrument identified below.

| | | | | | | |
|-------------------------|--|---------------------------------|-------|----------|----------------|-------------------|
| | | Ludlum 2929 Benchtop Instrument | | | | |
| | | efficiency | | bkg rate | bkg count time | MDA |
| 2929 S/N: 182597 | | α | 0.364 | 3 cpm | 1 min | 25.1 dpm per area |
| 43-10-1 S/N: 188736 | | β | 0.434 | 48.7 cpm | 1 min | 77.8 dpm per area |
| Cal Due Date: 5/13/2017 | | | | | | |

Tech A Sign/ Date *[Signature]* 2/3/17

Tech B Sign/ Date

Swipe sheet office

| IOSB Final Status Survey | | | | | | | | | | | |
|--------------------------|------|-----|-----|------|-------|-----|--------------|-------------|-------------|--------------------|-----------------|
| | LC1 | LC2 | LC3 | LC4* | LC6 | LC5 | | β CPM | β dpm | Date/Time of Count | Sample Comments |
| 1 | F830 | 013 | 3 | | 00016 | SM | IOSB Offices | 40 | -20 | | |
| 2 | F830 | 013 | 3 | | 00017 | SM | IOSB Offices | 31 | -41 | | |
| 3 | F830 | 013 | 3 | | 00018 | SM | IOSB Offices | 52 | 8 | | |
| 4 | F830 | 013 | 3 | | 00019 | SM | IOSB Offices | 46 | -6 | | |
| 5 | F830 | 013 | 3 | | 00020 | SM | IOSB Offices | 43 | -13 | | |
| 6 | F830 | 013 | 3 | | 00021 | SM | IOSB Offices | 50 | 3 | | |
| 7 | F830 | 013 | 3 | | 00022 | SM | IOSB Offices | 43 | -13 | | |
| 8 | F830 | 013 | 3 | | 00023 | SM | IOSB Offices | 42 | -15 | | |
| 9 | F830 | 013 | 3 | | 00024 | SM | IOSB Offices | 54 | 12 | | |
| 10 | F830 | 013 | 3 | | 00025 | SM | IOSB Offices | 41 | -18 | | |
| 11 | F830 | 013 | 3 | | 00026 | SM | IOSB Offices | 50 | 3 | | |
| 12 | F830 | 013 | 3 | | 00027 | SM | IOSB Offices | 39 | -22 | | |
| 13 | F830 | 013 | 3 | | 00028 | SM | IOSB Offices | 44 | -11 | | |
| 14 | F830 | 013 | 3 | | 00029 | SM | IOSB Offices | 32 | -38 | | |
| 15 | F830 | 013 | 3 | | 00030 | SM | IOSB Offices | 48 | -2 | | |

Comments By signature below, the required source check and background checks were satisfactorily performed prior to use of the instrument identified below.

| Ludlum 2929 Benchtop Instrument | | | | |
|---------------------------------|------------|----------|----------------|-------------------|
| | efficiency | bkg rate | bkg count time | MDA |
| α | 0.364 | 3 cpm | 1 min | 25.1 dpm per area |
| β | 0.434 | 48.7 cpm | 1 min | 77.8 dpm per area |

26

2/3/12

Tech A Sign/ Date

Tech B Sign/ Date

2929 S/N: 182597

43-10-1 S/N: 188736

Cal Due Date: 5/13/2017