



February 28, 2017  
L-2017-030  
10 CFR 50.36

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555-0001

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
2016 Annual Report of Reactor Coolant Specific Activity Limits

The 2016 Turkey Point Units 3 and 4 Annual Reactor Coolant System (RCS) Specific Activity Report is submitted herein pursuant to Turkey Point Technical Specification (TS) 6.9.1.2.

The reactor coolant specific activity limits of less than or equal to 0.25 microcuries per gram Dose Equivalent I-131 and less than or equal to 447.7 microcuries per gram of Dose Equivalent Xe-133 defined by Technical Specification 3.4.8.a and 3.4.8.b respectively were not exceeded for Turkey Point Units 3 and 4 during the year 2016.

Should there be any questions regarding this information, please contact Mr. Mitch Guth, Licensing Manager, at (305) 246-6698.

Sincerely,

A handwritten signature in black ink, appearing to read 'T. Summers', is written over a horizontal line.

Thomas Summers  
Regional Vice President, Southern Region  
Turkey Point Nuclear Plant

SM

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

ADD  
NRR