

May 1, 2017

Dr. Timothy W. Koeth, Director
University of Maryland
Radiation Facilities and Nuclear Reactor
Chemical and Nuclear Engineering
Building 090
College Park, MD 20742-2115

SUBJECT: UNIVERSITY OF MARYLAND - NON-POWER REACTOR CLOSEOUT OF
GENERIC LETTER 2016-01, "MONITORING OF NEUTRON-ABSORBING
MATERIALS IN SPENT FUEL POOLS," FOR THE MARYLAND UNIVERSITY
TRAINING REACTOR, DOCKET NO. 50-166 (CAC NO. A11010)

On April 7, 2016, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2016-01, "Monitoring of Neutron-Absorbing Materials in Spent Fuel Pools" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16097A169), to address the degradation of neutron-absorbing materials (NAM) in wet storage systems for reactor fuel at power and non-power reactors.

For the non-power reactors, GL 2016-01 requested that licensees provide facility-specific information related to the use of NAM. This information was needed by the NRC staff to verify continued compliance through licensee implementation of effective methods for monitoring of reactor fuel in wet storage so as to detect and mitigate any degradation or deformation of NAM when credited in the facility licensing or design basis for criticality control of fuel in wet storage.

On November 2, 2016, the University of Maryland submitted a response to GL 2016-01 (ADAMS Accession No. ML16319A369) for the Maryland University Training Reactor. The NRC staff conducted a review of your response to GL 2016-01 and determined that your facility does not use NAM in wet fuel storage. Based upon the information you submitted in response to GL 2016-01 and the results of the NRC staff review, the NRC staff has determined that the submission addresses the information requested in GL 2016-01. No further information or action is requested regarding this matter.

Sincerely,

/RA/

Alexander Adams Jr., Chief
Research and Test Reactors Licensing Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

cc: See next page

University of Maryland

Docket No. 50-166

cc:

Director, Dept. of Natural Resources
Power Plant Siting Program
Energy & Coastal Zone Administration
Tawes State Office Building
Annapolis, MD 21401

Roland G. Fletcher, Program Manager IV
Radiological Health Program
Maryland Department of Environment
1800 Washington Blvd., Suite 750
Baltimore, MD 21230-1718

Vincent G. Adams
Facility Coordinator
Chemical and Nuclear Engineering Building 090
University of Maryland
College Park, MD 20742

Mary J. Dorman
Radiation Safety Officer
Department of Environmental Safety
3115 Chesapeake Building 338
University of Maryland
College Park, MD 20742

Ray Phaneuf
Professor and Acting Chair
University of Maryland
Department of Materials Science and Engineering, Room 2135
Chem. & Nuclear Engineering Bldg (090)
College Park, MD 20742-2115

Test, Research and Training
Reactor Newsletter
P.O. Box 118300
University of Florida
Gainesville, FL 32611

SUBJECT: UNIVERSITY OF MARYLAND - NON-POWER REACTOR CLOSEOUT OF
 GENERIC LETTER 2016-01, "MONITORING OF NEUTRON-ABSORBING
 MATERIALS IN SPENT FUEL POOLS," FOR MARYLAND UNIVERSITY
 TRAINING REACTOR, DOCKET NO. 50-166 (CAC NO. A11010)
 DATED MAY 1, 2017

DISTRIBUTION:

PUBLIC

AAdams, NRR

AMendiola, NRR

TMensah, NRR

JAdams, NRR

EAllen, NRR

SStuchell, NRR

LLund, NRR

GBowman, NRR

NParker, NRR

ADAMS Accession No.: ML17067A375; *concurrent via e-mail

OFFICE	NRR/DPR/PRLB/PM*	NRR/DPR/PRLB/LA*	NRR/DPR/PGCB/BC	NRR/DPR/PRLB/BC
NAME	EAllen*	NParker	SStuchell	AAdams
DATE	4/18/17	4/7/17	4/28/17	5/1/17

OFFICIAL RECORD COPY