

March 22, 2017

Brycen Roy, Reactor Supervisor
U.S. Geological Survey
P.O. Box 25046 – Mail Stop 974
Denver Federal Center
Denver, CO 80225

SUBJECT: U.S. GEOLOGICAL SURVEY - NON-POWER REACTOR CLOSEOUT OF
GENERIC LETTER 2016-01, "MONITORING OF NEUTRON-ABSORBING
MATERIALS IN SPENT FUEL POOLS," FOR THE U.S. GEOLOGICAL SURVEY
TRIGA RESEARCH REACTOR, DOCKET NO. 50-274 (CAC NO. A11010)

On April 7, 2016, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2016-01, "Monitoring of Neutron-Absorbing Materials in Spent Fuel Pools" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16097A169), to address the degradation of neutron-absorbing materials (NAM) in wet storage systems for reactor fuel at power and non-power reactors.

For the non-power reactors, GL 2016-01 requested that licensees provide facility-specific information related to the use of NAM. This information was needed by the NRC staff to verify continued compliance through licensee implementation of effective methods for monitoring of reactor fuel in wet storage so as to detect and mitigate any degradation or deformation of NAM when credited in the facility licensing or design basis for criticality control of fuel in wet storage.

On June 2, 2016, the U.S. Geological Survey submitted a response to GL 2016-01 (ADAMS Accession No. ML16161A460) for the U.S. Geological Survey TRIGA Research Reactor. The NRC staff conducted a review of your response to GL 2016-01 and determined that your facility does not use NAM in wet fuel storage. Based upon the information you submitted in response to GL 2016-01 and the results of the NRC staff review, the NRC staff has determined that the submission addresses the information requested in GL 2016-01. No further information or action is requested regarding this matter.

Sincerely,

/RA/

Alexander Adams Jr., Chief
Research and Test Reactors Licensing Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

cc: See next page

U.S. Geological Survey

Docket No. 50-274

cc:

Brian Nielsen
Environmental Services Manager
480 S. Allison Pkwy.
Lakewood, CO 80226

Steve Tarlton
State of Colorado
Radiation Management Program
HMWM-RM-B2
4300 Cherry Creek Drive South
Denver, CO 80246

Test, Research and Training
Reactor Newsletter
P.O. Box 118300
University of Florida
Gainesville, FL 32611

Vito Nuccio, Reactor Administrator
U.S. Geological Survey
Denver Federal Center
PO Box 25046 MS 911
Denver, CO 80225-0046

SUBJECT: U.S. GEOLOGICAL SURVEY - NON-POWER REACTOR CLOSEOUT OF
 GENERIC LETTER 2016-01, "MONITORING OF NEUTRON-ABSORBING
 MATERIALS IN SPENT FUEL POOLS," FOR THE U.S. GEOLOGICAL SURVEY
 TRIGA RESEARCH REACTOR, DOCKET NO. 50-274 (CAC NO. A11010)
 DATED: March 22, 2017

DISTRIBUTION:

PUBLIC	AAdams, NRR	TMendiola, NRR
TMensah, NRR	SStuchell, NRR	LLund, NRR
GBowman, NRR	NParker, NRR	JAdams, NRR
GWertz, NRR		

ADAMS Accession No.: ML17067A394; *concurred via email

OFFICE	NRR/DPR/PRLB/PM*	NRR/DPR/PRLB/LA*	NRR/DPR/PGCB/BC	NRR/DPR/PRLB/BC
NAME	GWertz	NParker	SStuchell	AAdams
DATE	3/10/17	3/10/17	3/15/17	3/22/17

OFFICIAL RECORD COPY