

April 17, 2017

Dr. Donald Wall, Director  
Washington State University  
Nuclear Radiation Center  
50 Roundtop Drive  
Pullman, WA 99164-1300

SUBJECT: WASHINGTON STATE UNIVERSITY - NON-POWER REACTOR CLOSEOUT OF GENERIC LETTER 2016-01, "MONITORING OF NEUTRON-ABSORBING MATERIALS IN SPENT FUEL POOLS," FOR THE WASHINGTON STATE UNIVERSITY MODIFIED TRIGA NUCLEAR REACTOR, DOCKET NO. 50-027 (CAC NO. A11010)

On April 7, 2016, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2016-01, "Monitoring of Neutron-Absorbing Materials in Spent Fuel Pools" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16097A169), to address the degradation of neutron-absorbing materials (NAM) in wet storage systems for reactor fuel at power and non-power reactors.

For the non-power reactors, GL 2016-01 requested that licensees provide facility-specific information related to the use of NAM. This information was needed by the NRC staff to verify continued compliance through licensee implementation of effective methods for monitoring of reactor fuel in wet storage so as to detect and mitigate any degradation or deformation of NAM when credited in the facility licensing or design basis for criticality control of fuel in wet storage.

On November 7, 2016, Washington State University submitted a response to GL 2016-01 (ADAMS Accession No. ML16321A404) for the Washington State University Modified TRIGA Nuclear Reactor. The NRC staff conducted a review of your response to GL 2016-01 and determined that your facility does not use NAM in wet fuel storage. Based upon the information you submitted in response to GL 2016-01 and the results of the NRC staff review, the NRC staff has determined that the submission addresses the information requested in GL 2016-01. No further information or action is requested regarding this matter.

Sincerely,

*/RA/*

Alexander Adams Jr., Chief  
Research and Test Reactors Licensing Branch  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

cc: See next page

Washington State University

Docket No. 50-027

cc:

Director  
Division of Radiation Protection  
Department of Health  
7171 Cleanwater Lane, Bldg #5  
P.O. Box 47827  
Olympia, WA 98504-7827

Mr. David Clark, Director  
Washington State University  
Radiation Safety Office  
P.O. Box 641302  
Pullman, WA 99164-1302

Dr. Ken Nash Chair  
Washington State University  
Reactor Safeguards Committee  
Nuclear Radiation Center  
P.O. Box 641300  
Pullman, WA 99164-1300

Mr. Corey Hines, Assistant Director  
For Reactor Operations  
Washington State University  
Nuclear Radiation Center  
P.O. Box 641300  
Pullman, WA 99164-1300

Test, Research and Training  
Reactor Newsletter  
P.O. Box 118300  
University of Florida  
Gainesville, FL 32611-8300

SUBJECT: WASHINGTON STATE UNIVERSITY - NON-POWER REACTOR CLOSEOUT OF GENERIC LETTER 2016-01, "MONITORING OF NEUTRON-ABSORBING MATERIALS IN SPENT FUEL POOLS," FOR THE WASHINGTON STATE UNIVERSITY MODIFIED TRIGA NUCLEAR REACTOR, DOCKET NO. 50-027 (CAC NO. A11010) DATED: April 17, 2017

**DISTRIBUTION:**

PUBLIC	TMensah, NRR	NParker, NRR	XYin, NRR
GBowman, NRR	SStuchell, NRR	JAdams, NRR	PRLB r/f
AMendiola, NRR	AAdams, NRR	LLund, NRR	

**ADAMS Accession No.: ML17067A404; \*concurred via email**

<b>OFFICE</b>	NRR/DPR/PRLB/PM	NRR/DPR/PROB/LA*	NRR/DPR/PGCB/BC	NRR/DPR/PRLB/BC
<b>NAME</b>	XYin	NParker	SStuchel (AGarmoe for)	AAdams
<b>DATE</b>	4/11/17	4/7/17	4/17/17	4/17/17

**OFFICIAL RECORD COPY**