



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**EVALUATE JET PUMP OPERABILITY**

JPM Number: LOJPM6717

REVISION NUMBER: 001

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date



Note: This LGS format satisfies the TQ-JA-150 Format

I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>ST-6-043-320-1</u>	Rev: <u>45</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces 2010 RO A1-2 Revised to new template and to align with latest procedure revision.	08/15/14
001	Updated template and KA	10/31/16

**# Date of Revision** - refers to date revision was released for approval



**IV. TASK STANDARD:**

The candidate should report the test is UNSAT due to failure on "A" loop drive flow high and "A" loop jet pumps flow low.

**V. INITIAL CONDITIONS:**

Plant conditions are as follows:

1. Unit 1 is in OPCON 1
2. An unexpected drop in reactor power occurred
3. An unexplained rise in core flow occurred
4. ON-100, Failure Of A Jet Pump, was entered

**VI. INITIATING CUE:**

Perform ST-6-043-320-1, Daily Jet Pump Operability Verification for Two Recirculation Loop Operation, report the results, and (SRO only) any compensatory actions, if required

**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

**\***

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p><b>EVALUATORS NOTE:</b>            Provide Candidate with the following:</p> <ul style="list-style-type: none"> <li>• JPM briefing sheet</li> <li>• Yellow Copy of ST-6-043-320-1</li> <li>• PMS computer screen shots</li> <li>• Calculator</li> <li>• Unit 1 Tech Specs (<b>SRO Only</b>)</li> </ul>				
*	1. [ST-6-043-320-1 step 4.3.1.3]  Determine if Loop "A" flow is within 10% of the loop flow values on the established pump speed-loop flow characteristic curve	Candidate determines that Loop "A" is NOT within the limits – <b>UNSAT</b>		
*	2. [ST-6-043-320-1 step 4.3.2.3]  Determine if Loop "B" flow is within 10% of the loop flow values on the established pump speed-loop flow characteristics curve.	Candidate determines that loop "B" is within the limits – <b>SAT</b>		
*	3. [ST-6-043-320-1 step 4.3.3.4]  Determine if the value of total core flow is within 10% of the established Total Core Flow value derived from Recirc Loop Flow Measurements	Candidate determines that total core flow is within the limits – <b>SAT</b>		
*	4. [ST-6-043-320-1 step 4.3.4.4]  Determine if Loop "A" Jet Pump diffuser-to-lower plenum differential pressure is within 10% of the established patterns	Candidate determines that the jet pumps on Loop "A" are NOT within the limits - <b>UNSAT</b>		



ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
*	5. [ST-6-043-320-1 step 4.3.5.4] Determine if Loop "B" Jet Pump diffuser-to-lower plenum differential pressure is within 10% of the established patterns	Candidate determines that all of the jet pumps on Loop "B" are within the limits - <b>SAT</b>			
*	6. [ST-6-043-320-1 step 4.4.1] Verify at least two of the step combinations are satisfactory: <ul style="list-style-type: none"> <li>• 4.3.1.3 and 4.3.2.3 (Pump speed vs. drive flow) <b>UNSAT</b></li> <li>• 4.3.3.4 (Total loop flow vs. total core flow) <b>SAT</b></li> <li>• 4.3.4.4 and 4.3.5.4 (Individual JP DP vs. Drive Flow) <b>UNSAT</b></li> </ul>	Candidate determines that two of three areas are <b>UNSAT</b> and the overall ST results are <b>UNSAT</b>  Report the unsatisfactory results – The "A" Jet Pumps have failed the surveillance test.			
<p><b>NOTE: This is the termination point for RO's</b></p> <p><b>CUE: (RO's only) - You have met the termination criteria for this JPM</b></p> <p><b>The remaining portion of this JPM is "SRO's only"</b></p>					
*	7. SRO candidate determines Tech Spec implications of the failed Jet Pump surveillance test	Tech Spec LCO 3.4.1.2 . With one or more Jet Pumps inoperable, be in <b>HOT SHUTDOWN</b> within 12 hours			
<p><b>CUE: (SRO) You have met the termination criteria for this JPM</b></p>					

JPM Completion Time \_\_\_\_\_



JPM SUMMARY

Operator's Name: \_\_\_\_\_

Job Title:  SED  SM  SRO  RO  STA/IA  EO  OTHER

JPM Title: EVALUATE JET PUMP OPERABILITY

JPM Number: LOJPM6717

Revision Number: 001

Task Number and Title: 2000010401 ON-100, Actions For Jet Pump Failure  
3410070302 Direct action per T.S. when an LCO is not satisfied

K/A Number and Importance: Generic 2.1.19 3.9/3.8  
Generic 2.2.40 3.4/4.7

Safety Function (1-9) 1

Admin Category (A1-4) 1/2 (Conduct of Operations / Equipment Control)

Level of Difficulty (1-5) 3

Suggested Testing Environment: Classroom

Alternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s): ST-6-043-320-1, Daily Jet Pump Operability for Two Recirculation Loop  
Operation, Rev 45  
Tech Specs

Actual Testing Environment:  Simulator  Control Room  In-Plant  Other

Testing Method:  Simulate  Perform

Estimated Time to Complete: 20 minutes Actual Time Used: \_\_\_\_\_ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily?  Yes  No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

Plant conditions are as follows:

1. Unit 1 is in OPCON 1
2. An unexpected drop in reactor power occurred
3. An unexplained rise in core flow occurred
4. ON-100, Failure Of A Jet Pump, was entered

**INITIATING CUE:**

Perform ST-6-043-320-1, Daily Jet Pump Operability Verification for Two Recirculation Loop Operation, report the results, and (SRO only) any compensatory actions, if required.

**Document required action(s):**

---

---

---

---

---

---

---

---



RPV NORMAL CNTMT NORMAL RU RA CH 1 PM 47 RX 0 FC 2 T 19 CW 2 SS 18 EL 6

### Group Point Display - Group Data Display on LG1PA

Change Group

Group Definition

List Groups

Group Number: 33

Group Name: DAILY ST PTS (JET PP & DAILY)

Group Status: ACTIVE

Point ID	Description	Status	Current Value	Engineering Units	Plot Limit	Low	High	Plot Limit
1	R033 DRYWELL EL 330 FT TEMP	NML	136	DEGF	0			80
2	R036 DRYWELL EL 260 FT TEMP	NML	124	DEGF	50			250
3	R037 DRYWELL EL 260 FT TEMP	NML	124	DEGF	50			250
4	R034 DRYWELL EL 320 FT TEMP	NML	136	DEGF	50			250
5	B018 (18) REACTOR CORE FLOW	NML	89.2	MLB/H	0.0			120.0
6	B037 (19) A RECIRC PMP A1(DRIVE) FLOW	NML	16.875	MLB/H	0.000			20.000
7	B039 (21) B RECIRC PMP B1(DRIVE) FLOW	NML	15.122	MLB/H	0.000			20.000
8	E1266 A RECIRC PUMP SPEED	NML	1314	RPM	18.000			102.000
9	E1267 B RECIRC PUMP SPEED	NML	1314	RPM	18.000			102.000
10	E050 D11 4.16 KV SFGD BUS VOLTAGE	NML	4.31	KVAC	0.00			4.50
11	E052 D13 4.16 KV SFGD BUS VOLTAGE	NML	4.31	KVAC	0.00			4.50
12	E051 D12 4.16 KV SFGD BUS VOLTAGE	NML	4.31	KVAC	0.00			4.50
13	E053 D14 4.16 KV SFGD BUS VOLTAGE	NML	4.31	KVAC	0.00			4.50
14								
15								
16								
17								
18								
19								
20								

12:54:54 -I- Loading display MGPDFW

LIMERICK 1

FWD BWD

12:55:18

SIM

RPV NORMAL

CNTMT NORMAL

E1192FL2

D/W FLR DRN SUMP FLW 2 MIN AVGL

NML

0.248

GPM

8.000

## Group Point Display - Group Data Display on LG1PA

Change Group

Group Definition

List Groups

Group Number: 2

Group Name: JET PUMP D/P'S ("Z" SHIFT ST)

Group Status: ACTIVE

Point ID	Description	Status	Current Value	Engineering Units	Plot Limit	Low	High	Plot Limit
1	E1084 JET PUMP 1 SINGLE TAP DP	NML	35.529	%	0.000			100.000
2	E1103 JET PUMP 2 SINGLE TAP DP	NML	35.424	%	0.000			100.000
3	E1105 JET PUMP 3 SINGLE TAP DP	NML	33.156	%	0.000			100.000
4	E1247 JET PUMP 4 SINGLE TAP DP	NML	34.552	%	0.000			100.000
5	E1249 JET PUMP 5 SINGLE TAP DP	NML	44.395	%	0.000			100.000
6	E1255 JET PUMP 6 SINGLE TAP DP	NML	37.797	%	0.000			100.000
7	E1257 JET PUMP 7 SINGLE TAP DP	NML	33.784	%	0.000			100.000
8	E1259 JET PUMP 8 SINGLE TAP DP	NML	32.039	%	0.000			100.000
9	E1263 JET PUMP 9 SINGLE TAP DP	NML	34.901	%	0.000			100.000
10	E1265 JET PUMP 10 SINGLE TAP DP	NML	42.502	%	0.000			100.000
11	E1037 JET PUMP 11 SINGLE TAP DP	NML	27.541	%	0.000			100.000
12	E1097 JET PUMP 12 SINGLE TAP DP	NML	27.704	%	0.000			100.000
13	E1104 JET PUMP 13 SINGLE TAP DP	NML	25.119	%	0.000			100.000
14	E1235 JET PUMP 14 SINGLE TAP DP	NML	26.724	%	0.000			100.000
15	E1254 JET PUMP 15 SINGLE TAP DP	NML	27.187	%	0.000			100.000
16	E1248 JET PUMP 16 SINGLE TAP DP	NML	29.055	%	0.000			100.000
17	E1256 JET PUMP 17 SINGLE TAP DP	NML	15.519	%	0.000			100.000
18	E1258 JET PUMP 18 SINGLE TAP DP	NML	17.021	%	0.000			100.000
19	E1260 JET PUMP 19 SINGLE TAP DP	NML	27.541	%	0.000			100.000
20	E1264 JET PUMP 20 SINGLE TAP DP	NML	26.680	%	0.000			100.000

06:49:04

PS-PRINT

- %SYSTEM-S-NORMAL

LIMERICK 1

6:50:45

SIM



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**DETERMINE MAXIMUM GENERATOR VARS**

JPM Number: LOJPM6719

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By: \_\_\_\_\_  
Instructor Date

Validated By: \_\_\_\_\_  
SME or Instructor Date

Reviewed By: \_\_\_\_\_  
Operations Representative Date

Reviewed By: \_\_\_\_\_  
EP Representative Date

Approved By: \_\_\_\_\_  
Training Department Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

**I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>ON-126</u>	Rev: <u>14</u>
Procedure <u>E-5</u>	Rev: <u>22</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This is a new JPM.	07/25/16

# **Date of Revision** - refers to date revision was released for approval



#### IV. TASK STANDARD:

Determine the following:

Part 1 - Maximum VARs at 75 psig H2 and 1200 MWe determined to be **400 MVARs**

Part 2 - A power reduction to  $\leq 1160$  MWe ( $\leq 1163$  if linear interpretation is used) is required to maintain VARs at **400 MVARs** with Main Generator H2 press at 70 psig.

#### V. SIMULATOR SETUP

1. N/A

#### VI. INITIAL CONDITIONS:

1. Unit 2 is at 100% power when the PJM issued a Voltage Reduction Alert.
  - The TSO has requested the plant maintain maximum VAR support
  - U2 Generator Real Power is 1200 MWe
  - Current U2 Generator H2 pressure is 75 psig.

#### VII. INITIATING CUE:

1. Shift supervision directs you, due to Grid conditions, to respond to the TSOs request, and determine the Maximum VAR output that remains within the capability of the U2 Generator for the current plant conditions, and

#### VIII. FOLLOWUP CUE:

2. A leak developed in the generator H2 system that resulted in an unexpected "2 Gen Hydrogen And Seal Oil Sys Trouble" Alarm and uncontrolled Main Generator Hydrogen Pressure drop. The leak has been identified and mitigated, current generator H2 pressure is 70 psig and steady.

The load dispatcher informs you that they are prioritizing VAR support over MWe generation; What additional procedure entry is required and what if any U2 maneuvering is required to maintain the maximum VAR output determined in part 1 above while staying within the U2 Generator Capability?

**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

★

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**IX. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p><b>EVALUATORS NOTE:</b> Provide candidate with a copy of the following:</p> <ul style="list-style-type: none"> <li>E-5, Grid Emergency</li> </ul>				
*	<p>1. Candidate determines the Maximum VARS at 1200 MWe with H2 press at 75 psig.</p>	<p>Candidate concludes, using E-5 Attachment 2, the maximum VARS with H2 press at 75 psig and at <b>1200 MWe</b> determined to be <b>400 MVARs</b></p>		
<p><b>EVALUATORS NOTE:</b> Once Initiating Cue is complete provide candidate with Followup Cue and upon request for ON-126, Provide candidate with a copy of the following :</p> <ul style="list-style-type: none"> <li>ON-126, Uncontrolled Main Generator Hydrogen Depressurization.</li> </ul>				
*	<p>2. Candidate evaluates conditions provided in Follow-up Cue and determines ON procedure entry is required.</p>	<p>Candidate determines that the symptoms for ON-126, Uncontrolled Main Generator Hydrogen Depressurization have been met.</p>		
*	<p>3. Candidate determines the requirements for Maximum VAR support when U2 Generator H2 pressure is reduced to 70 psig.</p>	<p>Candidate, using Attachment 1 of ON-126 (OR E-5 Attachment 2) concludes that a power reduction to <b>≤ 1160 MWe</b> ( ≤ 1163 if linear interpretation is used) is required to maintain VARS at <b>400 MVARs</b> with Main Generator H2 press at 70 psig.</p>		
<p><b>CUE: You have met the termination criteria for this JPM</b></p>				

JPM Completion Time \_\_\_\_\_











**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**PREPARE A PARTIAL PROCEDURE**

JPM Number: LOJPM6777

REVISION NUMBER: 001

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

### I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>ST-6-043-200-1</u>	Rev: <u>23</u>
Procedure <u>AD-LG-101-1002</u>	Rev: <u>13</u>
Procedure <u>HU-AA-104-101</u>	Rev: <u>5</u>
Procedure <u>HU-AA-1212</u>	Rev: <u>7</u>
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0777 Rev. 1. Revised to new template and aligned with latest procedure revision(s).	5/31/15
Rev001	JPM revised to new JPM Template and procedure revisions	11/03/16

# Date of Revision - refers to date revision was released for approval



#### IV. TASK STANDARD:

Partial procedure, ST-6-043-200-1, Reactor Recirculation System Quarterly Valve Test prepared for PMT of HV-043-1F020, in accordance with plant procedures, AD-LG-101-1002, Temp Changes to Approved Documents and Partial Procedure Use, and HU-AA-104-101, Procedure Use and Adherence.

#### V. INITIAL CONDITIONS:

1. Maintenance on HV-043-1F020 is complete per work order C099590301.
2. A PMT is required to determine operability of HV-043-1F020.

#### VI. INITIATING CUE:

You are directed to prepare a partial on ST-6-043-200-1 to determine operability for valve HV-043-1F020, following maintenance, and

Document actions and notifications, if any, performed

#### Information for Evaluator's Use:

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER	
<p><b>EVALUATORS NOTE:</b> If copy of C099590301 requested, inform candidate "Work Order has been evaluated by the WCS".</p> <p><b>Provide Candidate with the following:</b></p> <ul style="list-style-type: none"> <li>• JPM briefing sheet</li> <li>• Yellow Copy of ST-6-043-200-1</li> <li>• AD-LG-101-1002, Temporary Changes to Approved Documents and Partial Procedure Use</li> <li>• HU-AA-104-101, Procedure Use and Adherence.</li> <li>• HU-AA-1212, Technical Task Risk/Rigor Assessment, Pre-Job Brief, Independent Third Party Review, and Post-Job Review</li> </ul>					
	<p>1. Review ST-6-043-200-1 for determining operability of HV-43-1F020</p>	<p>Candidate reviews ST-6-043-200-1, Reactor Recirculation System Quarterly Valve Test in preparation of determining operability of HV-43-1F020</p>			
	<p>2. Reference AD-LG-101-1002 section 4.1 "Partial Procedures" and perform the following:</p>	<p>N/A</p>			
	<p>2a. [AD-LG-101-1002 step 4.1.1] <b>IF</b> performing partial ST or RT, then <b>WRITE "PARTIAL"</b> on the first page of ST-6-043-200-1.</p>	<p><b>"PARTIAL"</b> written on the first page of ST-6-043-200-1. (duplicate, critical at step #9)</p>			
	<p>2b. [AD-LG-101-1002 step 4.1.2] <b>COMPLETE</b> partial performance of procedure per HU-AA-104-101, Procedure Use and Adherence.</p>	<p>Candidate references HU-AA-104-101, Procedure Use and Adherence.</p>			





ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER	
<p><b>EVALUATOR NOTE:</b> The following steps are directed from HU-AA-104-101, Procedure Use and Adherence, step 4.6.1, whereas “<b>IF</b> a portion of a procedure is used in lieu of performing the procedure in its entirety, <b>THEN</b> the Work Planner will...</p> <p>Partial procedure development for equipment operating or test procedures should be evaluated for technical human performance error precursors using HU-AA-1212.</p>					
3.	<p>[HU-AA-104-101 step 4.6.1.1]  <b>IF</b> required by HU-AA-1212, <b>THEN</b> conduct a prejob brief.</p>	Candidate determines a Pre-job brief is required.			
4.	<p>[HU-AA-104-101 step 4.6.1.2]  <b>DETERMINE</b> the steps that are adequate and appropriate to accomplish the desired task.</p>	Candidate determines all steps of ST-6-043-200-1 pertaining to HV-043-1F020 are required.			
5.	<p>[HU-AA-104-101 step 4.6.1.3]  <b>ENSURE</b> all applicable Prerequisites, Precautions, and Limitations and Actions are met before performing the associated steps.</p>	Candidate determines all Prerequisites, Precautions, and Limitations and Actions are met before performing the task.			
6.	<p>[HU-AA-104-101 step 4.6.1.4]  <b>ENSURE</b> the component/system is returned to a condition normal/ expected for plant conditions at that time.</p>	Candidate verifies “AS LEFT” position of HV-043-1F020 determined by plant conditions as directed by HU-AA-1212, prejob brief			
7.	<p>[HU-AA-104-101 step 4.6.1.5]  <b>ENSURE</b> that uncompleted steps will not result in missed acceptance criteria or an incomplete surveillance.</p>	N/A			



ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
<b>EVALUATORS NOTE:</b> Candidate may request to write "PARTIAL" on computer generated "Valve Stroke Timing List" report RO will obtain the "Timing List"					
*	8. [HU-AA-104-101 step 4.6.1.6] <b>WRITE</b> "PARTIAL" on the first page of the procedure.	"PARTIAL" written on the first page of the ST-6-043-200-1 (performed in step 3a)			
*	9. [HU-AA-104-101 step 4.6.1.7] <b>WRITE</b> "Reason for Partial Performance" on the first page of the procedure and <b>INSERT</b> the reason for partial procedure performance.	"Reason for Partial Performance" i.e. "PMT to determine operability following maintenance" or equivalent, written on the first page of the ST-6-043-200-1			
*	10. [HU-AA-104-101 step 4.6.1.8] <b>ANNOTATE</b> steps that are not applicable to HV-043-1F020 PMT before performing a partial procedure with "N/A". <ul style="list-style-type: none"><li>Step 4.5 Check Valve Test</li></ul>	Steps pertaining to Check Valve Test and HV-043-1F019 annotated as "N/A" <ul style="list-style-type: none"><li>Step 4.5 Check Valve Test</li></ul>			
*	11. [HU-AA-104-101 step 4.6.1.9] <b>WRITE</b> "Partial Procedure Approval" on the first page of the procedure.	"Partial Procedure Approval" written on the first page under "Additional Action/Comments" of the ST-6-043-200-1.			
*	12. [HU-AA-104-101 step 4.6.1.10] <b>AUTHORIZE</b> use of partial use procedure.	Authorization obtained and documented on the first page under "Additional Action/Comments" of the ST-6-043-200-1.			
<b>CUE: You have met the termination criteria for this JPM</b>					

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**         SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:**        Prepare A Partial Procedure

**JPM Number:** LOJPM6777

**Revision Number:**    001

**Task Number and Title:** TCO-2990110301 – Recommend Revisions to Operating Procedures

**K/A Number and Importance:**    Generic 2.2.6 Knowledge of the process for making changes to procedures.    CFR: 45.13    3.0/3.6

**Level of Difficulty (1-5)**   3  

**Safety Function (1-9)** \_\_\_\_\_

**Admin Category (A1-4)**   2  

**Suggested Testing Environment:**    Simulator/Classroom

**Alternate Path:**  Yes    No    **SRO Only:**  Yes    No    **Time Critical:**  Yes    No

**Reference(s):** ST-6-043-200-1, Reactor Recirculation System Quarterly Valve Test, Rev 23.

AD-LG-101-1002, Temp Changes to Approved Documents and Partial Procedure Use, Rev 13.

HU-AA-104-101, Procedure Use and Adherence, Rev 5.

HU-AA-1212, Technical Task Risk/Rigor Assessment, Pre-Job Brief, Independent Third Party Review, and Post-Job Review, Rev 7.

**Actual Testing Environment:**    Simulator    Control Room    In-Plant    Other

**Testing Method:**     Simulate    Perform

**Estimated Time to Complete:**   15   minutes    **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?     Yes     No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:     Satisfactory     Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_    **Date:** \_\_\_\_\_

**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Maintenance on HV-043-1F020 is complete per work order C099590301.
2. A PMT is required to determine operability of HV-043-1F020.

**INITIATING CUE:**

You are directed to prepare a partial on ST-6-043-200-1 to determine operability for valve HV-043-1F020, following maintenance, and

Document actions and notifications, if any, performed below:

---

---

---

---

---

---

---

---

---

---

---

---



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**ACTIONS REQUIRED FOR SPIKING ARM**

JPM Number: LOJPM6728

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

**I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>S27.1.A</u>	Rev: <u>21</u>
Procedure <u>S27.10.A</u>	Rev: <u>9</u>
Procedure <u>ARC MCR 109 B-4</u>	Rev: <u>2</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM is New	11/01/16

# Date of Revision - refers to date revision was released for approval



**IV. TASK STANDARD:**

1. On the Individual Briefing Sheet the following identified:
  - a. Location of ARM identified as Unit 1 RHR DIV 2 Rm (Area 16 Elev 201) and
  - b. Section 4.3 of S27.1.A to remove Area ARM from service, documented.

**V. SIMULATOR SETUP:**

None.

**VI. INITIAL CONDITIONS:**

1. Unit 1 is at 100% power.
2. Annunciator 109 B-4 "Reactor Encl Area Hi Radiation", has been received several times this shift
3. Each time it has been determined to be spiking of channel # 9
4. The RP tech has verified that local area readings are normal.

**VII. INITIATING CUE:**

1. Shift Supervision directs you to identify the location in the plant monitored by this ARM
2. Identify any compensatory actions required to address this nuisance alarm.
3. Provide your findings on Individual Briefing Sheet.



### Information for Evaluator's Use:

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER	
<p><b>EVALUATORS NOTE:</b>            Provide Candidate with the following:</p> <ul style="list-style-type: none"> <li>• Individual Briefing Sheet</li> <li>• ARC 109 RAD B-4, REACTOR ENCL AREA HI RADIATION</li> <li>• S27.10.A, Guidance For Addressing Area Radiation Monitoring Alarms</li> <li>• S27.1.A, Operation of the Area Radiation Monitoring System</li> </ul>					
	1. [ARC MCR 109 B-4] Reference ARC 109 B-4 to identify appropriate channel initiating alarm	Channel # 9 identified per Initial Conditions			
	2. [S27.10.A] Using S27.10.A, Guidance For Addressing Area Radiation Monitoring Alarm determine the following:	N/A			
	2a. [S27.10.A step 4.2] <b>IF</b> a high radiation alarm occurs <b>AND</b> Radiation Protection has determined the alarm to be false, <b>THEN USE</b> Attachment 1	S27.10.A Attachment 1 referenced			
	2b. [S27.10.A Attachment 1] HP has verified dose rates in area are normal <b>AND</b> ARM channel is spuriously spiking	Area dose rates normal and ARM spuriously spiking Identified per Initial Conditions			
*	2c. [S27.10.A Attachment 1] T-103 SAMP-2 ARM Channels 1,2,8,9,10,11,21,22 For either Unit 1 or 2	Candidate determines ARM channel 9 listed and follows <b>YES</b> path			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	2d. [S27.10.A Attachment 1] Place ARM in zero.	Candidate determines to place ARM in zero using S27.1.A			
*	2e. [S27.10.A Attachment 1] Have HP install a potable ARM in the vicinity of the inoperable monitor.	Candidate requests HP Tech to install potable ARM DIV 2 RHR room (Area 16, Elev 201')			
	3. [S27.1.A] Using S27.1.A, Operation of the Area Radiation Monitoring System determine area(s) affected by nuisance alarm.	DIV 2 RHR room (Area 16, Elev 201') identified			
*	4. [S27.1.A step 4.3] <b>ENSURE</b> mode switch for ARM to "ZERO" position at Aux Equipment Room panel	ARM #9 placed in ZERO			
*	5. [S27.1.A step 4.3] <b>PRESS</b> RESET button on ARM TRIP UNIT	RESET button depressed on ARM TRIP UNIT			
	6. [S27.1.A step 4.3] <b>HANG</b> an EST stating "Removed from Service per S27.1.A	EST tag hung on channel #9 ARM			
	7. [S27.1.A step 4.3] <b>VERIFY</b> applicable "Area Radiation" alarm reset in MCR	"Area Radiation" alarm reset in MCR			
	8. [S27.1.A step 4.3] <b>PRESS</b> "ACK Alarm" key on recorder RR-M1-0R601 or RR-M1-*R600	"ACK Alarm" key on recorder RR-M1-*R600 predded			
	9. [S27.1.A step 4.3] <b>VERIFY</b> LED for associated ARM on recorder RR-M1-0R601 or RR-M1-*R600 is lit	LED for associated ARM on recorder RR-M1-1R600 is lit			



ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
10. [S27.1.A step 4.3] <b>VERIFY</b> "Common Area Rad Monitor" downscale alarm 00-C824/G-5 <b>OR</b> "**Unit Area Rad Monitor" downscale *0C-800/A-5 is reset.	"Unit Area Rad Monitor" downscale 10C-800/A-5 is reset.			
<b>CUE: You have met the termination criteria for this JPM</b>				

JPM Completion Time \_\_\_\_\_

## NRC Answer Summary Page

**As a minimum the following conditions should be referenced for the spiking ARM”**

1. Identify appropriate channel initiating alarm, channel #9 is T-103 / SAMP referenced
2. Area(s) affected by nuisance alarm. - DIV 2 RHR room (Area 16, Elev 201’)
3. Have HP install a potable ARM in the vicinity of the inoperable monitor DIV 2 RHR room (Area 16, Elev 201’)
4. Place mode switch for ARM to “ZERO” position at Aux Equipment Room
5. Press RESET button on ARM TRIP UNIT



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**       SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:** ACTIONS REQUIRED FOR SPIKING ARM

**JPM Number:** LOJPM6728

**Revision Number:** 000

**Task Number and Title:** 2990090301 Apply Radiation and Contamination Safety Procedures

**K/A Number and Importance:** Generic                      2.3.15                      2.9/3.1

**Safety Function (1-9)**   9  

**Admin Category (A1-4)**   3   (*Radiation Controls*)

**Level of Difficulty (1-5)**   3  

**Suggested Testing Environment:** Classroom

**Alternate Path:**  Yes  No   **SRO Only:**  Yes  No   **Time Critical:**  Yes  No

**Reference(s):**      ARC 109 RAD B-4, REACTOR ENCL AREA HI RADIATION Rev 2

S27.10.A, Guidance For Addressing Area Radiation Monitoring Alarms Rev 9

S27.1.A, Operation of the Area Radiation Monitoring System Rev 21

**Actual Testing Environment:**  Simulator    Control Room    In-Plant    Other

**Testing Method:**    Simulate    Perform

**Estimated Time to Complete:**        15   minutes   **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?       Yes       No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:    Satisfactory    Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_      **Date:** \_\_\_\_\_





**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**DETERMINATION OF ADEQUATE SHIFT STAFFING**

JPM Number: LOJPM6712

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date





**Note:** This LGS format satisfies the TQ-JA-150 Format

### I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
 Procedure OP-LG-101-111 Rev: 5  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0712 Rev. 2. Revised to new template and to align with latest procedure revision.	11/04/16

# **Date of Revision** - refers to date revision was released for approval

#### **IV. TASK STANDARD:**

Determine that shift is below minimum staffing requirements and take appropriate corrective action to ensure adequate shift staffing.

#### **V. SIMULATOR SETUP:**

None

#### **VI. INITIAL CONDITIONS:**

1. Unit 1 is in OPCON 1
2. Unit 2 is in OPCON 4
3. Today's date is 12/25
4. It is night shift 18:00 – 06:00
5. The entire shift has participated in a Christmas meal at @ 0000
6. Initial shift staffing consists of the following;
  - 1 Shift Manager
  - 3 Senior Reactor Operators
  - 3 Reactor Operators
  - 11 Equipment Operators (5 Equipment Operators are Fire Brigade Qualified)

#### **VII. INITIATING CUE:**

At 0130, the Unit 2 Reactor Operator and a Fire Brigade Qualified Equipment Operator complain of severe stomach pain/headache and are unable to perform operator duties.

Determine if staffing requirements for current operating modes are met.

- Include any immediate and long term (greater than 2 hours) corrective actions that are required to ensure adequate shift staffing is met.

### Information for Evaluator's Use:

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



VIII. PERFORMANCE CHECKLIST:

JPM Start Time \_\_\_\_\_

ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
<b>EVALUATORS NOTE:</b> <b>Provide Candidate with the following:</b> <ul style="list-style-type: none"> <li>JPM Briefing Sheet</li> <li>OP-LG-101-111, Shift Staffing Requirements</li> </ul>					
	1. Candidate reviews OP-LG-101-111, to determine shift staffing requirements.	N/A			
	2. Determine that shift staffing is in violation of minimum shift staffing requirements per OP-LG-101-111.	N/A			
*	2a. <b>RO</b> position is not adequately filled, additionally Unit 2 must be staffed with an RO	Determination made that: RO staffing is not adequately filled per OP-LG-101-111 (Minimum required staffing is 3 ROs) An RO is required at the Unit 2 Controls			
*	2b. <b>Fire Brigade</b> position is not adequately filled	Determination made that Fire Brigade position is not adequately filled per OP-LG-101-111 (Minimum required staffing is 5)			
	3. Determine action necessary IAW current shift manning, as follows:	N/A			



ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<b>EVALUATORS NOTE:</b> <ul style="list-style-type: none"> <li>With 1 RO unable to perform duties, the shift is below minimum requirements, and Unit 2 must be staffed with an RO</li> <li>With 1 Fire Brigade qualified EO unable to perform duties the shift is below minimum requirements.</li> </ul>				
*	3a. [OP-LG-101-111 Step 4.1.1.4] States except for Shift Manager, shift crew composition may be one less than minimum requirements for up to 2 hours.	Determination made that action must be taken to restore the crew composition for the RO position within 2 hours		
*	3b. [OP-LG-101-111 Step 4.1.2.3] States the fire brigades may be less than the minimum requirements for a period not to exceed 2 hrs.	Determination made that action must be taken to restore the crew composition for the Fire Brigade within 2 hours		
	4. Take action to restore minimum shift staffing as follows:	N/A		
<b>EVALUATORS NOTE:</b> Action is required to staff the RO position. This action can include moving one of the 3 SROs into the RO position.				
*	4a. Take action to restore minimum shift staffing for RO	Perform operator call-in to get RO position manned within 2 hours or move one of the 3 SROs into the PRO/RO position. Have PRO replace Unit 2 RO until replacement arrives or SRO fills in for PRO		
*	4b. Take action to restore minimum shift staffing for Fire Brigade	Perform operator call-in to get Fire Brigade qualified EO manned within 2 hours		
<b>CUE: You have met the termination criteria for this JPM</b>				

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**       SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:**      DETERMINATION OF ADEQUATE SHIFT STAFFING

**JPM Number:** LOJPM6712                      **Revision Number:**    000

**Task Number and Title:** 3420140302   Manage the Shift Team

3430160302   Assure Adequate Personnel Coverage For All Plant Conditions In Accordance With Overtime Policy.

**K/A Number and Importance:**    Generic                      2.1.5                      2.9 / 3.9

**Safety Function (1-9)**   N/A

**Admin Category (A1-4)**   1   (Conduct Of Operations)

**Level of Difficulty (1-5)**   3

**Suggested Testing Environment:**    Classroom

**Alternate Path:**  Yes    No    **SRO Only:**  Yes    No    **Time Critical:**  Yes    No

**Reference(s):** OP-LG-101-111, Shift Staffing Requirements Rev 5

**Actual Testing Environment:**    Simulator    Control Room    In-Plant     Other

**Testing Method:**     Simulate     Perform

**Estimated Time to Complete:**   30 minutes    **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?       Yes                       No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:    Satisfactory     Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Unit 1 is in OPCON 1
1. Unit 2 is in OPCON 4
2. Today's date is 12/25
3. It is night shift 18:00 – 06:00
4. The entire shift has participated in a Christmas meal at @ 0000
5. Initial shift staffing consists of the following;
  - 1 Shift Manager
  - 3 Senior Reactor Operators
  - 3 Reactor Operators
  - 11 Equipment Operators (5 Equipment Operators are Fire Brigade Qualified)

**INITIATING CUE:**

At 0130, the Unit 2 Reactor Operator and a Fire Brigade Qualified Equipment Operator complain of severe stomach pain/headache and are unable to perform operator duties.

Determine if staffing requirements for current operating modes are met.

- Include any immediate and long term (greater than 2 hours) corrective actions that are required to ensure adequate shift staffing is met.

**Provide immediate and long term requirements and any corrective actions required below**

---

---

---

---

---

---

---

---

---

---

---

---





**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**DETERMINE ACCEPTABILITY OF INSTALLING FUEL POOL GATES**

JPM Number: LOJPM6763

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:

\_\_\_\_\_  
Instructor

\_\_\_\_\_  
Date

Validated By:

\_\_\_\_\_  
SME or Instructor

\_\_\_\_\_  
Date

Reviewed By:

\_\_\_\_\_  
Operations Representative

\_\_\_\_\_  
Date

Reviewed By:

\_\_\_\_\_  
EP Representative

\_\_\_\_\_  
Date

Approved By:

\_\_\_\_\_  
Training Department

\_\_\_\_\_  
Date



Note: This LGS format satisfies the TQ-JA-150 Format

I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>1GP-6.1</u>	Rev: <u>32</u>
Procedure <u>RT-1-053-850-0</u>	Rev: <u>7</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM is new	11/04/16

# Date of Revision - refers to date revision was released for approval

#### IV. TASK STANDARD:

Determine the heat transfer capability of the Fuel Pool Cooling System is currently insufficient to dissipate the current Decay Heat Load.

#### V. SIMULATOR SETUP:

None

#### VI. INITIAL CONDITIONS:

1. Unit 1 is in a Refueling Outage.
2. The reactor was shutdown 11 days ago
3. Refuel Floor Secondary Containment is established.
4. The only Fuel Pool Cooling available is the '2A' and '2B' FPC Pumps with the '2A' and '2B' FPC Heat Exchangers.
5. Reactor Engineering (Joe Rubinaccio) has determined the total decay heat load contained in the Spent Fuel Pools (SFP) to be the following:

Days after Shutdown	SFP Heat Load (cross tied) (MW)
9	4.77
10	4.66
11	4.56
12	4.47
13	4.40
14	4.33
15	4.27

#### VII. INITIATING CUE:

Shift Supervision directs you to perform GP- 6.1 step 3.12.10, Install Reactor Cavity/Spent Fuel Pool Gates.



**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p><b>EVALUATORS NOTE:</b>            Provide the following to the Candidate:</p> <ul style="list-style-type: none"> <li>• 1GP-6.1, Shutdown Operations – Refueling, Core Alteration and Core Offloading Pages 97, 98, and 135.</li> <li>• Completed copy of RT-1-053-850-0, Heat Transfer Capability of Fuel Pool Cooling Systems performed on 3/19/16.</li> <li>• Calculator</li> <li>• <b>Answer Rounding</b> – Students my round answers provided the rounding does not affect the outcome of the JPM.</li> </ul>				
*	1. [1GP6.1 step 3.12.10.1] <b>OBTAIN</b> the total decay heat load contained in the spent fuel pools.	Candidate determines the total heat load for day 11 of the refueling outage to be <b>4.56 MW</b> from Initial Conditions.		
	2. [1GP6.1 step 3.12.10.2] <b>RECORD</b> the spent fuel pool decay heat load on step 1 of Attachment #8	Candidate records on 1GP6-1 Attachment #8 Decay Heat Load = 4.56 MW		
	3. [1GP6.1 step 3.12.10.3] <b>DETERMINE</b> the number of Fuel Pool Cooling Water Pumps <b>AND</b> Heat Exchangers that are available	Candidate determines the 2A and 2B Fuel Pool Cooling Pumps with the 2A and 2B FPC Heat Exchangers are available from Initial Conditions.		
*	4. [1GP6.1 step 3.12.10.4] <b>RECORD</b> the heat transfer capability shown on Attachment 9 of RT-1-053-850-0 for available FPC Pumps <b>AND</b> Heat Exchangers on Step 2 of Attachment #8.	Candidate determines from Attachment #9 of RT-1-053-850-0 the Heat Transfer Capability of the Unit 2 'A' and 'B' FPC Pumps/HTXCH to be <b>15.1540845 BTU/hr</b>		



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	5. [1GP6.1 step 3.12.10.5] <b>VERIFY</b> that the heat transfer capability of the Fuel Pool Cooling System is greater than the decay heat load in the spent fuel pools.	Candidate determines the heat transfer capability of the FPC system using 1GP-6-1, Attachment 8  $15.1540845 \times 10^6 \frac{\text{BTU}}{\text{Hr}} \times 1 \frac{\text{MW}}{3.413 \times 10^6 \frac{\text{BTU}}{\text{HR}}}$ $= \underline{4.44} \text{ MW}$			
*	6. [1GP6.1 step 3.12.10.6] <b>IF</b> the heat transfer capability of the Fuel Pool Cooling System is less than the decay heat load in the spent fuel pools, <b>THEN PERFORM</b> one of the following:	Candidate determines that 4.4 MW (heat transfer capability of the FPC system) is < (less than) the 4.56 MW (decay heat load)  <u><b>4.44 MW &lt; 4.56 MW</b></u>			
*	6a. [1GP6.1 step 3.12.10.6a] <b>WAIT</b> to install Reactor Cavity/Spent Fuel Pool Gates until decay heat load in the spent fuel pool is less than or equal to the heat transfer capability of the fuel pool cooling system.	Candidate determines to wait until decay heat load in the spent fuel pool is less than or equal to the heat transfer capability of the fuel pool cooling system ( <b>Day 13</b> ) <i>(Candidate may determine to perform 1GP6.1 step 3.12.10.6b which is acceptable)</i>			
<b>CUE: You have met the termination criteria for this JPM</b>					

JPM Completion Time \_\_\_\_\_

### JPM SUMMARY

Operator's Name: \_\_\_\_\_

Job Title:  SED  SM  SRO  RO  STA/IA  EO  OTHER

JPM Title: DETERMINE ACCEPTABILITY OF INSTALLING FUEL POOL GATES

JPM Number: LOJPM6763

Revision Number: 000

Task Number and Title: 2035010401 Monitor Fuel Pool Cooling Operation

K/A Number and Importance: G2.1.40 2.8/3.9

Safety Function (1-9) N/A

Admin Category (A1-4) 1 (Conduct of Operations)

Level of Difficulty (1-5) 5

Suggested Testing Environment: Classroom

Alternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s): RT-1-053-850-0, Heat Transfer Capability of Fuel Pool cooling Systems Rev 7  
1GP6.1, Shutdown Operations, Refueling, Core Alteration and Core Offloading Rev 32

Actual Testing Environment:  Simulator  Control Room  In-Plant  Other

Testing Method:  Simulate  Perform

Estimated Time to Complete: 25 minutes Actual Time Used: \_\_\_\_\_ minutes

#### EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily?  Yes  No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_





**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Unit 1 is in a Refueling Outage.
2. The reactor was shutdown 11 days ago
3. Refuel Floor Secondary Containment is established.
4. The only Fuel Pool Cooling available is the '2A' and '2B' FPC Pumps with the '2A' and '2B' FPC Heat Exchangers.
5. Reactor Engineering (Joe Rubinaccio) has determined the total decay heat load contained in the Spent Fuel Pools (SFP) to be the following:

<b>Days after Shutdown</b>	<b>SFP Heat Load (cross tied) (MW)</b>
9	4.77
10	4.66
11	4.56
12	4.47
13	4.40
14	4.33
15	4.27

**INITIATING CUE:**

Shift Supervision directs you to perform GP- 6.1 step 3.12.10, Install Reactor Cavity/Spent Fuel Pool Gates.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**CALCULATE THE AVERAGE OFFGAS PRE-TREATMENT  
RADIOACTIVITY RELEASE RATE**

JPM Number: LOJPM6720

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By: \_\_\_\_\_  
Instructor Date

Validated By: \_\_\_\_\_  
SME or Instructor Date

Reviewed By: \_\_\_\_\_  
Operations Representative Date

Reviewed By: \_\_\_\_\_  
EP Representative Date

Approved By: \_\_\_\_\_  
Training Department Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

### I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
 Procedure GP-5 App 1 EOC Rev: 58  
 Procedure Tech Specs U#1 Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

_____	SME / Instructor	_____	Date
_____	SME / Instructor	_____	Date
_____	SME / Instructor	_____	Date

**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM modifies LLOJPM6760 Rev. 1 to an SRO JPM	10/31/16

# **Date of Revision** - refers to date revision was released for approval

#### IV. TASK STANDARD:

**RO:** Determines Radioactive off gas release rate is 14,668 to 15,266  $\mu\text{Ci}/\text{sec}$  and chemistry sampling is required.

**SRO:** Determines Tech Spec 3.4.5 sampling requirements for DOSE EQUIVALENT I-131: Perform the sampling and analysis requirements of Item 4.a of Table 4.4.5-1 (At least once per 4 hours) until the specific activity of the primary coolant is restored to within its limit.

#### V. SETUP INSTRUCTIONS

1. Provide the following:
  - Calculator
  - GP-5 Appendix 1, End of Steady State Operations
  - Placard that is mounted to the 10C600 Panel

SUM OF SIX	<u>139</u>
K "A"	<u>0.082</u>
K "B"	<u>0.080</u>
Date:	_____

#### VI. INITIAL CONDITIONS:

##### 1. Initial Conditions

- a. Unit 1 is in OPCON 1
- b. 1 hour ago
  - The average Off-gas pretreatment release rate was 341.2  $\mu\text{Ci}/\text{sec}$
  - FR-69-115 read 74 scfm

##### 2. Current Plant Conditions 1 hour later

- a. Unit 1 is in OPCON 1
- b. There was an increase in SJAE Discharge Rad Monitor readings, the current readings are:
  - RR-26-1R601 "A" SJAE Discharge Rad Monitor reads 2461 mRem/hr
  - RR-26-1R601 "B" SJAE Discharge Rad Monitor reads 2534 mRem/hr
- c. FR-69-115 reads 74 scfm



**VII. INITIATING CUE:**

You are directed to calculate the average offgas pre-treatment radioactivity release rate per GP-5 Appendix 1, End of Steady State Operations, and identify any required actions.

<b>U/1 OFFGAS</b>	
SUM OF SIX	<u>139</u>
K "A"	<u>0.082</u>
K "B"	<u>0.080</u>
Date:	_____

**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**

**VIII. PERFORMANCE CHECKLIST:**
**JPM Start Time** \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p>1. Obtain a copy of current revision of GP-5 Appendix 1, End of Steady State Operations</p> <p><b>CUE:</b> Candidate is given a copy of the procedure when knowledge of the correct location of procedure is demonstrated.</p>	<p>Candidate demonstrates ability (actual or discuss) to locate the correct procedure.</p>			
<p>2. CALCULATE Off-gas release rates for the A <u>AND</u> B channels using the following equation:</p> $RR = RL \times F \times K$ <p>RR = Release Rate for A(B) (<math>\mu</math>Ci/second)</p> <p>RL = Radiation Level of SJAE as indicated on RR-26-1R601 (mRem/hour)</p> <p>F = Off-gas flow as indicated by FR-69-115 (scfm), Point 2</p> <p>K = Conversion Factor for A(B) data (posted on panel 10C600)</p>	<p>N/A</p>			
<p>* 3. <b>Channel A</b> (Point 1)</p> <p>RR = _____ mRem/hour X _____ CFM X <u> K</u></p> <p>RR = _____ <math>\mu</math>Ci/second</p>	<p>Calculate "A" channel release</p> $2461 \times 74 \times 0.082 =$ <p><u>14,933.3</u> <math>\mu</math>Ci/sec</p>			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
*	<p>4. <b>Channel B</b> (Point 2)</p> <p>RR = ___ mRem/hour x ___ CFM x ___ K</p> <p>RR = ___ <math>\mu</math>Ci/second</p>	<p>Calculate "B" channel release</p> <p>2534 x 74 x 0.080 = 15,001.2 <math>\mu</math>Ci/sec</p>			
*	<p>5. CALCULATE the average of the A AND B channel values to obtain the average Off-gas pretreatment release rate as follows:</p> $ARR = \frac{(RR \text{ "A"} + (RR \text{ "B"}))}{2}$ <p>Where:</p> <p>ARR = Average Off-gas Pretreatment Release Rate (<math>\mu</math>Ci/second)</p> <p>RR "A" = Release Rate value for "A" Channel (<math>\mu</math>Ci/second)</p> <p>RR "B" = Release Rate value for "B" Channel (<math>\mu</math>Ci/second)</p> $ARR = \frac{( \quad ) + ( \quad )}{2}$ <p>ARR = _____ <math>\mu</math>Ci/second</p>	<p>Calculate the average release rate</p> <p>ARR =</p> $\frac{(14,933.3 + 15001.2)}{2}$ <p>ARR=14,967.2 <math>\mu</math>Ci/sec</p> <p>Acceptable band is 14,668 to 15,266 (14,967 +/- 2%)</p>			
*	<p>6. <b>IF</b> Off-Gas Release Rate rises by &gt;10,000 <math>\mu</math>Ci/second in 1 hour during steady state operation at release rates &lt;75,000 <math>\mu</math>Ci/second <b>THEN CONTACT</b> Chemistry to perform ST-5-041-885-*, Dose Equivalent I-131 Determination</p>	<p>Chemistry notified to perform ST.</p> <p>Cue: Chemistry acknowledges request to complete the ST and will notify the CRS with the results</p>			





ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p>7. <b>IF</b> Off-Gas Release Rate rises by more than 50%, <b>THEN CONTACT</b> Chemistry to perform ST-5-070-885-*, Isotopic Offgas Analysis</p> <p><b>CUE:</b> Chemistry acknowledges request to complete the ST and notifies the CRS with the results</p> <p><b>RO ONLY:</b> You have met the termination criteria for this JPM</p>	<p>Chemistry notified to perform ST.</p>			
<p><b><u>SRO ONLY Portion</u></b></p> <p><b>EVALUATORS NOTE:</b> With time compression, Chemistry has completed ST-5-041-885-1 and notifies the CRS with the results.</p> <p><b>Provide candidate with final briefing sheet #2</b>            Fill in date and time 15 minutes after sample requested</p> <p>If requested, Chemistry also notifies the CRS that they are still working on ST-5-070-885-1</p>				
<p>*</p>	<p>8. Based on the results of ST-5-041-885-1 the CRS determines Tech Spec action(s)</p>	<p>In OPERATIONAL CONDITION 1, 2, 3, or 4, with the specific activity of the primary coolant greater than 0.2 microcuries per gram DOSE EQUIVALENT I-131, <b><u>perform the sampling and analysis requirements of Item 4.a of Table 4.4.5-1 ( at least once per 4 hours)</u></b> until the specific activity of the primary coolant is restored to within its limit.</p>		
<p><b>CUE: You have met the termination criteria for this JPM</b></p>				

JPM Completion Time \_\_\_\_\_





LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET

INITIAL CONDITIONS - Sheet # 1

2. Initial Conditions

- a. Unit 1 is in OPCON 1
- b. 1 hour ago
  - The average Off-gas pretreatment release rate was 341.2 uCi/sec
  - FR-69-115 read 74 scfm

3. Plant Conditions 1 hour later

- a. Unit 1 is in OPCON 1
- b. There was an increase in SJAE Discharge Rad Monitor readings, the current readings are:
  - RR-26-1R601 "A" SJAE Discharge Rad Monitor reads 2461 mRem/hr
  - RR-26-1R601 "B" SJAE Discharge Rad Monitor reads 2534 mRem/hr
- c. FR-69-115 reads 74 scfm

INITIATING CUE

You are directed to calculate the average offgas pre-treatment radioactivity release rate per GP-5 Appendix 1, End of Steady State Operations, and identify any required actions.

The following placard is mounted to the 10C600 panel:

<b>U/1 OFFGAS</b>	
SUM OF SIX	<u>139</u>
K "A"	<u>0.082</u>
K "B"	<u>0.080</u>
Date:	_____



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET (#2)**

**Final Conditions - Sheet # 2**

**Chemistry notifies the Control Room Supervisor with the results of  
ST-5-041-885-1 Dose Equivalent I-131 Determination**

I.D.E. Activity (uCi/gm) .3 microcuries per gram

Sample Date/Time \_\_\_\_\_ / \_\_\_\_\_

**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**ERP CLASSIFICATION AND REPORTING (TIME CRITICAL)**

JPM Number: LOJPM3097

REVISION NUMBER: 004

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date



Note: This LGS format satisfies the TQ-JA-150 Format

I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- 1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cues (and terminating cues if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
8. If an alternate path is used, the task standard contains criteria for successful completion.
9. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure EP-AA-1008 Addendum 3 Rev: 002
Procedure EP-MA-114-100-F-01 Rev: P
Procedure EP-AA-112-100-F-01 Rev: V
Procedure EP-AA-111-F-11 Rev: A
Procedure Rev:
10. Verify cues both verbal and visual are free of conflict.
11. Verify performance time is accurate
12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor Date
SME / Instructor Date
SME / Instructor Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0097 Rev. 10. Revised to new template and to align with latest procedure revision.	10/15/13
001	Added Site Area Emergency declared 10 minutes after initial event due to the fact that original JPM did not provide an initial declaration within the required 15 minutes. This changes the JPM to an escalation.	10/6/14
002	Revised due to new Limerick PAR Flowchart, EP-AA-111-F-11. Sectors expanded for evacuation 2-5 miles.	06/19/15
003	Revised to new template	10/13/15
Rev004	Revised JPM to new template and procedural revisions	11/03/16

# Date of Revision - refers to date revision was released for approval

#### IV. TASK STANDARD:

1. General Emergency (FG1) is declared within 15 minutes of the candidate beginning the classification.
2. Notification form completed and provided to Shift Communicator within 15 minutes of declaring the General Emergency.

#### V. SIMULATOR SETUP:

Use existing IC Met Data

Insert the following Met Data values:

**RZZ002** MET Data Wind Direction (0-360) DEG AZIMUTH Target Value = 311°

**RZZ003** MET Data Wind Speed (0-100) MPH Target Value = 5.0 mph

North Stack WRAM is indicating 2.5E+6  $\mu$ Ci/sec.

Post LOCA Rad Monitors are reading the following:

A - 96 R/hr.

B - 89 R/hr.

C - 103 R/hr.

D - 97 R/hr.

#### VI. INITIAL CONDITIONS:

Unit 1 is initially at 100% power when the following events occur:

T = 0

- 'A' Steam Line ruptures in the Outboard MSIV Room
- Group 1 Isolation signal is received due to high steam line flow
- A full scram occurs with all rods inserted
- "A" Steam Line Inboard and Outboard MSIVs fail to isolate automatically or manually

T = 5 minutes

- Reactor Coolant Activity starts to rise

T = 10 minutes

- EAL threshold recognized and emergency declaration made

T = 15 minutes

- State and Local notifications complete for emergency declaration
- Shift Communicator has activated the ERO





## VII. CURRENT PLANT CONDITIONS:

- RPV pressure is 850 psig and lowering
- RPV level is +18" and steady
- DW pressure is 0.3 psig
- Reactor Coolant Activity is 370  $\mu\text{Ci/gm}$
- Outboard MSIV Room temperature is 210 degrees F, up slow
- Security personnel confirms a steam release outside secondary containment from blowout panels
- North Stack WRAM is indicating 2.5E+6  $\mu\text{Ci/sec}$ .
- Post LOCA Rad Monitors are reading the following:
  - A - 96 R/hr.
  - B - 89 R/hr.
  - C - 103 R/hr.
  - D - 97 R/hr.

## VIII. INITIATING CUES: This Task is Time Critical

This JPM will start when you tell the evaluator that you are aware of task conditions and are ready to begin.

You are required to make the highest classification based on the given plant conditions and make subsequent call outs. All communications should indicate a drill.

### Information for Evaluator's Use:

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**IX. PERFORMANCE CHECKLIST:**

JPM Start Time: \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<b>NOTE TO EVALUATOR//DRIVER:</b> If JPM is NOT conducted in Simulator: Provide a screen shot of "Meteorological 15 Minute Average Point Data".					
	1. REFER to the appropriate LGS EAL Matrix	N/A	N/A		
	2. Call for Shift Communicator to report to MCR	Shift Communicator called to report to MCR			
	3. Identify the operating MODE for the affected Unit(s) prior to the abnormal condition, and obtain appropriate Matrix.	Matrix obtained: <input checked="" type="checkbox"/> HOT <input type="checkbox"/> COLD			
	4. Review the initiating conditions applicable to the operating MODE.	Use EAL Matrix to classify event	N/A		
*	5. DECLARE the event	Event Declared: <input type="checkbox"/> UNUSUAL EVENT <input type="checkbox"/> ALERT <input type="checkbox"/> SITE AREA EMERGENCY <input checked="" type="checkbox"/> GENERAL EMERGENCY Declared 15 minutes of the JPM START TIME: DECLARATION TIME:			
	6. Direct Shift Communicator to activate the ERO or make management only notifications	N/A  (Shift Communicator has activated ERO per Initial Conditions)			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	7. Complete the Event Notification form	At the completion of the JPM the Event Notification Form will be evaluated against the JPM standard located below.	N/A		
	8. Direct Shift Communicator to perform state and local notifications	Shift Communicator notified to make notifications <b>within 15</b> minutes of DECLARATION TIME.  Declaration Time: Notification Initiated Time:  NOTE: the expectation is notification is initiated <b>within 9</b> (nine) minutes of declaration time. Notification times between 9-15 minutes constitutes a pass with comment.			
	<b>CUE:</b> When form has been completed and Shift Communicator informed to process form:  "You have met the termination criteria for this JPM"	N/A	N/A		
	<b>NOTE:</b> The following steps are performed by the evaluator following the student providing the Notification form to the evaluator.				



	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	COMMENT NUMBER
<b>EP-MA-114-100-F-01, STATE/LOCAL EVENT NOTIFICATION FORM</b>					
	9. UTILITY MESSAGE NO.	"2" or equivalent entered			
	10. VERIFIED WITH	N/A	N/A		
	11. EMERGENCY DIRECTOR APPROVAL	Signature entered			
*	12. CALL STATUS:	Call Status marked <input checked="" type="checkbox"/> THIS IS A DRILL			
*	13. AFFECTED STATION:	Affected Station marked for <input checked="" type="checkbox"/> LIMERICK			
*	14. AFFECTED UNIT(S):	Unit(s) marked <input checked="" type="checkbox"/> ONE <input type="checkbox"/> TWO			
*	15. CLASSIFICATION:	Classification marked <input type="checkbox"/> UNUSUAL EVENT <input type="checkbox"/> ALERT <input type="checkbox"/> SITE AREA EMERGENCY <input checked="" type="checkbox"/> GENERAL EMERGENCY			
*	16. DECLARED AT:	Time entered Date entered			
	17. THIS REPRESENTS A/AN:	This Represents marked <input type="checkbox"/> INITIAL DECLARATION <input checked="" type="checkbox"/> ESCALATION <input type="checkbox"/> NO CHANGE			
*	18. EMERGENCY ACTION LEVEL (EAL) NUMBER:	"FG1" entered Thresholds: FC.1 <u>AND</u> (RC.5 <u>OR</u> RC.4.1 <u>OR</u> RC.4.3) <u>AND</u> (CT.6.1 <u>OR</u> CT.6.3.a)			



	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	COMMENT NUMBER
*	19. A BRIEF NON-TECHNICAL DESCRIPTION OF THE EVENT:	<input type="checkbox"/> A- Abnormal Rad Levels/ Radiological Effluent <input checked="" type="checkbox"/> B- Fission Product Barrier Degradation <input type="checkbox"/> C- System Malfunction <input type="checkbox"/> D- Hazards and Other Conditions Affecting Plant Safety <input type="checkbox"/> E- Independent Spent Fuel Storage Installation Malfunction <input type="checkbox"/> F- Cold Shutdown/Refueling System Malfunctions			
*	20. RADIOLOGICAL RELEASE STATUS:	Release Status marked <input type="checkbox"/> NO RELEASE <input checked="" type="checkbox"/> AIRBORNE <input type="checkbox"/> LIQUID <input type="checkbox"/> RELEASE TERMINATED			
*	21. METEOROLOGY DATA:  Cue: Provide MET Attachment only if in location other than simulator	<b>Simulator Values</b> match displayed Tower 1 175' using 15 minute average values: Wind Direction: <u>311.0</u> (degrees) Wind Speed: <u>5.0</u> (MPH) <b>Attachment Values :</b> Wind Direction: <u>311.0</u> (degrees) Wind Speed: <u>5.0</u> (MPH)			
*	22. PROTECTIVE ACTION RECOMMENDATION (a or b):	PAR Recommendation marked <input type="checkbox"/> NOT Applicable <input checked="" type="checkbox"/> PAR Recommendation			



	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	COMMENT NUMBER																																
	<p><b>NOTE: IF PAR RECOMMENDATION is required the following items should be marked:</b></p> <p>[S/E] 360 DEGREES FROM 0 MILES (SITE BOUNDARY) TO 2 MILES</p> <p><b>AND</b></p> <p><b>THE FOLLOWING SECTORS FROM 2 MILES TO 5 MILES:</b></p> <table border="0"> <tr> <td>[S/E] N</td> <td>[S/E] E</td> <td>[S/E] S</td> <td>[S/E] W</td> </tr> <tr> <td>[S/E] NNE</td> <td>[S/E] ESE</td> <td>[S/E] SSW</td> <td>[S/E] WNW</td> </tr> <tr> <td>[S/E] NE</td> <td>[S/E] SE</td> <td>[S/E] SW</td> <td>[S/E] NW</td> </tr> <tr> <td>[S/E] ENE</td> <td>[S/E] SSE</td> <td>[S/E] WSW</td> <td>[S/E] NNW</td> </tr> </table> <p><b>AND</b></p> <p><b>THE FOLLOWING SECTORS FROM 5 MILES TO 10 MILES:</b></p> <table border="0"> <tr> <td>[S/E] N</td> <td>[S/E] E</td> <td>[S/E] S</td> <td>[S/E] W</td> </tr> <tr> <td>[S/E] NNE</td> <td>[S/E] ESE</td> <td>[S/E] SSW</td> <td>[S/E] WNW</td> </tr> <tr> <td>[S/E] NE</td> <td>[S/E] SE</td> <td>[S/E] SW</td> <td>[S/E] NW</td> </tr> <tr> <td>[S/E] ENE</td> <td>[S/E] SSE</td> <td>[S/E] WSW</td> <td>[S/E] NNW</td> </tr> </table> <p><b>AND</b></p> <p>Potassium Iodide (KI) be administered to the general public in accordance with state procedures and advise the remainder of the EPZ to Monitor and Prepare.</p> <p><b>AND</b></p> <p>This Protective Action Recommendation [IS] [IS NOT] the result of a Rapidly Progressing Severe Accident</p>					[S/E] N	[S/E] E	[S/E] S	[S/E] W	[S/E] NNE	[S/E] ESE	[S/E] SSW	[S/E] WNW	[S/E] NE	[S/E] SE	[S/E] SW	[S/E] NW	[S/E] ENE	[S/E] SSE	[S/E] WSW	[S/E] NNW	[S/E] N	[S/E] E	[S/E] S	[S/E] W	[S/E] NNE	[S/E] ESE	[S/E] SSW	[S/E] WNW	[S/E] NE	[S/E] SE	[S/E] SW	[S/E] NW	[S/E] ENE	[S/E] SSE	[S/E] WSW	[S/E] NNW
[S/E] N	[S/E] E	[S/E] S	[S/E] W																																		
[S/E] NNE	[S/E] ESE	[S/E] SSW	[S/E] WNW																																		
[S/E] NE	[S/E] SE	[S/E] SW	[S/E] NW																																		
[S/E] ENE	[S/E] SSE	[S/E] WSW	[S/E] NNW																																		
[S/E] N	[S/E] E	[S/E] S	[S/E] W																																		
[S/E] NNE	[S/E] ESE	[S/E] SSW	[S/E] WNW																																		
[S/E] NE	[S/E] SE	[S/E] SW	[S/E] NW																																		
[S/E] ENE	[S/E] SSE	[S/E] WSW	[S/E] NNW																																		
*	23. UTILITY PAR recommendations	Correct PAR Recommendation marked including required sectors																																			
	24. CONCLUSION	Conclusion marked <input checked="" type="checkbox"/> THIS IS A DRILL (Critical that at least one of the two status blocks on the page is marked correctly and no contradictory info is marked. If contradictory info is marked, then the incorrect step is UNSAT. If one block is blank and the other is correct, then the blank block is N/A)																																			

JPM Stop Time: \_\_\_\_\_

**JPM SUMMARY**

Operator's Name: \_\_\_\_\_

Job Title:         SED    SM    SRO    RO    STA/IA    EO    OTHER

JPM Title:    ERP CLASSIFICATION AND REPORTING (TIME CRITICAL)

JPM Number: LOJPM3097

Revision Number:    004

Task Number and Title: 3440070302, Classify Emergency Events Requiring Emergency Plan Implementation

K/A Number and Importance:    Generic                    2.4.41                    4.6

Safety Function (1-9)   N/A  Admin Category (A1-4)   4  Level of Difficulty (1-5)   3  

Suggested Testing Environment:    Simulator

Alternate Path:  Yes  No    SRO Only:  Yes  No    Time Critical:  Yes  No

Reference(s):    EP-AA-1008, LGS EMERGENCY ACTION LEVEL (EAL) MATRIX, Rev 2

EP-MA-114-100-F-01, STATE/LOCAL EVENT NOTIFICATION FORM, Rev P

EP-AA-112-100-F-01, SHIFT EMERGENCY DIRECTOR CHECKLIST, Rev V

\*\*\*\*\* EP-AA-111-F-11, Limerick PAR Flowchart, Rev. A

Actual Testing Environment:  Simulator    Control Room    In-Plant    OtherTesting Method:    Simulate    PerformEstimated Time to Complete:  27  minutes    Actual Time Used:        minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?    Yes    NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:    Satisfactory    UnsatisfactoryComments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

Unit 1 is initially at 100% power when the following events occur:

T = 0

- 'A' Steam Line ruptures in the Outboard MSIV Room
- Group 1 Isolation signal is received due to high steam line flow
- A full scram occurs with all rods inserted
- "A" Steam Line Inboard and Outboard MSIVs fail to isolate automatically or manually

T = 5 minutes

- Reactor Coolant Activity starts to rise

T = 10 minutes

- EAL threshold recognized and emergency declaration made

T = 15 minutes

- State and Local notifications complete for emergency declaration
- Shift Communicator has activated the ERO





**Current Plant Conditions:**

- RPV pressure is 850 psig and lowering
- RPV level is +18" and steady
- DW pressure is 0.3 psig
- Reactor Coolant Activity is 370  $\mu\text{Ci/gm}$
- Outboard MSIV Room temperature is 210 degrees F, up slow
- Security personnel confirms a steam release outside secondary containment from blowout panels
- North Stack WRAM is indicating  $2.5\text{E}+6 \mu\text{Ci/sec}$ .
- Post LOCA Rad Monitors are reading the following:
  - A - 96 R/hr.
  - B - 89 R/hr.
  - C - 103 R/hr.
  - D - 97 R/hr.

**INITIATING CUES: This Task is Time Critical**

This JPM will start when you tell the evaluator that you are aware of task conditions and are ready to begin.

You are required to make the highest classification based on the given plant conditions and make subsequent call outs. All communications should indicate a drill.

## 917 METEOROLOGICAL 15 MINUTE AVERAGE POINT DATA

	PID	SENSOR	DESCRIPTION	VALUE	EU
<b>T O W E R  1</b>	T1DTULFA	T1.SP.U	TOWER 1 270 FT WIND SPEED	6.7	MPH
	T1SPIFA	T1.SP.I	TOWER 1 175 FT WIND SPEED	5.0	MPH
	T12SPLFA	T1.SP.L	TOWER 1 30 FT WIND SPEED	7.3	MPH
	T1DRUFA	T1.DR.U	TOWER 1 270 FT WIND DIRECTION	252.3	DEG AZ
	T1DRIFA	T1.DR.I	TOWER 1 175 FT WIND DIRECTION	311.0	DEG AZ
	T1DRLFA	T1.DR.L	TOWER 1 30 FT WIND DIRECTION	257.2	DEG AZ
	T1DTULFA	T1.DT.U-L	TOWER 1 266 - 26 FT DELTA TEMP	-0.3	DEG F
	T1DTILFA	T1.DT.I-L	TOWER 1 171 - 26 FT DELTA TEMP	0.4	DEG F
	T1ATLFA	T1.AT.L	TOWER 1 26 FT AMBIENT TEMP	85.2	DEG F
	T1DPLFA	T1.DP.L	TOWER 1 26 FT DEW POINT	45.00	DEG F
	T1RNFA	T1.RN	TOWER 1 PRECIPITATION	0.1	INCHES
<b>T O W E R  2</b>	T2DTULFA	T2.SP.U	TOWER 2 304 FT WIND SPEED	6.8	MPH
	T2SPIFA	T2.SP.I	TOWER 2 159 FT WIND SPEED	7.3	MPH
	T22SPLFA	T2.SP.L	TOWER 2 30 FT WIND SPEED	7.8	MPH
	T2DRUFA	T2.DR.U	TOWER 2 304 FT WIND DIRECTION	251.7	DEG AZ
	T2DRIFA	T2.DR.I	TOWER 2 159 FT WIND DIRECTION	250.5	DEG AZ
	T2DRLFA	T2.DR.L	TOWER 2 30 FT WIND DIRECTION	257.6	DEG AZ
	T2DTULFA	T2.DT.U-L	TOWER 2 304 - 26 FT DELTA TEMP	-0.4	DEG F
	T2DTILFA	T2.DT.I-L	TOWER 2 155 - 26 FT DELTA TEMP	0.6	DEG F
	T2ATLFA	T2.AT.L	TOWER 2 26 FT AMBIEWNT TEMP	85.0	DEG F
	T2DPLFA	T2.DP.L	TOWER 2 26 FT DEW POINT	44.81	DEG F



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**SCRAM RESET**

JPM Number: LOJPM3001

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:

\_\_\_\_\_  
Instructor

\_\_\_\_\_  
Date

Validated By:

\_\_\_\_\_  
SME or Instructor

\_\_\_\_\_  
Date

Reviewed By:

\_\_\_\_\_  
Operations Representative

\_\_\_\_\_  
Date

Reviewed By:

\_\_\_\_\_  
EP Representative

\_\_\_\_\_  
Date

Approved By:

\_\_\_\_\_  
Training Department

\_\_\_\_\_  
Date



Note: This LGS format satisfies the TQ-JA-150 Format

I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- 1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cues (and terminating cues if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
8. If an alternate path is used, the task standard contains criteria for successful completion.
9. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure GP-11 Rev: 29
Procedure Rev:
Procedure Rev:
Procedure Rev:
Procedure Rev:
10. Verify cues both verbal and visual are free of conflict.
11. Verify performance time is accurate
12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor Date
SME / Instructor Date
SME / Instructor Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM supersedes LLOJPM0001Rev. 15. Revised to new template and to align with latest procedure revision.	10/31/16

# **Date of Revision** - refers to date revision was released for approval

#### IV. TASK STANDARD:

Insert a full reactor scram signal upon recognition that scram will not reset after 2<sup>nd</sup> attempt.

#### V. SIMULATOR SETUP:

1. Reset simulator to IC-3, or another IC if JPM was validated in the respective IC.

**NOTE:** It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Transfer house loads.
3. Place Reactor Mode Switch in "SHUTDOWN".
4. Ensure Rod Drift Alarms are reset.
5. Insert malfunction **MRP028B**, RPS Group 1 Reactor Scram.
6. Acknowledge and clear all spurious alarms.

#### VI. INITIAL CONDITIONS:

1. Unit 1 Reactor was scrammed for a planned shutdown.
2. The SDV has been surveyed by Radiation Protection
3. HEPA Filters and Protective Laundry Bags are not required to be installed on 253' Elevation Floor Drains
4. Flushing of the SDV per RT-6-047-600-1 has been determined not to be required after SCRAM reset
5. No HCUs currently have clearances applied
6. All Prerequisites have been met.

#### VII. INITIATING CUE:

Shift supervision directs you to perform a Unit 1 RPS scram reset per GP-11.



**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
	<p>1. Obtain current revision of GP-11, Scram Reset</p> <p><b>CUE:</b> Candidate is given a copy of GP-11, Scram Reset when knowledge of the correct location of procedure is demonstrated.</p>	<p>Candidate demonstrates ability (actual or discuss) to locate GP-11, Scram Reset</p>			
	<p>2. <b>REQUEST</b> Radiation Protection to perform the following:</p>	N/A			
	<p>2a. <b>SURVEY</b> SDV prior to release of fluid inventory.</p>	<p>Radiation Protection requested to survey SDV</p>			
	<p>2b. <b>EVALUATE</b> the need for RT-6-047-600-*, Flush of CRD Scram Discharge Volume (SDV)."</p> <p><b>CUE:</b> Report that RP has surveyed the SDV and that the RT is not required to be done.</p>	<p>CRD Scram Discharge Volume flush not required per Initial Conditions.</p>			
	<p>2c. <b>IF</b> time permits <b>THEN NOTIFY</b> Rad Pro to install HEPA filters <b>AND</b> Protective Clothing Bags over the Reactor Enclosure 253' elevation floor drains per RP-LG-301-2001 <u>prior to</u> scram reset</p> <p><b>CUE:</b> Protective bags and HEPA Filters are not required.</p>	<p>Protective bags over floor drains not required per Initial Conditions.</p>			





ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
* 3. <b>PLACE</b> Scram Discharge Volume High Level Bypass Keylock Switch on *0C603 to "BYPASS".	SDV High Level Bypass Switch in "BYPASS" position.			
* 4. <b>VERIFY</b> Annunciator Panel *07, REACTOR, Window C-2, "SCRAM DISC VOLUME HI LEVEL SCRAM BYPASSED," is in alarm.	Verify by observation that "SDV HI LEVEL SCRAM BYPASSED", 107 REACTOR (C-2), is lit.			
5. <b>ENSURE</b> Annunciator panel *08, REACTOR, Window E-5, "RPIS INOPERATIVE" is clear.	Annunciator panel *08, REACTOR, Window E-5, "RPIS INOPERATIVE" is clear			
6. <b>IF</b> Annunciator Panel *08, REACTOR, Window E-4, "RDCS INOPERATIVE," is in alarm, <b>THEN RESET</b> the Rod Drive Control System (RDCS) in accordance with S73.0.F, "Resetting the Rod Drive Control System". <u>Otherwise MARK</u> this	N/A			
7. <b>IF</b> CRD Full Core Display <b>OR</b> Process Computer indicates <b>not all</b> control rods are fully inserted, <b>THEN PERFORM</b> GP-11 Appendix I using Attachment 1. <u>Otherwise MARK</u> this step <b>AND</b> Appendix 1 Steps 3.1 through 3.2.2 N/A	N/A			
8. <b>RESET</b> Alternate Rod Insertion (ARI) at panel *0C603 as follows:	N/A			
8a. <b>DEPRESS</b> ARI RESET pushbuttons (1A, 1B, 2A, 2B).	ARI Reset pushbuttons 1A, 1B, 2A, 2B depressed.			
9. <b>RESET</b> RPS at panel *0C603 as follows:	N/A			
* 9a. <b>PLACE</b> Scram Reset switch to "GP 1/4".	Scram Reset Switch taken to GP 1/4 position.			
* 9b. <b>PLACE</b> Scram Reset switch to "GP 2/3".	Scram Reset Switch taken to GP 2/3 positions.			
<p><b>Evaluator Note: Alternate Path begins with the next step. The next step is a failure of the scram to reset.</b></p>				



ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
*	10. <b>VERIFY</b> the eight (8) scram group white lights are Lit for Scram System A <b>AND</b> Scram System B on *0C603.	Recognize 1 light for RPS 'A' and 1 light for RPS 'B' did <b>not</b> light.			
	11. <b>IF</b> the eight scram group white lights are <b>not</b> lit after initial reset, <b>THEN VERIFY</b> proper Reactor Mode Switch position...	Verify Mode switch in "SHUTDOWN".			
*	12. <b>AND REPEAT</b> step 3.8 one time (Reset RPS)	N/A			
*	13. <b>PLACE</b> Scram Reset switch to "GP 1/4".	Scram Reset Switch taken to GP 1/4 position.			
*	14. <b>PLACE</b> Scram Reset switch to "GP 2/3".	Scram Reset Switch taken to GP 2/3 position.			
*	15. <b>VERIFY</b> the eight (8) scram group white lights are Lit for Scram System A <b>AND</b> Scram System B on *0C603.	Recognize 1 light for RPS 'A' and 1 light for RPS 'B' did <b>not</b> light.			
	16. <b>IF</b> the eight scram group white lights are <b>not</b> Lit after second reset attempt, <b>THEN PERFORM</b> the following:	N/A			
	17. <b>VERIFY</b> blue lights on Full Core Display are not Lit, unless determined to be expected for clearance application	No HCUs have clearances applied per Initial Conditions.			
	18. <b>IF</b> blue lights on Full Core Display are Lit <b>THEN PERFORM</b> the following:	N/A			
*	18a. <b>INSERT</b> a full scram signal via Manual Scram Pushbuttons	Manual scram initiated using Manual Scram Pushbuttons			
*	18b. <b>VERIFY</b> SDV vent <b>AND</b> drain valves close	SDV vent and drain valves verified closed.			
<b>CUE: You have met the termination criteria for this JPM</b>					

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**         SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:** SCRAM RESET

**JPM Number:** LOJPM3001

**Revision Number:** 000

**Task Number and Title:** 2957010401, Reset a Scram

**K/A Number and Importance:** 295006                      AA1.01                      4.2/4.2

**Safety Function (1-9)   1   (Reactivity Control)**

**Admin Category (A1-4)   N/A**

**Level of Difficulty (1-5)   3**

**Suggested Testing Environment:** Simulator

**Alternate Path:**  Yes    No   **SRO Only:**  Yes    No   **Time Critical:**  Yes    No

**Reference(s):** GP-11 Reactor Protection System – Scram reset Rev 29

**Actual Testing Environment:**  Simulator    Control Room    In-Plant    Other

**Testing Method:**    Simulate    Perform

**Estimated Time to Complete:**   15   minutes   **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?         Yes                       No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:    Satisfactory    Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Unit 1 Reactor was scrammed for a planned shutdown.
2. The SDV has been surveyed by Radiation Protection
3. HEPA Filters and Protective Laundry Bags are not required to be installed on 253' Elevation Floor Drains
4. Flushing of the SDV per RT-6-047-600-1 has been determined not to be required after SCRAM reset
5. No HCUs currently have clearances applied
6. All Prerequisites have been met.

**INITIATING CUE:**

Shift supervision directs you to perform a Unit 1 RPS scram reset per GP-11.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**RCIC MANUAL SLOW START USING FIC-49-1R600**

JPM NUMBER: LOJPM3015

REVISION NUMBER: 002

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

### I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>S49.1.D</u>	Rev: <u>42</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0015 Rev. 7. The purpose of this revision is to reformat in accordance with the new JPM template and to ensure agreement with latest procedure revision.	08/30/13
001	Minor revision for procedural compliance, and remove prerequisite steps from JPM section VIII.	10/20/15
002	Revised to new JPM standard and added prerequisites satisfied	8/04/16

# **Date of Revision** - refers to date revision was released for approval

#### IV. TASK STANDARD:

RCIC in full flow with a discharge pressure at least 70 psig greater than reactor pressure, and a pump flowrate of 600 gpm with the controller in AUTO.

#### V. SIMULATOR SETUP:

1. Reset simulator to IC-3, or another IC if JPM was validated in the respective IC.

**NOTE:** It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Align RCIC for automatic operation.

#### VI. INITIAL CONDITIONS:

1. LGS Unit 1 is in OPCON 1
2. ST-6-060-390-1 is currently being performed by a second operator
3. S49.9.A, Routine Inspection of RCIC system has been performed
4. Vibration Monitoring System is in service
5. Steam Leak Detection System is not known to be INOP
6. An EO and RP Tech are on station and the Unit 1 RCIC room is posted
7. S49.1.D, RCIC System Full Flow Functional Test prerequisites are satisfied

#### VII. INITIATING CUE STATEMENT (Describe the task clearly):

You are directed by Shift Supervisor to place Unit 1 RCIC in full flow test for a 15 minute PMT using S49.1.D, to obtain discharge pressure at least 70 psig greater than reactor pressure, and a pump flowrate of 600 gpm with the controller in AUTO by the manual slow start method using FIC-49-1R600.





**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

**\***

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
1. <b>OBTAIN</b> current revision of S49.1.D.  <b>CUE:</b> Provide M/U copy of S49.1.D to candidate, with prerequisites signed-off.	Current revision of S49.1.D obtained.			
2. <b>VERIFY</b> all prerequisites satisfied.	Prerequisites are verified and checked off as complete.			
3. <b>VERIFY</b> procedure being performed on correct unit/train	N/A			
4. <b>IF</b> Vibration Monitoring System is available, <b>THEN VERIFY</b> in service.	N/A			
5. <b>PERFORM</b> the following:	N/A			
5a. <b>ENSURE</b> HV-55-*F071, "HPCI/RCIC Flush Line to Suppression Pool" (TEST OUTBOARD), closed.	HV-55-1F071 is verified closed.			
5b. <b>ENSURE</b> HV-55-*F008, "Test Loop Shutoff" (TEST ISOL), closed.	HV-55-1F008 is verified closed.			
5c. <b>ENSURE</b> HV-49-*F022, "RCIC Test Loop Isolation" (TEST ISOL), is closed.	HV-49-1F022 is verified closed.			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	6. <b>PERFORM</b> the following to open HV-055-*F011, "HPCI/RCIC PP. Test Return to C.S.T. (CONDENSATE RETURN)".	N/A			
*	6a. <b>PLACE</b> HS-55-*11 in OPEN at panel *0C647	HS-55-111 placed in OPEN			
	6b. <b>WHEN</b> HV-55-*F011 is full open <b>THEN PLACE</b> HS-55-*11 in STOP.	When HV-55-1F011 indicates full open (red light on, green light off) HS-55-111 placed in STOP.			
	7. <b>START</b> *0P219, "Barometric Condenser Vacuum Pump" (VACUUM PUMP).	10P219 Vacuum Pump is running.			
*	8. <b>OPEN</b> HV-50-*F046, "RCIC Lube Oil Cooling Water Supply" (COOLING WATER).	HV-50-1F046 is open.			
	9. <b>MONITOR</b> Suppression Pool temperature per ST-6-060-390-*, Suppression Pool Temperature Check.	N/A Per Initial Conditions ST-6-060-390-1 is currently being performed by a second operator.			
	10. <b>IF</b> required to limit Suppression Pool temperature any time during this procedure, <b>THEN PLACE</b> Suppression Pool Cooling Mode of RHR System in service per S51.8.A, Suppression Pool Cooling Operation.  <b>CUE:</b> If requested, inform operator Suppression Pool Cooling is not required.	N/A			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	11. <b>INFORM</b> HP of changing radiological conditions due to RCIC system start.	HP is informed of Unit 1 RCIC start.			
	12. <b>PLACE</b> FIC-49-*R600, "RCIC Pump Discharge Flow Controller" (FL), in "MANUAL" <b>AND SET</b> to 0%.	FIC-49-1R600 M/A selector switch repositioned to "M". Depress FIC-49-1R600 "CLOSE" detent pushbutton until controller output indicating 0%.			
*	13. <b>OPEN</b> HV-50-*F045, "RCIC Steam Supply" (INLET).	HV-50-1F045 is OPEN.			
	14. <b>PERFORM</b> the following to start RCIC turbine:	N/A			
*	14a. Slowly <b>RAISE</b> the output of FIC-49-*R600 until turbine speed begins to raise as indicated on SI-50-*01-1, "Turbine Speed" (S).	FIC-49-1R600 OPEN detent pushbutton is depressed until speed rises as indicated on SI-50-101-1.			
*	14b. <b>WHEN</b> speed begins to increase, <b>THROTTLE OPEN</b> HV-49-*F022, "RCIC Full Flow Shutoff" (TEST ISOL).	HV-49-1F022 handswitch is placed in OPEN and then Pull to Stop and repeated until valve indicates desired flow.			
*	14c. Slowly <b>INCREASE</b> output of FIC-49-*R600, FL, to greater than 2200 rpm as indicated on SI-50-*01-1, "Turbine Speed" (S).	FIC-49-1R600 OPEN detent pushbutton is depressed until speed rises to greater than 2200 rpm as indicated on SI-50-101-1.			
	15. <b>IF</b> HV-49-*F022 will <b>not</b> open, <b>THEN PERFORM</b> the following: <b>LOWER</b> output of FIC-49-*R600, "RCIC Pump Discharge Flow Controller" (FL), to approximately 2500 rpm. <b>THROTTLE OPEN</b> HV-49-*F022.	N/A			



ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<b>EVALUATORS NOTE:</b> If the candidate is unable to establish 600 GPM due to a partially throttled HV-49-1F022 and the candidate recognizes that the valve needs to be throttled further open and requests permission to do this, it is acceptable to grant permission.				
*	16. Slowly <b>RAISE</b> output of FIC-49-*R600 to approximately 600 gpm <b>AND MATCH</b> setpoint to actual flow, <b>THEN PLACE</b> FIC-49-*R600 in "AUTO".	Depress FIC-49-1R600 "OPEN" detent to achieve 400 to 700 gpm as indicated on FI-49-1R600.  Flow controller is adjusted such that when the controller is switched to AUTO, flowrate changes less than 100 gpm.  M/A selector switch in AUTO.		
*	17. <b>THROTTLE</b> HV-49-*F022, "RCIC Full Flow Test" (TEST ISOL) <b>AND ADJUST</b> FIC-49-*R600, as necessary, to maintain pump discharge pressure at least 70.3 psig over reactor pressure <b>AND</b> pump flow rate of 600 pm.	Maintain pump discharge pressure as indicated on PI-49-1R601 at least 70 psig over reactor pressure as indicated on PI-49-1R602 by adjusting HV-49-1F022 as necessary while maintaining pump flow 550 to 650 gpm on FIC49-1R600.		
<b>CUE: You have met the termination criteria for this JPM</b>				

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**         SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:** RCIC MANUAL SLOW START USING FIC-49-1R600

**JPM Number:** LOJPM3015

**Revision Number:** 002

**Task Number and Title:** TPO-2170070201 Conduct RCIC System Full Flow Functional Test

<b>K/A Number and Importance:</b>	217000	A4.01	3.7/3.7
	217000	A4.03	3.4/3.3
	217000	A4.04	3.6/3.6

**Safety Function (1-9)**   2   (Reactor Water Inventory Control)

**Admin Category (A1-4)**   N/A  

**Level of Difficulty (1-5)**   3  

**Suggested Testing Environment:** Simulator

**Alternate Path:**  Yes  No   **SRO Only:**  Yes  No   **Time Critical:**  Yes  No

**Reference(s):** S49.1.D, RCIC System Full Flow Functional Test and Turbine Oil Priming, Rev. 42

**Actual Testing Environment:**  Simulator    Control Room    In-Plant    Other

**Testing Method:**    Simulate    Perform

**Estimated Time to Complete:**  20  minutes   **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?         Yes         No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:    Satisfactory    Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_        **Date:** \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. LGS Unit 1 is in OPCON 1
2. ST-6-060-390-1 is currently being performed by a second operator
3. S49.9.A, Routine Inspection of RCIC system has been performed
4. Vibration Monitoring System is in service
5. Steam Leak Detection System is not known to be INOP
6. An EO and RP Tech are on station and the Unit 1 RCIC room is posted
7. S49.1.D, RCIC System Full Flow Functional Test prerequisites are satisfied

**INITIATING CUE:**

You are directed by Shift Supervisor to place Unit 1 RCIC in full flow test for a 15 minute PMT using S49.1.D, to obtain discharge pressure at least 70 psig greater than reactor pressure, and a pump flowrate of 600 gpm with the controller in AUTO by the manual slow start method using FIC-49-1R600.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**SHUTDOWN COOLING FLOW ADJUSTMENTS**

JPM Number: LOJPM3515

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date





Note: This LGS format satisfies the TQ-JA-150 Format

I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- 1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cues (and terminating cues if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
8. If an alternate path is used, the task standard contains criteria for successful completion.
9. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure S51.8.B Rev: 81
Procedure Rev:
Procedure Rev:
Procedure Rev:
Procedure Rev:
10. Verify cues both verbal and visual are free of conflict.
11. Verify performance time is accurate
12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor Date
SME / Instructor Date
SME / Instructor Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM supersedes LLOJPM0515 Rev. 9. Revised to new template and to align with latest procedure revision.	10/31/16

# Date of Revision - refers to date revision was released for approval



**IV. TASK STANDARD:**

Additional cooling provided to the '1A' RHR Heat Exchanger.

Following confirmation of the RHRSW High Radiation alarm, '1A' RHR pump is tripped and '1A' RHR Heat Exchanger is isolated

**V. SIMULATOR SETUP:**

**NOTE:** It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

1. Reset the simulator to IC-\_\_\_\_\_ (1A RHR in Shutdown Cooling) and make the manipulations below or reset the simulator to the prepared exam IC and verify the conditions below.
2. Adjust HV-C-51-103A (1A RHR Heat Exchanger Outlet Bypass POS) to 100%
3. Ensure HV-51-1F015A (Shutdown Cooling Return Valve) is full open
4. Close HV-51-1F003A (Heat Exchanger Outlet)
5. Throttle HV-C-51-1F048A (Heat Exchanger Bypass) closed to obtain 9000 gpm flow
6. Verify 51-1031A and 51-10181 Condensate Transfer valves closed
7. Verify HV-51-1F007A, Min Flow Valve is closed and de-energized
8. Verify DAS Screen set to 1A SDC Loop
9. Verify PMS SDC Monitor is active
10. Apply Robust Barriers (mousetraps) to the following:

HV-43-1F023A, RECIRC SUCTION	HV-43-1F023B, RECIRC SUCTION
HV-51-1F027A, SUPP POOL SPRAY	HV-51-1F027B, SUPP POOL SPRAY
HV-51-1F040, LETDOWN TO RW	HV-51-1F049, LETDOWN TO RW
HV-51-1F024A, SUPP POOL CLNG	HV-51-1F006B, SUCTION A
HV-51-1F008, SHUTDOWN COOLING SUCTION (OUTBOARD)	HV-51-1F009, SHUTDOWN COOLING SUCTION (INBOARD)
HV-51-1F-15A, SHUTDOWN COOLING INJECTION (OUTBOARD)	HV-51-1F048A. HEAT EXCH BYPASS
1AP202, '1A' RHR Pump Handswitch	0AP506, '0A' RHRSW Pump Handswitch
HV-51-1F014A, RHRSW INLET	HV-51-1F068A, RHRSW OUTLET
HV-51-1F006, SUCTION B	

11. Prepare a copy of S51.8.B marked up completed to step 4.4.30
12. Establish the Malfunction **MRM019A**, U1 RHR SW Return Hdr Rad Mon fails to 500 cpm on Automatic Trigger #1 or other available trigger if performing this JPM in an exam set of JPMs. This Trigger will be activated when HIC51-103A Controller Output meter reads less than or equal to 15%.



**VI. INITIAL CONDITIONS:**

1. '1A' RHR has been placed in service for Shutdown Cooling with Reactor Coolant temperature at 125°F as read on XI-36-101 TE-51-1N004A
2. '0A' RHRSW pump is in service providing flow to '1A' RHR Heat Exchanger
3. Reactor level is being maintained at 83" as read on LI-42-1R605
4. HV-C-51-103A, RHR Heat Exchanger Outlet Bypass (POS), is full open and additional cooling is required to maintain reactor coolant temperature within the 110°F to 130°F band
5. The Unit 1 Reactor Operator is performing ST-6-107-640-1, Rx Vessel Temperature and Pressure Monitoring

**VII. INITIATING CUE:**

The CRS has directed you to continue performing S51.8.B at step number 4.4.30 to provide additional cooling to reactor coolant



**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
	<p>1. Candidate obtains copy of S51.8.B completed up to and including step 4.4.30</p> <p><b>CUE:</b> Candidate is given a copy of S51.8.B, Shutdown Cooling/Reactor Coolant Circulation Operation Start-Up And Shutdown marked up completed to and including step 4.4.30.</p>	<p>Candidate obtains marked up copy of S51.8.B and determines additional cooling is required.</p>			
	<p>2. [4.4.23.6] <b>IF</b> additional cooling is required, <b>THEN PERFORM</b> the following:</p>	N/A			
*	<p>2a. [4.4.23.6.a] <b>OPEN</b> HV-C-51-1F048A, HEAT EXCH BYPASS.</p>	<b>OPEN</b> HV-C-51-1F048A, red light lit			
*	<p>2b. [4.4.23.6.b] <b>OPEN</b> HV-51-1F003A, OUTLET.</p>	<b>OPEN</b> HV-51-1F003A, red light lit			
*	<p>2c. [4.4.23.6.c] <b>CLOSE</b> HV-C-51-103A, POS.</p>	<b>CLOSE</b> HV-C-51-103A, green light lit			
<p><b>EVALUATORS NOTE: THE ALTERNATE PATH PORTION OF THE JPM BEGINS IN THE NEXT STEP WITH THE FOLLOWING INDICATIONS:</b></p> <ul style="list-style-type: none"> <li>• <b>Insert MRM019A</b>, U1 RHR SW Return Hdr Rad Mon fails to 500 cpm</li> <li>• The following steps include actions from the ARC-MCR 011-B-4 Annunciator (RHRSW Hi Radiation)</li> </ul>					
	<p>3. Respond to alarm 011 B-4, SERV WTR B (RHRSW HI RADIATION)</p>	<p>ARC MCR 011 B-4, SERV WTR B (RHRSW HI RADIATION) referenced.</p>			



ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
4. Verify the high radiation condition on RR-0R615A panel C667	Observe RHRSW rad recorder RR-0R615A and determine increasing trend			
5. <b>IF</b> an actual high radiation condition is suspected, <b>THEN:</b>  <b>CUE:</b> If asked, report Chemistry has confirmed that a hi rad condition exist.	Determine recorder response is due to an actual increasing radiation condition			
* 5a. Trip associated RHR pump	'1A' RHR Pump handswitch taken to STOP (Green Flag)			
* 5b. <b>AND</b> Isolate the shell side of HX by closing HV-51-1F047A or HV-51-182A with HS-51-182A (309/238' U/1)	HV-51-1F047A keylock switch taken to CLOSE, (Green light on, Red light off).			
* 5c. <b>AND</b> HV-51-1F003A or HV-C-51-103A	HV-51-1F003A keylock switch taken to CLOSE, (Green light on, Red light off).			
<b>CUE: You have met the termination criteria for this JPM</b>				

JPM Completion Time \_\_\_\_\_



JPM SUMMARY

Operator's Name: \_\_\_\_\_

Job Title:  SED  SM  SRO  RO  STA/IA  EO  OTHER

JPM Title: SHUTDOWN COOLING FLOW ADJUSTMENTS

JPM Number: LOJPM3515

Revision Number: 000

Task Number and Title: 2031010101 Place RHR in Shutdown Cooling Operation, Monitor and Secure

K/A Number and Importance: 205000 K1.15 3.5/3.6

Safety Function (1-9) 4 (Heat Removal From the Core)

Admin Category (A1-4) N/A

Level of Difficulty (1-5) 3

Suggested Testing Environment: Simulator

Alternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s): S51.8.B, Shutdown Cooling / Reactor Coolant Circulation Operation Start-up and Shutdown, Rev 081

ARC-MCR-011-B4, RHRSW Hi Radiation, Rev 004

Actual Testing Environment:  Simulator  Control Room  In-Plant  Other

Testing Method:  Simulate  Perform

Estimated Time to Complete: 15 minutes Actual Time Used: \_\_\_\_\_ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily?  Yes  No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_





**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**IX. INITIAL CONDITIONS:**

1. '1A' RHR has been placed in service for Shutdown Cooling with Reactor Coolant temperature at 125°F as read on XI-36-101 TE-51-1N004A
2. '0A' RHRSW pump is in service providing flow to '1A' RHR Heat Exchanger
3. Reactor level is being maintained at 83" as read on LI-42-1R605
4. HV-C-51-103A, RHR Heat Exchanger Outlet Bypass (POS), is full open and additional cooling is required to maintain reactor coolant temperature within the 110°F to 130°F band
5. The Unit 1 Reactor Operator is performing ST-6-107-640-1, Rx Vessel Temperature and Pressure Monitoring

**X. INITIATING CUE:**

The CRS has directed you to continue performing S51.8.B at step number 4.4.30 to provide additional cooling to reactor coolant



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**MAIN TURBINE BYPASS VALVE EXERCISING**

JPM Number: LOJPM3083

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By: \_\_\_\_\_  
Instructor Date

Validated By: \_\_\_\_\_  
SME or Instructor Date

Reviewed By: \_\_\_\_\_  
Operations Representative Date

Reviewed By: \_\_\_\_\_  
EP Representative Date

Approved By: \_\_\_\_\_  
Training Department Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

### I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>ST-6-001-761-1</u>	Rev: <u>28</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM supersedes LLOJPM0083 Rev. 3. Revised to new template and to align with latest procedure revision.	10/31/16

# Date of Revision - refers to date revision was released for approval



#### IV. TASK STANDARD:

Bypass Valve #1 tested successfully as directed by ST-6-001-761-1, Main Turbine Bypass Valve Exercising

#### V. SIMULATOR SETUP:

1. Reset simulator to IC-3, or another IC if JPM was validated in the respective IC.

**NOTE:** It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

#### VI. INITIAL CONDITIONS:

1. Unit 1 is at 99% power.
2. No other testing is in progress on Unit 1.
3. ST-6-001-761-1, Main Turbine Bypass Valve Exercising is complete up to section 4.3.

#### VII. INITIATING CUE:

You have been directed by the CRS to continue performance of ST-6-001-761-1, Main Turbine Bypass Valve Exercising.

**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

★

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**

**VIII. PERFORMANCE CHECKLIST:**
**JPM Start Time** \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	1. Obtain M/U copy of ST-6-001-761-Main Turbine Bypass Valve Exercising  <b>CUE:</b> Candidate is given M/U copy of ST-6-001-761-Main Turbine Bypass Valve Exercising	Candidate obtains M/U copy of ST-6-001-761-Main Turbine Bypass Valve Exercising Test			
	2. <b>RECORD</b> "AS FOUND" positions of all valves listed in Attachment 1, Independent Verification Of Restoration (IVOR).	Positions of all valves listed in Attachment 1			
	3. <b>VERIFY</b> all 9 BPV's are closed.	All 9 BPV's are closed			
	4. <b>PERFORM</b> the following for Bypass Valve #1	N/A			
	4a. <b>SELECT TESTS</b>	TESTS selected			
	4b. <b>SELECT VALVE TESTS</b>	VALVE TESTS selected			
	4c. <b>SELECT BPV TESTS</b>	BPV TESTS selected			
*	4d. <b>SELECT</b> #1 BPV for test at the VALVE TEST SELECTION window.	#1 BPV selected for test at the VALVE TEST SELECTION window.			
*	4e. <b>VERIFY</b> the correct BPV selected for test is indicated on the test window	#1 BPV selected			



ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
*	4f. <b>DEPRESS</b> OPEN TREND button, <b>OR TREND</b> all 9 BPVs.	OPEN TREND button depressed			
*	4g. <b>DEPRESS</b> START button to initiate opening test	START button depressed			
	4h. <b>DEPRESS</b> PAUSE button if necessary, <b>AND THEN DEPRESS</b> CONTINUE button to resume test	N/A			
*	4i. <b>VERIFY</b> #1 Bypass Valve opens <b>AND</b> recloses	Candidate verifies #1 Bypass Valve opens and recloses			
	4j. <b>IF</b> #1 BPV remains opened and fails to reclose, <b>THEN SELECT CANCEL AND VERIFY</b> Bypass Valve Closes	Candidate verifies #1 Bypass Valve opens and recloses			
	4k. <b>VERIFY</b> BYPASS VALVE OPEN annunciator on 106 MAIN STEAM clears.	106 D-4, BYPASS VALVE OPEN, annunciator cleared.			
	4l. <b>SAVE</b> the Trend file, if required  <b>CUE:</b> Saving the Trend file is not req'd	N/A			
	4m. <b>IF</b> trend file saved, <b>THEN ENTER</b> a comment in the Additional Action/Test Comments section noting the file name <b>AND</b> location.	N/A			
	4n. <b>WHEN</b> plant conditions are stable, <b>THEN PROCEED</b> to next BYPASS VALVE.	N/A			
<b>CUE: You have met the termination criteria for this JPM</b>					

JPM Completion Time \_\_\_\_\_





**JPM SUMMARY**

Operator's Name: \_\_\_\_\_

Job Title:         SED    SM    SRO    RO    STA/IA    EO    OTHER

JPM Title: MAIN TURBINE BYPASS VALVE EXERCISING

JPM Number: LOJPM3083

Revision Number: 000

Task Number and Title: 2480090201 Perform Bypass Valve Exercise Test

K/A Number and Importance:        241000                    A4.06                    3.9/3.9

Safety Function (1-9) 3 (Reactor Pressure Control)

Admin Category (A1-4) N/A

Level of Difficulty (1-5) 3

Suggested Testing Environment: Simulator

Alternate Path:  Yes  No    SRO Only:  Yes  No    Time Critical:  Yes  No

Reference(s): ST-6-001-761-Main Turbine Bypass Valve Exercising, Rev28

Actual Testing Environment:  Simulator    Control Room    In-Plant    Other

Testing Method:    Simulate    Perform

Estimated Time to Complete: 15 minutes    Actual Time Used: \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?         Yes                     No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory    Unsatisfactory

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Unit 1 is at 99% power.
2. No other testing is in progress on Unit 1.
3. ST-6-001-761-1, Main Turbine Bypass Valve Exercising is complete up to section 4.3.

**INITIATING CUE:**

You have been directed by the CRS to continue performance of ST-6-001-761-1, Main Turbine Bypass Valve Exercising.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**SUPPLY RECW TO THE DRYWELL COOLERS**

JPM Number: LOJPM3028

REVISION NUMBER: 001

DATE: \_\_\_\_\_

Developed By:

\_\_\_\_\_

Instructor

\_\_\_\_\_

Date

Validated By:

\_\_\_\_\_

SME or Instructor

\_\_\_\_\_

Date

Reviewed By:

\_\_\_\_\_

Operations Representative

\_\_\_\_\_

Date

Reviewed By:

\_\_\_\_\_

EP Representative

\_\_\_\_\_

Date

Approved By:

\_\_\_\_\_

Training Department

\_\_\_\_\_

Date



Note: This LGS format satisfies the TQ-JA-150 Format

I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision;
 

Procedure <u>S13.6.D</u>	Rev: <u>15</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0028 Rev. 0. Revised to new template and to align with latest procedure revision.	10/15/13
001	This SEG is revised to new 3/16 SEG format template, including any procedure revisions.	08/05/16

# **Date of Revision** - refers to date revision was released for approval

#### IV. TASK STANDARD:

RECW aligned to Drywell Chilled Water.

#### V. SIMULATOR SETUP INSTRUCTIONS:

1. Reset simulator to IC-3
2. Trip '1B' Drywell Chiller
3. Place HS-87-115 and HS-87-116 in BYPASS
4. Trip '1A' RWCU Pump and close the HV-44-1F001 and HV-44-1F004 valves.
5. Build a trigger to toggle Remote Function **RPC306** to CLOSE.

#### VI. INITIAL CONDITIONS:

1. A manual scram was inserted due to rising Drywell pressure.
2. The CRS has entered OT-101, and T-102.
3. Drywell pressure is 4 psig and steady.
4. Drywell temperature is 160°F and steady.
5. The Drywell Chilled Water isolation has been bypassed and Chilled Water inlet and outlet valves have been re-opened.
6. '1B' Drywell Chiller has tripped and '1A' Drywell Chiller is unable to be started.
7. Service Water is aligned to the RECW Heat Exchangers.
8. RWCU has been shutdown per S44.2.A, Reactor Water Cleanup Shutdown.
9. Administrative Clearances have been applied for valves in S13.6.D, section 4.2.4.
10. An EO is briefed and in the field with a copy of S13.6.D.

#### VII. INITIATING CUE:

Shift Supervision has directed you to supply RECW to the 'A' Drywell Chilled Water Loop per S13.6.D beginning at step 4.2.2.

- Locked Valve Log entries have been authorized for required beaker closures

**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

★

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p>1. Obtain a current revision of S13.6.D, RECW Operation With Loss of Drywell Chilled Water.</p> <p><b>CUE:</b> Candidate is given a copy of S13.6.D, RECW Operation With Loss of Drywell Chilled Water.</p>	<p>Candidate demonstrates ability (actual or discuss) to locate the correct procedure.</p>			
<p>2. <b>SHUTDOWN</b> RWCU system per S44.2.A, Reactor Water Cleanup Shutdown.</p>	<p>RWCU shutdown per initial conditions</p>			
<p>* 3. <b>CLOSE</b> HV-13-*02, Cooling Water to Reactor Building Isolation (SUPPLY ISOL).</p>	<p>Handswitch for HV-13-102 taken to close and valve verified to close</p>			
<p>4. <b>IF</b> loss of instrument air prohibits closure of HV-13-*02, SUPPLY ISOL, in step 4.2.2, <b>THEN CLOSE</b> 13-*039, "RECW Header Valve to RWCU Non-Regen Heat Exchanger."</p>	<p>N/A</p>			
<p>5. Block <b>CLOSE</b> the following sample point isolation valves</p> <ul style="list-style-type: none"> <li>• HV 51 *F080A</li> <li>• HV 51 *F080B</li> <li>• HV 41 *F085</li> <li>• HV 43 *F020</li> <li>• 023-1246</li> </ul> <p><b>CUE:</b> After 1 minute <b>report:</b> EO reports 023-1246 is closed and info tagged.</p>	<p>Candidate verifies Information tags on:</p> <ul style="list-style-type: none"> <li>• HV 51 1F080A</li> <li>• HV 51 1F080B</li> <li>• HV 41 1F085</li> <li>• HV 43 1F020</li> </ul> <p>And directs EO to close and Info tag:</p> <ul style="list-style-type: none"> <li>• 023-1246</li> </ul>			





ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER	
<b>EVALUATORS NOTE:</b> When operator requests the breakers in the following step to be closed, activate trigger associated with remote function <b>RPC306</b> to close the breakers.					
*	<p>6. <b>UNLOCK AND CLOSE</b> the following breakers:</p> <ul style="list-style-type: none"> <li>• D*14-R-C-15 (124A)</li> <li>• D*14-R-C-19 (124B)</li> <li>• D*14-R-C-16 (125A)</li> <li>• D*14-R-C-20 (125B)</li> </ul> <p><b>CUE:</b> After confirmation of 124A(B) and 125A(B) closed (Trigger 1 activated) report the following breakers closed:</p> <ul style="list-style-type: none"> <li>• D114-R-C-15</li> <li>• D114-R-C-19</li> <li>• D114-R-C-16</li> <li>• D114-R-C-20</li> </ul>	<p>Candidate directs EO to close following breakers:</p> <ul style="list-style-type: none"> <li>• D114-R-C-15</li> <li>• D114-R-C-19</li> <li>• D114-R-C-16</li> <li>• D114-R-C-20</li> </ul>			
	<p>7. <b>ENSURE</b> indication for the valves is received in MCR</p>	<p>Indication (Green Lights) received for 124A(B) and 125A(B)</p>			
	<p>8. <b>IF</b> required <b>THEN BYPASS</b> isolations per GP-8.5.</p>	<p>N/A</p>			
*	<p>9. <b>PLACE</b> HSS-87-*21A(B), Loop Drywell Water Source Mode Switch (LOOP), in "RE CLG WTR" for loop to be supplied by RECW AND VERIFY the following:</p>	<p>HSS-87-121A in RE CLG WTR placed position for LOOP A.</p>			
	<p>9a. Red indicating lights RECW IN <b>AND</b> RECW OUT lit.</p>	<p>RECW IN and OUT red lights verified lit</p>			
	<p>9b. Green indicating lights CHLD WTR IN <b>AND</b> CHLD WTR OUT lit.</p>	<p>CHLD WTR IN and OUT green lights verified lit</p>			
<p><b>CUE: You have met the termination criteria for this JPM</b></p>					

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**         SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:** SUPPLY RECW TO THE DRYWELL COOLERS

**JPM Number:** LOJPM3028

**Revision Number:** 001

**Task Number and Title:** 2080040401, Line Up RECW System to Supply Drywell Chilled Water System

**K/A Number and Importance:**        400000                    A2.01                    3.3/3.4

**Safety Function (1-9)**   5   (*Containment Control*)

**Admin Category (A1-4)**   N/A  

**Level of Difficulty (1-5)**   3  

**Suggested Testing Environment:**        Simulator

**Alternate Path:**  Yes  No   **SRO Only:**  Yes  No   **Time Critical:**  Yes  No

**Reference(s):** S13.6.D, RECW Operation With Loss Of Drywell Chilled Water, Rev. 15

**Actual Testing Environment:**  Simulator    Control Room    In-Plant    Other

**Testing Method:**    Simulate    Perform

**Estimated Time to Complete:**   15   minutes   **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?    Yes    No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:    Satisfactory    Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. A manual scram was inserted due to rising Drywell pressure.
2. The CRS has entered OT-101, and T-102.
3. Drywell pressure is 4 psig and steady.
4. Drywell temperature is 160°F and steady.
5. The Drywell Chilled Water isolation has been bypassed and Chilled Water inlet and outlet valves have been re-opened.
6. '1B' Drywell Chiller has tripped and '1A' Drywell Chiller is unable to be started.
7. Service Water is aligned to the RECW Heat Exchangers.
8. RWCU has been shutdown per S44.2.A, Reactor Water Cleanup Shutdown.
9. Administrative Clearances have been applied for valves in S13.6.D, section 4.2.4.
10. An EO is briefed and in the field with a copy of S13.6.D.

**INITIATING CUE:**

Shift Supervision has directed you to supply RECW to the 'A' Drywell Chilled Water Loop per S13.6.D beginning at step 4.2.2.

- Locked Valve Log entries have been authorized for required beaker closures



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**DIESEL GENERATOR FAST START FROM THE MCR**

JPM Number: LOJPM3130

REVISION NUMBER: 003

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	N/A EP Representative	N/A Date
Approved By:	_____	_____
	Training Department	Date

**Note:** This LGS format satisfies the TQ-JA-150 Format

## I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>ST-6-092-318-1</u>	Rev: <u>55</u>
Procedure <u>S92.2.N</u>	Rev: <u>34</u>
Procedure <u>ARC MCR 123 D14 D-1</u>	Rev: <u>0</u>
Procedure <u>ARC BOP 1DC514 D-1</u>	Rev: <u>2</u>
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

## II. RECORD OF TEMPORARY CHANGES:

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

## III. REVISION HISTORY:

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0130 Rev. 2. Revised to new template and to align with latest procedure revision. Changed from D11 D/G to D14 D/G.	10/17/13
001	Revised to align with latest procedure revisions. Deleted Low Jacket Water Pressure indication from EO field report. Previous revision included both High Jacket Water Temperature indication as well as Low Jacket Water Pressure but did not include any indication of a leak. High Jacket Water Temperature alone is an appropriate reason to secure the Diesel Generator with actual temperature greater than the auto trip setpoint of 195 degrees F.	1/17/13
002	Revised to align with the latest procedure revisions.	10/11/15
003	Aligned to new JPM format and verified procedure revisions and changed alarm condition to Lube Oil Filter dP High.	10/24/16

# Date of Revision - refers to date revision was released for approval



#### IV. TASK STANDARD:

D14 DG is synchronized to the bus and secured from service following high Lube Oil Filter Differential Pressure.

#### V. SIMULATOR SETUP INSTRUCTIONS:

1. This JPM can be run from any Simulator IC.
2. Build trigger to activate 30 seconds after D14 DG  $\geq$  200 KVAR to toggle Annunciator 123 D-1, D14 D-G TROUBLE, to ON.

**NOTE:** It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

3. Start D14 EDG
4. Insert Remote RSW397, "ESW Loop B Service Water Isolated?"
5. Change Service Water Placards for 11-1013 and 11-2013 to indicate closed

#### VI. INITIAL CONDITIONS:

1. ST-6-092-318-1, D14 Diesel Generator Fast Start Operability Test Run, is complete up to and including Step 4.5.14.
2. An Equipment Operator is standing by at D14 D/G to support Diesel Generator operation.

#### VII. INITIATING CUES:

You are directed by the CRS to continue with ST-6-092-318-1, D14 Diesel Generator Fast Start Operability Test Run.



**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

★

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**





**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	1. Provide the candidate with a marked up copy of ST-6-092-318-1 completed up to and including Step 4.5.14	N/A			
*	2. <b>PLACE</b> 125-11807/SS, DIESEL GEN 14, SYNC, to "ON," using Sync Switch handle, at Panel 1DC661	125-11807/SS, DIESEL GEN 14, SYNC, placed to "ON," using Sync Switch handle, at Panel 1DC661			
	3. <b>VERIFY</b> Synchroscope is rotating with both lights Lit fully bright at 180° <b>AND not</b> Lit at 0°	Synchroscope S/EAS-4 verified rotating with both lights Lit fully bright at 180° <b>AND not</b> Lit at 0°			
	4. <b>OBSERVE</b> change in D/G frequency by placing 165-DG501/CS, SPEED GOVERNOR, to "RAISE" <b>AND</b> to "LOWER	165-DG501/CS rotated to "RAISE," F/DG501-2 (HERTZ) rises. 165-DG501/CS rotated to "LOWER," F/DG501-2 (HERTZ) lowers			
	5. <b>OBSERVE</b> change in D/G voltage by placing 170-DG502/CS, VOLTAGE REGULATOR, to "RAISE," <b>AND</b> to "LOWER."	170-DG502/CS rotated to "RAISE," V/1-EAS-4 (INCOMING) rises. 170-DG502/CS rotated to "LOWER," V/1-EAS-4 (INCOMING) lowers			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
*	6. <b>ADJUST</b> 165-DG501/CS, SPEED GOVERNOR, so Synchroscope is rotating slowly in FAST (CW) direction	165-DG501/CS, SPEED GOVERNOR adjusted so that Synchroscope S/EAS-4 is rotating slowly in FAST direction			
*	7. <b>ADJUST</b> 170-DG502/CS, VOLTAGE REGULATOR, so INCOMING Voltage is slightly higher than RUNNING Voltage	170-DG502/CS, VOLTAGE REGULATOR, adjusted so that V/1-EAS-4 (INCOMING) indicates between 0 to 5 volts greater than V/R-EAS-4			
*	8. <b>WHEN</b> Synchroscope is within 3° before 12 o'clock position rotating slowly in FAST (CW) direction, <b>THEN CLOSE</b> 152-11807/CS GENERATOR Breaker, at Panel 1DC661	D14 DG Output Breaker closed			
	9. Immediately <b>RAISE</b> load to 200 to 300 KW by placing 165-DG501/CS, SPEED GOVERNOR, to "RAISE."	165-DG501/CS, SPEED GOVERNOR, rotated to "RAISE until W/DG501-2 (AC KILOWATTS) indicates between 200 to 300 KW			
	10. <b>RAISE</b> reactive load to 100 to 150 KVAR by placing 170-DG502/CS, VOLTAGE REGULATOR, to "RAISE."	170-DG502/CS, VOLTAGE REGULATOR, rotated to "RAISE" until VAR/DG5012 (AC KILOVAR) indicates between 100 to 150 KVAR			



ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
	11. <b>PLACE</b> 125-11807/SS, DIESEL GEN 14, SYNC, to "OFF"	125-11807/SS, DIESEL GEN 14, SYNC, placed in "OFF."			
<b>EVALUATORS NOTE:</b> 30 seconds after D14 D/G Reactive Load exceeds 200 KVAR, "D14 D-G TROUBLE" will alarm and the alternate path will begin.					
	12. <b>RESPOND</b> to ARC-MCR-123 D14 D1, "D14 D-G TROUBLE"	Annunciator reported to CRS			
	12a. <b>REFER</b> to ARC-MCR-123 D14 D-1, D14 D-G TROUBLE	ARC-MCR-123 D14 D-1, "D14 D-G TROUBLE" referenced			
*	12b. <b>DISPATCH</b> Equipment Operator to investigate Trouble Alarm  <b>CUE:</b> Equipment Operator reports local alarm is Lube Oil Filter Differential Pressure Hi, ARC-BOP-1DC514 D1. Current Filter dP Is 16 psid UP SLOW	<b>DISPATCH</b> Equipment Operator to investigate Trouble Alarm			
	13. <b>DETERMINE</b> D14 DG should be shutdown with the given filter dP condition.	Review ARC and execute Operator Action #2, "IF engine is under test, THEN shutdown engine AND investigate cause of high filter dP."			
<b>EVALUATORS NOTE:</b> The following steps may be performed from memory or by performing S92.2.N, Shutdown of Diesel Generators, Section 4.2, Rapid Shutdown Due To Alarm Or Abnormal Condition.					
	13a. <b>PLACE</b> Diesel Generator Breaker to "TRIP" <b>AND</b> "PULL-TO-LOCK"	Diesel Generator Breaker placed to "TRIP" <b>AND</b> "PULL-TO-LOCK"			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
*	13b. <b>PLACE</b> Diesel Generator Control Switch 101-DG501/CS to "STOP" <b>AND</b> "PULL-TO-LOCK"	Diesel Generator Control Switch 101-DG501/CS placed to "STOP" <b>AND</b> "PULL-TO-LOCK"			
<b>CUE: You have met the termination criteria for this JPM</b>					

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**         SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:** DIESEL GENERATOR FAST START FROM THE MCR

**JPM Number:** LOJPM3130

**Revision Number:** 003

**Task Number and Title:** TPO-2640020101 Manually Startup, Load and monitor a Diesel Generator

**K/A Number and Importance:**            264000            A4.04            3.7/3.7

**Safety Function (1-9) 6 (Electrical)**

**Admin Category (A1-4) N/A**

**Level of Difficulty (1-5) 3**

**Suggested Testing Environment:** Simulator

**Alternate Path:**  Yes  No   **SRO Only:**  Yes  No   **Time Critical:**  Yes  No

**Reference(s):** ST-6-092-318-1 D14 Diesel Generator Fast Start Operability Test Run, Rev. 55  
S92.2.N, Shutdown of Diesel Generators Rev. 34  
ARC MCR 123 D14 D-1, D14 D-G Trouble, Rev 0  
ARC BOP 1DC514 D-1, Lube Oil Filter Differential Pressure High, Rev 2

**Actual Testing Environment:**  Simulator    Control Room    In-Plant    Other

**Testing Method:**    Simulate    Perform

**Estimated Time to Complete:** 20 minutes   **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?         Yes         No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:    Satisfactory    Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_        **Date:** \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. ST-6-092-318-1, D14 Diesel Generator Fast Start Operability Test Run, is complete up to and including Step 4.5.14.
2. An Equipment Operator is standing by at D14 DG to support Diesel Generator operation.

**INITIATING CUE STATEMENT:**

You are directed by the CRS to continue with ST-6-092-318-1, D14 Diesel Generator Fast Start Operability Test Run.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**PLACING SAFEGUARD PIPING FILL SYSTEM IN SERVICE**

JPM Number: LOJPM3118

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:	_____	_____
	Instructor	Date
Validated By:	_____	_____
	SME or Instructor	Date
Reviewed By:	_____	_____
	Operations Representative	Date
Reviewed By:	_____	_____
	EP Representative	Date
Approved By:	_____	_____
	Training Department	Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

**I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>S52.1.C</u>	Rev: <u>11</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date





**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This is a New JPM	08/15/16

# **Date of Revision** - refers to date revision was released for approval



#### IV. TASK STANDARD:

Safeguard Piping Fill System in service with both Fill Pumps and feedwater lines filled

#### V. SIMULATOR SETUP

1. Reset the simulator to an IC that does not require feedwater in service, or an IC if JPM was validated in the respective IC.

**NOTE:** It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Initiate Loss Of Offsite Power **MED261**
3. Ensure all Diesels are running

#### VI. INITIAL CONDITIONS:

1. A LOCA/LOOP condition occurred 30 minutes ago.
2. SE-10, LOCA is in progress
3. S52.1.C prerequisites have been performed

#### VII. INITIATING CUE:

Shift Supervision directs you to place the Safeguard Piping Fill System in service per S52.1.C, "Operation of Safeguard Piping Fill System" to fill the Feedwater Lines.

**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

★

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	<p>1. Obtain current revision of M/U S52.1.C, Operation of Safeguard Piping Fill System.</p> <p><b>CUE:</b> Candidate is given a copy of S52.1.C, Operation of Safeguard Piping Fill System with prerequisites completed.</p>	<p>Candidate reviews M/U copy of S52.1.C, Operation of Safeguard Piping Fill System.</p>			
	<p>2. <b>VERIFY</b> all prerequisites satisfied</p>	<p>Prerequisites verified complete.</p>			
	<p>3. <b>VERIFY</b> procedure being performed on correct unit/train</p>	<p>Candidate verifies procedure being performed on correct unit/train</p>			
	<p>4. <b>IF</b> required <b>PERFORM</b> S52.1.C (COL), Equipment Alignment For Safeguard Fill System For Operation.</p> <p><b>CUE:</b> S52.1.C(COL) is not required</p>	<p>N/A</p>			
<p>*</p>	<p>5. <b>ENSURE</b> the following Core Spray Pump Supp Pool Suct valves are open:</p> <ul style="list-style-type: none"> <li>• HV-52-1F001A</li> <li>• HV-52-1F001B</li> <li>• HV-52-1F001C</li> <li>• HV-52-1F001D</li> </ul>	<p>Core Spray Pump Supp Pool Suction valves HV-52-1F001A thru 1F001D are opened. (Red Light)</p>			



ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
	6. <b>START</b> the following pumps.	N/A			
*	6a. 1AP256, "Fill Pump A"	Fill Pump A started (Red Light)			
*	6b. 1BP256, "Fill Pump B"	Fill Pump B started (Red Light)			
*	7. <b>IF</b> system is required to fill the feedwater lines, <b>THEN OPEN</b> the following valves; as appropriate: <ul style="list-style-type: none"> <li>• HV-41-130A</li> <li>• HV-41-130B</li> <li>• HV-41-133A</li> <li>• HV-41-133B</li> </ul>	Safeguard Piping PCIVs open <ul style="list-style-type: none"> <li>• HV-41-130A</li> <li>• HV-41-130B</li> <li>• HV-41-133A</li> <li>• HV-41-133B</li> </ul>			
<b>CUE: You have met the termination criteria for this JPM</b>					

JPM Completion Time \_\_\_\_\_





**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. A LOCA/LOOP condition occurred 30 minutes ago.
2. SE-10, LOCA is in progress
3. S52.1.C prerequisites have been performed

**INITIATING CUE:**

Shift Supervision directs you to place the Safeguard Piping Fill System in service per S52.1.C, "Operation of Safeguard Piping Fill System" to fill the Feedwater Lines.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**T-239 DEFEATING HIGH RPV LEVEL INTERLOCKS**

JPM Number: LOJPM2273

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:

\_\_\_\_\_  
Instructor

\_\_\_\_\_  
Date

Validated By:

\_\_\_\_\_  
SME or Instructor

\_\_\_\_\_  
Date

Reviewed By:

\_\_\_\_\_  
Operations Representative

\_\_\_\_\_  
Date

Reviewed By:

\_\_\_\_\_  
EP Representative

\_\_\_\_\_  
Date

Approved By:

\_\_\_\_\_  
Training Department

\_\_\_\_\_  
Date





**Note:** This LGS format satisfies the TQ-JA-150 Format

**I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
 

Procedure <u>T-239 U/1</u>	Rev: <u>0</u>
Procedure <u>T-239 U/2</u>	Rev: <u>0</u>
Procedure _____	Rev: _____
Procedure _____	Rev: _____
Procedure _____	Rev: _____
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This is a New JPM	11/01/16

# Date of Revision - refers to date revision was released for approval



**IV. TASK STANDARD:**

The high RPV level interlocks defeated for the Unit \_\_\_\_ 'B' RFPT, and the HPCI system per T-239, Defeating RFPT, HPCI and RCIC High RPV Level Interlocks, completed sat.

**V. SIMULATOR SETUP**

1. None

**VI. INITIAL CONDITIONS:**

1. Unit \_\_\_\_RPV level cannot be determined
2. RPV flooding is required

**VII. INITIATING CUE:**

Shift Supervision directs you to defeat the high RPV level interlocks on Unit \_\_\_\_ for the '\_\_\_\_B' RFPT, and the HPCI system per T-239, "Defeating RFPT, HPCI and RCIC High RPV Level Interlocks."



**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

★

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



VIII. PERFORMANCE CHECKLIST:

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p><i>For In-Plant T-200 JPMs, include the following:</i></p> <p><b>NOTE:</b></p> <p><b>IF</b> this JPM is the <i>first</i> of multiple T-200 series JPMs being performed by a single candidate</p> <p><b>THEN</b> steps #1 and #2 apply.</p> <p><b>OTHERWISE</b> mark steps #1 and #2 as N/A</p> <p><b>AND</b> provide the following to the candidate :</p> <p>a. <b>INITIATING CUE(S)</b></p> <p>b. <b>CUE:</b> "You are now in possession of the T-239 equipment container. It contains all tools and equipment required by the procedure. You are to simulate their use during performance of the procedure."</p> <p>c. <b>PROCEDURE COPY</b></p>				
	<p>1. Obtain current revision of T-239, Defeating RFPT, HPCI and RCIC High RPV Level Interlocks for Unit # ____.</p> <p><b>CUE:</b> Candidate is given a copy of T-239, Defeating RFPT, HPCI and RCIC High RPV Level Interlocks, when knowledge of the correct location of procedure is demonstrated.</p>	<p>Candidate demonstrates ability (actual or discuss) to locate T-239, Defeating RFPT, HPCI and RCIC High RPV Level Interlocks.</p>		
	<p>2. Obtain required tools.</p> <ul style="list-style-type: none"> <li>• Insulated screwdriver</li> <li>• Holding screwdriver</li> <li>• Flashlight</li> <li>• Roll of electrical tape</li> </ul> <p><b>CUE:</b> You have tools identified.</p>	<p>Tools obtained.</p>		



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
*	<p>3. <b>PERFORM</b> the following at panel *C612, Bay A (AER) to defeat high RPV level trip of “*B” RFPT (ATTACHMENT 1).</p> <ul style="list-style-type: none"> <li>• <b>LIFT</b></li> <li>• <b>AND TAPE</b> lead connected to FFF5-3</li> </ul> <p><b>CUE:</b> Lead from FFF5-3 lifted and tapped.</p>	Lead from FFF5-3 lifted and tapped.			
	<p>4. <b>WHEN</b> the respective RFPT high RPV level trip(s) defeated is complete, <b>THEN NOTIFY</b> Main Control Room.</p>	MCR notified the “*B’ RFPT high level trip defeated per T-239.			
*	<p>5. <b>PERFORM</b> the following at panel *C620, (AER) (ATTACHMENT 2).</p> <ul style="list-style-type: none"> <li>• <b>LIFT</b></li> <li>• <b>AND TAPE</b> lead connected to FFF5-2</li> </ul> <p><b>CUE:</b> Lead from FFF5-2 lifted and tapped.</p>	Lead from FFF5-2 lifted and tapped.			
	<p>6. At Panel *0C647, <b>PRESS</b> E41A-S25, “RPV High Water Level” (Rx LEVEL HIGH RESET) Reset Pushbutton <b>AND VERIFY</b> white Rx LEVEL HIGH RESET light <b>not</b> Lit.</p> <p><b>CUE:</b> PRO reports “E41A-S25, RPV High Water Level” reset pushbutton and white Rx LEVEL HIGH RESET light <b>not</b> Lit.</p>	E41A-S25, “RPV High Water Level” Reset Pushbutton depressed and white Rx LEVEL HIGH RESET light <b>not</b> Lit.			



ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
7. At Panel *0C647, <b>VERIFY</b> HPCI TURB TRIP ISOL ENERGIZED DS37 status light <b>not</b> lit  <b>CUE:</b> PRO reports "HPCI TURB TRIP ISOL ENERGIZED DS37 status light <b>not</b> lit"	DS37 status light <b>not</b> lit at panel *0C647			
8. <b>WHEN</b> the HPCI high RPV level trip is defeat is complete, <b>THEN</b> NOTIFY Main Control Room.	MCR notified HPCI high level trip defeated per T-239			
<b>CUE:</b> You have met the termination criteria for this JPM				

JPM Completion Time \_\_\_\_\_







**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Unit \_\_\_ RPV level cannot be determined
2. RPV flooding is required

**INITIATING CUE:**

Shift Supervision directs you to defeat the high RPV level interlocks on Unit \_\_\_ for the '\_\_\_B' RFPT, and the HPCI system per T-239, "Defeating RFPT, HPCI and RCIC High RPV Level Interlocks."



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**RESET RDCS**

JPM Number: LOJPM2119

REVISION NUMBER: 000

DATE: \_\_\_\_\_

Developed By:

\_\_\_\_\_

Instructor

\_\_\_\_\_

Date

Validated By:

\_\_\_\_\_

SME or Instructor

\_\_\_\_\_

Date

Reviewed By:

\_\_\_\_\_

Operations Representative

\_\_\_\_\_

Date

Reviewed By:

\_\_\_\_\_

EP Representative

\_\_\_\_\_

Date

Approved By:

\_\_\_\_\_

Training Department

\_\_\_\_\_

Date



Note: This LGS format satisfies the TQ-JA-150 Format

I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- 1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cues (and terminating cues if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
8. If an alternate path is used, the task standard contains criteria for successful completion.
9. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure S73.0.F Rev: 17
Procedure S73.0.E Rev: 18
Procedure Rev:
Procedure Rev:
Procedure Rev:
10. Verify cues both verbal and visual are free of conflict.
11. Verify performance time is accurate
12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor Date
SME / Instructor Date
SME / Instructor Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This is a New LOJPM	08/10/16

# Date of Revision - refers to date revision was released for approval



**IV. TASK STANDARD:**

Unit \_\_\_ Control Rod 18-31 bypassed from RMCS, and RDCS is reset

**V. SIMULATOR SETUP**

1. None

**VI. INITIAL CONDITIONS:**

1. Unit \_\_\_ Control Rod 18-31 has drifted out
2. Unit \_\_\_ Control Rod 18-31 was fully inserted, and isolated.
3. Tech Spec 3.1.3.1 has been referenced
4. Unit \_\_\_ Control Rod 18-31 was declared INOP
5. 'RDCS INOP' alarm on ARC MCR \*08 E-4 has annunciated
6. The LED for Unit \_\_\_ HCU 18-31 on The Rod Drive Control System Analyzer - Fault Location Map is lit

**VII. INITIATING CUE:**

Shift supervision directs you to reset Unit \_\_\_ RDCS in accordance with S73.0.F, Operation of the Rod Drive Control System.



**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

**\***

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VIII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p>1. Obtain current revision of S73.0.F, Operation Of The Rod Drive Control System.</p> <p><b>CUE:</b> Candidate is given a copy of S73.0.F, Operation Of The Rod Drive Control System when knowledge of the correct location of procedure is demonstrated.</p>	<p>Candidate demonstrates ability (actual or discuss) to locate S73.0.F</p>			
<p>2. Reference section 4.3 'RDCCS RESET' of S73.0.F, Operation Of The Rod Drive Control System.</p>	<p>Section 4.3 'RDCCS RESET' of S73.0.F referenced</p>			
<p>3. [S73.0.F 4.3.1] <b>IF</b> immediate reset of RDCCS is required as determined by Shift Supervision <b>THEN</b> MARK N/A for steps 4.3.2 and 4.3.10</p> <p><b>CUE:</b> Immediate reset of RDCCS is required</p>	<p>N/A</p>			
<p>4. [S73.0.F 4.3.3] <b>ENSURE</b> RO has logged RDCCS INOP</p> <p><b>CUE:</b> RO has logged RDCCS INOP</p>	<p>N/A</p>			
<p>5. [S73.0.F 4.3.4] <b>OBTAIN</b> CRS permission to reset RDCCS</p> <p><b>CUE:</b> Permission given in Initiating Cue.</p>	<p>N/A (given in Initiating Cue)</p>			



	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
*	6. [S73.0.F 4.3.5] <b>DEPRESS</b> RESET for at least two seconds	RESET depressed for at least two seconds			
<b>Evaluator Note:</b> Alternate Path begins with the next step.					
	7. [S73.0.F 4.3.6] <b>IF</b> RDCS INOPERATIVE will not clear THEN <b>PERFORM</b> the following:  <b>CUE:</b> RDCS Inoperative LED remains lit and the LED for HCU 18-31 on The Fault Location Map remains lit	Candidate verifies RDCS inoperative LED remains lit			
	7a. [S73.0.F 4.3.6.1] <b>CONTACT</b> I&C for troubleshooting	I&C contacted			
	7b. [S73.0.F 4.3.6.2] <b>CONSIDER</b> performing S73.0.E, Bypassing/ Unbypassing a Control Rod from the Reactor Manual Control System.  <b>CUE:</b> As SSVN, request candidates recommendation on how to proceed, then agree with their recommendation.	Candidate recommends bypassing Control Rod 18-31 from the Reactor Manual Control System.			
	8. Candidate obtains 73.0.E, Bypassing/Unbypassing a Control Rod from the Reactor Manual Control System  <b>CUE:</b> Candidate is given a copy of S73.0.E, Bypassing/Unbypassing a Control Rod from the Reactor Manual Control System.	Candidate obtains copy of S73.0.E.			





ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p><b>EVALUATORS NOTE:</b> Per S73.0.E, Bypassing/Unbypassing a Control Rod from the Reactor Manual Control System, Bypassed Rod Identity switches are labeled X4, X3, X2, X1, X0 and Y4, Y3, Y2, Y1, Y0. A switch in UP position corresponds to '1', and DOWN position corresponds to '0'</p>				
<p>*</p>	<p>9. [S73.0.E 4.2.1] <b>REFER TO S73.0.E, Attachment 1 AND PLACE BYPASSED ROD INENTITY switches in position corresponding to binary coordinates for Control Rod 18-31 at *0C616.</b></p> <p><b>CUE:</b> Switches X2, X1, Y3, Y0 are in UP position, and remaining switches are in the down position.</p>	<p>Binary coordinates for control rod 18-31 identified as:  X = 00110 Y = 01001  Switches aligned:  X4, down                      Y4, down  X3, down                      Y3, up  X2, up                            Y2, down  X1, up                            Y1, down  X0, down                        Y0, up</p>		
	<p>10. [S73.0.E 4.2.2] <b>OBTAIN SSV Permission to bypass the Rod</b></p> <p><b>CUE:</b> SSV has granted permission for Control Rod Bypass.</p>	<p>SSV permission requested to bypass Control Rod 18-31.</p>		
<p>*</p>	<p>11. [S73.0.E 4.2.3] <b>PLACE BYPASSED Switch in UP in position at *0C616 panel.</b></p> <p><b>CUE:</b> Switch is in the Up Position</p>	<p>BYPASSED Switch in UP position</p>		
<p>*</p>	<p>12. [S73.0.E 4.2.4] <b>IF RDCS is INOP, as indicated by "INOPERABLE" LED Lit on RDCS Status section at *0C616 THEN DEPRESS "RESET" pushbutton in RDCS STATUS section of analyzer card for several seconds AND RELEASE.</b></p> <p><b>CUE:</b> RDCS INOP LED and HCU 18-31 LED light both extinguish</p>	<p>"RESET" pushbutton in RDCS STATUS section of analyzer card for several seconds <b>AND RELEASE.</b></p>		



ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
<p>13. [S73.0.E 4.2.5] <b>VERIFY</b> ROD BYPASS light Lit on the RDCS STATUS section of the ROD SELECT MODULE at *0C603 panel</p> <p><b>CUE:</b> The RO reports, "The ROD BYPASS light is lit on the *0C603 "Reactor Control Console."</p>	<p>Request from MCR status of ROD BYPASS light Lit on the RDCS STATUS section of the ROD SELECT MODULE at *0C603 panel</p>			
<p>14. [S73.0.E 4.2.5] <b>VERIFY</b> RDCS INOPERATIVE annunciator clear on *08 REACTOR (E-4)</p>	<p>Candidate calls MCR to verify RDCS INOPERATIVE annunciator clear on *08 REACTOR (E-4)</p>			
<p><b>CUE: You have met the termination criteria for this JPM</b></p>				

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

Operator's Name: \_\_\_\_\_

Job Title:  SED  SM  SRO  RO  STA/IA  EO  OTHER

JPM Title: RESET RDCS

JPM Number: LOJPM2119

Revision Number: 000

Task Number and Title: 2140050401, Bypass A ROD From RMCS

K/A Number and Importance: 201002 K3.01 3.4/3.4

Safety Function (1-9) 1 (Reactivity Control)

Admin Category (A1-4) N/A

Level of Difficulty (1-5) 3

Suggested Testing Environment: In-Plant

Alternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s): S73.0.F, Operation Of The Rod Drive Control System, Rev 17  
S73.0.E, Bypassing/Unbypassing a Control Rod from the Reactor Manual Control System. Rev 18  
ARC-MCR-\*08 E-4, RDCS INOPERATIVE

Actual Testing Environment:  Simulator  Control Room  In-Plant  Other

Testing Method:  Simulate  Perform

Estimated Time to Complete: 15 minutes Actual Time Used: \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?  Yes  No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Unit \_\_\_ Control Rod 18-31 has drifted out
2. Unit \_\_\_ Control Rod 18-31 was fully inserted, and isolated.
3. Tech Spec 3.1.3.1 has been referenced
4. Unit \_\_\_ Control Rod 18-31 was declared INOP
5. 'RDCS INOP' alarm on ARC MCR \*08 E-4 has annunciated
6. The LED for Unit \_\_\_ HCU 18-31 on The Rod Drive Control System Analyzer - Fault Location Map is lit

**INITIATING CUE:**

Shift supervision directs you to reset Unit \_\_\_ RDCS in accordance with S73.0.F, Operation of the Rod Drive Control System.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**MANUALLY INITIATE A CONTROL ROOM CHLORINE /  
TOXIC CHEMICAL ISOLATION**

JPM Number: LOJPM3023

REVISION NUMBER: 001

DATE: \_\_\_\_\_

Developed By:

\_\_\_\_\_

Instructor

\_\_\_\_\_

Date

Validated By:

\_\_\_\_\_

SME or Instructor

\_\_\_\_\_

Date

Reviewed By:

\_\_\_\_\_

Operations Representative

\_\_\_\_\_

Date

Reviewed By:

\_\_\_\_\_

EP Representative

\_\_\_\_\_

Date

Approved By:

\_\_\_\_\_

Training Department

\_\_\_\_\_

Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

**I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
 Procedure S78.8.A Rev: 17  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
Subsequent validations, sign and date below:

_____	SME / Instructor	_____	Date
_____	SME / Instructor	_____	Date
_____	SME / Instructor	_____	Date



**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0023 Rev. 10. Revised to new template and to align with latest procedure revision.	11/04/14
001	This JPM revised to new JPM template and procedure changes	10/28/16

# **Date of Revision** - refers to date revision was released for approval



#### **IV. SIMULATOR SETUP INSTRUCTIONS:**

1. Reset the Simulator to IC-3
2. Ensure the "B" CREFAS fan switch is in "AUTO" and the "A" CREFAS fan switch is in "STBY"
3. Ensure the "A" Control Room Supply and Return fans are in "RUN," and the "B" Control Room Supply and Return fans are in "AUTO."

#### **V. TASK STANDARD:**

The Main Control Room HVAC System is operating in the Chlorine/Toxic Chemical Isolation mode with a chlorine/toxic chemical isolation signal present on "B" and "D" isolation channels and no radiation isolation signals present.

#### **VI. INITIAL CONDITIONS:**

1. Main Control Room HVAC System is in the normal operating mode per Section 4.2 of S78.1.A.
2. The Main Control Room Emergency Fresh Air Supply System is lined up for automatic operation per S78.1.B.
3. All prerequisites of S78.8.A are met.

#### **VII. INITIATING CUE:**

You are directed by Shift Supervision to manually initiate a Main Control Room HVAC Chlorine/Toxic Chemical Isolation for maintenance using the "B" subsystem only per S78.8.A, Section 4.5.





**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

\*

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**

**VIII. PERFORMANCE CHECKLIST:**
**JPM Start Time** \_\_\_\_\_

	<b>*ELEMENT</b>	<b>STANDARD</b>	<b>SAT</b>	<b>UNSAT</b>	<b>COMMENT NUMBER</b>
	1. Obtain copy of S78.8.A, Manual Initiation of Control Room Radiation or Chlorine/Toxic Chemical Isolation.	N/A			
	2. <b>IF</b> no chemical isolation has been initiated, <b>THEN ENSURE</b> alignment as follows:	N/A			
	2a. HS-78-010B, “B” CONT RM EMERG FRESH AIR FAN CONT 0BV127” in AUTO	HS-78-010B, verified in AUTO			
	2b. HS-78-010A, “A” CONT RM EMERG FRESH AIR FAN 0AV127” in STANDBY	HS-78-010A, verified in STANDBY			
*	3. <b>PLACE</b> Control Room Isolation Valve Reset Keylock switch HS-78-017B (RESET B) to RESET.	Reset Keylock switch HS-78-017B (RESET B) is placed in RESET at Panel 00C681.			
*	4. <b>PLACE</b> Control Room Isolation Valve Reset Keylock switch HS-78-017D (RESET D) to RESET.	Reset Keylock switch HS-78-017D (RESET D) is placed in RESET at Panel 00C681.			
*	5. <b>PLACE</b> Control Room Isolation Valve Trip Switch HSS-78-017B (TRIP B) to CL <sub>2</sub> .	Switch HSS-78-017B (TRIP B) arming collar is rotated to CL <sub>2</sub> at Panel 00C681.			
*	6. <b>PLACE</b> Control Room Isolation Valve Trip Switch HSS-78-017D (TRIP D) to CL <sub>2</sub> .	Switch HSS-78-017D (TRIP D) arming collar is rotated to CL <sub>2</sub> at Panel 00C681.			



	*ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
*	7. <b>PLACE</b> Control Room Isolation Valve Reset Keylock switch HS-78-017B (RESET B) to AUTO.	Reset Keylock switch HS-78-017B (RESET B) is placed in AUTO at Panel 00C681.			
*	8. <b>PLACE</b> Control Room Isolation Valve Reset Keylock switch HS-78-017D (RESET D) to AUTO.	Reset Keylock switch HS-78-017D (RESET D) is placed in AUTO at Panel 00C681.			
*	9. <b>DEPRESS AND RELEASE</b> pushbutton portion of Trip Switch HSS-78-017B (TRIP B).	Trip Switch HSS-78-017B (TRIP B) pushbutton is depressed and released at Panel 00C681.			
*	10. <b>DEPRESS AND RELEASE</b> pushbutton portion of Trip Switch HSS-78-017D (TRIP D).	Trip Switch HSS-78-017D (TRIP D) pushbutton is depressed and released at Panel 00C681.			
<b>EVALUATORS NOTE:</b> [4.5.6] CREFAS run time data will be logged by another operator					
	11. <b>RECORD</b> CREFAS run time in appropriate log.  <b>CUE:</b> Another Operator will log the CREFAS Run time data	N/A			
	12. <b>ENSURE</b> "CHLOR ISLN CHAN B" AND "CHLOR ISLN CHAN D" amber lights are lit.	"CHLOR ISLN CHAN B" AND "CHLOR ISLN CHAN D" amber lights are lit on 00C681.			
	13. <b>VERIFY</b> "CONTROL ROOM CHLORINE ISOLATION INITIATED" annunciator alarmed at 002 VENT A-2.	Annunciator window A-2, "CONTROL ROOM CHLORINE ISOLATION INITIATED," on 002 VENT, is in alarm.			



*ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
14. <b>VERIFY</b> "CONTROL ROOM ISOLATION NOT COMPLETE" annunciator is <b>not</b> alarmed at 002 VENT A-3, after 25 seconds.	Annunciator window A-3, "CONTROL ROOM ISOLATION NOT COMPLETE," on 002 VENT, is not alarmed 25 seconds after the isolation is initiated.			
15. <b>ENSURE</b> 0B(A)V127, EMERGENCY AIR FAN B(A), is running.	0BV127, EMERGENCY AIR FAN B, is running.			
16. <b>ENSURE</b> 0A(B)V116, CONTROL ROOM AIR SUPPLY FAN A(B), running.	0AV116, SUPPLY FAN A, is running.			
17. <b>ENSURE</b> 0A(B)V121, CONTROL ROOM AIR RETURN FAN A(B), running.	0AV121, RETURN FAN A, is running.			
<b>CUE: You have met the termination criteria for this JPM</b>				

JPM Completion Time \_\_\_\_\_



**JPM SUMMARY**

**Operator's Name:** \_\_\_\_\_

**Job Title:**       SED    SM    SRO    RO    STA/IA    EO    OTHER

**JPM Title:** MANUALLY INITIATE A CONTROL ROOM CHLORINE/TOXIC CHEMICAL ISOLATION

**JPM Number:** LOJPM3023

**Revision Number:** 001

**Task Number and Title:** TPO-2881030401 Manually Initiate Control Room Radiation or Chlorine/Toxic Chemical Isolation

**K/A Number and Importance:** 290003      A3.01      3.3/3.5

**Safety Function (1-9)** 9 (Radioactivity Release)

**Admin Category (A1-4)** N/A

**Level of Difficulty (1-5)** 3

**Suggested Testing Environment:** Simulator

**Alternate Path:**  Yes  No   **SRO Only:**  Yes  No   **Time Critical:**  Yes  No

**Reference(s):** S78.8.A, "Manual Initiation of Control Room Radiation or Chlorine / Toxic Chemical Isolation", Rev. 17

**Actual Testing Environment:**  Simulator    Control Room    In-Plant    Other

**Testing Method:**  Simulate    Perform

**Estimated Time to Complete:** 20 minutes      **Actual Time Used:** \_\_\_\_\_ minutes

**EVALUATION SUMMARY:**

Were all the Critical Elements performed satisfactorily?       Yes       No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory    Unsatisfactory

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Evaluator's Name:** \_\_\_\_\_ (Print)

**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. Main Control Room HVAC System is in the normal operating mode per Section 4.2 of S78.1.A.
2. The Main Control Room Emergency Fresh Air Supply System is lined up for automatic operation per S78.1.B.
3. All prerequisites of S78.8.A are met.

**INITIATING CUE:**

You are directed by Shift Supervision to manually initiate a Main Control Room HVAC Chlorine/Toxic Chemical Isolation for maintenance using the "B" subsystem only per S78.8.A, Section 4.5. maintenance using the "B" subsystem only per S78.8.A, Section 4.5.



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE**

**START ESW PUMP PER SE-1**

JPM Number: LOJPM2258

REVISION NUMBER: 002

DATE: \_\_\_\_\_

Developed By: \_\_\_\_\_  
Instructor Date

Validated By: \_\_\_\_\_  
SME or Instructor Date

Reviewed By: \_\_\_\_\_  
Operations Representative Date

Reviewed By: \_\_\_\_\_  
EP Representative Date

Approved By: \_\_\_\_\_  
Training Department Date



**Note:** This LGS format satisfies the TQ-JA-150 Format

**I. JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 through 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cues (and terminating cues if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
 Procedure SE-1 Rev: 73  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page.  
 Subsequent validations, sign and date below:

_____	SME / Instructor	_____	Date
_____	SME / Instructor	_____	Date
_____	SME / Instructor	_____	Date





**II. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	ILT/LORT Approval	Action Tracking	Revision Date

**III. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (i.e. for conversion to LLOJPM format).
- D. For Revision 000, put reason for writing this JPM and for all subsequent revisions, annotate the changes that were made or incorporated.

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
000	This JPM replaces LLOJPM0258 Rev. 4. Revised to new template and to align with latest procedure revision. This revision changes this JPM to an Alternate Path.	10/7/13
001	Revised to new template and aligned for Equipment Operator use	10/01/15
002	This SEG is revised to new 3/16 SEG format template, including any procedure revisions	10/24/16

# Date of Revision - refers to date revision was released for approval



**IV. TASK STANDARD:**

'0C' ESW Pump Breaker closed from controls at D23 Switchgear.

**V. INITIAL CONDITIONS:**

1. The Main Control Room has been evacuated.
2. SE-1 has been entered and Remote Shutdown Panel transfer switches have been positioned to Emergency
3. D12, D13, D21, D22, and D23 Safeguard Buses are energized from their normal sources.
4. D11 Safeguard Bus is being powered from the D11 Diesel Generator.
5. An Equipment Operator performing running checks for D11 D/G reports that there is no indication of ESW flow through the D11 D/G Heat Exchangers.

**VI. INITIATING CUE:**

Shift Supervision has directed you to start '0A' ESW Pump per section 4.5 of SE-1 beginning at step 4.5.3.

**Information for Evaluator's Use:**

Any **UNSAT** requires written comments on respective step.

**\***

Denotes critical steps

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**The JPM Start Time clock starts when the candidate acknowledges the initiating cue.**



**VII. PERFORMANCE CHECKLIST:**

JPM Start Time \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	COMMENT NUMBER
	1. Obtain current revision of SE-1.  <b>CUE:</b> When candidate demonstrates the ability to obtain current revision of procedure, provide a copy of SE-1.	Current revision of SE-1 obtained.			
	2. <b>IF</b> 'A' ESW Pump is <b>not</b> running, <b>THEN</b> perform the following	N/A			
<p><b>EVALUATOR NOTE:</b> Alternate path starts here. 'A' ESW Pump will fail to start from RSP handswitch.</p>					
	2a. <b>START</b> 0AP548, "A" ESW Pump" (PUMP A).	Candidate simulates placing 'A' ESW Pump switch in START.			
	2b. <b>VERIFY</b> 0AP548, PUMP A, running.  <b>CUE:</b> When 'A' ESW Pump control switch is placed in START, inform the candidate: <i>"The green light above the switch is on, red light is off."</i>	Candidate recognizes pump is not running.  <b>Note:</b> Candidate may place handswitch back in Normal after Stop. This is not critical.			
	3. <b>IF</b> 'A' ESW will not function from the RSP, <b>THEN PERFORM</b> the following to start 'C' ESW Pump from D23 Switchgear:	N/A			
	3a. <b>PLACE</b> 152-11708/CST, "Test Switch" ESW C Pump 0CP548 to "PULL TO LOCK"	Candidate simulates placing 152-11708/CST in PULL TO LOCK			



ELEMENT		STANDARD	SAT	UNSAT	COMMENT NUMBER
<b>EVALUATOR NOTE:</b> The GE-75 key required for transfer switch HSS-11-095 is an alternate remote shutdown key on remote shutdown key ring obtained in SE-1.					
*	3b. <b>PLACE</b> HSS-11-095, "Handswitch For MCR or Local Control of 'OC' ESW Pump," to "EMERGENCY"	Candidate simulates placing HSS-11-095, "Transfer Switch" to "EMERGENCY"			
*	3c. <b>PLACE</b> 152-11708/CST, to "CLOSE"  <b>CUE:</b> "Breaker closing sound can be heard, the red light is lit, the green light is out and ammeter indicates starting current value decaying to running value."	Candidate simulates placing 152-11708/CST, to "CLOSE"  Candidate recognizes that 'OC' ESW Pump feeder breaker is closed.			
<b>CUE: You have met the termination criteria for this JPM</b>					

JPM Completion Time \_\_\_\_\_



### JPM SUMMARY

Operator's Name: \_\_\_\_\_

Job Title:         SED    SM    SRO    RO    STA/IA    EO    OTHER

JPM Title:    START ESW PUMP PER SE-1

JPM Number: LOJPM2258

Revision Number:    002

Task Number and Title: 2000410501, (SE-1) Control Room Abandonment (RO)  
2000160404, Manual S/U of Pumps from Emergency Switchgear Room (EO)

K/A Number and Importance:        295016                    AA1.04                    3.1/3.2

Safety Function (1-9)   8   (Plant Service Systems)

Admin Category (A1-4) \_\_\_\_\_

Level of Difficulty (1-5)   3  

Suggested Testing Environment:    In-Plant

Alternate Path:  Yes    No   SRO Only:  Yes    No   Time Critical:  Yes    No

Reference(s): SE-1, Remote Shutdown, Rev. 73

Actual Testing Environment:    Simulator    Control Room    In-Plant    Other

Testing Method:     Simulate    Perform

Estimated Time to Complete:   15   minutes    Actual Time Used: \_\_\_\_\_ minutes

#### EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily?         Yes         No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be:     Satisfactory         Unsatisfactory

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_



**LIMERICK GENERATING STATION  
JOB PERFORMANCE MEASURE  
INDIVIDUAL BRIEFING SHEET**

**INITIAL CONDITIONS:**

1. The Main Control Room has been evacuated.
2. SE-1 has been entered and Remote Shutdown Panel transfer switches have been positioned to Emergency.
3. D12, D13, D21, D22, and D23 Safeguard Buses are energized from their normal sources.
4. D11 Safeguard Bus is being powered from the D11 Diesel Generator.
5. An Equipment Operator performing running checks for D11 D/G reports that there is no indication of ESW flow through the D11 D/G Heat Exchangers.

**INITIATING CUE:**

Shift Supervision has directed you to start '0A' ESW Pump per section 4.5 of SE-1 beginning at step 4.5.3.



CODE NO:	SEG-5006E	REV NO:	000
AUTHOR:	T. A. BYERS	APPROXIMATE RUN TIME:	70 minutes
TYPE:	SIMULATOR EVALUATION GUIDE	EFFECTIVE DATE:	
PROGRAM:	LICENSED OPERATOR TRAINING		
COURSE:	LICENSED OPERATOR (REQUALIFICATION/INITIAL) TRAINING		
TITLE:	Simulator Evaluation Guide for Individual and Crew Performance		

Prepared By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Training Instructor - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Program (ILT or LOR) Lead - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
 EP (as appropriate) - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
 RE (as appropriate) - Signature

Approval: \_\_\_\_\_ Date: \_\_\_\_\_  
 OPS Manager - Signature

Approved For Use: \_\_\_\_\_ Date: \_\_\_\_\_  
 Training Manager - Signature



## Appendix D

## Scenario Outline

Form ES-D-1

Facility: Limerick 1 & 2 Scenario No.: SEG-5006E Rev 0 Op-Test No.: 1Examiners: \_\_\_\_\_ Operators: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Initial Conditions:**Unit 1 is at 100 % power. Unit 2 is at 100 % power.**Turnover:**Maintain 100% Reactor power  
Place '1C' SBLC Pump in Automatic Injection Mode per S48.1.A, Standby Liquid Control System Set-Up For Normal Operation, step 4.7 in preparation of a 1B SLC System Outage Window.

Event No.	Malfunction Number	Event Type*	Event Description
1.	MSL198B C41-S1C	N-PRO TS-SRO	Align '1C' SLC Pump for automatic operation
2.	MPR020C	C-RO	#3 APRM fails upscale ( <b>Malfunction</b> )
3.	MRR430A MRD024	R-RO C-PRO TS-SRO	'1A' Reactor Recirc Pump shaft seizure resulting in Recirc Pump trip ( <b>Abnormal</b> )
4.	MFH563C	C-PRO	Low Pressure FWH Level Transient ( <b>Abnormal</b> )
5.	MFH116C MFH016C MPR003A	C-RO	'6C' FWH Isolation ( <b>Abnormal</b> ) Core Power Oscillations
6.	MFW252A MRR440A	M-ALL	LOCA Inside Containment ( <b>T-111</b> )
7.	MRC457B	C-PRO	RCIC controller in AUTO failure ( <b>Malfunction</b> )
8.	MAD148D	C-PRO	'1M' SRV fails to open ( <b>Malfunction</b> )

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor





## I. QUANTITATIVE ATTRIBUTES

### A. ILT

Target Quantitative Attributes (Per Scenario; See ES-301 Section D.5.d)	ACTUAL NUMBER
1. Malfunctions after EOP entry (1-2)	2
2. Abnormal events (2-4)	2
3. Major transients (1-2)	1
4. EOPs entered/requiring substantive actions (1-2)	2
5. EOP contingencies requiring substantive actions (0-2)	2
6. EOP based Critical tasks (2-3)	4

Review TQ-AA-151 attachment 5 and ES-301-5 for individual position requirements for scenario and scenario set



**II. PURPOSE:** Systematically evaluate individual and team performance to identify areas for improvement. Critical Tasks and Assessment Items from this evaluation guide are to be used to assess crew and individual performance and as input into a 4.0 Crew Critique Process.

**III. SIMULATOR EVALUATION GUIDE OBJECTIVES:**

- A. The following evaluation objectives apply to the Crew (C), Shift Manager (SM), Control Room Supervisor (S), Unit Reactor Operator / Plant Reactor Operator (R), or Incident Assessor / Shift Technical Advisor (A).
1. The general condition for each of the evaluation objectives will be "Given the plant conditions and sequence of events in the Simulator Evaluation Guide (SEG)".
  2. The general acceptable evaluation objective criteria for each of the evaluation objectives will be "To perform effectively as an individual and contribute to successful crew performance in accordance with appropriate reference plant procedures and Operations Expectations, Fundamentals and Strategies".
  3. Specific UNSAT evaluation objective criteria will be consistent with TQ-AA-155, Conduct of Simulator Training and Evaluation with applicable forms and job aids.
  4. During performance of this Simulator Evaluation Guide, the individuals and crew should satisfactorily demonstrate the following overall procedure and plant control objectives:
    - Direct and perform actions per OT-104, Unexpected, Unexplained Positive or Negative Reactivity Insertion
    - Direct and perform actions per OT-112, Unexplained/Unexpected Change in Core Flow
    - Direct and perform actions per T-101, RPV Control
    - Direct and perform actions per OT-101, Drywell High Pressure
    - Direct and perform actions per T-102, Primary Containment Control
    - Direct and perform actions per T-111, Level Restoration/Steam Cooling
    - Direct and perform actions per T-112, Emergency Blowdown



**RECORD OF TEMPORARY CHANGES:**

- B. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- C. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- D. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	LORT Approval	Action Tracking	Revision Date

**IV. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (e.g for conversion of LSTS to LLORSEG format).

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
Rev000	Initial Issue of Simulator Evaluation Guide Template to revised LSES 5006	07/15/16

**# Date of Revision** - refers to date revision was released for approval

**SCENARIO EVENT AND EVALUATION SUMMARY:**

**Event One:** Shortly after the crew has assumed responsibility, they will be required to align the '1C' SLC Pump for automatic operation, using S48.1.A, Standby Liquid Control System Set-Up For Normal Operation, and remove the '1B' SLC Pump from service.

**Evaluation:** Evaluate the crew's ability to perform the procedure and place equipment in service and to evaluate the CRSs ability to apply Tech Spec 3.1.5. for the SLC Pump being removed from service.

**Event Two:** Shortly after the evolution of placing the '1C' SLC Pump in standby service, APRM #3 will fail upscale.

**Evaluation:** Evaluate the crew's response to the plant for the failed APRM, reference Tech Spec 3.3.1 and place the inoperable APRM in the BYPASS position.

**Event Three:** After the failed APRM issue is resolved, the '1A' Recirc Pump shaft will seize resulting in a Recirc Pump trip and reduction in core flow and reactor power.

**Evaluation:** To evaluate the crew's ability to address the sudden change in reactor power by entering and executing OT-104, Unexpected/ Unexplained Positive or Negative Reactivity Insertion, and OT-112, Unexpected/ Unexplained Change In Core Flow, for the tripped Recirc Pump. The crew will isolate the failed Recirc Pump and insert Control Rods to exit the Restricted Region of the Power/Flow Map. The crew will also execute GP-5 to stabilize the plant.

**Event Four:  
and Five:** As the crew is recovering from the tripped Recirc Pump and attempting to exit the Restricted Region of the Power/flow Map a low pressure FWH level transient will occur requiring re-entry into OT-104. As the crew addresses the transient another FWH level control problem will result in a 6<sup>th</sup> FWH isolation causing a larger positive reactivity addition and subsequent Thermal Hydraulic Instabilities (THI) .

**Evaluation:** To evaluate the crew's ability to diagnose the positive reactivity addition from the loss of FWH while in the Restricted Region of the Power/Flow Map and to detect/suppress core THI, by monitoring LPRM, APRM and period meters to detect indications for signs of core THI. The crew will shutdown the plant due to the Thermal Hydraulic Instabilities.

**SCENARIO EVENT AND EVALUATION SUMMARY cont'd**

Event Six: After the reactor is shutdown, a Feedwater line break will occur resulting in a loss of all feedwater to the RPV.

Evaluation: To evaluate the crew's ability to take appropriate actions to control RPV level using T-101, RPV Control, and eventually T-111, Level Restoration/Steam Cooling. The crew will start ECCS Pumps in preparation to maintain RPV level following an RPV Emergency Blowdown. Also to maintain Containment parameters, enter T-102, Primary Containment Control and, as RPV level drops due to the loss of high pressure feed, enter T-112, Emergency Blowdown to assure adequate core cooling with the low pressure injection systems.

Event Seven: During reactor RPV level restoration the RCIC flow controller will fail in automatic.

Evaluation: To evaluate the PROs response to the RCIC system failure and diagnose that RCIC is available only when manual control is taken.

Event Eight: As RPV level decreases to -161" the crew performs the T-112, Emergency Blowdown allowing low pressure ECCS systems to maintain RPV level. To accomplish the blowdown, five ADS valves are selected to be opened, however the '1M' SRV will fail to open from the handswitch, and require an alternate SRV be opened to ensure 5 SRVs are opened.

Evaluation: Evaluate the crew's ability to identify failure of the '1M' SRV to open, and open a non-ADS valve to ensure 5 SRV's are open.

Termination Point: The scenario may be terminated when the Emergency Blowdown is complete, RPV level is restored to normal band with ECCS systems and Containment Spray is in service.

**V. REFERENCES**

- A. Training Procedures
  - 1. TQ-LG-150, Limerick Operator Training Programs
  - 2. TQ-AA-151, ILT Certification and NRC Examination Development and Administration
  - 3. TQ-AA-155, Conduct of Simulator Training and Evaluation
- B. Annunciator Response Cards (ARC)
  - 1. 102 F-1, 1C FEEDWATER HEATER HI LEVEL
  - 2. 102 F-2, 2C FEEDWATER HEATER HI LEVEL
  - 3. 102 G-4, FW HTRS 1&2 HI-HI LEVEL LP HTR STRING ISOLATION
  - 4. 102 G-3, 6C FEEDWATER HEATER HI LEVEL
  - 5. 102 G-5, FEEDWATER HEATER 3/4/5/6 HI HI LEVEL ISOLATION
  - 6. 107 A-3, SLCS PUMP AUTO-START STATUS TROUBLE
  - 7. 107 H-2, REACTOR HI/LO LEVEL
  - 8. 107 I-2, VIBRATION ALARM ALERT
  - 9. 108 A-4, OPRM TRIPS ENABLED
  - 10. 108 B-3, APRM UPSCALE TRIP/INOP
  - 11. 108 F-3, ROD OUT BLOCK
  - 12. 108 B-4, APRM UPSCALE
  - 13. 108 A-3, OPRM PRE-TRIP
  - 14. 108 I-1, 1A/1B/1C STANDBY LIQUID PUMP MOTOR OVERLOAD/LOSS OF POWER
  - 15. 111 B-1, 1A RECIRC ASD TRIPPED
  - 16. 111 B-2, 1A RECIRC ASD MAJOR FAILURE
  - 17. 111 D-2, 1A RECIRC PUMP MOTOR HI VIBRATION
  - 18. 111 E-2, 1A RECIRC ASD 13 KV BKR TRIP
- C. System Procedures (S)
  - 1. S48.1.A, Standby Liquid Control System Set-up For Normal Operation.
  - 2. S12.1.A, RHR Service Water System Startup.
- D. General Procedures (GP)
- E. Off Normal Procedures (ON)
- F. Operating Transient Procedures (OT)
  - 1. OT-104, Unexpected, Unexplained Positive or Negative Reactivity Insertion
  - 2. OT-112, Unexpected/Unexplained Change in Core Flow
  - 3. OT-101, Drywell High Pressure
- G. Event Procedures (E)
- H. Special Event Procedures (SE)
  - 1. SE-10, LOCA
- I. Surveillance Test and Routine Test Procedures (ST and RT)

**REFERENCES cont'd**

- J. Technical Specifications and TRM (TS)
  - 1. 3.4.1.1.a.
  - 2. 3.1.5
  - 3. 3.3.1
  - 4. 3.3.6
  - 5. 3.5.1.c.
  - 6. 3.3.2.1
  - 7. 3.7.3.a,
- K. Transient Response Implementation Procedures (T-100 series)/SAMPs
  - 1. T-101, RPV Control
  - 2. T-102, Primary Containment Control
  - 3. T-111, Level Restoration/Steam Cooling
  - 4. T-112, Emergency Blowdown
- L. TRIP 200 Series Procedures
  - 1. T-240, Maximizing CRD Flow After Shutdown During Emergency Conditions
  - 2. T-225, Startup And Shutdown Of Suppression Pool And Drywell Spray Operation
- M. EP-AA-1008, Limerick, Radiological Emergency Plan Annex for Limerick Generating Station
- N. Administrative Procedures
  - 1. OP-AA Procedures
    - a. OP-AA-1, Conduct of Operations
    - b. OP-AA-20, Conduct of Operations Process Description
    - c. OP-AA-101-111-1003, Operations Department Standards and Expectations
    - d. OP-AA-101-113, Operations Fundamentals
    - e. OP-AA-101-113-1006, 4.0 Crew Critique Guidelines
    - f. OP-AA-106-101-1006, Operational Decision Making Process
  - 2. OP-LG Procedures
    - a. OP-LG-101-111-1000, Licensed Operator Duties
    - b. OP-LG-102-106, Operator Response Time Program at Limerick
    - c. OP-LG-103-102-1000, Human Performance Continuing Good Practices
    - d. OP-LG-103-102-1002, Strategies for Successful Transient Mitigation
    - e. OP-LG-108-101-1001, Simple Quick Acts / Transient Acts
- O. Current Shift Night Orders Forced Outage Plan
- P. INPO Significant Operating Experience Reports (SOER), Significant Event Reports (SER) and INPO Event Reports (IER)
  - 1. IER-L1 11-3, Weaknesses in Operator Fundamentals
  - 2. SER 3-05, Weakness in Operator Fundamentals
  - 3. SOER 10-02, Engaged Thinking Organizations
  - 4. INPO 15-004, Operator Fundamentals



## VI. PREBRIEF INSTRUCTIONS

Unit 2 is in OPCON 1 at 100 % power  
Unit 1 is in OPCON 1 at 100 % power

### **Specific Plant Conditions are as Follows:**

- None

### **Inoperable/Out of Service Equipment and Estimated Time of Return (ETR):**

- None

### **Restrictions on Plant Operations:**

- None

### **Planned Evolutions:**

- Place '1C' SBLC Pump in Automatic Injection Mode per S48.1.A, Standby Liquid Control System Set-Up For Normal Operation, step 4.7 in preparation of a '1B' SLC System Outage Window

### **Documents Provided:**

- S48.1.A, Standby Liquid Control System Set-Up For Normal Operation





**VII. DIRECTIONS FOR EVALUATION PREPARATION**

**A. INITIAL PREPARATION**

✓	ITEM / MALFUNCTION / REMOTE FUNCTIONS
	Complete TQ-AA-155, Operator Training Programs Attachment 02, Evaluated Scenario Administration Checklist.
	Complete TQ-LG-201-0113, Limerick Training Department Simulator Examination Security Actions Checklist

**B. SIMULATOR SETUP**

✓	ITEM / MALFUNCTION / REMOTE FUNCTIONS
	Complete Limerick Simulator Pre-Evaluation Checklist
	Reset Simulator to the Pre-loaded Cycle <b>IC</b> developed for the Evaluation <b>OR</b> Reset the simulator to designated base load <b>IC-3</b> <b>AND</b> Load scenario file <b>SEG5006E Rev000.scn</b> <ul style="list-style-type: none"> <li>• Verify that all Malfunctions, Remotes, Overrides, Annunciators and Triggers are properly loaded</li> </ul> <b>OR</b> <ul style="list-style-type: none"> <li>• Manually enter the Malfunctions, Remotes, Overrides, Annunciators and Triggers per the Scenario Generator Screen Shots:</li> </ul>
	Simulator Operator (Driver) perform the following: <ul style="list-style-type: none"> <li>• Momentarily place simulator in RUN</li> <li>• Acknowledge and clear all spurious alarms</li> <li>• Place the simulator back into FREEZE</li> <li>• Place appropriate tags and equipment in required condition / status.</li> </ul>



C. MALFUNCTION/REMOTE/OVERRIDE/ANNUNCIATORS FUNCTION TIME TABLE

Interventions Summary

Hide Malfunctions - 12    Hide Remotes - 8    Show Overrides - 1    Show Annunciators - 1

**Malfunction Summary**

Mal ID	Mult ID	Description	Current Value	Target Value	Rmptime	Actime	Dactime	Trig
MSL198B		SLC Pump 1B Loss of Control Power	False	False				
MPR020C		APRM Channel 3 Fails to Selected Value	100.1036	125.0000	00:00:10	00:00:15		2
MRR430A		Reactor Recirculation Pump 1A Seizure	False	True		00:00:15		3
MPR003A		In-Phase Core Power Oscillations	0.00	23.00000	00:04:00	00:01:00		5
MFH116C		Feedwater Heater 16C Dump Valve Fails	0.00	0.00				5
MFH016C		Feedwater Heater 16C Drain Valve Fails	0.00	0.00				5
MRO024		Rod Drive Control System Failure	False	True		00:00:15		5
MRR440A		Recirculation Loop A Rupture	0.00	1.500000	00:10:00	00:03:00		6
MFV252A		FW Line A Break Inside Primary Containment	0.00	100.0000	00:01:00	00:02:00		6
MRC457B		RCIC Flow Controller Fails Low	True	True				
MAD148D		Relief Valve (FD13M) Fails (Closed)	True	True				
MFH563C		Feedwater Heater 11C Level Sensing Line Fails High	False	True		00:01:00	00:00:25	4

Timer Pause    Delete All    Active Pending

**Remotes Summary**

Remf ID	Mult ID	Description	Current Value	Target Value	Rmptime	Actime	Trig
RRE148		Refuel Floor To SGT5 Isolation damper SGD76-206-3	CLOSE	CLOSE			
RRE156		Unit 2 Refuel Floor Isol Sw HS76-281A	RESET	RESET			
RRE157		Unit 2 Refuel Floor Isol Sw HS76-281B	RESET	RESET			
RRM032		SPE & MVP Rad Monitor RE-160 Skid 10S408 Enable	DISABLE	DISABLE			
RPR061		APRM Channel 1 Gain Adjustment Factor	.8654	.8654			
RPR063		APRM Channel 3 Gain Adjustment Factor	.8570	.8570			
RPR062		APRM Channel 2 Gain Adjustment Factor	.8710	.8710			
RPR064		APRM Channel 4 Gain Adjustment Factor	.8490	.8490			

Timer Pause    Clear List    Active Pending

Interventions Summary

Show Malfunctions - 11    Show Remotes - 4    Hide Overrides - 1    Hide Annunciators - 1

**Override Summary**

Tag ID	Description	Position / Target	Actual Value	Override Value	Rmptime	Actime	Dactime	Trig
C41-S1C	1C Standby Liquid Control Pump Ind Lamps	CONTINUITY	ON	OFF				1

Timer Pause    Delete All    Active Pending

**Annunciator Summary**


Window	Description	Tagname	Override Type	OVal	AVal	Actime	Dactime	Trig
14	Standby Liquid Squib Valve Loss of Continuity	108 REACTOR I4	ON	ON	OFF			1

Timer Pause    Delete All    Active Pending



D. EVENT TRIGGERS ASSIGNMENT

1. Timers should be used on event triggers where possible for time validation
2. Timing of event triggers may be altered by the Lead Evaluator (or designee)
3. Verify triggers are actuated automatically as designed or manually initiate the trigger when the initiating action has occurred.
4. Inform Lead Evaluator (or designee) of expected plant response prior to actuation of each trigger.
5. Trigger #1 is manually initiated at Lead Evaluator (or designee) direction after the crew assumes responsibility for operation.

	TRIGGER / TIME	MALFUNCTION / EVENT	DESCRIPTION
	1	Manual	Remove power from XV-48-1F004C
	2	Manual	Initiates APRM #3 Upscale
	3	Manual	Initiates '1A' Recirc Pump trip
	4	Auto / ZDIB1(3864)    ZDIB1(3858)	HV-043-1F031A or 1F023A to Close Initiates Low Pressure FWH Level Transient
	5	Auto / FWZR607R<=20852	Total Steam Flow reduced to 10 Mlbm/hr Initiates 6 <sup>th</sup> FWH high level and THI
	6	Auto / ZRPS1SDN	RMS to SHUTDOWN Initiates Feedwater Line rupture / DW leak

Event Trigger Builder / Viewer

Favorites Triggers

Trigger #	Trigger Text
1	
2	
3	
4	ZDIB1(3864)    ZDIB1(3858)
5	FWZR607R <= 20852
6	ZRPS1SDN
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	

Operators:

Arithmetic:

- \* Multiplication
- / Division
- + Addition
- Subtraction

Relational:

- > Greater than
- >= Greater than or equal
- < Less than
- <= Less than or equal
- == Equal to
- != Not equal to

Logical:

- && And
- || Or
- ! Not

Other:

- [ Open Paren
- ] Close Paren

Trigger Now Clear Clear All Accept Exit

**E. EQUIPMENT REPORTS AND LEAD EVALUATOR (OR DESIGNEE) OPERATIONS**

1. Scripted Activity Reports should be followed with adherence to Operations Communication standards of performance.
2. The T-200 procedure reference book should be used for familiarity of reports to aid in operator prompting and expected communications.
3. The Lead Evaluator (or designee) should be informed if any event is not reported as scripted due to lack of Operator request.
4. The Standard Equipment Operator Response Times are per Attachment 1
5. A record of communications from the MCR and to the MCR will be maintained by the Simulator Operator using **Attachment 2**.
6. The OCOEE Simulator Operator Station P&IDs, Floor Plans and Panels should be used by the Simulator Operator as reference information when making reports to the MCR for plant parameters which are not driven by a communications script. Examples include: ARMs, Blowout Panel status, Reactor Building Area Temperatures and Pressures, RMMS, Turbine Enclosure parameters etc.



## X. CREW CRITICAL TASKS

A. Critical Tasks are based on the current Crew Critical Task List revision, NUREG 1021 and TQ-AA-150 requirements.

1. **T-111.4 Inhibit Automatic ADS**  
K/A 218000 A2.06 4.2/4.3

Standard: Prevent automatic initiation of ADS prior to exceeding -129" reactor level and ADS logic being completed.

### SAT/UNSAT

2.a **T-112.1 Perform emergency blowdown per T-112.**  
K/A 295031 EA1.07 3.7/3.7  
K/A 295031 EA2.04 4.6/4.8

Standard: When RPV level drops below TAF, open 5 SRV's.

### SAT/UNSAT

OR

2.b **T-102.2 Perform emergency blowdown per T-112.**  
K/A 295024 EA1.08 3.9/3.9  
K/A 295024 EA2.04 3.9/3.9

Standard: When Suppression Pool Pressure cannot be maintained below the Pressure Suppression Pressure (PC/P-3) curve and before Drywell pressure exceeds 55 psig, open 5 SRVs.

### SAT/UNSAT

3. **T-111.3 Maintain RPV level greater than the TAF.**  
K/A 295031 EA1.01 4.4/4.5  
K/A 295031 EA1.02 4.5/4.5  
K/A 295031 EA1.05 4.3/4.3  
K/A 295031 EA1.11 4.1/4.1  
K/A 295031 EA1.12 3.9/4.1

Standard: Operate injection systems to maintain reactor level greater than the TAF or enter T-112, perform an emergency blowdown, and when pressure permits, inject with low pressure ECCS to restore RPV level above TAF.

### SAT/UNSAT



### CREW CRITICAL TASKS cont'd

4.      **T-102.1**      **Spray the Drywell per T-225.**
- |     |        |        |         |
|-----|--------|--------|---------|
| K/A | 295024 | EA1.11 | 4.2/4.2 |
| K/A | 295028 | EA1.01 | 3.8/3.9 |
| K/A | 295028 | EA1.04 | 3.9/4.0 |

Standard:      When Drywell temperature and pressure are on the SAFE side of curve PC/P-2, spray the Drywell before exceeding 340°F or 55 psig.

#### SAT/UNSAT



- XI. ASSESSMENT OF CREW PERFORMANCE DURING CONDUCT OF THE DYNAMIC SIMULATOR EVALUATIONS:**
- A. Conduct the Simulator Evaluation Session per TQ-AA-155, Conduct of Simulator Training and Evaluation, Attachment 02, Evaluated Scenario Administration Checklist
  - B. Assessment of Crew and Individual performance shall be consistent with OP-AA-20, Conduct of Operations Process Description
  - C. Where possible record the time and position responsible for performance of each task or assessment item
  - D. Items not performed as expected **SHALL** be discussed in the post performance crew critique
  - E. During the performance of the evaluation, the Simulator Evaluators shall **MAINTAIN** notes of observations and information consistent with the timeline
  - F. Assessment items with the ⌚ symbol indicate a time critical standard for performance
  - G. Assessment items with the ⚡ symbol indicate a Probabilistic Risk Assessment (PRA) association with the task
  - H. The Simulator Operator will respond with scripted or proceduralized responses when requested by the MCR operators with Procedure completion times requested per **Attachment 1**
  - I. The Simulator Operator will also maintain a timeline and record of all reports and requests issued by the MCR personnel with response provided by the simulator operator using **Attachment 2**

**1. EVENT – 1 PLACE '1C' SLC PUMP IN AUTOMATIC INJECTION MODE****Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

At time 1 min when requested to power down the '1B' SLC Pump insert malfunction MSL198B and

**report:** Feed breaker for '1B' SLC Pump, D124-R-C-34 is opened.

When requested by RO to remove fuse 2 and fuse 3 from C640 panel per S48.1.A step 4.7.2 and 4.7.3, manually actuate **Trigger # 1** to remove power to C41-S1C XV-048-1F004C Squib Valve, and alarm 108 I-4, Standby Liquid Squib Valve Loss Of Continuity.

Ensure annunciator 108 I-4, Standby Liquid Squib Valve Loss Of Continuity cleared when fuses re-installed, per step 4.7.10 and 4.7.11 of S48.1.A

When requested by RO to install fuse 2 and fuse 3 from C640 panel per S48.1.A step 4.7.10 and 4.7.11, **DELETE - C41-S1C** '1C' SBLC Pump Indicating Lamps

**AND DELETE** - Annunciator Override 108 Reactor I4 (Standby Liquid Squib Valve Loss of Continuity).





TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
1.	<b>EVENT – 1 PLACE ‘1C’ SLC PUMP IN AUTOMATIC INJECTION MODE</b>	
<b>Lead Evaluator (or designee) Notes:</b> The crew will be directed to align the ‘1C’ SBLC Pump for automatic injection per S48.1.A, Standby Liquid Control System Set-up For Normal Operation, section 4.7. When the 1B SLC Pump is de-energized, annunciator 108 I-1, 1A/1B/1C STANDBY LIQUID PUMP MOTOR OVERLOAD/LOSS OF POWER will be received.		
	[S48.1.A 4.7.1] Direct EO to open ‘1B’ SLC Pump Feed (D124-R-C-34)	PRO
	SRO references Tech Spec 3.1.5 action a for only one pump and corresponding explosive valve OPERABLE	SRO
	[S48.1.A 4.7.2/3] <b>REMOVE</b> fuse F2 and F3 in panel C640 to disarm XV-48-1F004C	PRO
	[S48.1.A 4.7.4/5] <b>OBTAIN</b> key for 1CP208 SLC Injection Pump and <b>PLACE</b> 1CP208 control switch to “NORM” position	PRO
	[S48.1.A 4.7.6] <b>VERIFY</b> annunciator 107 A-3 SLCS PUMP AUTO-START STATUS TROUBLE alarmed	PRO
	[S48.1.A 4.7.7] <b>VERIFY</b> “OVERRIDE (amber) light not Lit	RO
	[S48.1.A 4.7.8] <b>PLACE</b> SS-48-104C-1 switch to “ENABLE” position	RO
	[S48.1.A 4.7.9] <b>VERIFY</b> annunciator 107 A-3 SLCS PUMP AUTO-START STATUS TROUBLE clears	RO/PRO
	[S48.1.A 4.7.10/11] <b>INSTALL</b> fuse F2 and F3 in panel C640 to arm XV-48-1F004C	RO
	The CRS References Tech Spec 3.1.5 and determines with 2 pumps and corresponding explosive valves are operable.	SRO



**2. EVENT – 2    APRM # 3 FAILS UPSCALE (Malfunction)**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

Manually actuate **Trigger # 2** when requested by Lead Evaluator, to initiate APRM #3 Upscale

At time 5 min after FSSV or EO action requested to investigate #3 APRM failure,  
**report:** "Unit 1, APRM #3 shows an internal failure on the ODA."

Manually actuate **Trigger # 3** when requested by Lead Evaluator, to initiate '1A' Recirc Pump trip.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
2.	EVENT – 2      APRM # 3 FAILS UPSCALE (Malfunction)	
<b>Lead Evaluator (or designee) Notes:</b> The RO will identify APRM #3 fails upscale as the annunciator alarms. THE ODA on 10C603 panel will show APRM #3 upscale with all other APRMs reading normal.		
	Reference appropriate ARC: <ul style="list-style-type: none"> <li>• 108 B-3, APRM UPSCALE TRIP/INOP</li> <li>• 108 F-3, ROD OUT BLOCK</li> <li>• 108 B-4, APRM UPSCALE</li> </ul>	RO/PRO
	[ARC MCR 108 B-3] Determine APRM #3 ODA has upscale trip with 'TRIP' message on display header	RO
	CRS directs bypassing APRM #3	SRO
	[ARC MCR 108 B-3] RO places #3 APRM in BYPASS	RO
	Reference Tech Spec 3.3.1 and 3.3.6 and determines the requirement of 3 is met	SRO
	Reset annunciators on panel 108	RO



**3. EVENT – 3 ‘1A’ REACTOR RECIRC PUMP SHAFT SIEZURE (Abnormal)**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

At time 5 min when FSSV or EO directed to respond to investigate ‘1A’ Recirc Pump trip  
**report:** The ‘1A’ ASD feed breaker is tripped. There is nothing that is obvious wrong with it.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
3.	EVENT – 3 '1A' REACTOR RECIRC PUMP SHAFT SIEZURE (Abnormal)	
<p><b>Lead Evaluator (or designee) Notes:</b> The 1A Reactor Recirc Pump will experience a shaft seizure resulting in a trip of the 1A ASD. OT-104, Unexpected/Unexplained Positive or Negative Reactivity Insertion is normally entered during a reactivity addition event, and directs entry into OT-112, Unexpected/Unexplained Change in Core Flow, due to Recirc Pump trip.</p>		
	<p>Reference ARCs as appropriate:</p> <ul style="list-style-type: none"> <li>• 111 B-1, 1A RECIRC ASD TRIPPED</li> <li>• 111 B-2, 1A RECIRC ASD MAJOR FAILURE</li> <li>• 111 D-2, 1A RECIRC PUMP MOTOR HI VIBRATION</li> <li>• 111 E-2, 1A RECIRC ASD 13 KV BKR TRIP</li> <li>• 107 H-2, REACTOR HI/LO LEVEL</li> <li>• 107 I-2, VIBRATION ALARM ALERT</li> <li>• 108 A-4, OPRM TRIPS ENABLED</li> </ul>	
	<p>[OT-104, 3.1] Enter OT-104 Unexpected/Unexplained Positive or Negative, Reactivity Insertion and directs entering OT-112</p>	SRO
	<p>[ARC-MCR 111 B-2/D-2] Enter OT-112, Unexpected/Unexplained Change in Core Flow</p>	SRO
	<p>[OT-112, 2.0] Immediate Operator Action <b>MONITOR</b> RPV level AND manually CONTROL RPV level, as required</p>	RO
	<p>[OT-112, 3.1] <b>DIRECT</b> RO to monitor for core THI indications</p> <ul style="list-style-type: none"> <li>• APRM flux level oscillations</li> <li>• APRM and LPRM signal changes from random to periodic variations</li> <li>• Period meter display strong positive to negative swings</li> </ul>	SRO
	<p>[OT-112, 3.2] Direct OT-112, Att. 1</p>	SRO
	<p>[OT-112, Att.1 step 5.0] CLOSE HV-043-1F031A, "A Recirc Pump Disch Vlv" (DISCHARGE A) <b>OR</b> HV-043-1F023A, "A Recirc Pump Suction Vlv" (SUCTION A) for tripped Recirc Pump.</p>	PRO
	<p>[OT-112, Att.1 step 6.0] <u>IF</u> Recirc Pump discharge isolation valve is <u>not</u> required to be closed <b>AND</b> approximately 5 minutes have elapsed, <b>THEN OPEN</b> HV-043-1F031A, "A Recirc Pump Disch Vlv" (DISCHARGE A) <b>OR</b> HV-043-1F023A, "A Recirc Pump Suction Vlv" (SUCTION A) for tripped Recirc Pump</p>	PRO



**3. EVENT – 3 '1A' REACTOR RECIRC PUMP SHAFT SEIZURE (Abnormal)**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
3.	<b>EVENT – 3 '1A' REACTOR RECIRC PUMP SHAFT SIEZURE (Abnormal)</b>	
	[OT-112, Att.1 step 7.0] Limit speed of operating Recirc Pump to <1510 rpm	RO
	[OT-112, Att.1 step 8.0] <u>IF</u> possible, <u>THEN</u> Maintain flow in operating loop such that total core flow is >40 Mlb/hr	RO
	[OT-112, Att.1 step 9.0] <b>PERFORM</b> S43.2.A, Shutdown of a Recirculation Pump, to ensure tripped Recirc pump is properly shutdown	RO
	[OT-112, Att.1 step 10.0 GP-5 step 3.1.6] (If time permits) <b>SELECT</b> the new MCPR limit for SLO using S38.1.L / <b>ENSURE</b> Reactor Engineering enters new MCPR limit into PMS Computer.	RO
	[OT-112, Att.1 step 11.0] <b>NOTIFY</b> Chemistry that power change of greater than 15% occurred in less than one hour (Tech Spec 3.4.5)	RO
	[OT-112, Att.1 step 12] (If time permits) <b>REQUEST</b> APRM channels calibrated for SLO	CRS
	[OT-112, Att.1 step 15] (If time permits) <b>ENSURE</b> ST-6-043-321-1, Daily Jet Pump Operability Verification For Single Recirc Loop Operation, performed	PRO
	[OT-112, Att.1 step 16] <b>ENTER</b> GP-5, Appendix 3, Unintentional Drop in Power	CRS
	[OT-112, 3.2 GP-5 App#3 step 3.1.1.2] <b>PERFORM</b> OT-112, Att. 3 to confirm operation in the authorized region of the Power/Flow Map	SRO
	[OT-112, 3.3] <b>DEMAND</b> a P-1 edit <u>AND</u> determine whether a Thermal Limit violation exists	RO/SRO
	[OT-112, 3.4] <u>IF</u> any Thermal Limit violations exist, <u>THEN</u> ENTER GP-14	SRO
	[OT-112, 3.5] <b>CONSIDER</b> reportability of Rx power excursion <u>AND REFER</u> to Discussion Step 6.17	SRO
	[OT-112, Att. 3, GP-5 App#3 step 3.1.1.5] Direct RO to insert control rods to exit restricted region of power/flow map (~45%)	SRO

3. **EVENT – 3 '1A' REACTOR RECIRC PUMP SHAFT SIEZURE (Abnormal)**



**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

Ensure **Trigger # 4** automatically actuates when either HV-043-1F031A or HV-043-1F023A is closed to initiate a low pressure FWH level transient





TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
3.	<b>EVENT – 3 ‘1A’ REACTOR RECIRC PUMP SHAFT SIEZURE (Abnormal)</b>	
	Insert control rods IAW RMSI to reduce power to exit restricted region	RO
	[GP-5 App#3 step 3.1.6.2] (time permitting) <b>ENSURE</b> , within 4 hrs. ST-6-107-889-1, Thermal Limits Determination For Single Recirc Loop Operation, has been performed.	SRO
	[GP-5 App#3 step 3.1.6.3/4] (time permitting) <b>ENSURE</b> ST-6-043-321-1, Daily Jet Pump Operability Verification For Single Recirc Loop Operation, and shiftly check sections of ST-6-107-590-*, Daily Surveillance Log/OPCONS 1, 2, 3, performed.	SRO
	Reference Tech Spec 3.4.1.1.a.1 for Single Loop Operations (time permitting) With one reactor coolant system recirculation loop not in operation: 1. Within 4 hours: a. Place the recirculation flow control system in the Local Manual mode, and, b. Reduce THERMAL POWER to $\leq 74.9\%$ of RATED THERMAL POWER, and, c. Limit the speed of the operating recirculation pump to less than or equal to 90% of rated pump speed, and d. Verify that the differential temperature requirements of Surveillance Requirement 4.4.1.1.5 are met if THERMAL POWER is $\leq 30\%$ of RATED THERMAL POWER or the recirculation loop flow in the operating loop is $\leq 50\%$ of rated loop flow, or suspend the THERMAL POWER or recirculation loop flow increase. 2. Within 6 hours, change APRM and Rod Block setpoints for Single Loop Ops	SRO

**4. EVENT – 4 Low Pressure FWH Level Transient****Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

At time 5 min when FSSV or EO directed to respond to investigate 1C and 2C Feedwater Heater High Level **report:** The 1C Low Pressure FWH Levels have returned to normal.

Ensure **Trigger # 5** automatically actuates when reactor power decreased to ~65% as designated by Main Steam Total Flow, to initiate FWH high level, RDCS failure and In-Phase Core Power Oscillations



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4.	<b>EVENT – 4      Low Pressure FWH Level Transient</b>	
<p><b>Lead Evaluator (or designee) Notes:</b> During the power reduction the 1C Low Pressure Feedwater heater (FWH) String will experience a level transient that will cause a temporary high high level condition of the string. This condition will initiate an automatic isolation of the FWH String. The condition will clear and the crew is expected to identify that the isolation is no longer required to go to completion and take actions to stop the closure and re-open the isolation valves.</p>		
	Reference ARCs as appropriate: <ul style="list-style-type: none"> <li>• 102 F-1, 1C FEEDWATER HEATER HI LEVEL</li> <li>• 102 F-2, 2C FEEDWATER HEATER HI LEVEL</li> <li>• 102 G-4, FW HTRS 1&amp;2 HI-HI LEVEL LP HTR STRING ISOLATION</li> </ul>	PRO
	[ARC MCR 102 G-4] Verify L.P. FW HTR string inlet AND outlet valve HV-06-101C AND HV-06-102C close	PRO
	[ARC MCR 102 G-4] <b>IF</b> low pressure heater string isolation is occurring <b>THEN</b> Enter OT-104, (positive reactivity insertion) and maintain power below pre-transient value.	SRO/RO
	[ARC MCR 102 G-4] Attempt to reset alarm on MCR panel 102.	PRO
	[ARC MCR 102 G-4] IF alarm clears, AND the MOV's are still in mid position, THEN: <ol style="list-style-type: none"> <li>a. Pull to stop HS-006-101C AND HS-006-102C.</li> <li>b. Re-open HV-006-101C AND HV-006-102C.</li> </ol>	PRO

**5. EVENT – 5 ‘6C’ FWH ISOLATION WITH THI (Abnormal)****Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

Ensure **Trigger # 5** automatically actuates when reactor power decreased to ~65% as designated by Total Steam Flow, to initiate FWH high level, RDCS failure and In-Phase Core Power Oscillations

Ensure **Trigger # 6** automatically actuates when RMS is taken to SHUTDOWN, to initiate Feedwater Line break and drywell leak.

At time 3 min after FSSV or EO action requested to verify 6C FWH level locally  
**report:** FWH level indicates high ~ 30" Double Red Dots.

**IMPORTANT NOTE:**

**DELETE** malfunction **MPR003A**, In-Phase Core Power Oscillations, on reactor scram.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
5.	EVENT – 5 '6C' FWH ISOLATION WITH THI (Abnormal)	
<p><b>Lead Evaluator (or designee) Notes:</b> A high level in the '6C' FWH will result due to a malfunction of the FWH level controller. As a result of the high level in the FWH the Feedwater will isolate causing a rise in core reactivity, and a shift in the core power shape. The core is already operating in the RESTRICTED REGION of the Power/Flow Map due to the Recirc Pump trip where there is an increased potential for core THI. The RO will identify indications of THI using LPRM, APRM and SRM period meter indications.</p>		
	Reference ARCs <ul style="list-style-type: none"> <li>• 102 G-3, 6C FEEDWATER HEATER HI LEVEL</li> <li>• 102 G-5, FEEDWATER HEATER 3/4/5/6 HI HI LEVEL ISOLATION</li> </ul>	RO
	[ARC MCR 102 G-3] Dispatch operator to verify high level locally	RO
	[ARC MCR 102 G-5] Verify extraction steam valve to 6C FWH closed	RO
	[ARC MCR 102 G-5] Monitor Feedwater temperature decreasing	RO/PRO
	[ARC MCR 102 G-5] Re-Enter OT-104, Unexpected/Unexplained Positive or Negative Reactivity Insertion, and perform Attachment 3	SRO
	[OT-104 Attach # 3] <b>DETERMINE</b> amount of FW inlet temperature reduction by comparing pre-transient and post-transient FW temperature from Core Power And Flow Log OR P-1.	SRO/RO
	[OT-104 Attach # 3] <b>IF</b> transient is due to Feedwater Heating isolation, <b>THEN MAINTAIN</b> power level in accordance with Attachment #8 guidelines	SRO
	[OT-104 Attach # 3] <b>IF</b> FW inlet temperature is <b>not</b> in the "Normal Operating Region" of Attachment 2 "Feedwater Inlet Temperature vs Core Thermal Power" in GP-5 Appendix 2, <ul style="list-style-type: none"> <li>• <b>REDUCE</b> Rx power to in accordance with GP-5 Appendix 2, Planned Rx Maneuvering Without Shutdown, Section 3.1, Reducing Rx Power,</li> <li>• <b>AND</b> Reactor Maneuvering Shutdown Instructions until FW inlet temperature returns to the "Normal Operating Region".</li> </ul>	SRO



5. EVENT – 5 '6C' FWH ISOLATION WITH THI (Abnormal)

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

Ensure **Trigger # 5** automatically actuates when RMS is taken to SHUTDOWN, to initiate Feedwater Line break and drywell leak.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
5.	EVENT – 5 '6C' FWH ISOLATION WITH THI (Abnormal)	
<b>Lead Evaluator (or designee) Notes:</b> The OPRM System enabled region is APR Simulated Thermal Power (STP) $\geq$ 29.5% AND Recirc Drive Flow <60%. The RO will identify indications of THI using LPRM, APRM and/or period meter indications.		
	Reference ARCs <ul style="list-style-type: none"> <li>• 108 A-4, OPRM TRIPS ENABLED</li> <li>• 108 A-3, OPRM PRE-TRIP</li> <li>• 108 F-3, ROD OUT BLOCK</li> </ul>	RO
	[OT-104 Attach # 8] RO identifies abnormal swings on APRMs indications due to signal growth by two or more times than initial levels, and with APRM flux level oscillations exceeding 10% peak-to-peak.	RO
	Notify CRS THI identified	RO
	Direct manual scram	SRO
	PLACE Reactor Mode Switch in "SHUTDOWN"	RO
	Recognize/report indications for scram; <ul style="list-style-type: none"> <li>• Scram annunciators for auto RPS actuation</li> <li>• White scram lights extinguished</li> </ul>	RO
	Enter T-101	SRO
	[T-101 RC-6] Insert SRM and IRM detectors	RO
	[T-101 RC/Q-1] Verify all control rods inserted	RO
	[T-101 RC/Q-2] Ensure turbine trip and gen lockout	PRO
	[T-101 RC/L-7] Restore and maintain RPV level between +12.5" AND +54"	RO
	[T-101 RC/L-7] Ensure RCIC start and injection on RPV Level <-38"	PRO
	[T-101 RC/P-13] Stabilize RPV press below 1096 psig.	RO



**6/7. EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger





TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/7.	EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE	
	<b>Lead Evaluator (or designee) Notes:</b> After the plant is scrammed a rupture of the 'A' Feedwater line occurs. The operator will identify the Feedwater line break as RPV level decreases and Primary Containment pressure rises.	
	Recognize RPV level decreasing and Drywell pressure increasing	RO/PRO
	Recognize 'A' FW Line Break	RO
	Attempt to isolate 'A' Feedwater Line	RO
	Report rising drywell pressure	RO/PRO
	Enter and execute OT-101, Drywell High Pressure, as drywell pressure rises	SRO
	[OT-101 3.1] <b>ESTABLISH</b> Drywell pressure as a Critical Parameter	PRO
	Enter T-102, Primary Containment Control, and Re-enter T-101, Reactor Control, on 1.68# Drywell Pressure	SRO
	Verify Isolations complete for >1.68 psig drywell press. and RPV level <12.5"	RO/PRO
	Secure from depressurization	PRO
	Evaluate closing MSIV's to conserve RPV inventory	SRO
	[T-101 RC/L-12] Enter T-111 on lowering RPV level	SRO
	[T-111 LR-5] Manually inhibit auto ADS ( <b>Critical Task</b> )	PRO
	[T-111 LR-6] Maximize RPV Injection with CRD per T-240	RO
	[T-111 LR-6] Maximize RPV Injection using RCIC	PRO
	Identify RCIC flow controller in AUTO failed	PRO
	Direct to operate RCIC in Manual mode	SRO
	[T-111 LR-7] Start SLC Pumps	RO
	[T-111 LR-8] Start 2 or more subsystems (ie. C & D RHR Pumps)	PRO
	Identify RPV level decreasing – approaching LOCA -129"	Crew

**6/7. EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE****Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger

At time 8 min after FSSV or EO action requested for T-240 field actions (Insert **RCR019** to open 'B' CRD Pump discharge valve) and

**report:** Field actions for T-240 are complete and standby pump ready for start.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/7.	<b>EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE</b>	
	Enter SE-10, LOCA when RPV level <-129"	Crew
	[SE-10 3.1] <b>PLACE</b> the following to "CLOSE" <ul style="list-style-type: none"> <li>52-20224/CS, "D*24 Safeguard L.C. D*24-G-D MCC Bkr" (SAFEGUARDS B), on *BC661</li> <li>52-20124/CS, "D*14 Safeguard L.C. D*14-G-D MCC Bkr" (SAFEGUARDS A), on *AC661.</li> </ul>	RO
	[SE-10 3.2] <b>PLACE</b> to "RESET": <ul style="list-style-type: none"> <li>43-22322/CS, "Div. III Non SFGD Instr. Panel" (INST AC 201 CONTROL PNL), on *CC661</li> <li>43-22422/CS, "Div. IV Non SFGD Instr. Panel" (INST AC 202 CONTROL PNL), on *DC661.</li> </ul>	RO
	Dispatch Equipment Operator to perform SE-10-1 field actions	PRO
	[SE-10 4.3] Maintain ECCS for injection <b>IF</b> Low Pressure ECCS is not required to restore RPV level, <b>THEN ALIGN</b> per SSV direction.	SRO
	Re-start of '1A' CRD Pump following LOCA and maximize using T-240	RO
	Restart '1A' and '1C' SLC Pumps following LOCA	RO
	[T-240 4.2] Fully <b>OPEN</b> HV-46-1F003, "Drive Water Pressure Control" (DRIVE WATER PRESSURE), at 10C603 (Main Control Room). [no power available]	RO
	[T-240 4.3] <b>OPEN</b> FV-C-46-1F002A(B), "Flow Control," at 10C603 (Main Control Room) using FC-46-1R600, "Rod Drive Flow Controller" (FL), in "MANUAL" to maximize CRD flow, while maintaining greater than 1,200 psig as indicated on PI-46-108A(B), "CRD Pump Discharge" (252-T6-200).	RO
	[T-240 4.4] <b>OPEN</b> 46-1F045, "CRD Pumps Suction Filter Bypass Valve" (EO)	RO
	[T-240 4.5] If additional CRD flow required place second CRD Pump in Service	RO
	Trend RPV Level to TAF	RO/PRO



**6/7. EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/7.	EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE	
	<b>EVALUATORS NOTE:</b> The following steps are directed from T-102 to address the rise in Containment pressure. T-225, Startup and Shutdown of Suppression Pool (Section 4.2) and Drywell Spray Operation (Section 4.5) is used to control containment pressure.	
	[T-102 PC/P-7] <b>DIRECT</b> before Supp Pool pressure reaches 7.5 psig Spray the <b>Suppression Pool</b> per T-225, Startup and Shutdown of Suppression Pool and Drywell Spray Operation	SRO
	[T-225 4.2.1] <b>ENSURE</b> HV-51-1F004A(B), "1A(B) RHR Pump Suction PCIV" (SUCTION A(B)), open	PRO
	[T-225 4.2.2] <b>ENSURE</b> the following valves closed: <ul style="list-style-type: none"> <li>• HV-51-1F006A(B), "1A(B) RHR Pp S/D Clg Suct Intertie Vlv"</li> <li>• HV-51-1F015A(B), "1A(B) Shutdown Clg Injection PCIV"</li> <li>• HV-51-1F016A(B), "1A(B) RHR Cntmt Spray Line Outboard PCIV"</li> <li>• HV-51-1F017A(B), "1A(B) RHR LPCI Inj PCIV"</li> </ul>	PRO
	[T-225 4.2.3] <b>IF</b> RHR pump not running <b>THEN</b> start 1A(B)P202 "RHR Pump"	PRO
	[T-225 4.2.4] <b>ENSURE</b> the following valves open: <ul style="list-style-type: none"> <li>• HV-51-1F047A(B), "1A RHR Htx Shell Side Inlet Vlv" (INLET)</li> <li>• HV-51-1F003A(B), "1A RHR Htx Shell Side Outlet Vlv" (OUTLET)</li> <li>• HV-C-51-1F048A(B), "1A RHR Htx Shell Side Bypass Vlv" (HEAT EXCH BYPASS)</li> </ul>	PRO
	[T-225 4.2.5] <b>OPEN</b> HV-51-1F024A(B), "1A RHR Pp Full Flow Test Return Vlv" (SUPP POOL CLG A <b>AND OBTAIN</b> flow of 8,000 to 8,500 gpm as indicated on FI-51-1R603A, FL.	PRO
	[T-225 4.2.6] <b>OPEN</b> HV-51-1F027A(B), "1A RHR Supp Pool Spray Line PCIV" (SUPP POOL SPRAY).	PRO
	[T-225 4.2.8] <b>PLACE</b> RHR Service Water Pump for RHR Heat Exchanger to be used in service per S12.1.A, RHR Service Water System Startup.	PRO



**6/7. EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/7.	<b>EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE</b>	
	[T-225 4.2.9] <b>CLOSE</b> HV-C-51-1F048A(B), "1A RHR Htx Shell Side Bypass Vlv" (HEAT EXCH BYPASS).	PRO
	[T-225 4.2.10] <b>IF</b> more spray flow is required, <b>THEN REDUCE</b> flow through Full Flow Test line by throttling closed HV-51-1F024A(B), "1A RHR Pp Full Flow Test Return Vlv" (SUPP POOL CLG A).	PRO
<b>EVALUATORS NOTE:</b> The following steps are performed as directed by S12.1.A, RHR Service Water System Startup.		
	[S12.1.A 4.1.4/5 or App1 1.3] <ul style="list-style-type: none"> <li>• <b>OPEN</b> HV-51-1F014A(B), HEAT EXCHANGER INLET.</li> <li>• Throttle <b>OPEN</b> HV-51-1F068A(B) for 18 to 20 seconds.</li> </ul>	PRO
	[S12.1.A, 4.1.6(7) or App1 1.4] <b>VERIFY</b> PI-51-105A-1(B), HX DISCH, indicates system static pressure greater than or equal to 15 psig.	PRO
	[S12.1.A 4.1.8 or App1 1.4] <b>IF</b> the HI RAD AND/OR HI Pump Discharge pressure trips need to be bypassed <b>AND</b> the required actions of ODCM Part 1 Control 3.1.1 have been met for the INOPERABLE RHRSW Radiation Monitor, <b>THEN PLACE</b> HSS-12-002A(B), PUMP TRIP BYPASS, in "BYPASS."	PRO
	[S12.1.A 4.2.1.1 or App1 1.6] <b>IF</b> 'A' Loop pump (0A(C)-P506) is to be placed in service, <b>THEN ENSURE</b> 0A-V543 OR 0C-V543, Spray Pond Pump Room Fans, in "RUN" at 00C681.	PRO
	[S12.1.A 4.2.1.2 or App1 1.7] <b>IF</b> 'B' Loop pump (0B(D)-P506) is to be placed in service, <b>THEN ENSURE</b> 0B-V543 OR 0D-V543, Spray Pond Pump Room Fans, in "RUN" at 00C681.	PRO
	[S12.1.A 4.2.2 or App1 1.8] <b>START</b> 0A(B),(C,D)P506, RHRSW PUMP.	PRO
	[S12.1.A 4.2.3 or App1 1.9] <b>THROTTLE</b> HV-51-1F068A(B) to the maximum obtainable position without exceeding 11,000 gpm on FI-51-*R602A(B) while maintaining pump disch pressure (PI-12-001A-1(B) between 75 psig to 85 psig.	PRO



**6/7. EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger





TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/7.	EVENTS 6 - 7 '1A' FEEDWATER LINE RUPTURE / RCIC CONTROLLER FAILURE	
<b>EVALUATORS NOTE:</b> The following steps are performed as directed by T-225 section 4.5 to spray the Drywell.		
	[T-225 4.5.3] <b>IF</b> RHR pump not running <b>THEN START</b> 1A(B)P202 "RHR Pump."	PRO
	[T-225 4.5.4] <b>ENSURE</b> the following valves open: <ul style="list-style-type: none"> <li>• HV-51-1F047A(B), "1A(B) RHR Htx Shell Side Inlet Vlv" (INLET)</li> <li>• HV-51-1F003A(B), "1A(B) RHR Htx Shell Side Outlet Vlv" (OUTLET)</li> <li>• HV-C-51-1F048A(B), "1A(B) RHR Htx Shell Side Bypass Vlv" (HEAT EXCH BYPASS)</li> </ul>	PRO
	[T-225 4.5.5] <b>TRIP</b> Reactor Recirc Pumps.	PRO/RO
	[T-225 4.5.6] <b>REMOVE</b> Drywell Cooling Fans from service by placing all 16 Drywell Cooler Fan switches to "OFF."	PRO/RO
	[T-225 4.5.7] <b>IF</b> Drywell High Pressure <b>AND</b> LOCA signals are present, <b>THEN GO TO</b> T-225 step 4.5.11.	PRO
	[T-225 4.5.11] <b>OPEN</b> HV-51-1F024A(B), "1A(B) RHR Pp Full Flow Test Return Vlv" (SUPP POOL CLG A(B)), <b>AND OBTAIN</b> flow of 9,250 to 10,500 gpm as indicated on FI-51-1R603A(B), FL.	PRO
	[T-225 4.5.12] <b>OPEN</b> only one loop HV-51-1F021A(B), "1A(B) RHR Cntmt Spray Line Inboard PCIV" (INBOARD).	PRO
	[T-225 4.5.13] <b>REQUEST</b> SSV verify drywell temperature <b>AND</b> drywell pressure are on SAFE side of Drywell Spray Initiation Limit Curve per T-102, Primary Containment Control <b>OR</b> SAMP-1, RPV and Primary Containment Flooding Control.	PRO/SRO
	[T-102 PC/P-9] <b>DIRECT</b> to Spray the <b>Drywell</b> per T-225, Startup and Shutdown of Suppression Pool and Drywell Spray Operation ( <b>Critical Task</b> )	SRO
	[T-225 4.5.14] Throttle <b>OPEN</b> only one loop HV-51-1F016A(B), "1A(B) RHR Cntmt Spray Line Outboard PCIV" (OUTBOARD) to initiate spray <b>AND OBSERVE</b> raising flowrate as indicated on FI-51-1R603A(B), FL.	PRO



**8. EVENT – 8 '1M' SRV FAILS TO OPEN (Malfunction)**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
8.	EVENT – 8 '1M' SRV FAILS TO OPEN (Malfunction)	
<p><b>Lead Evaluator (or designee) Notes:</b> As RPV level drops to -161" the crew will enter and execute T-112, Emergency Blowdown to rapidly depressurize the RPV. SRVs are the preferred mechanism to discharge steam. As the operator opens 5 SRVs the '1M' SRV will fail to open. As the crew identifies the failed SRV, another SRV will be opened until a total of 5 SRVs are open.</p>		
	[T-111 LR-10] When RPV level drops to -161 inches, or when the safe side of the PSP curve cannot be maintained enter T-112 ( <b>Critical Task</b> )	SRO
	Enter T-112, Emergency Blowdown	SRO
	[T-112 EB-12] <b>DIRECT</b> Open all 5 ADS valves	SRO
	<span style="font-family: cursive;">R</span> [T-112 EB-12] <b>PERFORM</b> Open all 5 ADS valves ( <b>Critical Task</b> )	PRO
	Recognize that the '1M' SRV failed to open ( <b>Malfunction</b> )	PRO
	The CRS directs to open additional non ADS SRVs until a total of 5 ADS/SRVs are open	SRO
	[T-111 LR-20] Maximize RPV injection using all available systems subsystems and alt subsystems EXCEEDING pump NPSH and vortex limits if necessary.	Crew
	Restore RPV Level restored above TAF ( <b>Critical Task</b> )	Crew
	[T-111 LR-2] When RPV level above -161" exit T-111 and re-enter T-101 at RC/L-1.	SRO
	Restore RPV Level to +12.5" to 54" with ECCS	RO/PRO
<p><b>EVALUATORS NOTE:</b> The scenario may be terminated when the Emergency Blowdown is complete, RPV level is restored to normal band with ECCS systems and Containment Spray is in service. After the scenario is terminated, direct the SRO to make the highest EAL classification for the scenario.</p>		
<p>EAL: FA-1 declaration due to: (RC.3.1 and RC.3.2)</p> <ul style="list-style-type: none"> <li>• Drywell pressure &gt; 1.68 psig</li> </ul> <p><b>AND</b></p> <ul style="list-style-type: none"> <li>• Drywell pressure rise is due to RCS leakage</li> </ul>		

**Attachment 1  
Simulator Operator Response Times**

<b>Procedure</b>	<b>Performance</b>	<b>Response Time (Minutes)</b>
T-209	Injection from the Standby Liquid Control Storage Tank with the RCIC System	45
T-212	Bypassing SQUIB Valves for SLC Injection	19
T-215	De-energization of Scram Solenoids	7
T-216	Manual Isolation and Vent of Scram Air Header	7
T-217	RPS/ARI Reset and Backup Method of Draining Scram Discharge Volume	17
T-219	Maximizing CRD Cooling Water Header Flow during ATWS Conditions	23
T-221	MSIV Isolation Bypass Procedure	11
T-225	Startup and Shutdown of Suppression Pool and Drywell Spray Operations	8
T-240	Maximizing CRD flow after Shutdown During Emergency Conditions	8
T-245	RPV Injection from RHR S/D Cooling	12
T-248	Injection from SLC Test Tank to RPV	15
T-251	Establish a HPCI Injection flow Path VIA Feedwater Only	6
T-270	Terminate and Prevent Injection into the RPV	7
T-290	Instrumentation Available for T-103 SAMP-2	5
S46.7.A (4.2.1)	Control Rod Drive Hydraulic System Operation Following Reactor Scram (Securing CRD flow to the Reactor - Close 46-1F060, CRD Water Pressure Control Station Inlet Valve)	7
SE-10-1 Resets and Floor action	Breaker Reset Following LOCA (Also reset ARMs, RHRSW Rad Monitor and RDCS)	10





**This Page  
Intentionally  
Blank**



## **XII. CREW PREBRIEF INSTRUCTIONS**

Unit 2 is in OPCON 1 at 100 % power

Unit 1 is in OPCON 1 at 100 % power

### **Specific Plant Conditions are as Follows:**

- None

### **Inoperable/Out of Service Equipment and Estimated Time of Return (ETR):**

- None

### **Restrictions on Plant Operations:**

- None

### **Planned Evolutions:**

- Place '1C' SBLC Pump in Automatic Injection Mode per S48.1.A, Standby Liquid Control System Set-Up For Normal Operation, step 4.7 in preparation of a '1B' SLC System Outage Window

### **Documents Provided:**

- S48.1.A, Standby Liquid Control System Set-Up For Normal Operation



CODE NO:	SEG-2007E	REV NO:	002
AUTHOR:	T. A. BYERS	APPROXIMATE RUN TIME:	65 minutes
TYPE:	SIMULATOR EVALUATION GUIDE	EFFECTIVE DATE:	
PROGRAM:	LICENSED OPERATOR TRAINING		
COURSE:	LICENSED OPERATOR (REQUALIFICATION/INITIAL) TRAINING		
TITLE:	Simulator Evaluation Guide for Individual and Crew Performance		

Prepared By: \_\_\_\_\_ Date: \_\_\_\_\_  
Training Instructor - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
LORT Lead Instructor - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
EP (as appropriate) - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
N/A  
 RE (as appropriate) - Signature

Approval: \_\_\_\_\_ Date: \_\_\_\_\_  
OPS Manager - Signature

Approved For Use: \_\_\_\_\_ Date: \_\_\_\_\_  
Training Manager - Signature





Facility: Limerick 1 & 2      Scenario No.: SEG-2007E      Rev 2      Op-Test No.: 1

Examiners: \_\_\_\_\_ Operators: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Initial Conditions:**

Unit 1 is at 90% power. Unit 2 is at 100% power.

**Turnover:**

Withdraw Control Rods per ReMA and raise Recirc flow to return to 100% Reactor power

'1B' EHC Pump is blocked for pump replacement. Repairs are scheduled to be complete in two (2) hours. Maintain 100% power and support PMT of '1B' EHC pump when it is returned to operations.

Event No.	Malfunction Number	Event Type*	Event Description
1.	None	R-RO	Raise Power with Control Rods
2.	MRD016E (46-15)	C-RO TS-SRO	Control Rod (46-15) uncoupled <b>(Abnormal)</b>
3.	MAD149E	C-RO C-PRO	'1N' SRV fails open / closes when Rx power lowered to <90 % <b>(Abnormal)</b>
4.	MCS183C	C-RO C-PRO TS-SRO	Inadvertent Div 4 LOCA Signal <b>(Abnormal)</b>
5.	MRH172D	C-PRO TS-SRO	'1D' RHR Pump fails to auto start <b>(Malfunction)</b>
6.	MRR441	C-PRO	Small leak in Drywell <b>(Abnormal)</b>
7.	MMS067	M-ALL	Large Steam Leak in Drywell
8.	MRH600B	C-PRO	'1B' RHR Pump Trips <b>(Malfunction)</b>
9.	MRH573A	C-PRO	HV-51-1F024A Thermal Overload condition <b>(Malfunction)</b>

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor



## I. QUANTITATIVE ATTRIBUTES

### A. ILT

<b>Target Quantitative Attributes (Per Scenario; See ES-301Section D.5.d)</b>	<b>ACTUAL NUMBER</b>
1. Malfunctions after EOP entry (1-2)	2
2. Abnormal events (2-4)	4
3. Major transients (1-2)	1
4. EOPs entered/requiring substantive actions (1-2)	2
5. EOP contingencies requiring substantive actions (0-2)	1
6. EOP based Critical tasks (2-3)	2

Review TQ-AA-151 attachment 5 and ES-301-5 for individual position requirements for scenario and scenario set



- II. **PURPOSE:** Systematically evaluate individual and team performance to identify areas for improvement. Critical Tasks and Assessment Items from this evaluation guide are to be used to assess crew and individual performance and as input into a 4.0 Crew Critique Process.

III. **SIMULATOR EVALUATION GUIDE OBJECTIVES:**

- A. The following evaluation objectives apply to the Crew (C), Shift Manager (SM), Control Room Supervisor (S), Unit Reactor Operator / Plant Reactor Operator (R), or Incident Assessor / Shift Technical Advisor (A) as indicated in the following categories.
1. The general condition for each of the evaluation objectives will be "Given the plant conditions and sequence of events in the Simulator Evaluation Guide (SEG)".
  2. The general acceptable evaluation objective criteria for each of the evaluation objectives will be "To perform effectively as an individual and contribute to successful crew performance in accordance with appropriate reference plant procedures and Operations Expectations, Fundamentals and Strategies".
  3. Specific UNSAT evaluation objective criteria will be consistent with TQ-AA-155, Conduct of Simulator Training and Evaluation with applicable forms and job aids.
  4. During performance of this Simulator Evaluation Guide, the individuals and crew should satisfactorily demonstrate the following overall procedure and plant control objectives:
    - Direct and perform actions per ON-104, Control Rod Problems.
    - Direct and perform actions per OT-101, Drywell High Pressure
    - Direct and perform actions per OT-104, Unexpected/Unexplained Positive or Negative Reactivity Insertion.
    - Direct and perform actions per OT-114, Inadvertent Opening of a Relief Valve
    - Direct and perform actions per SE-10, LOCA
    - Direct and perform actions per OT-101, High Drywell Pressure
    - Direct and perform actions per OT-102, Reactor High Pressure
    - Direct and perform actions per T-112, Emergency Blowdown



**IV. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	LORT Approval	Action Tracking	Revision Date

**V. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (e.g for conversion of LSTS to LLORSEG format).

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
Rev000	This is a reformat to the new SEG Evaluation template. This replaces LSES2007 Rev 9. Deleted '1N' SRV failing open and added HV-51-1F024A Thermal Overload.	10/28/13
Rev001	Revised to new template, and control rod drift	9/2/15
Rev002	Revised to new template, changed to control rod uncoupled, and open SRV response	7/22/16

# Date of Revision - refers to date revision was released for approval

**SCENARIO EVENT AND EVALUATION SUMMARY:**

- Events One and Two: As the crew assumes responsibility for the shift, they are directed to withdraw Control Rods and adjust Recirc flow per the ReMA and return the reactor to 100% power. During the power ascension and as Control Rod 46-15 is being withdrawn, a "Rod Overtravel" alarm will annunciate, and Control Rod 46-15 will become uncoupled.
- Evaluation: To evaluate the crews ability to raise Recirc flow and withdraw Control Rods per a ReMA, and when the 'Rod Overtravel' alarms, identify an uncouple Control Rod, implement ON-104, Control Rod Problems, and OT-104, Unexpected/ Unexplained Positive or Negative Reactivity Insertion, isolate the Control Rod (46-15) and evaluate Tech Specs for the INOP Control Rod.
- Event Three: When the Control Rod has been fully inserted as directed by the ON procedure, and Tech Specs are evaluated for the Control Rod being INOP, the '1N' SRV will inadvertently open. The SRV will close when reactor power is lowered to ~90%.
- Evaluation: To evaluate the crews' response to an open SRV. The crew will enter and execute OT-114, Inadvertent Opening Of A Relief Valve. The crew will identify that when reducing reactor power to ~90%, per the OT procedure, the SRV closes. The crew will then evaluate the plants response to the now closed SRV.
- Event Four: After the SRV is closed, an inadvertent Division 4 LOCA signal will occur.
- Evaluation: To evaluate the crews response to use MCR instrumentation and determine the Division 4 LOCA signal is inadvertent. The crew will identify the cause of the Division 4 LOCA signal to be an excess flow check valve actuation. The crew will recognize a reactor power increase and that HPCI is running and injecting into the RPV, and isolate the HPCI system. The crew will also identify the D14 EDG running unloaded, and a Core Spray Pump running. The CRS will determine the required Tech Spec Actions for systems that are unavailable due to the LOCA signal.
- Event Five: During the inadvertent Division 4 LOCA signal, the '1D' RHR Pump will fail to auto start.
- Evaluation: To evaluate the crews response to the failure to auto start of the '1D' RHR Pump. Identify the Tech Spec requirements for an RHR system that failed to auto start.

**SCENARIO EVENT AND EVALUATION SUMMARY cont'd:**

Events Six and Seven: When actions for the inadvertent LOCA signal are complete, a gradually increasing coolant leak in the drywell will develop requiring the plant to shutdown. Following Plant shutdown a large steam leak into the Drywell will occur which will eventually require a T-112, Emergency Blowdown be performed.

Evaluation: To evaluate the crews response to increasing drywell pressure and temperature, including the initial execution of OT-101, Drywell High Pressure, and eventually a plant shutdown and execution of T-101, RPV Control, and T-102, Primary Containment Control.

Event Eight and Nine: The '1B' RHR Pump, which was placed in service when the SRV opened, trips on a time delay after the plant is shutdown, and when the crew transitions to the 'A' Loop of RHR for containment cooling, the HV-51-1F024A, 'A' Loop RHR Test Return Valve, will trip on a Thermal Overload condition.

Evaluation: To evaluate the crew's response to the tripped '1B' RHR Pump and to transition the '1A' RHR Pump when directed to re-direct from Suppression Pool Spray to Drywell Spray. As the crew re-directs to 'A' RHR for Drywell Spray they will manually open the HV-51-1F024A valve when a thermal overload trip is identified.

Termination Point: The scenario may be terminated when an Emergency Depressurization has been performed, Drywell Spray is in service, control rods inserted and reactor level is restored.

**VI. REFERENCES**

- A. Training Procedures
  - 1. TQ-LG-150, Limerick Operator Training Programs
  - 2. TQ-AA-151, ILT Certification and NRC Examination Development and Administration
  - 3. TQ-AA-155, Conduct of Simulator Training and Evaluation
- B. Annunciator Response Cards (ARC)
  - 1. 002 D-4, B CONTROL STRUCTURE CHILLER OUT OF SERVICE
  - 2. 002 A-1, CONTROL ROOM RADIATION ISOLATION
  - 3. 004 B-1, B DRYWELL CHILLER TRIP/FAILED TO START
  - 4. 004 B-4, DIV I/II RRCS CHANNEL ACTIVATED
  - 5. 103 B-3 DRYWELL FLOOR DRAIN HI LEVEL
  - 6. 107 H-2, REACTOR HI/LO LEVEL
  - 7. 107 F-2, DRYWELL HI / LO PRESS
  - 8. 108 F-5, ROD OVERTRAVEL
  - 9. 110 B-1, SRV/HEAD VENT VALVE LEAKING
  - 10. 110 B-2, SAFETY RELIEF VALVE OPEN
  - 11. 112 H-1, RWCU PUMP SUCTION LO FLOW
  - 12. 112 C-5, DRYWELL EQUIP DRN TK/FLR DRN SUMP LEAKAGE HI FLOW
  - 13. 112 E-5, EXCESS FLOW CHECK VALVE OPERATED 10C218
  - 14. 113 B-5, CORE SPRAY LINE INTERNAL BREAK
  - 15. 114 C-2, REACTOR LO-LO LEVEL
  - 16. 114 D-1, DIV 4 NSSSS MSIV INITIATED
  - 17. 114 C-2, REACTRO LO-LO LEVEL
  - 18. 114 D-1, DIV 4 NSSSS MSIV INITIATED
  - 19. 115 H-3, REACTOR LO-LO-LO LEVEL
  - 20. 115 I-1, DIV 4 RHR AUTO START
  - 21. 115 D-1, DIV 4 CORE SPRAY AUTO START
  - 22. 115 B-5, DRYWELL COOLER DRAIN FLOW HIGH
  - 23. 118 C-2, 1B INSTRUMENT AIR HDR LO PRESS
- C. System Procedures (S)
  - 1. S73.1.A, Normal Operation of the Reactor Manual Control system
  - 2. S51.8.A App. 1, Placing RHR SP Cooling in Service During a Plant Event
  - 3. S12.1.A App. 2, RHR Service Water System Dual Loop Startup Hard Card
  - 4. S78.7.A, Control Room HVAC System Restoration from an Isolation
  - 5. S87.1.A App. 1, Startup of Standby/Tripped Drywell Chiller Hard Card
  - 6. S91.6.B App. 1, Transferring House Loads to S/U Buses Hard Card
- D. General Procedures (GP)
  - 1. GP-3, Normal Plant Shutdown
  - 2. GP-4, Rapid Plant Shutdown to Hot Shutdown
- E. Off Normal Procedures (ON)
  - 1. ON-104, Control Rod Problems
- F. Operating Transient Procedures (OT)
  - 1. OT-101, High Drywell Pressure

**REFERENCES cont'd**

2. OT-104, Unexpected/Unexplained Positive or Negative Reactivity Addition
  3. OT-114, Inadvertent Opening of a Relief Valve
- G. Event Procedures (E)
- H. Special Event Procedures (SE)
1. SE-10, LOCA
- I. Surveillance Test and Routine Test Procedures (ST and RT)
- J. Technical Specifications and TRM (TS)
1. 3.1.3.1, Control Rod Operability
  2. 3.1.3.6, Control Rod Drive Coupling
  3. 3.3.3, Emergency Core Cooling System Actuation Instrumentation 3.5.1, ECCS – Operating
  4. TRM 3.4.4, Reactor Coolant System – Chemistry
  5. 3.4.3, Reactor Coolant System – Leakage Detection Systems
  6. 3.5.1, Emergency Core Cooling Systems
- K. Transient Response Implementation Procedures (T-100 series)/SAMPs
1. T-101, RPV Control
  2. T-102, Primary Containment Control
  3. T-112, Emergency Blowdown
- L. TRIP 200 Series Procedures
1. T-225, Startup and Shutdown of Suppression Pool and Drywell Spray Operation
- M. EP-AA-1008, Limerick, Radiological Emergency Plan Annex for Limerick Generating Station
- N. Administrative Procedures
1. OP-AA Procedures
    - a. OP-AA-1, Conduct of Operations
    - b. OP-AA-20, Conduct of Operations Process Description
    - c. OP-AA-101-111-1003, Operations Department Standards and Expectations
    - d. OP-AA-101-113, Operations Fundamentals
    - e. OP-AA-101-113-1006, 4.0 Crew Critique Guidelines
    - f. OP-AA-103-102-1001, Strategies For Successful Transient Mitigation
    - g. OP-AA-106-101-1006, Operational Decision Making Process
  2. OP-LG Procedures
    - a. OP-LG-101-111-1000, Licensed Operator Duties
    - b. OP-LG-102-106, Operator Response Time Program at Limerick
    - c. OP-LG-103-102-1000, Human Performance Continuing Good Practices
    - d. OP-LG-103-102-1002, Strategies for Successful Transient Mitigation
    - e. OP-LG-108-101-1001, Simple Quick Acts / Transient Acts
- O. Current Shift Night Orders Forced Outage Plan
- P. INPO Significant Operating Experience Reports (SOER), Significant Event Reports (SER) and INPO Event Reports (IER)
1. IER-L1 11-3, Weaknesses in Operator Fundamentals
  2. SER 3-05, Weakness in Operator Fundamentals
  3. SOER 10-02, Engaged Thinking Organizations
  4. INPO 15-004, Operator Fundamentals



**VII. PREBRIEF INSTRUCTIONS**

Unit 2 is in OPCON 1 at 100% power

Unit 1 is in OPCON 1 at 90% power

**Specific Plant Conditions are as Follows:**

- Reactor power reduced to 90% due to Control Rod pattern adjustment

**Inoperable/Out of Service Equipment and Estimated Time of Return (ETR):**

- '1B' EHC pump is blocked for replacement
- Repairs are scheduled to be complete in 2 hours

**Restrictions on Plant Operations:**

- None

**Planned Evolutions:**

- Raise Reactor power to 100%
- Continue replacement of '1B' EHC pump and perform PMT when complete

**Documents Provided:**

- ReMA and Control Rod Move Sheet (with control rod steps 1-16 signed off )
- GP-5 Attachment 1 (signed off to step 2.6)
- S73.1.A, Normal Operation of the Reactor Manual Control System



**VIII. DIRECTIONS FOR EVALUATION PREPARATION**

**A. INITIAL PREPARATION**

✓	ITEM / MALFUNCTION / REMOTE FUNCTIONS
	Complete TQ-AA-155, Operator Training Programs Attachment 02, Evaluated Scenario Administration Checklist.
	Complete TQ-LG-201-0113, Limerick Training Department Simulator Examination Security Actions Checklist

**B. SIMULATOR SETUP**

✓	ITEM / MALFUNCTION / REMOTE FUNCTIONS
	Complete Limerick Simulator Pre-Evaluation Checklist
	Reset Simulator to the Pre-loaded Cycle <b>IC</b> developed for the Evaluation OR Reset the simulator to designated base load <b>IC-3</b> AND Load scenario file <b>SEG2007E Rev002.scn</b> <ul style="list-style-type: none"> <li>• Verify that all Malfunctions, Remotes, Overrides, Annunciators and Triggers are properly loaded</li> </ul> <p style="text-align: center;"><b>OR</b></p> <ul style="list-style-type: none"> <li>• Manually enter the Malfunctions, Remotes, Overrides, Annunciators and Triggers per the Scenario Generator Screen Shots:</li> </ul>
	Simulator Operator (Driver) perform the following: <ul style="list-style-type: none"> <li>• Momentarily place simulator in RUN</li> <li>• Ensure reactor power is at 90%</li> <li>• Acknowledge and clear all spurious alarms</li> <li>• Place the simulator back into FREEZE</li> <li>• Place INFO tag on '1B' EHC Pump with handswitch in PTL</li> </ul>




**C. MALFUNCTION/REMOTE/OVERRIDE/ANNUNCIATORS FUNCTION TIME TABLE**

Interventions Summary								
Hide Malfunctions - 8		Hide Remotes - 9		Hide Overrides - 4		Show Annunciators - 0		
<b>Malfunction Summary</b>								
Mal ID	Mult ID	Description	Current Value	Target Value	Rmptime	Actime	Dactime	Trig
MRD016E	46-15	Control Rod Failure, Uncoupled	True	True				
MRH172D		RHR Pump 1D Fails to Auto Start	True	True				
MAD149E		Relief Valve (F013N) Fails (Fails Open: Mechanical)	False	True		00:00:15		1
MVI231D		Instrument Line Break Downstream of XV42-1F045D	False	True		00:00:15		2
MRR441		Small Coolant Leak in Drywell (0-100%)	0.00	15.00000	00:05:00	00:00:15		3
MMS067		Steam Leak in Drywell (0-5000 gpm)	0.00	2000.000	00:08:00	00:02:00		4
MRH600B		RHR Pump 1BP202 Elect Fault	FALSE	TRUE		00:05:00		4
MRH573A		HV51-1F024A Fails due to Thermal OVL	False	True				4
<input type="checkbox"/> Timer Pause <span style="float: right;">Delete All</span> <span style="float: right;">Active Pending</span>								
<b>Remotes Summary</b>								
Rem ID	Mult ID	Description	Current Value	Target Value	Rmptime	Actime	Trig	
RRE148		Refuel Floor To SGTS Isolation damper S6D76-206-3	CLOSE	CLOSE				
RRE156		Unit 2 Refuel Floor Isol Sw HS76-281A	RESET	RESET				
RRE157		Unit 2 Refuel Floor Isol Sw HS76-281B	RESET	RESET				
RRM032		SPE & MVP Rad Monitor RE-160 Skid 10S408 Enable	DISABLE	DISABLE				
RPR061		APRM Channel 1 Gain Adjustment Factor	8754	8754				
RPR063		APRM Channel 3 Gain Adjustment Factor	8650	8650				
RPR062		APRM Channel 2 Gain Adjustment Factor	8600	8600				
RPR064		APRM Channel 4 Gain Adjustment Factor	8300	8300				
RAD216		Safety Relief Valve F013N Fuse	IN	OUT				6
<input type="checkbox"/> Timer Pause <span style="float: right;">Clear List</span> <span style="float: right;">Active Pending</span>								
<b>Override Summary</b>								
TagID	Description	Position / Target	Actual Value	Override Value	Rmptime	Actime	Dactime	Trig
C22-51B	BRCS Channel 2A Trip Pushbutton Arming Collar	ARM	OFF	OFF				
C22-51A	BRCS Channel 1A Trip Pushbutton Arming Collar	ARM	OFF	OFF				
42-12605/CS	Main Turb EHC Pump 1BP113 Ind Lamps	GREEN	OFF	OFF				
42-12605/CS	Main Turb EHC Pump 1BP113 Ind Lamps	RED	OFF	OFF				
<input type="checkbox"/> Timer Pause <span style="float: right;">Delete All</span> <span style="float: right;">Active Pending</span>								



D. EVENT TRIGGERS ASSIGNMENT

1. Timers should be used on event triggers where possible for time validation
2. Timing of event triggers may be altered by the Lead Evaluator (or designee)
3. Verify triggers are actuated automatically as designed or manually initiate the trigger when the initiating action has occurred.
4. Inform Lead Evaluator (or designee) of expected plant response prior to actuation of each trigger.
5. Trigger #1 is manually initiated at Lead Evaluator (or designee) direction after the crew assumes responsibility for operation.

	TRIGGER / TIME	MALFUNCTION / EVENT	DESCRIPTION
	1	Manual	Initiates '1N' Safety Relief Valve fails open
	2	Manual	XV-42-1F045D Instrument Line break / '1D' RHR Pump failure to Auto Start
	3	Manual	Small coolant leak in Drywell
	4	Auto / ZRPS1SDN	RMS to SHUTDOWN Initiates Drywell Steam Leak / '1B' RHR pp trip
	5	N/A	N/A
	6	Manual	'1N' Safety Relief Valve Fuse removed



- E. EQUIPMENT REPORTS AND LEAD EVALUATOR (OR DESIGNEE) OPERATIONS
1. This table section is moved and now integrated with Assessment of Crew Performance to facilitate simulator Operator and Instructor observation of crew activities related to simulator operation and instructor intervention.
  2. Scripted Activity Reports should be followed with adherence to Operations Communication standards of performance.
  3. The T-200 procedure reference book should be used for familiarity of reports to aid in operator prompting and expected communications.
  4. The Lead Evaluator (or designee) should be informed if any event is not reported as scripted due to lack of Operator request.
  5. The Standard Equipment Operator Response Times are per **Attachment 1**
  6. A record of communications from the MCR and to the MCR will be maintained by the Simulator Operator using **Attachment 2**.
  7. The OCOEE Simulator Operator Station P&IDs, Floor Plans and Panels must be used by the Simulator Operator as reference information when making reports to the MCR for plant parameters which are not driven by a communications script. Examples include: ARMs, Blowout Panel status, Reactor Building Area Temperatures and Pressures, RMMS, Turbine Enclosure parameters etc.



**IX. CREW CRITICAL TASKS**

A. Critical Tasks are based on the current Crew Critical Task List revision, NUREG 1021 and TQ-AA-150 requirements.

**1. T-102.1 Spray the Drywell per T-225.**

K/A	295024	EA1.11	4.2/4.2
K/A	295028	EA1.01	3.8/3.9
K/A	295028	EA1.04	3.9/4.0

Standard: When Drywell temperature and pressure are on the SAFE side of curve PC/P-2, spray the Drywell before exceeding 340°F or 55 psig.

**SAT/UNSAT**

**2. T-102.2 Perform emergency blowdown per T-112.**

K/A	295024	EA1.08	3.9/3.9
K/A	295024	EA2.04	3.9/3.9

Standard: When suppression Pool Pressure cannot be maintained below the Pressure Suppression Pressure (PC/P-3) curve and before Drywell pressure exceeds 55 psig, open 5 SRVs.

**SAT/UNSAT**

**3. OT-114.1 Close the stuck open relief valve.**

K/A	239002	A2.03	4.1/4.2
-----	--------	-------	---------

Standard: Direct closure of the stuck open SRV by removing fuses or reducing turbine inlet pressure per OT-114.

**SAT/UNSAT**



- X. ASSESSMENT OF CREW PERFORMANCE DURING CONDUCT OF THE DYNAMIC SIMULATOR EVALUATIONS:**
- A. Conduct the Simulator Evaluation Session per TQ-AA-155, Conduct of Simulator Training and Evaluation, Attachment 02, Evaluated Scenario Administration Checklist
  - B. Assessment of Crew and Individual performance shall be consistent with OP-AA-20, Conduct of Operations Process Description
  - C. Where possible record the time and position responsible for performance of each task or assessment item
  - D. Items not performed as expected **SHALL** be discussed in the post performance crew critique
  - E. During the performance of the evaluation, the Simulator Evaluators shall **MAINTAIN** notes of observations and information consistent with the timeline
  - F. Assessment items with the ⌚ symbol indicate a time critical standard for performance
  - G. Assessment items with the ⚡ symbol indicate a Probabilistic Risk Assessment (PRA) association with the task
  - H. The Simulator Operator will respond with scripted or proceduralized responses when requested by the MCR operators with Procedure completion times requested per **Attachment 1**
  - I. The Simulator Operator will also maintain a timeline and record of all reports and requests issued by the MCR personnel with response provided by the simulator operator using **Attachment 2**
  - J. Shaded items do not require assessment for ILT Evaluations; The CRS may be requested to complete the Shift ED forms and determine the EAL classification at the completion of the scenario.



**This Page  
Intentionally  
Blank**





**1/2. EVENTS 1 – 2 RAISE POWER / CONTROL ROD UNCOUPLED (Abnormal)**

**Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger.

Respond to request for assistance as appropriate.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
1/2.	<b>EVENTS 1 – 2 RAISE POWER / CONTROL ROD UNCOUPLED (Abnormal)</b>	
<p><b>Lead Evaluator (or designee) Notes:</b> As the RO withdraws control rods per the ReMA "Rod Overtravel" will alarm indicating a control rod has failed its coupling check. ON-104 will be referenced and the operator will perform a second attempt to verify the coupling check. When the second attempt fails the control rod will be declared Inoperable, fully inserted and isolated.</p> <p><b>Note:</b> [ST-6-107-730-1 4.3.4] If a coupling check is signed off in ReMA/Control Rod Move Sheets, <b>THEN</b> copy of ReMA is normally attached to ST-6-107-730-1</p>		
	Withdraw control rods IAW ReMA and S73.1.A	RO
	[S73.1.A 4.3.3] <b>SELECT</b> the control rod to be withdrawn	RO
	[S73.1.A 4.3.4] <b>VERIFY</b> correct rod position on four rod display	RO
	[S73.1.A 4.3.7] Simultaneously <b>DEPRESS</b> Withdraw and Continuous Withdraw pushbuttons to withdraw control rod	RO
	[S73.1.A 4.3.8] <b>VERIFY</b> proper RDCS light sequence for control rod withdraw	RO
	[S73.1.A 4.3.10] <b>WHEN</b> control rod is located two notches before target position <b>RELEASE</b> Withdraw and Continuous Withdraw pushbuttons (Note: Student may hold continuous withdraw to notch position 48 as permitted by Note 4 on Page 8 of S73.1.A)	RO
	[S73.1.A 4.3.11] <b>VERIFY</b> the SETTLE light Lit AND THEN extinguishes after ~ 6.1.sec.	RO
	[S73.1.A 4.3.12] <b>IF</b> control rod settles short of target position, <b>THEN PLACE</b> the control rod in target position using single notch withdraw per Section 4.2	RO
	[S73.1.A 4.3.13] <b>VERIFY</b> control rod has been withdrawn to target position at Four Rod Display	RO
	[S73.1.A 4.3.14] <b>IF</b> control rod is positioned to notch position 48, <b>THEN PERFORM</b> an overtravel check per ST-6-107-730-1, Control Rod Coupling Check	RO
	Select next rod in sequence, repeat previous steps	RO

**1/2. EVENTS 1 – 2 RAISE POWER / CONTROL ROD UNCOUPLED (Abnormal)****Simulator Operator Instructions:**

Inform Floor Instructor prior to each event trigger.

Respond to request for assistance as appropriate.

If RE's contacted for support for uncoupled control rod:

**report:** "A Reactor Engineer is on the way to assist with a Recovery ReMA".

At time 5 min after floor personnel are dispatched to isolate HCU (46-15),

**DELETE malfunction MRD016E for (46-15) and**

**report:** Valves 047-1-03-46-15 and 047-1-05-46-15 valves are closed for HCU (46-15).

OR

**report:** ON-104 step 2.5.6.5 is complete for Unit 1 HCU 46-15.

Manually actuate **Trigger # 1** when directed by Lead Evaluator, to initiate '1N'SRV to fail open.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
1/2.	<b>EVENTS 1 – 2 RAISE POWER / CONTROL ROD UNCOUPLED (Abnormal)</b>	
	Respond to • 108 F-5, ROD OVERTRAVEL	RO
	Report alarm and notify SRO that control rod (46-15) may be uncoupled	RO
	Enter ON-104, Control Rod Problems ( <b>Abnormal</b> )	SRO
	[ON-104 2.5.6] <b>IF</b> reactor power is greater than 25%, then perform the following: - Insert the rod to position 46 - Withdraw the control rod to 48 and attempt a coupling check	RO
	[ON-104 2.5.6.3] <b>IF</b> coupling check unsuccessful <b>DECLARE</b> control rod INOP and continue	RO
	[ON-104 2.5.6.4] Fully continuously <b>INSERT</b> the control rod and <b>MAINTAIN</b> insert signal for 10 seconds	RO
	[ON-104 2.5.6.5] <b>DISARM</b> directional control valves by closing 047-1-03-46-15 and 047-1-05-46-15 vlvs	RO
	Demand P-1 Edit (after rod settles at 00)	RO
	Contact RE for assistance	SRO
	Enter T.S. 3.1.3.6 – Control Rod Drive Coupling and T. S. 3.1.3.1 – Control Rod Operability for Control Rod (46-15)	SRO

**1/2. EVENTS 1 – 2 RAISE POWER / CONTROL ROD UNCOUPLED (Abnormal)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

Manually actuate **Trigger # 1** when directed by Lead Evaluator, to initiate '1N' SRV to fail open.

**IMPORTANT**

**DRIVER NOTE:** When Reactor power reduction initiated  
Manually **DELETE MAD149E** at <90% APRM power, to simulate closure of the '1N' SRV.

**\*\*\* OT-114 directs a GP-4 Shutdown if SRV remains open at 85% power \*\*\***



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
<b>3.</b>	<b>EVENT - 3 '1N' SRV INADVERTENTLY OPEN (Abnormal)</b>	
<p><b>Lead Evaluator (or designee) Notes:</b> The '1N' SRV will inadvertently open. The crew will enter and execute OT-114 for the open SRV. Two loops of Suppression Pool Cooling will be placed in service (Six minute requirement per OP-LG-102-108) and reactor power will be reduced to 85%. Since the SRV closes prior to reaching 85% reactor power, a GP-3 Shutdown will be performed.</p>		
	Reference ARCs <ul style="list-style-type: none"> <li>• 110 B-1, SRV/HEAD VENT VALVE LEAKING</li> <li>• 110 B-2, SAFETY RELIEF VALVE OPEN</li> </ul>	RO/PRO
	Recognize '1N' SRV open (confirming indications)	PRO
	Enter OT-114, Inadvertent Opening Of A Relief Valve, and perform Immediate Operator Actions ( <b>Abnormal</b> )	SRO
⌚	[OT-114 IOA] Place both loops Suppression Pool Cooling in service	PRO
	[S51.8.A App. 1 1.1] <b>START</b> selected RHRSW loop per S12.1.A	PRO
	[S12.1.A App.2 1.3] <ul style="list-style-type: none"> <li>• <b>OPEN</b> HV-51-1F014A, HEAT EXCHANGER INLET</li> <li>• Throttle <b>OPEN</b> HV-51-1F068A for 18 to 20 seconds</li> </ul>	PRO
	[S12.1.A App.2 1.4] <ul style="list-style-type: none"> <li>• <b>OPEN</b> HV-51-1F014B, HEAT EXCHANGER INLET</li> <li>• Throttle <b>OPEN</b> HV-51-1F068B for 18 to 20 seconds</li> </ul>	PRO
	[S12.1.A App.2 1.5] <b>VERIFY</b> PI-51-105A-1, HX DISCH, indicates system static pressure greater than or equal to 15 psig	PRO
	[S12.1.A App.2 1.6] <b>VERIFY</b> PI-51-105B, HX DISCH, indicates system static pressure greater than or equal to 15 psig	PRO
	[S12.1.A App.2 1.8] <b>ENSURE</b> 0A-V543 OR 0C-V543, Spray Pond Pump Room Fans, in "RUN" at 00C681.	PRO
	[S12.1.A App.2 1.9] <b>ENSURE</b> 0B-V543 OR 0D-V543, Spray Pond Pump Room Fans, in "RUN" at 00C681.	PRO
	[S12.1.A App.2 1.10] <b>START</b> 0A(C)P506, RHRSW PUMP	PRO



**3. EVENT - 3 '1N' SRV INADVERTENTLY OPEN (Abnormal)**

**Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

At time 5 min if requested to pull fuses per OT-114, Attachment 1:  
Manually actuate **Trigger #6** to remove fuses for '1N' SRV



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
<b>3.</b>	<b>EVENTS - 3 '1N' SRV INADVERTENTLY OPEN (Abnormal)</b>	
	[S12.1.A App.2 1.11] <b>THROTTLE</b> HV-51-1F068A to the maximum obtainable position without exceeding 11,000 gpm on FI-51-*R602A(B) while maintaining pump disch pressure (PI-12-001A-1) between 75 psig to 85 psig	PRO
	[S12.1.A App.2 1.12] <b>START</b> 0B(D)P506, RHRSW PUMP	PRO
	[S12.1.A App.2 1.13] <b>THROTTLE</b> HV-51-1F068B to the maximum obtainable position without exceeding 11,000 gpm on FI-51-*R602A(B) while maintaining pump disch pressure (PI-12-001B) between 75 psig to 85 psig	PRO
	[S51.8.A App.1 1.4] (Repeated for A Loop and B Loop) <b>START</b> 1A(B) P202 RHR Pump	PRO
	[S51.8.A App.1 1.5] (Repeated for A Loop and B Loop) Throttle <b>OPEN</b> HV-51-1F024A(B) "RHR Pump Full Flow Test Return" AND <b>MAINTAIN</b> flow indicated on FI-51-1R603A(B) between 8000 to 8500 gpm	PRO
	[S51.8.A App.1 1.6] (Repeated for A Loop and B Loop) <b>CLOSE</b> HV-C-51-1F048A(B) HEAT EXCH BYPASS	PRO
	[OT-114 3.1] <b>DISPATCH</b> EO to attempt SRV closure by pulling fuses using OT-114 Attachment 1 for PSV-41-1F013N	PRO
	[OT-114 3.2] <b>REDUCE</b> Reactor power to 85% per RMSI	RO
	[OT-114 3.3] Establish Suppression Pool Temperature as Critical Parameter	SRO
	CRS briefs stuck open SRV and contingency plans	SRO
	Crew trends Suppression Pool temperatures	PRO
	Crew identifies '1N' SRV closed during power reduction	PRO/RO
	CRS directs to perform a GP-3 Plant shutdown	SRO



**4/5. EVENTS 4 – 5 INADVERTANT DIV 4 LOCA SIGNAL / '1D' RHR PUMP FAILS****Simulator Operator Instructions**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

At time 10 min after FSSV or EO action requested for SE-10 Floor Actions Load **All SE-10 Floor Actions with Time Delays Scenario** and **report: "SE-10 Floor Actions for Div 4 are complete"**



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4/5.	<b>EVENTS 4 – 5 INADVERTANT DIV 4 LOCA SIGNAL / '1D' RHR PUMP FAILS</b>	
	<b>Lead Evaluator (or designee) Notes:</b> An instrument line downstream of excess flow check valve XV-42-1F045D breaks resulting in a DIV 4 LOCA signal. As a result DIV 4 ECCS will start on reactor level low signal. HPCI will also start and inject into the vessel, and D14 EDG will start, but the output breaker will not close. Also, all DIV 4 shunt trips will result in trips of various BOP systems.	
	Reference appropriate ARC: <ul style="list-style-type: none"> <li>• 002 A-1, CONTROL ROOM RADIATION ISOLATION</li> <li>• 002 D-4, B CONTROL STRUCTURE CHILLER OUT OF SERVICE</li> <li>• 004 B-1, B DRYWELL CHILLER TRIP/FAILED TO START</li> <li>• 004 B-4, DIV I/II RRCS CHANNEL ACTIVATED</li> <li>• 107 H-2, REACTOR HI/LO LEVEL</li> <li>• 112 H-1, RWCU PUMP SUCTION LO FLOW</li> <li>• 112 E-5, EXCESS FLOW CHECK VALVE OPERATED 10C218</li> <li>• 113 B-5, CORE SPRAY LINE INTERNAL BREAK</li> <li>• 114 C-2, REACTOR LO-LO LEVEL</li> <li>• 114 D-1, DIV 4 NSSSS MSIV INITIATED</li> <li>• 115 I-1, DIV 4 RHR AUTO START</li> <li>• 115 D-1, DIV 4 CORE SPRAY AUTO START</li> <li>• 115 H-3, REACTOR LO-LO-LO LEVEL</li> <li>• 118 C-2, 1B INSTRUMENT AIR HDR LO PRESSURE</li> </ul>	PRO/RO
	Recognize Div 4 LOCA signal	PRO
	Enter SE-10, LOCA ( <b>Abnormal</b> )	SRO
	[SE-10 3.2] <b>PLACE</b> to "RESET": <ul style="list-style-type: none"> <li>• 43-22422/CS, "Div. IV Non SFGD Instr. Panel" (INST AC 202 CONTROL PNL), on *DC661.</li> </ul>	PRO
	Dispatch Equipment Operator to perform SE-10-1 field actions	PRO
	Recognize/report HPCI running and injecting	PRO
	Enter OT-104, Unexpected/Unexplained Positive or Negative Reactivity Insertion. ( <b>Abnormal</b> )	SRO
	[OT-104 IOA] Reduce power to pre-transient power levels or below per OT-104	RO
	[OT-104 Attach #2] Recognize power rise due to HPCI injection and is NOT required	PRO
	[OT-104 Attach #2] TRIP HPCI per S55.2.A	PRO

**4/5. EVENTS 4 – 5 INADVERTANT DIV 4 LOCA SIGNAL / '1D' RHR PUMP FAILS****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

At time 5 min after requested to respond to Excess Flow Check Valve Panel 10C218, and **report:** At panel 10C218, Excess Flow Check Valve XV-42-1F045D is indicating CLOSED. All other Excess Flow Valves indicate open.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4/5.	<b>EVENTS 4 – 5 INADVERTANT DIV 4 LOCA SIGNAL / '1D' RHR PUMP FAILS</b>	
	[ARC MCR 112 E-5] Recognize excess flow check valve actuated and send an operator to investigate 10C218 panel	PRO/RO
	[ARC MCR 002 A-1] Recognize partial CR HVAC RAD isolation and reset the isolation per S78.7.A	PRO
	[S78.7.A 4.3.1] <b>PLACE</b> the desired following Control Room Isolation Valve Reset Keylock Switches to "RESET" <ul style="list-style-type: none"> <li>• HS-78-017D, RESET D</li> </ul>	PRO
	[S78.7.A 4.3.2] <b>ENSURE</b> the desired following Control Room Isolation Valve Trip Switches to "NOR" <ul style="list-style-type: none"> <li>• HSS-78-017D, TRIP D</li> </ul>	PRO
	[S78.7.A 4.3.3] <b>PLACE</b> the desired Control Room Isolation Valve Reset Keylock Switches to "AUTO" <ul style="list-style-type: none"> <li>• HS-78-017D, RESET D</li> </ul>	PRO
	Recognize D14 D/G is running and send an EO to perform running checks	PRO
	[ARC MCR 004 B-1] Recognize loss of '1B' Drywell Chiller	PRO
	Enter OT-101 on rising Drywell Pressure	SRO
	[OT-101, 3.1] <b>ESTABLISH</b> Drywell pressure as a Critical Parameter	Crew
	[OT-101 Att 3 2] <b>IF</b> the Drywell Chiller is tripped <b>PLACE</b> a Drywell Chiller in-service using S87.1.A Appendix 1.	PRO
	[S87.1.A App1 2.1] <b>PLACE</b> 1BK111 Drywell Chiller (CHILLER) to STOP (Green Flagged).	PRO
	[S87.1.A App1 2.2 and 2.3] <b>PLACE</b> DW Chilled water pumps 1A-P161 and 1B-P161 to OFF.	PRO
	[S87.1.A App1 4.0] <b>PLACE</b> 1BK111, "DW Chiller" (CHILLER) for oncoming Drywell Chiller in "START."	PRO



**4/5. EVENTS 4 – 5 INADVERTANT DIV 4 LOCA SIGNAL / '1D' RHR PUMP FAILS**

**Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

Manually actuate **Trigger # 3** when directed by Lead Evaluator, to initiate Small Coolant Leak in the Drywell.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4/5.	<b>EVENTS 4 – 5 INADVERTANT DIV 4 LOCA SIGNAL / '1D' RHR PUMP FAILS</b>	
	[S87.1.A App1 4.0] <b>ENSURE</b> 1A-P161 and 1B-P161 in RUN.	PRO
	[ARC MCR 115 I-1] Recognize '1D' RHR Pump failed to Auto start on LOCA signal	PRO
	Manually start of '1D' RHR Pump ( <b>Malfunction</b> )	PRO
	Recognize RWCU is Out of Service and contact Chemistry to perform conductivity sampling per TRM 3.4.4	PRO
	Direct Chemistry to perform sampling for Containment Leak Detector INOP	PRO
	Determine Tech Spec LCO's: 3.5.1.c.2 HPCI and '1D' LPCI (8 hours) 3.4.3.1.a Cont. Leak Detector (12 hours sampling/restore within 30 days) TRM 4.4.4.c RWCU (4 hour sampling) 3.3.3 for Div 4 ECCS instrumentation	SRO

**6/7. EVENTS 6 - 7 STEAM LEAK IN THE DRYWELL****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

Manually actuate **Trigger # 3** when directed by Lead Evaluator, to initiate Small Coolant Leak in the Drywell.

Ensure **Trigger # 4** automatically actuates when RMS taken to SHUTDOWN, to initiate Steam Leak in the Drywell



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/7.	<b>EVENTS 6 - 7 STEAM LEAK IN THE DRYWELL</b>	
	<b>EVALUATORS NOTE:</b> A coolant leak will develop in the Drywell. The coolant leak will result in a plant shutdown. Once the reactor is shutdown the operators will continue to address the containment parameters.	
	Reference ARCs: <ul style="list-style-type: none"> <li>• 112 C-5, DRYWELL EQUIP DRN TK/FLR DRN SUMP LEAKAGE HI FLOW</li> <li>• 115 B-5, DRYWELL COOLER DRAIN FLOW HIGH</li> <li>• 107 F-2, DRYWELL HI / LO PRESS</li> </ul>	RO/PRO
	Re-enter and execute OT-101 on rising Drywell pressure	RO
	[OT-101 3.1] ESTABLISH Drywell pressure as a Critical Parameter	SRO
	[OT-101 3.3] Perform OT-101 Attach #4	PRO
	[OT-101, Att. 4] <b>ENSURE</b> Main Steam Line sample valves closed HV-041-(1F084 and 1F085)	PRO
	[OT-101, Att. 4] <b>ENSURE</b> Recirc sample valves closed HV-043-(1F019 and 1F020)	PRO
	[OT-101, Att. 4] PRO secures and isolates RWCU (time permitting) <ul style="list-style-type: none"> <li>• <b>SECURE</b> operating RWCU pump(s) (Already secured)</li> <li>• <b>ENSURE</b> the following valves closed: <ul style="list-style-type: none"> <li>• HV-C-044-1F003</li> <li>• HV-44-1F001, INBD</li> <li>• HV-44-1F004, OUTBD</li> <li>• HV-44-1F100, BOTTOM HEAD DRAIN</li> <li>• HV-44-1F105, INLET FLOW</li> </ul> </li> </ul>	PRO
	Direct GP-4 rapid plant shutdown (time permitting)	SRO
	Transfer House Loads per S91.6.B (time permitting)	PRO
	Reduce Recirc Flow to Minimum (time permitting)	RO
	Manually scram reactor before DW pressure reaches 1.68 psig	RO
	Place Mode Switch to Shutdown	RO
	[T-101 RC-6] Insert SRMs AND IRMs	RO





**6/7. EVENTS 6 - 7 STEAM LEAK IN THE DRYWELL**

**Simulator Operator Instructions**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

Ensure **Trigger # 4** automatically actuates when RMS taken to SHUTDOWN, to initiate Steam Leak in the Drywell



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
<b>6/7. EVENTS 6 - 7 STEAM LEAK IN THE DRYWELL</b>		
<b>EVALUATORS NOTE:</b> When the plant is shutdown a steam leak into the drywell occurs. The crew will enter and execute T-102, Primary Containment Control and utilize RHR system to spray the Suppression Pool and Drywell.		
	Enter/Re-enter T-102 and T-101 when Drywell pressure exceeds 1.68 psig	SRO
	[OT-101 3.5] Trip both Recirc pumps when Drywell pressure exceeds 1.68 psig	RO
	[T-101 RC/Q-2] Ensure Turbine trip and Gen lockout	PRO
<i>R</i>	[T-101 RC/L-7] Restore and maintain RPV level between +12.5" and +54"	PRO
	[T-101 RC/P-1] Stabilize RPV pressure below 1096 psig	PRO
	[T-101 RC-5] Verify isolations for RPV level <+12.5" and >1.68 psig Drywell pressure	PRO/RO
	Verify HPCI System initiation on 1.68 psig Drywell pressure (already running from DIV 4 LOCA signal)	PRO
	Establish Suppression Pool Temperature as a Critical Parameter	CRS
	CRS directs depressurizing reactor to 600 psig to reduce leak input	SRO
	[OT-200 Att. 11] Depressurizes to 600 psig using EHC	RO
	[T-102 DW/T-5] When Drywell temperature exceeds 145 °F, verify DWCW Head Tank level, then bypass isolations and maximize Drywell cooling (time permitting)	PRO



**8/9. EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD**

**Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

At time 5 min after requested to investigate the trip of the '1B' RHR Pump  
**report:** "The '1B' RHR Pump breaker has tripped on 'B' Phase Overcurrent."



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
8/9.	<b>EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD</b>	
<b>EVALUATOR NOTE:</b> The following steps are performed as directed by T-225, Startup and Shutdown of Suppression Pool and Drywell Spray Operation.		
	[T-102 PC/P-5] <b>BEFORE</b> Supp Pool pressure reaches 7.5 psig Spray the Suppression Pool per T-225, Startup and Shutdown of Suppression Pool and Drywell Spray Operation	PRO
	Recognize '1B' RHR pump trips ( <b>Malfunction</b> )	PRO
	Investigate trip of '1B' RHR pump	PRO
	[T-225 4.2.4] <b>ENSURE</b> the following valves open: <ul style="list-style-type: none"> <li>• HV-51-1F047A(B), "1A(B) RHR Htx Shell Side Inlet Vlv" (INLET)</li> <li>• HV-51-1F003A(B), "1A(B) RHR Htx Shell Side Outlet Vlv" (OUTLET)</li> <li>• HV-C-51-1F048A(B), "1A(B) RHR Htx Shell Side Bypass Vlv" (HEAT EXCH BYPASS)</li> </ul>	PRO
	[T-225 4.2.5] <b>OPEN</b> HV-51-1F024A(B), "1A(B) RHR Pp Full Flow Test Return Vlv" (SUPP POOL CLG A(B)) <b>AND OBTAIN</b> flow of 8,000 to 8,500 gpm as indicated on FI-51-1R603A(B), FL	PRO
	Recognize HV-51-1F024A, "1A RHR Pp Full Flow Test Return Vlv" tripped on thermals and requires to be manually opened	PRO
	Override HV-51-1F024A thermals by holding handswitch in OPEN ( <b>Malfunction</b> )	PRO
	[T-225 4.2.6] <b>OPEN</b> HV-51-1F027A(B), "1A(B) RHR Supp Pool Spray Line PCIV" (SUPP POOL SPRAY)	PRO
<b>EVALUATOR NOTE:</b> The following steps are normally performed as directed by S12.1.A, RHR Service Water System Startup as directed from T-225. For this scenario RHRSW should have been placed in service for the open SRV (Event 2). If required reference page 23 of this SEG for RHRSW being placed in service.		



**8/9. EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD**

**Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
8/9.	EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD	
	<b>EVALUATOR NOTE:</b> The following steps are normally performed as directed by S12.1.A, RHR Service Water System Startup as directed from T-225. For this scenario RHRSW should have been placed in service for the open SRV (Event 2). If required reference page 23 of this SEG for RHRSW being placed in service.	
	[T-225 4.2.8] <b>PLACE</b> RHR Service Water Pump for RHR Heat Exchanger to be used in service per S12.1.A, RHR Service Water System Startup	PRO
	[T-225 4.2.9] <b>CLOSE</b> HV-C-51-1F048A(B), "1A(B) RHR Htx Shell Side Bypass Vlv" (HEAT EXCH BYPASS)	PRO
	[T-102 PC/P-12] WHEN SAFE side of the Pressure Suppression Pressure (PSP) curve (Curve PC/P-3) cannot be maintained, enter T-112	CRS
	[T-112 EB-12] <b>DIRECT</b> Open all 5 ADS valves	CRS
	[T-112 EB-12] <b>PERFORM</b> Open all 5 ADS valves ( <b>Critical Task</b> )	RO/PRO
	[T-102 PC/P-10] –or- [T-102 DW/T-8] Spray the <b>Drywell</b> per T-225, Startup and Shutdown of Suppression Pool and Drywell Spray Operation	PRO
	[T-225 4.5.1] <b>ENSURE</b> HV-51-1F004A(B), "1A(B) RHR Pump Suction PCIV" (SUCTION A(B)), open	PRO
	[T-225 4.5.2] <b>ENSURE</b> the following valves closed: <ul style="list-style-type: none"> <li>• HV-51-1F006A(B), "1A(B) RHR Pp S/D Clg Suct Intertie Vlv" (SUCTION A(B))</li> <li>• HV-51-1F015A(B), "1A(B) Shutdown Clg Injection PCIV" (OUTBOARD A(B))</li> <li>• HV-51-1F016A(B), "1A(B) RHR Cntmt Spray Line Outboard PCIV" (OUTBOARD A(B))</li> <li>• HV-51-1F017A(B), "1A(B) RHR LPCI Inj PCIV" (OUTBOARD A(B))</li> </ul>	RO/PRO



**8/9. EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD**

**Simulator Operator Instructions**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
8/9.	<b>EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD</b>	
	[T-225 4.5.4] <b>ENSURE</b> the following valves open: <ul style="list-style-type: none"> <li>• HV-51-1F047A(B), "1A(B) RHR Htx Shell Side Inlet Vlv" (INLET)</li> <li>• HV-51-1F003A(B), "1A(B) RHR Htx Shell Side Outlet Vlv" (OUTLET)</li> <li>• HV-C-51-1F048A(B), "1A(B) RHR Htx Shell Side Bypass Vlv" (HEAT EXCH BYPASS)</li> </ul>	PRO
	[T-225 4.5.5] <b>TRIP</b> Reactor Recirc Pumps	PRO
	[T-225 4.5.6] <b>REMOVE</b> Drywell Cooling Fans from service by placing all 16 Drywell Cooler Fan switches to "OFF"	PRO
	[T-225 4.5.7] <b>IF</b> Drywell High Pressure <b>AND LOCA</b> signals are present, THEN GO TO step 4.5.11	PRO
	[T-225 4.5.11] <b>OPEN</b> HV-51-1F024A(B), "1A(B) RHR Pp Full Flow Test Return Vlv" (SUPP POOL CLG A(B)), AND OBTAIN flow of 9,250 to 10,500 gpm as indicated on FI-51-1R603A(B), FL	PRO
	[T-225 4.5.12] <b>OPEN</b> only one loop HV-51-1F021A(B), "1A(B) RHR Cntmt Spray Line Inboard PCIV" (INBOARD)	PRO
	[T-225 4.5.13] <b>REQUEST</b> SSV verify drywell temperature AND drywell pressure are on SAFE side of Drywell Spray Initiation Limit Curve per T-102, Primary Containment Control OR SAMP-1, RPV and Primary Containment Flooding Control	PRO
	[T-225 4.5.14] Throttle <b>OPEN</b> only one loop HV-51-1F016A(B), "1A(B) RHR Cntmt Spray Line Outboard PCIV" (OUTBOARD) to initiate spray AND <b>OBSERVE</b> raising flowrate as indicated on FI-51-1R603A(B), FL.	PRO
	[T-225 4.5.15] <b>MONITOR</b> Drywell pressure.	PRO
	[T-225 4.5.16] <b>(Critical Task)</b> Throttle <b>OPEN</b> HV-51-1F016A(B), "1A(B) RHR Cntmt Spray Line Outboard PCIV" (OUTBOARD) AND Fully <b>CLOSE</b> HV-51-1F024A(B), "1A(B) RHR Pp Full Flow Test Return Vlv", (SUPP POOL CLG A(B)) AND OBTAIN flow of 9,250 to 10,500 gpm as indicated on FI-51-1R603A(B), FL	PRO



**8/9. EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD****Simulator Operator Instructions**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger.

At time 10 min after FSSV or EO action requested for SE-10 Floor Actions


Load **All SE-10 Floor Actions with Time Delays Scenario** and

**report:** The status of individual resets as requested OR when all resets are timed out

**report:** All SE-10 Floor Actions are complete



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
8/9.	<b>EVENTS 8 – 9 '1B' RHR PUMP TRIP / HV-51-1F024A THERMAL OVERLOAD</b>	
	[T-225 4.5.18] <b>CLOSE</b> HV-C-1F048A(B), "1A(B) RHR Htx Shell Side Bypass Valve" (HEAT EXCHANGER BYPASS).	PRO
<b>EVALUATORS NOTE:</b> The following steps are from SE-10, LOCA.		
	Recognize LOCA signal when RPV pressure drops below 455 psig	Crew
	Enter SE-10, LOCA	Crew
	[SE-10 3.1] <b>PLACE</b> the following to "CLOSE" <ul style="list-style-type: none"> <li>52-20224/CS, "D*24 Safeguard L.C. D*24-G-D MCC Bkr" (SAFEGUARDS B), on *BC661</li> <li>52-20124/CS, "D*14 Safeguard L.C. D*14-G-D MCC Bkr" (SAFEGUARDS A), on *AC661.</li> </ul>	RO
	[SE-10 3.2] <b>PLACE</b> to "RESET": <ul style="list-style-type: none"> <li>43-22322/CS, "Div. III Non SFGD Instr. Panel" (INST AC 201 CONTROL PNL), on *CC661</li> </ul>	RO
	Dispatch Equipment Operator to perform SE-10-1 field actions	PRO
	Restore RPV Level to +12.5" to 54" with Condensate and/or Low Pressure ECCS	RO/PRO
<p><b>EVALUATORS NOTE:</b> The scenario may be terminated when an Emergency Depressurization has been performed, Drywell Spray is in service, control rods inserted and reactor level is restored. After the scenario is terminated, direct the SRO to make the highest EAL classification for the scenario.</p> <p>EAL: FA-1 declaration due to: (RC.3.1 and RC.3.2)</p> <ul style="list-style-type: none"> <li>Drywell pressure &gt; 1.68 psig</li> </ul> <p><b>AND</b></p> <ul style="list-style-type: none"> <li>Drywell pressure rise is due to RCS leakage</li> </ul>		



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
	<p>Rough Log(s) Maintained by the crew with the following items noted:</p> <ul style="list-style-type: none"><li>• Rod (46-15) uncoupled</li><li>• '1N' SRV</li><li>• DIV 4 LOCA</li><li>• '1D' RHR Pump failed to auto start</li><li>• Reactor Scram</li><li>• ATWS</li><li>• 1.68 Drywell Pressure</li><li>• RPV Level &lt; +12.5" and Drywell Pressure &gt; 1.68 psig Isolations verified</li><li>• HV-51-1F024A thermal overload</li><li>• '1B' RHR Pump Trip</li><li>• FA-1 declaration due to: (RC.3.1 and RC.3.2)<ul style="list-style-type: none"><li>• Drywell pressure &gt; 1.68 psig</li></ul></li></ul> <p><b>AND</b></p> <ul style="list-style-type: none"><li>• Drywell pressure rise is due to RCS leakage</li></ul>	Crew
	Critique any instances where fundamentals were not properly adhered to, and whether in-the-moment coaching was provided by Supervision. Provide examples of effective Leadership and areas for improvement.	SM

**Attachment 1  
Simulator Operator Response Times**

<b>Procedure</b>	<b>Performance</b>	<b>Response Time (Minutes)</b>
T-209	Injection from the Standby Liquid Control Storage Tank with the RCIC System	45
T-212	Bypassing SQUIB Valves for SLC Injection	19
T-215	De-energization of Scram Solenoids	7
T-216	Manual Isolation and Vent of Scram Air Header	7
T-217	RPS/ARI Reset and Backup Method of Draining Scram Discharge Volume	17
T-219	Maximizing CRD Cooling Water Header Flow during ATWS Conditions	23
T-221	MSIV Isolation Bypass Procedure	11
T-225	Startup and Shutdown of Suppression Pool and Drywell Spray Operations	8
T-240	Maximizing CRD flow after Shutdown During Emergency Conditions	8
T-245	RPV Injection from RHR S/D Cooling	12
T-248	Injection from SLC Test Tank to RPV	15
T-251	Establish a HPCI Injection flow Path VIA Feedwater Only	6
T-270	Terminate and Prevent Injection into the RPV	7
T-290	Instrumentation Available for T-103 SAMP-2	5
S46.7.A (4.2.1)	Control Rod Drive Hydraulic System Operation Following Reactor Scram (Securing CRD flow to the Reactor - Close 46-1F060, CRD Water Pressure Control Station Inlet Valve)	7
SE-10-1 Resets and Floor action	Breaker Reset Following LOCA (Also reset ARMs, RHRSW Rad Monitor and RDCS)	10



## **XI. CREW PREBRIEF INSTRUCTIONS**

Unit 2 is in OPCON 1 at 100% power

Unit 1 is in OPCON 1 at 90% power

### **Specific Plant Conditions are as Follows:**

- Reactor power reduced to 90% due to Control Rod pattern adjustment

### **Inoperable/Out of Service Equipment and Estimated Time of Return (ETR):**

- '1B' EHC pump is blocked for replacement
- Repairs are scheduled to be complete in 2 hours

### **Restrictions on Plant Operations:**

- None

### **Planned Evolutions:**

- Raise Reactor power to 100%
- Continue replacement of '1B' EHC pump and perform PMT when complete

### **Documents Provided:**

- ReMA and Control Rod Move Sheet
- GP-5 Attachment 1
- S73.1.A, Normal Operation of the Reactor Manual Control System



CODE NO:	SEG-7016E	REV NO:	002
AUTHOR:	T. A. BYERS	APPROXIMATE RUN TIME:	75 minutes
TYPE:	SIMULATOR EVALUATION GUIDE	EFFECTIVE DATE:	
PROGRAM:	LICENSED OPERATOR TRAINING		
COURSE:	LICENSED OPERATOR (REQUALIFICATION/INITIAL) TRAINING		
TITLE:	Simulator Evaluation Guide for Individual and Crew Performance		

Prepared By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Training Instructor - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
 LORT Lead Instructor - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
 EP (as appropriate) - Signature

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_  
 RE (as appropriate) - Signature

Approval: \_\_\_\_\_ Date: \_\_\_\_\_  
 OPS Manager - Signature

Approved For Use: \_\_\_\_\_ Date: \_\_\_\_\_  
 Training Manager - Signature



## Appendix D

## Scenario Outline

Form ES-D-1

Facility: Limerick 1 & 2Scenario No.: SEG-7016ERev 002 Op-Test No.: 1

Examiners: \_\_\_\_\_

Operators: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**Initial Conditions:**Unit 1 is at 100% power. Unit 2 is at 100% power.**Turnover:**

None

Event No.	Malfunction Number	Event Type*	Event Description
1.	MFW001	R-RO C-PRO TS-SRO	HWC System Failure ( <b>Abnormal</b> )
2.	VIC104C8 MFW250A MFW246A	C-RO C-PRO	'1C' RFP Min Flow Valve fails open ( <b>Abnormal</b> )
3.	MCW481A MCW486B	C-PRO	'1A' TECW Pump trip '1B' TECW fails to auto start ( <b>Abnormal</b> )
4.	MVI234C	C-RO TS- SRO	Reactor High Pressure Transmitter Failure ( <b>Abnormal</b> )
5.	MRP029D MSL559 MRP407C	M-ALL	ATWS The ATWS is mitigated by the insertion of control rods via T-215. ( <b>Major</b> )
6.	MRD024	C-RO	RDCS Inoperative after reactor shutdown ( <b>Malfunction</b> )
7.	MMT002 MEH108	C-PRO C-RO	Turbine Trip / Bypass Valves Fail Closed ( <b>Malfunction</b> )
8.	MRSW600A MRSW600C	C-PRO	'0A' or '0C' RHRSW Pump Trips ( <b>Malfunction</b> )
<b>(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor</b>			





**I. QUANTITATIVE ATTRIBUTES**

**A. ILT**

<b>Target Quantitative Attributes (Per Scenario; See ES-301Section D.5.d)</b>	<b>ACTUAL NUMBER</b>
1. Malfunctions after EOP entry (1-2)	2
2. Abnormal events (2-4)	4
3. Major transients (1-2)	1
4. EOPs entered/requiring substantive actions (1-2)	2
5. EOP contingencies requiring substantive actions (0-2)	1
6. EOP based Critical tasks (2-3)	4

Review TQ-AA-151 attachment 5 and ES-301-5 for individual position requirements for scenario and scenario set



**II. PURPOSE:** Systematically evaluate individual and team performance to identify areas for improvement. Critical Tasks and Assessment Items from this evaluation guide are to be used to assess crew and individual performance and as input into a 4.0 Crew Critique Process.

**III. SIMULATOR EVALUATION GUIDE OBJECTIVES:**

A. The following evaluation objectives apply to the Crew (C), Shift Manager (SM), Control Room Supervisor (S), Unit Reactor Operator / Plant Reactor Operator (R), or Incident Assessor / Shift Technical Advisor (A) as indicated in the following categories.

1. The general condition for each of the evaluation objectives will be "Given the plant conditions and sequence of events in the Simulator Evaluation Guide (SEG)".
2. The general acceptable evaluation objective criteria for each of the evaluation objectives will be "To perform effectively as an individual and contribute to successful crew performance in accordance with appropriate reference plant procedures and Operations Expectations, Fundamentals and Strategies".
3. Specific UNSAT evaluation objective criteria will be consistent with TQ-AA-155, Conduct of Simulator Training and Evaluation with applicable forms and job aids.
4. During performance of this Simulator Evaluation Guide, the individuals and crew should satisfactorily demonstrate the following overall procedure and plant control objectives:
  - Direct and perform actions per ON-102, Air Ejector Discharge or Main Steam Line High Radiation.
  - Direct and perform actions per ON-117, Loss of TECW
  - Direct and perform actions per OT-100, Reactor Low Level
  - Direct and perform actions per OT-104, Unexpected-Unexplained Positive or Negative Reactivity Insertion.
  - Direct and perform actions per OT-117, RPS Failures
  - Direct and perform actions per GP-5, App. 2, Planned Rx Maneuvering Without Shutdown.
  - Direct and perform actions per T-270, Terminate And Prevent Injection Into The RPV
  - Direct and perform actions per T-101, RPV Control
  - Direct and perform actions per T-102, Primary Containment Control
  - Direct and perform actions per T-117, Level/Power Control



**IV. RECORD OF TEMPORARY CHANGES:**

- A. Approval of Pen & Ink Changes will be by the ILT or LORT Lead Instructor with OTM concurrence
- B. All Pen & Ink Changes are to be tracked in ILT or LOR Program Action Tracking for Next Revision
- C. All Pen & Ink Changes shall be in accordance with TQ-AA-223

Temp Change #	Date of Change	Purpose of Change	Lead Approval	Action Tracking	Revision Date

**V. REVISION HISTORY:**

- A. If a Revision affects a Task Performance from VISION Terminal Performance Objectives then the revision must also be made in the VISION database.
- B. The description of the Revision should adequately indicate how the training content of the Revision has changed.
- C. The description of the Revision should also include previous format reference and number and previous template used (e.g for conversion of LSTS to LLORSEG format).

Revision Number	Description of Revision and Affect on Training Content	# Date of Revision
Rev000	This was originally used as 2012 ILT Cert Scenario #3 (This scenario was designated as the spare and was not used).	8/12/13
Rev001	Revised to template with changes including RPS Pressure transmitter failure and RHRSW Pumps trip	8/15/15
Rev002	Revised to new template, removed APRM failure, added TECW Pump failure(s), reordered first 4 events, and changed initial power from 80% to 100%.	10/08/16

# Date of Revision - refers to date revision was released for approval

**SCENARIO EVENT AND EVALUATION SUMMARY:**

**Event One:** Shortly after the crew has taken responsibility of the shift, the HWC system will fail such that the Hydrogen Flow Controller output will rise and the PLC will lock up. The MSL Rad Monitor alarms will be received due to excess Hydrogen injection.

**Evaluation:** Evaluate the crews' response to the HWC malfunction including actions taken per ON-102, Air Ejector Discharge Or Main Steam Line High Radiation and T-103, Secondary Containment Control. The crew will reduce power and will trip the HWC System as well as reference Tech Specs due to excessive H2 injection.

**Event Two:** After the crew has taken Tech Spec actions for HWC, the '1C' RFP Min Flow Valve will fail open causing '1C' RFP injection rate to lower and the '1A' and '1B' RFPs to increase injection to the vessel.

**Evaluation:** Evaluate the crew's response to the '1C' RFP Min Flow Valve failing open and to secure the '1C' RFP, and isolate the minimum flow valve. The crew will execute OT-104, Unexpected/ Unexplained Positive or Negative Reactivity Insertion and reduce total Feedwater less than 13 Mlb/hr per GP-5.

**Event Three:** After the '1C' RFP is secured and reactor power lowered, the in-service '1A' TECW Pump will inadvertently trip, with the '1B' TEWC Pump failing to auto start.

**Evaluation:** Evaluate the crew's response to identify the TECW Pump failure, enter and execute ON-117, Loss of TECW, manually start the '1B' TECW Pump, and monitor Condensate Pump and Air Compressor temperatures.

**Event Four:** After the crew has started the '1B' TECW Pump a RPS reactor pressure transmitter fails upscale. The failed RPS instrument will result in a failed RPS channel (Will fail to de-energize. As a result of the RPS channel failure a manual full scram is required. On the scram the Control Rods will fail to insert, resulting in an ATWS.

**Evaluation:** Evaluate the crews' ability to address the failed pressure transmitter and implement OT-117, RPS Failures, and respond to a failure of the reactor to manually scram, and subsequent ATWS. The crew will be evaluated on their ability to implement T-101, RPV Control and T-117, Level/Power Control, and the initial level lowering per T-270, Terminate And Prevent Injection Into The RPV. Complicating the event, the SLC discharge line will rupture in the DW.

**SCENARIO EVENT AND EVALUATION SUMMARY: cont'd**

Event Six: After the Mode Switch is taken to shutdown, RDCS will become inoperative and prevent manual insertion of control rods.

Evaluation: Evaluate the crew's ability to recognize the failure of RDCS and call out for floor assistance in resetting RDCS in the AER. Once RDCS is reset, the crew is expected to manually insert control rods to help mitigate the ATWS condition.

Event Seven: After level is lowered and pressure has been stabilized, the Main Turbine will begin to experience vibration caused by bearing failure. The excess vibration will eventually cause a MT trip. Along with the Turbine trip, the Bypass Valves will fail to maintain RPV pressure, resulting in a rise in Suppression Pool temperature.

Evaluation: Evaluate the crews' ability to respond to a Main Turbine trip while maintaining reactor pressure control by manual operation of SRVs. The crew will perform a second lowering of reactor level per T-270, to less than -161" and maintain level between -186" to -161" as Suppression Pool temperature exceeds 110 deg F.

Event Eight: Also, after the Main Turbine Trip, the first started '0A' Loop RHRSW Pump will fail to start from the MCR.

Evaluation: To identify the trip of the lead RHRSW Pump and place the alternate pump in service in the '0A' RHRSW loop.

Termination Criteria: The scenario is terminated when RPV level has been maintained -186" to -161", followed by Control Rods inserted per T-215, De-energizing Of Scram Solenoids.

**VI. REFERENCES**

- A. Training Procedures
  - 1. TQ-LG-150, Limerick Operator Training Program
  - 2. TQ-AA-151, ILT Certification and NRC Examination Development and Administration
  - 3. TQ-AA-155, Conduct of Simulator Training and Evaluation
- B. Annunciator Response Cards (ARC)
  - 1. 101 E-5, CONDENSATE FILTERDEMIN TROUBLE
  - 2. 104 D-4, CONDENSATE PUMPS DISCHARGE HEADER LO PRESS
  - 3. 104 D-5, CONDENSATE PUMPS DISC SAMPLE STATION TRB
  - 4. 107 I-1, MAIN STEAM LINE HIGH-HIGH RADIATION
  - 5. 107 D-5, FWLCS Trouble
  - 6. 107 G-1, REACTOR HIGH PRESSURE TRIP
  - 7. 107 I-2, VIBRATION ALARM ALERT
  - 8. 107 I-3, VIBRATION ALARM DANGER
  - 9. 108 E-4, RDCS INOPERATIVE
  - 10. 109 F-1, 1 MAIN STEAM LINE DIV 1 RAD MONITOR HI/DNSC
  - 11. 109 F-2, 1 MAIN STEAM LINE DIV II RAD MONITOR HI/DNSC
  - 12. 109 B-5, TURBINE ENCL AREA HI RADIATION
  - 13. 118 G-3, TURB BLDG COOLING WATER HTX OUT LO PRESS
  - 14. 118 A-1, SERVICE AIR COMPRESSOR TROUBLE
  - 15. 118 B-1, 1A INST AIR COMPRESSOR TROUBLE
  - 16. 118 C-1, 1B INST AIR COMPRESSOR TROUBLE
  - 17. 127 I-1, 1 UNIT HWC SYSTEM TROUBLE
- C. System Procedures (S)
  - 1. S12.1.A, RHR Service Water System Startup
  - 2. S51.8.A, Placing RHR Suppression Pool Cooling in service
- D. General Procedures (GP)
  - 1. GP-5, Steady State Operations
  - 2. GP-5 Appendix 2, Planned Reactor Maneuvering Without Shutdown
- E. Off Normal Procedures (ON)
  - 1. ON-102, Air Ejector or Main Steam Line High Radiation
  - 2. ON-117 Loss Of TECW
- F. Operating Transient Procedures (OT)
  - 1. OT-104, Unexpected-Unexplained Positive or Negative Reactivity Insertion
  - 2. OT-117, RPS Failures
  - 3. OT-100, Reactor Low Level
- G. Event Procedures (E)
- H. Special Event Procedures (SE)
  - 1. SE-10, LOCA
- I. Surveillance Test and Routine Test Procedures (ST and RT)

**REFERENCES cont'd**

- J. Technical Specifications and TRM (TS)
  - 1. TS 3.11.2.6
- K. Transient Response Implementation Procedures (T-100 series)
  - 1. T-101, RPV Control
  - 2. T-102, Primary Containment Control
  - 3. T-103, Secondary Containment Control
  - 4. T-117, ATWS Level Control
- L. TRIP 200 Series Procedures
  - 1. T-215, De-energization of Scram Solenoids
  - 2. T-221, MSIV Isolation Bypass Procedure
  - 3. T-251, Establish a HPCI Injection Path Via Feedwater Only
  - 4. T-270, Terminate and Prevent Injection into the RPV
  - 5. T-290, Instrumentation Available For T-103/SAMP-2
- M. EP-AA-1008, Limerick, Radiological Emergency Plan Annex for Limerick Generating Station
- N. Administrative Procedures
  - 1. OP-AA Procedures
    - a. OP-AA-1, Conduct of Operations
    - b. OP-AA-20, Conduct of Operations Process Description
    - c. OP-AA-101-111-1003, Operations Department Standards and Expectations
    - d. OP-AA-101-113, Operations Fundamentals
    - e. OP-AA-101-113-1006, 4.0 Crew Critique Guidelines
    - f. OP-AA-106-101-1006, Operational Decision Making Process
  - 2. OP-LG Procedures
    - a. OP-LG-101-111-1000, Licensed Operator Duties
    - b. OP-LG-101-111-1002, Time Critical Operator Actions
    - c. OP-LG-103-102-1000, Human Performance Continuing Good Practices
    - d. OP-LG-103-102-1002, Strategies for Successful Transient Mitigation
    - e. OP-LG-108-101-1001, Simple Quick Acts / Transient Acts
- O. Current Shift Night Orders Forced Outage Plan
- P. INPO Significant Operating Experience Reports (SOER), Significant Event Reports (SER) and INPO Event Reports (IER)
  - 1. IER-L1 11-3, Weaknesses in Operator Fundamentals
  - 2. SER 3-05, Weakness in Operator Fundamentals
  - 3. SOER 10-02, Engaged Thinking Organizations
  - 4. INPO 15-004, Operator Fundamentals



**VII. PREBRIEF INSTRUCTIONS**

Unit 2 is in OPCON 1 at 100% power

Unit 1 is in OPCON 1 at 100% power

**Specific Plant Conditions are as Follows:**

- Operation per GP-5, Steady State Operations

**Inoperable/Out of Service Equipment and Estimated Time of Return (ETR):**

- None

**Restrictions on Plant Operations:**

- None

**Planned Evolutions:**

- Maintain 100%.

**Documents Provided:**

- None





**VIII. DIRECTIONS FOR EVALUATION PREPARATION**

**A. INITIAL PREPARATION**

✓	ITEM / MALFUNCTION / REMOTE FUNCTIONS
	Complete TQ-AA-155, Operator Training Programs Attachment 02, Evaluated Scenario Administration Checklist.
	Complete TQ-LG-201-0113, Limerick Training Department Simulator Examination Security Actions Checklist

**B. SIMULATOR SETUP**

✓	ITEM / MALFUNCTION / REMOTE FUNCTIONS
	Complete Limerick Simulator Pre-Evaluation Checklist
	Reset Simulator to the Pre-loaded Cycle <b>IC</b> developed for the Evaluation OR Reset the simulator to designated base load IC-3 AND Load scenario file <b>SEG7016E Rev002.scn</b> <ul style="list-style-type: none"> <li>• Verify that all Malfunctions, Remotes, Overrides, Annunciators and Triggers are properly loaded</li> </ul> <p><b>OR</b></p> <ul style="list-style-type: none"> <li>• Manually enter the Malfunctions, Remotes, Overrides, Annunciators and Triggers per the Scenario Generator Screen Shots:</li> </ul>
	Simulator Operator (Driver) perform the following: <ul style="list-style-type: none"> <li>• Momentarily place simulator in RUN</li> <li>• Acknowledge and clear all spurious alarms</li> <li>• Place the simulator back into FREEZE</li> <li>• Place appropriate tags and equipment in required condition / status.</li> </ul>



C. MALFUNCTION/REMOTE/OVERRIDE/ANNUNCIATORS FUNCTION TIME TABLE

Interventions Summary								
Hide Malfunctions - 15		Hide Remotes - 8		Show Overrides - 0		Show Annunciators - 0		
<b>Malfunction Summary</b>								
Mal ID	Mult ID	Description	Current Value	Target Value	Rmptime	Actime	Dactime	Trig
MFW001		HWC System Excess H2 Injection and PLC Lockup	False	True				1
MFw250A		Reactor Feedpump C Min Flow Recirc Valve Fails Open	False	True		00:00:15		2
MFw246A		Reactor Feedpump C Trip	False	True		00:10:00		2
MCW486B		TECW Pump B Fails to Auto Start	Fails	Fails				
MCW481A		TECW Pump A Trips (Magnetic Overload)	False	True		00:00:15		3
MV1234C		Reactor Vessel Pressure Transmitter (RPS) N0788 Fails High	False	True		00:00:15		4
MRD024		Rod Drive Control System Failure	False	True		00:06:30		5
MMT002		TBWD Turbine Thrust Failure - MILS	8.939348	50.00000	00:04:00	00:11:00		5
MRP029D		RPS Fails to Scram Channel B	True	True				
MSL559		SLC Injection Line Rupture Inside the Drywell	True	True				
MRP407C		BOTH RRCS Divisions ARI Fails to Initiate	True	True				
MEH108		Turbine Bypass Valves Fail to Selected Value (0-100%)	-5.00000	20.00000	00:05:00	00:16:00		5
MRSW600A		RHR Service Water Pump OAP506 Elect Fault	FALSE	TRUE			00:00:01	6
MRSW600C		RHR Service Water Pump OCP506 Elect Fault	FALSE	TRUE			00:00:01	7
VIC104C8		1C RFPT Pump Imbalance at Probe 104C08	2.900000	10.00000	00:08:00	00:00:15		2
<input type="checkbox"/> Timer Pause <span style="margin-left: 200px;"><u>Delete All</u></span> <span style="float: right;"><b>Active</b> <b>Pending</b></span>								
<b>Remotes Summary</b>								
Rem ID	Mult ID	Description	Current Value	Target Value	Rmptime	Actime		Trig
RRE148		Refuel Floor To SGTIS Isolation damper SGD76-206-3	CLOSE	CLOSE				
RRE156		Unit 2 Refuel Floor Isol Sw HS76-281A	RESET	RESET				
RRE157		Unit 2 Refuel Floor Isol Sw HS76-281B	RESET	RESET				
RRM032		SPE & MVP Rad Monitor RE-160 Skid 10S408 Enable	DISABLE	DISABLE				
RPR061		APRM Channel 1 Gain Adjustment Factor	.8654	.8654				
RPR063		APRM Channel 3 Gain Adjustment Factor	.8570	.8570				
RPR062		APRM Channel 2 Gain Adjustment Factor	.8710	.8710				
RPR064		APRM Channel 4 Gain Adjustment Factor	.8490	.8490				
<input type="checkbox"/> Timer Pause <span style="margin-left: 200px;"><u>Clear List</u></span> <span style="float: right;"><b>Active</b> <b>Pending</b></span>								



**D. EVENT TRIGGERS ASSIGNMENT**

1. Timers should be used on event triggers where possible for time validation
2. Timing of event triggers may be altered by the Lead Evaluator (or designee)
3. Verify triggers are actuated automatically as designed or manually initiate the trigger when the initiating action has occurred.
4. Inform Lead Evaluator (or designee) of expected plant response prior to actuation of each trigger.
5. Trigger #1 is manually initiated at Lead Evaluator (or designee) direction after the crew assumes responsibility for operation.

⌚	TRIGGER / TIME	MALFUNCTION	DESCRIPTION
	1.	Manual	Initiates HWC system lockup
	2.	Manual	Initiates '1C' RFP Min Flow Valve opens
	3.	Manual	Initiates '1A' TECW Pump trip
	4.	Manual	Initiates Rx Pressure Transmitter Failure
	5.	Auto / ZRPS1SDN	RMS TO SHUTDOWN Initiates TBWD failure and RDCS failure
	6.	Auto / ZSWRPCC	'C' RHRSW Pump CS to START Deactivates 'A' RHRSW failure
	7.	Auto / ZSWRPAC	'A' RHRSW Pump CS to START Deactivates 'C' RHRSW failure

**Event Trigger Builder / Viewer**

**Triggers**

Trigger #	Trigger Text
1	
2	
3	
4	
5	ZRPS1SDN
6	ZSWRPCC
7	ZSWRPAC
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	

**Operators:**

- Arithmetic:**
  - \* Multiplication
  - / Division
  - + Addition
  - Subtraction
- Relational:**
  - > Greater than
  - >= Greater than or equal
  - < Less than
  - <= Less than or equal
  - == Equal to
  - != Not equal to
- Logical:**
  - && And
  - || Or
  - ! Not
- Other:**
  - { Open Paren
  - } Close Paren

Buttons: Trigger Now, Clear, Clear All, Accept, Exit



## E. EQUIPMENT REPORTS AND SIMULATOR INSTRUCTOR OPERATIONS

1. Scripted Activity Reports should be followed with adherence to Operations Communication standards of performance.
2. The T-200 procedure reference book should be used for familiarity of reports to aid in operator prompting and expected communications.
3. The Lead Evaluator (or designee) should be informed if any event is not reported as scripted due to lack of Operator request.
4. The Standard Equipment Operator Response Times are per Attachment 1
5. A record of communications from the MCR and to the MCR will be maintained by the Simulator Operator using **Attachment 2**.
6. The OCOEE Simulator Operator Station P&IDs, Floor Plans and Panels should be used by the Simulator Operator as reference information when making reports to the MCR for plant parameters which are not driven by a communications script. Examples include: ARMs, Blowout Panel status, Reactor Building Area Temperatures and Pressures, RMMS, Turbine Enclosure parameters etc.

**IX. CREW CRITICAL TASKS**

A. Critical Tasks are based on the current Crew Critical Task List revision, NUREG 1021 and TQ-AA-150 requirements.

**1. T-117.1 Inhibit automatic ADS**

K/A	295037	EA2.06	4.04.1
K/A	218000	EA4.04	4.1/4.1

Standard: Prevent automatic initiation of ADS

**SAT/UNSAT****2. T-117.12 Terminate and prevent injection into the RPV.**

K/A	295037	EK1.02	4.1/4.3
K/A	295037	EK3.03	4.1/4.5
K/A	295037	EA2.02	4.1/4.2

Standard: RPV level deliberately lowered by Terminating and Preventing injection into the RPV per LQ-11 when conditions of step LQ-14 are met.

**SAT/UNSAT****3. T-101.5 Implement T-215 to insert control rods.**

K/A	295037	EA1.05	3.9/4.0
K/A	295037	EA2.05	4.2/4.3

Standard: Direct the performance of T-215 to operations personnel located outside the control room.

**SAT/UNSAT****4. T-117.8 Maintain RPV level between -186 inches and the level to which it was intentionally lowered.**

K/A	295037	EA2.01	4.2/4.3
K/A	295037	EA2.02	4.1/4.2

Standard: RPV level maintained between -186 inches and -161 inches after initially raising RPV level into the required band. Any deviations from the RPV level band DO NOT require an Emergency Blowdown per T-117.

**SAT/UNSAT**



- X. ASSESSMENT OF CREW PERFORMANCE DURING CONDUCT OF THE SIMULATOR EVALUATION GUIDE TRAINING:**
- A. Conduct the Simulator Evaluation Session per TQ-AA-155, Conduct of Simulator Training and Evaluation, Attachment 02, Evaluated Scenario Administration Checklist
  - B. Assessment of Crew and Individual performance shall be consistent with OP-AA-20, Conduct of Operations Process Description
  - C. Where possible record the time and position responsible for performance of each task or assessment item
  - D. Items not performed as expected **SHALL** be discussed in the post performance crew critique
  - E. During the performance of the evaluation, the Simulator Evaluators shall **MAINTAIN** notes of observations and information consistent with the timeline
  - F. Assessment items with the Ⓟ symbol indicate a time critical standard for performance
  - G. Assessment items with the Ⓡ symbol indicate a Probabilistic Risk Assessment (PRA) association with the task
  - H. The Simulator Operator will respond with scripted or proceduralized responses when requested by the MCR operators with Procedure completion times requested per **Attachment 1**
  - I. The Simulator Operator will also maintain a timeline and record of all reports and requests issued by the MCR personnel with response provided by the simulator operator using **Attachment 2**
  - J. Shaded items do not require assessment for ILT Evaluations. The CRS may be requested to complete the Shift ED forms and determine the EAL classification at the completion of the scenario



**This Page  
Intentionally  
Blank**

**1. EVENT - 1 HYDROGEN WATER CHEMISTRY FAILURE (Abnormal)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate

Inform Floor Instructor prior to each event trigger

Manually actuate **Trigger # 1** when directed by Lead Evaluator to initiate HWC PLC Lockup

At time 5 min after FSSV or EO action requested to investigate HWC Panel 10C177,  
**report:** The local alarm is HYDROGEN FLOW TO SETPOINT ERROR.

Manually actuate **Trigger # 2** when directed by Lead Evaluator to initiate '1C' RFP Min Flow Valve to fail open





TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
1.	<b>EVENT - 1 HYDROGEN WATER CHEMISTRY FAILURE (Abnormal)</b>	
<b>Lead Evaluator (or designee) Notes:</b> A HWC flow control valve failure causes H2 flow to increase into the suction of the RFPs and result in a lockup of the HWC system. The crew will identify the increased H2 flow and isolate the system by depressing HS-06-154 on the C673 panel.		
	Reference appropriate ARCs <ul style="list-style-type: none"> <li>• 109 F-1, 1 MAIN STEAM LINE DIV 1 RAD MONITOR HI/DNSC</li> <li>• 109 F-2, 1 MAIN STEAM LINE DIV II RAD MONITOR HI/DNSC</li> <li>• 109 B-5, TURBINE ENCL AREA HI RADIATION</li> <li>• 127 I-1, 1 UNIT HWC SYSTEM TROUBLE</li> <li>• 107 I-1, MAIN STEAM LINE HIGH-HIGH RADIATION</li> </ul>	RO/PRO
	Dispatch EO to 10C177 panel to investigate H2 system	PRO
	[ARC MCR 109 F-2/107 I-1] Enter and execute ON-102, Air Ejector Discharge Or Main Steam Line High Radiation	SRO
	[ARC MCR 109 F-2/107 I-1] Enter T-103, Secondary Containment Control	RO/PRO
	[T-103 SCC-6] Direct performance of T-290 for available instrumentation	SRO
	[ON-102 2.2] <b>Direct</b> power reduction IAW GP-5, App.2 and RMSI to maintain air ejector discharge rad below HI HI Alarm setpoint and Main Steam Line Rad less than 1.5 X NFPB	SRO
	<b>Perform</b> power reduction IAW GP-5, App.2 and RMSI to maintain air ejector discharge rad below HI HI Alarm setpoint and Main Steam Line Rad less than 1.5 X NFPB <b>(Reactivity)</b>	RO
	Verify proper H2 and O2 flows and Offgas indications	PRO
	[ON-102 2.2] Trip HWC by depressing HS-06-154 on the C673 panel.	PRO
	Contact WWM for assistance	SRO
	[ON-102 2.2] Notify Chemistry for sampling	PRO
	Verify Rad Levels Dropping in Offgas and MS Lines after HWC Trip	RO
	Reference TS 3.11.2.6 when Offgas H2 is >4%	SRO

**2. EVENT - 2 '1C' RFP MIN FLOW VALVE FAILS OPEN (Abnormal)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate

Inform Floor Instructor prior to each event trigger

At time 3 min after FSSV or EO action requested to close 006-1007C

**report:** We can't get the '1C' RFP Min Flow Recirc Isolation valve closed. We have four operators attempting to close it now and it will not move even with wrenches.

Manually actuate **Trigger # 3** when directed by Lead Evaluator to initiate TECW Pump trip.

**DELETE** malfunction **VIC104C8** '1C' RFPT vibration when '1C' RFP is tripped.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
2.	<b>EVENT - 2 '1C' RFP MIN FLOW VALVE FAILS OPEN (Abnormal)</b>	
<p><b>Lead Evaluator (or designee) Notes:</b> As the '1A' RFP Min Flow Recirc Vlv fails open, the DFWLCS will respond to a reduction in FW flow to the RPV and lower RPV level which raises speed of the RFPTs to control RPV level. The RO will identify '1A' RFP flow is lower than the other RFPs and identify the Min Flow Recirc Valve opened.</p>		
	<p>Reference appropriate ARCs:</p> <ul style="list-style-type: none"> <li>• 107 D-5, FWLCS Trouble</li> <li>• 101 E-5, CONDENSATE FILTERDEMIN TROUBLE</li> <li>• 104 D-4, CONDENSATE PUMPS DISCHARGE HEADER LO PRESS</li> <li>• 104 D-5, CONDENSATE PUMPS DISC SAMPLE STATION TRB</li> </ul>	RO/PRO
	Identify '1C' feedflow lowering on FI-06-1R604C	RO
	Recognize unexpected/unexplained drop in RPV level – enter OT-100, Reactor Low Level	SRO
	Recognize and report '1C' RFP Min Flow Valve is Open	RO
	<p>[OT-100 step 2.2 IOA] Reduce Rx power per GP-5, App. 2, section 3.1 and RMSI until Reactor Level is restored</p>	RO
	Direct EO to close 06-1007C, '1C' RFP min flow manual isolation valve	RO
	Direct '1C' RFP be secured when the manual isolation valve cannot be closed <b>(Malfunction)</b>	SRO
	Recognize vibration on '1C' RFP rising	RO
	Trip '1C' RFP	RO
	Close the '1C' RFP Suction Valve <b>(Malfunction)</b>	RO
	Direct Rx power reduction per RMSI until Total FW flow is <13Mlbm/hr <b>(Reactivity)</b>	RO
	<p>[OT-100 ATT 1] Reduce Total FW flow &lt;13Mlbm/hr per RMSI, if &gt; 13Mlbm/hr</p>	RO
	Contact Work Week Manager to investigate RFP Min Flow Valve going open	SRO
	Perform S06.2.A to Shutdown the '1C' RFP	RO
	Notify TSO and Power Team of power changes	SRO
	Notify Chemistry that GEZIP is OOS and surveillance required for power reduction	PRO



**3. EVENT – 3 '1A' TECW PUMP TRIP / '1B' TECW PUMP FAILS IN AUTO (Abnormal)**

**Simulator Operator Instructions:**

Respond to request for assistance as appropriate

Inform Floor Instructor prior to each event trigger

Manually actuate **Trigger # 3** when directed by Lead Evaluator to initiate TECW Pump trip.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
3.	<b>EVENT – 3 ‘1A’ TECW PUMP TRIP / ‘1B’ TECW PUMP FAILS IN AUTO (Abnormal)</b>	
<p><b>Lead Evaluator (or designee) Notes:</b> The PRO will respond to alarm and identify the ‘1A’ TECW Pump has tripped and the ‘1B’ TECW Pump has failed to start in AUTO. If the PRO immediately manually starts the ‘1B’ TECW Pump the air compressor Hi temperature alarms will not occur.</p>		
	<p>Reference appropriate ARC:</p> <ul style="list-style-type: none"> <li>• 118 G-3, TURB BLDG COOLING WATER HTX OUT LO PRESS</li> <li>• 118 A-1, SERVICE AIR COMPRESSOR TROUBLE</li> <li>• 118 B-1, 1A INST AIR COMPRESSOR TROUBLE</li> <li>• 118 C-1, 1B INST AIR COMPRESSOR TROUBLE</li> </ul>	RO/PRO
	<p>[ARC MCR 118 G-3] Verify low TECW header pressure using PI-14-106 at C655 panel</p>	PRO
	<p>[ARC MCR 118 G-3] Verify standby TECW Pump failed to auto start on lo header pressure</p>	PRO
	<p>[ARC MCR 118 G-3] Enter ON-117, Loss Of TECW</p>	SRO
	<p>[ON-117 2.1] Place alternate TECW Pump in service</p>	PRO
	<p>[ON-117 2.6] <b>DISPATCH</b> an operator to monitor Instrument and Service Air Compressor temperatures</p>	PRO
	<p>[ON-117 2.8] <b>MONITOR</b> Condensate Pump bearing temperatures on PMS points</p>	PRO

**4 / 5    EVENTS 4 - 5    RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger

Manually actuate **Trigger # 4** at Lead Evaluators discretion to initiate RPS instrument failure.

At time 5 min after FSSV or EO action requested to investigate RPS Pressure Trip units in AER,

**report:** PIS-042-1N678B is indicating upscale.



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4 / 5	<b>EVENTS 4 - 5 RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)</b>	
	Reference appropriate ARC: • 107 G-1, REACTOR HIGH PRESSURE TRIP	RO
	Verify Rx pressure normal with high RPS pressure transmitter alarm	RO
	Recognize failure to ½ scram on B RPS and inform CRS	RO
	Dispatch an EO to investigate the Rx pressure transmitter	PRO/RO
	Enter OT-117, RPS Failures, for failure to ½ scram on B RPS	SRO
	[OT-117 3.2.1] <b>Direct</b> inserting manual ½ scram on 'B' Side	SRO
	<b>Perform</b> Arm and depress 'B1' RPS	RO
	Recognize failure to ½ SCRAM on 'B' RPS	RO
	[OT-117 3.2.1] <b>Direct</b> Arm and depress 'B2'	SRO
	<b>Perform</b> Arm and depress 'B2' RPS	RO
	[OT-117 3.2.1] <b>Direct</b> manual scram	SRO
	Insert 'A' Side RPS Manual SCRAM signals	RO
	Place the Reactor Mode Switch in SHUTDOWN	RO
	Recognize failure to scram	RO
	Enter T-101 on SCRAM condition with power above 4%	SRO
	[T-101 RC-6] Insert SRMs/IRMs	RO
	[T-101 RC/Q-5] Initiate RRCS ( <b>Malfunction</b> )	RO
	Verify after 118 seconds after RRCS initiation SLC pumps start and inject	RO
	Manually attempt SLC injection including '1C' SLC Pump	RO
	Recognize/report SLC low discharge pressure	RO
	<b>Direct</b> securing SLC	SRO
	Secure SLC pumps	RO

**4 / 5    EVENTS 4 - 5    RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger

At time 11 min after FSSV or EO action requested for T-221, perform the following:  
**Toggle** Remote Function **RTR051** to "**BYPASS**" and  
**report (via phone):** T-221 is complete on Unit 1.

At time 7 min **OR** immediately if pre-staged for at least 7 minutes after FSSV or EO action requested for T-270, manually perform T-270 as follows:  
**Toggle** Remote Functions **RTR220 through RTR227** to "**TEST**"  
**OR** load the 7-minute T-270 file from the Ops Training Scenarios\Remotes folder and  
**report (via phone):** Section 4.6 of T-270 is complete

At time 6 min after FSSV or EO action requested for implementation of T-251;  
**contact MCR:** and have Operators verify that HV-055-1F006 indicates closed in the MCR  
**AND** perform the following: **Toggle** Remote Function **RTR309** to "**OPEN**" and  
**report:** T-251 is complete in the field





TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4 / 5	<b>EVENTS 4 - 5 RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)</b>	
	[T-101 RC/Q-8] Runback Recirc pumps to minimum with 28% runback pushbutton	RO
	[T-101 RC/Q-10] Trip both Recirc pumps at least 10 seconds apart	RO
	[T-101 RC/Q-12] Insert control rods manually with RWM bypassed	RO
	[T-101 RC/Q-13] Direct performance of T-213 to personnel outside Main Control Room (MCR)	SRO
	[T-101 RC/Q-5] Direct performance of T-214 to personnel outside Main Control Room (MCR)	SRO
	[T-101 RC/Q-13] <b>(Critical Task)</b> Direct performance of T-215 to personnel outside Main Control Room (MCR)	SRO
	[T-101 RC/Q-13] Direct performance of T-216 to personnel outside Main Control Room (MCR)	SRO
P	[T-101 RC/Q-19] <b>(Critical Task)</b> Inhibit Auto ADS	PRO
	[T-101 RC/Q-20] Direct performance of T-209	SRO
	Stabilize RPV pressure	PRO
	Enter and execute T-117	SRO
	[T-101 RC/P-11] Direct performance of T-221 w/MSIVs open	SRO
	[T-117 LQ/7] <b>Direct</b> establish RPV level < -50 inches performing T-270	SRO
	<b>Direct</b> performance of Section 4.6 of T-270 to personnel outside Main Control Room (MCR) <b>(Critical Task)</b>	PRO
	[T-270 4.2.1] <b>IF</b> HPCI initiation signal is present, <b>AND CANNOT</b> be reset, <b>THEN SHUTDOWN</b> 10S211, "HPCI Turbine" as follows: <b>DEPRESS AND RELEASE</b> "Pushbutton For Manual Isolation", and <b>ENSURE</b> HV-55-1F003 closed	PRO

**4 / 5    EVENTS 4 - 5    RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger

When requested to perform **T-221**, toggle remote function **RTR051** to **BYPASS** on an **11 minute delay**. When time has expired, call and report as complete.

At time 7 min **OR** immediately if pre-staged for at least 7 minutes after FSSV or EO action requested for T-270, manually perform T-270 as follows:

**Toggle** Remote Functions **RTR220 through RTR227** to **"TEST"**

**OR** load the 7-minute T-270 file from the Ops Training Scenarios\Remotes folder and **report (via phone):** Section 4.6 of T-270 is complete

At time 6 min after FSSV or EO action requested for implementation of T-251;

**contact MCR:** and have Operators verify that HV-055-1F006 indicates closed in the MCR

**AND** perform the following: **Toggle** Remote Function **RTR309** to **"OPEN"** and **report:** T-251 is complete in the field



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4 / 5	<b>EVENTS 4 - 5 RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)</b>	
	<p>[T-270 4.2.2]  <b>IF</b> HPCI initiation signal is <u>not</u> present, <b>THEN SHUTDOWN</b> 10S211, "HPCI Turbine" as follows:            Simultaneously <b>DEPRESS AND HOLD</b> HS-056-161, "Pushbutton for HPCI Turbine Trip (E41A-S19) (TURBINE TRIP)  <b>AND CLOSE</b> HV-55-1F003, "HPCI Main Steam Supply Outbd PCIV (OUTBOARD)</p>	PRO
	<p>[T-270 4.4.1]  <b>ENSURE</b> HV-06-138A, (BYPASS) is closed</p>	RO
	<p>[T-270 4.4.2]  <b>ENSURE</b> LIC-06-138, (STARTUP BYPASS) in Manual and set to 0%</p>	RO
	<p>[T-270 4.4.3]  <b>ENSURE</b> LIC-06-120, (PUMP BYPASS) in Manual and set to 0% at</p>	RO
	<p>[T-270 4.4.4]  <b>ENSURE</b> FIC-M1-1R601A, B, C "A,B,C RFPT Speed Controller in Manual for all three RFPTs</p>	RO
	<p>[T-270 4.4.5]  <b>DEPRESS</b> EMERGENCY STOP pushbutton for ALL AVAILABLE RFPTs at panel 10C603</p>	RO
	<p>[T-270 4.4.6]  <b>WHEN</b> the emergency stop light goes out, <b>THEN DEPRESS</b> AUTO START pushbutton for <b>ALL AVAILABLE</b> RFPTs</p>	RO
	<p>[T-270 4.4.7]  <b>CLOSE</b> HV-06-108A, "1A RFP Discharge"</p>	RO
	<p>[T-270 4.4.8]  <b>CLOSE</b> HV-06-108B, "1B RFP Discharge"</p>	RO
	<p>[T-270 4.4.9]  <b>CLOSE</b> HV-06-108C, "1C RFP Discharge"</p>	RO
	<p>Stabilize RPV level between -60" and -100"</p>	RO
	<p>[T-101 RC-5]            Isolations verified for +12.5" and -38"</p>	PRO
	<p>[T-117 LQ/18]            Direct performance of T-251</p>	SRO



**4 / 5    EVENTS 4 - 5    RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)**

**Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
4 / 5	<b>EVENTS 4 - 5 RPS HIGH PRESSURE TRANSMITTER FAILURE / ATWS (Major)</b>	
<p><b>EVALUATORS NOTE:</b> The crew, if permitted, during a high power ATWS, is expected to place RHRSW in service. The following steps are directed by S12.1.A, RHR Service Water System Startup followed by, S51.8.A, Suppression Pool Cooling Operation (Startup and Shutdown) and Level Control.</p>		
	<b>START</b> selected RHR Service Water Pump loop per S12.1.A, RHR Service Water System Startup	PRO
	[S12.1.A 4.1.4 or App #1 1.3] <b>OPEN</b> HV-51-1F014A(B), HEAT EXCHANGER INLET	PRO
	[S12.1.A 4.1.5 or App #1 1.3] Throttle <b>OPEN</b> HV-51-1F068A(B) for 18 to 20 seconds	PRO
	[S12.1.A 4.1.6(7) or App #1 1.4] <b>VERIFY</b> PI-51-105A-1(B), HX DISCH, indicates system static pressure greater than or equal to 15 psig	PRO
	[S12.1.A 4.1.8 or App #1 1.5] <b>IF</b> the HI RAD AND/OR HI Pump Discharge pressure trips need to be bypassed <b>AND</b> the required actions of ODCM Part 1 Control 3.1.1 have been met for the INOPERABLE RHRSW Radiation Monitor, <b>THEN PLACE</b> HSS-12-002A(B), PUMP TRIP BYPASS, in "BYPASS"	PRO
	[S12.1.A 4.1.10 or App #1 1.6 / 1.7] <b>START</b> 0A(B,C,D)V543 Spray Pond Room Fan	PRO
	[S12.1.A 4.2.2 or App #1 1.8] <b>START</b> 0A(B,C,D)P506, RHRSW PUMP	PRO
	[S12.1.A 4.2.3 or App #1 1.9] <b>THROTTLE</b> HV-51-1F068A(B) to the maximum obtainable position without exceeding 11,000 gpm on FI-51-1R602A(B) while maintaining pump disch pressure (PI-12-001A-1(B)) between 75 psig to 85 psig	PRO

**6/8 EVENTS 6 – 8 RDCS INOP/TURBINE TRIP/A LOOP RHRSW INOP (Malfunction)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger

At time 5 min after FSSV or EO action requested to reset RDCS  
**DELETE MRD024** and toggle **RRD001** to **RESET** and  
**report: "RDCS has been reset in the AER"**



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/8	<b>EVENTS 6 – 8 RDCS INOP/TURBINE TRIP/A LOOP RHRSW INOP (Malfunction)</b>	
<b>EVALUATORS NOTE:</b> When reactor power is lowered a RDCS failure will prevent control rod insertion.		
	Reference appropriate ARC: <ul style="list-style-type: none"> <li>• 107 I-2, VIBRATION ALARM ALERT</li> <li>• 107 I-3, VIBRATION ALARM DANGER</li> <li>• 108 E-4, RDCS INOPERATIVE</li> </ul>	PRO
	Respond to High (Main Turbine)Vibration alarms	PRO
	Recognize/report Main Turbine Hi Vibration	PRO
	Trip the Main Turbine due to high vibration	PRO
	[T-101 RC/P-1] Stabilize Rx pressure with SRVs, 990-1096 psig <b>(Malfunction)</b>	PRO
	If RPV pressure rises above 1096 psig, re-enter T-101	SRO
	[T-101 RC/P-13] RFPTs are used to consume additional Steam. (108 valve closed with elevated Feedpump RPM) <b>(Malfunction)</b>	RO
	Recognize and report RDCS INOP alarm	RO
	Direct RDCS Reset in AER <b>(Malfunction)</b>	RO
	When RDCS Reset in the MCR manually inset control rods	RO
	Enter T-102, Primary Containment Control on Suppression Pool Temp > 95°F	SRO
	Establish Suppression Pool Temperature as a Critical Parameter	SRO
	[T-102 SP/T-2] Place Two Loops of Suppression Pool Cooling in service per S51.8.A	PRO
	[S51.8.A App #1 step 1.4] <b>START</b> 1A(B)P202, RHR Pump (PUMP)	PRO
	[S51.8.A App #1 step 1.5] <b>OPEN</b> HV-51-1F024A(B) "RHR Pump Full Flow Test Return" (SUPP POOL CLG), <b>AND MAINTAIN</b> flow indicated on FI-51-1R603A(B), "RHR Loop Flow" between 8000 to 8500 gpm	PRO
	[S51.8.A App #1 step 1.6] <b>CLOSE</b> HV-C-51-1F048A(B), HEAT EXCH BYPASS	PRO
	Recognize failure of either '0A' or '0C' RHRSW pump to Start <b>(Malfunction)</b>	PRO
	Start other RHRSW pump in 'A' loop	PRO
	When SP temperature reaches 110 deg F <b>DIRECT</b> perform T-270 to lower level until -161, SRV closed or <4% power	SRO
	<b>Perform</b> T-270 to lower level until -161, SRV closed or <4% power <b>(Critical Task)</b>	PRO/RO

**6/8 EVENTS 6 – 8 RDCS INOP/TURBINE TRIP/A LOOP RHRSW INOP (Malfunction)****Simulator Operator Instructions:**

Respond to request for assistance as appropriate.

Inform Floor Instructor prior to each event trigger

At time 10 min after FSSV or EO action requested to perform SE-10 Floor Actions Load **All SE-10 Floor Actions with Time Delays** Scenario and,  
**report:** status of individual resets as requested or when all resets are timed out **OR**  
**report:** "All SE-10 Floor Actions are complete."

**Perform T-215 following T-270 second lowering with RPV level -161" to -186"**

**Control Rods to be inserted by T-215 as follows:** When directed by Lead Evaluator Call MCR and notify MCR control rod movement should occur and **DELETE MRP029D**

The **PURPOSE** of this SEG is to get to the T-270 second lowering. With Lead Evaluators permission, vary Bypass Valve malfunction **MEH108** so the crew achieves their objective.





TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
6/8	<b>EVENTS 6 – 8 RDCS INOP/TURBINE TRIP/A LOOP RHRSW INOP (Malfunction)</b>	
	Re-perform T-270 steps to Emergency Stop Reactor Feed Pumps	RO
	Re-inject with Feedwater when RPV level is < -161" (TAF) and stabilize level between -186" and -161"	RO
	[SE-10 3.1] <b>PLACE</b> the following to "CLOSE" <ul style="list-style-type: none"> <li>• 52-20224/CS, "D*24 Safeguard L.C. D*24-G-D MCC Bkr" (SAFEGUARDS B), on *BC661</li> <li>• 52-20124/CS, "D*14 Safeguard L.C. D*14-G-D MCC Bkr" (SAFEGUARDS A), on *AC661.</li> </ul>	RO
	[SE-10 3.2] <b>PLACE</b> to "RESET": <ul style="list-style-type: none"> <li>• 43-22322/CS, "Div. III Non SFGD Instr. Panel" (INST AC 201 CONTROL PNL), on *CC661</li> <li>• 43-22422/CS, "Div. IV Non SFGD Instr. Panel" (INST AC 202 CONTROL PNL), on *DC661.</li> </ul>	RO
	Dispatch Equipment Operator to perform SE-10-1 field actions	PRO
	Ensure ECCS Pumps other than '1A' and '1B' RHR remain shutdown	PRO
	RPV level restored and stabilized between –186 and –161 inches <b>(Critical Task)</b>	RO
	MCR notified of expected control rod movement and recognize all rods in due to T-215, De-energization Of Scram Solenoids <b>(Critical Task)</b>	RO
	Secure SLC Pumps that restart on LOCA Signal	RO
	Exit T-117 when all Control Rod in	SRO
	Isolations verified for -129" RPV level	PRO
	Stabilize level with the core covered after rod insertion to maintain the cooldown rate	RO
	Slowly raise Reactor Level Band 12.5" to 54"	RO
<p><b>EVALUATORS NOTE:</b> The scenario is terminated when RPV level has been maintained –186" to –161", followed by Control Rods inserted per T-215, De-energizing Of Scram Solenoids. After the scenario is terminated, direct the SRO to make the highest EAL classification for the scenario.</p> <p>EAL: <b>Alert (MA3)</b> due to:</p> <ol style="list-style-type: none"> <li>1. Automatic or manual scram did <b>not</b> shutdown the reactor as indicated by Reactor Power &gt; 4%.</li> </ol> <p><b>AND</b></p> <ol style="list-style-type: none"> <li>2. Manual / ARI actions taken at the Reactor Console are <b>not</b> successful in shutting down the reactor as indicated by Reactor Power &gt; 4%.</li> </ol>		



TIME	ASSESSMENT ITEMS AND TASK PERFORMANCE	POSITION
	<ul style="list-style-type: none"><li>• Rough Log(s) Maintained by the crew with the following items noted:</li><li>• '1C' RFP Min Flow Valve fails open</li><li>• '1C' RFP manually tripped</li><li>• ON-102 entry</li><li>• HWC tripped</li><li>• RPV High Pressure Trip with failure to scram</li><li>• OT-117 entry</li><li>• ATWS</li><li>• T-101 entry</li><li>• T-200 Callouts:<ul style="list-style-type: none"><li>• T-209</li><li>• T-213</li><li>• T-214</li><li>• T-215</li><li>• T-216</li><li>• T-221</li><li>• T-251</li><li>• T-270</li></ul></li><li>• T-117 entry</li><li>• Main Turbine Vibration/Trip</li><li>• BPV failure</li><li>• A or C RHRSW Pump Trip</li><li>• LOCA signal</li><li>• SE-10 entry/floor actions</li><li>• Isolations verified for +12.5", -38", -129"</li><li>• All rods in</li><li>• Level restored above TAF</li><li>• Alert (MA3) declaration due to ATWS with failure of auto and manual RPS and RRCS</li></ul>	Crew



## Attachment 1

### Simulator Operator Response Times

<b>Procedure</b>	<b>Performance</b>	<b>Response Time (Minutes)</b>
T-209	Injection from the Standby Liquid Control Storage Tank with the RCIC System	45
T-212	Bypassing SQUIB Valves for SLC Injection	19
T-215	De-energization of Scram Solenoids	7
T-216	Manual Isolation and Vent of Scram Air Header	7
T-217	RPS/ARI Reset and Backup Method of Draining Scram Discharge Volume	17
T-219	Maximizing CRD Cooling Water Header Flow during ATWS Conditions	23
T-221	MSIV Isolation Bypass Procedure	11
T-225	Startup and Shutdown of Suppression Pool and Drywell Spray Operations	8
T-240	Maximizing CRD flow after Shutdown During Emergency Conditions	8
T-245	RPV Injection from RHR S/D Cooling	12
T-248	Injection from SLC Test Tank to RPV	15
T-251	Establish a HPCI Injection flow Path VIA Feedwater Only	6
T-270	Terminate and Prevent Injection into the RPV	7
T-290	Instrumentation Available for T-103 SAMP-2	5
S46.7.A (4.2.1)	Control Rod Drive Hydraulic System Operation Following Reactor Scram (Securing CRD flow to the Reactor - Close 46-1F060, CRD Water Pressure Control Station Inlet Valve)	7
SE-10-1 Resets and Floor action	Breaker Reset Following LOCA (Also reset ARMs, RHRSW Rad Monitor and RDCS)	10





## **XI. CREW PREBRIEF INSTRUCTIONS**

Unit 2 is in OPCON 1 at 100% power

Unit 1 is in OPCON 1 at 100% power

### **Specific Plant Conditions are as Follows:**

- Operation per GP-5, Steady State Operations

### **Inoperable/Out of Service Equipment and Estimated Time of Return (ETR):**

- None

### **Restrictions on Plant Operations:**

- None

### **Planned Evolutions:**

- Maintain 100%.

### **Documents Provided:**

- None