

10 CFR 21.21

March 2, 2017

52-027

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

**SUBJECT: INTERIM 10 CFR PART 21 REPORT REGARDING A PIPE SUPPORT FOR
V. C. SUMMER UNIT 2 AP1000® PROJECT**

This letter provides an interim report in accordance with 10 CFR 21.21 pertaining to a Passive Core Cooling System (PXS) pipe support that is being supplied for the V. C. Summer Unit 2 AP1000® project. Based on information contained in a nonconformance and disposition report, a corrective action report, and an inspection report, it was found that a PXS pipe support was labeled in a manner that could have resulted in an SA240 Type 304L steel plate being used in a location where an A572 Grade 50 steel plate was required.

Evaluation for reportability in accordance with 10 CFR Part 21 was not able to be completed within the 60-day evaluation period. It is currently expected that the evaluation of this condition will be completed by May 3, 2017.

If you have any questions pertaining to this information, please contact Curtis Castell, Licensing Manager, at 980-859-6373.

Sincerely,



David Durham
President
WECTEC LLC

cc: Regional Administrator, USNRC, Region II

IE19
NRD