

## **NRR-PMDAPem Resource**

---

**From:** Asselin, David (DEQ) <AsselinD1@michigan.gov>  
**Sent:** Monday, March 13, 2017 2:41 PM  
**To:** Goetz, Sujata  
**Subject:** [External\_Sender] RE: NRC Issuance of an Expedited Amendment Associated with Emergency Core Cooling System

Hi Sue,

The State of Michigan does not have any comments and supports the issuance of requested license amendment.

Sincerely,

David

-----  
David Asselin, Acting Manager  
Radiological Protection Section  
Waste Management and Radiological Protection Division  
Michigan Department of Environmental Quality  
Telephone: (517) 614-9913  
Email: [asselind1@michigan.gov](mailto:asselind1@michigan.gov)

---

**From:** Goetz, Sujata [mailto:Sujata.Goetz@nrc.gov]  
**Sent:** Monday, March 13, 2017 1:58 PM  
**To:** Asselin, David (DEQ)  
**Cc:** Yale, Ken (DEQ)  
**Subject:** NRC Issuance of an Expedited Amendment Associated with Emergency Core Cooling System

Mr. Asselin,

The Nuclear Regulatory Commission (NRC) is in the process of approving a license amendment request from DTE Electric Company, for Fermi 2.

The proposed amendment would add footnotes indicating that the injection functions of "Drywell Pressure - High" for High Pressure Coolant Injection (HPCI) and "Manual Initiation" for HPCI and RCIC are not required to be operable under low reactor pressure conditions. The NRC staff's proposed no significant hazard consideration determination was published in the Federal Register on March 13 (82 FR 13512).

Please let me know if you have any comments on this action. I can be reached at 301-415-8004.

Thanks,  
Sue

**Sujata Goetz**  
**Project Manager, Fermi, Unit 2**

**Nuclear Regulatory Commission**

**11555 Rockville Pike  
Office of the Nuclear Reactor Regulation  
NRC/NRR/DORL/LP3**

**Mailroom, 08C10  
Rockville, MD 20852-2738  
Washington, DC 20555-0001**

**(o) 301.415.8004 (fax) 301.415.3313 (fax)  
Mail Stop 08D15**

**Hearing Identifier:** NRR\_PMDA  
**Email Number:** 3398

**Mail Envelope Properties** (BY2PR09MB0143F0A7AE8D2A97680FC44F9E250)

**Subject:** [External\_Sender] RE: NRC Issuance of an Expedited Amendment Associated with Emergency Core Cooling System  
**Sent Date:** 3/13/2017 2:41:26 PM  
**Received Date:** 3/13/2017 2:41:36 PM  
**From:** Asselin, David (DEQ)

**Created By:** AsselinD1@michigan.gov

**Recipients:**  
"Goetz, Sujata" <Sujata.Goetz@nrc.gov>  
Tracking Status: None

**Post Office:** BY2PR09MB0143.namprd09.prod.outlook.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1803	3/13/2017 2:41:36 PM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**