

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Jaime H. McCoy
Vice President Engineering

March 9, 2017
ET 17-0005

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Reference: Letter dated March 12, 2012, from E. J. Leeds and M. R. Johnson, USNRC, to M. W. Sunseri, WCNO, "Request for Information Pursuant to Title 10 of the Code of Federal Regulations 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3, of the Near-Term Task Force (NTTF) Review of Insights from the Fukushima Dai-ichi Accident"


Subject: Docket No. 50-482: Seismic High Frequency Confirmation for Wolf Creek Generating Station (WCGS), Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding Recommendation 2.1 of the Near - Term Task Force Review of Insights from the Fukushima Dai-ichi Accident

Gentlemen:

On March 12, 2012, the Nuclear Regulatory Commission (NRC) issued the reference to Wolf Creek Nuclear Operating Corporation (WCNO). The Enclosure to this letter provides requested information to address the High Frequency Confirmation requirements of Item (4), Enclosure 1, Recommendation 2.1: Seismic, of the reference. The Attachment to this letter contains the commitment discussed in the Enclosure.

If you have any questions concerning this matter, please contact me at (620) 364-4156, or Cynthia R. Hafenstine (620) 364-4204.

Sincerely,



Jaime H. McCoy

JHM/rtt

Attachment

Enclosure

cc: K. M. Kennedy (NRC), w/a, w/e
B. K. Singal (NRC), w/a, w/e
N. H. Taylor (NRC), w/a, w/e
Senior Resident Inspector (NRC), w/a, w/e

ADID
NRR

LIST OF REGULATORY COMMITMENTS

The following table identifies those actions committed to by Wolf Creek Nuclear Operating Corporation (WCNOC) in this document. Any other statements in this letter are provided for information purposes and are not considered regulatory commitments. Please direct questions regarding these commitments to Cynthia R. Hafenstine, Manager Regulatory Affairs at Wolf Creek Generating Station, (620) 364-4204.

REGULATORY COMMITMENT	DUE DATE
WCNOC will provide documentation of seismic acceptability of the 38 components requiring resolution, as identified in Table B-1 of the Seismic High Frequency Confirmation Report, by analytical, testing, or recommended action approaches.	No later than 30 days following completion of Refueling Outage 22, spring 2018

Enclosure to ET 17-0005

**50.54(f) NTTF 2.1 Seismic High Frequency Confirmation for WCGS
(67 pages)**