

April 7, 2017

Dr. Cameron Goodwin, Director  
Rhode Island Nuclear Science Center  
16 Reactor Road  
Narragansett, RI 02882-1165

SUBJECT: RHODE ISLAND ATOMIC ENERGY COMMISSION - NON-POWER REACTOR  
CLOSEOUT OF GENERIC LETTER 2016-01, "MONITORING OF  
NEUTRON-ABSORBING MATERIALS IN SPENT FUEL POOLS," FOR RHODE  
ISLAND NUCLEAR SCIENCE CENTER DOCKET NO. 50-193  
(CAC NO. A11010)

On April 7, 2016, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2016-01, "Monitoring of Neutron-Absorbing Materials in Spent Fuel Pools" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16097A169), to address the degradation of neutron-absorbing materials (NAM) in wet storage systems for reactor fuel at power and non-power reactors.

For the non-power reactors, GL 2016-01 requested that licensees provide facility-specific information related to the use of NAM. This information was needed by the NRC staff to verify continued compliance through licensee implementation of effective methods for monitoring of reactor fuel in wet storage so as to detect and mitigate any degradation or deformation of NAM when credited in the facility licensing or design basis for criticality control of fuel in wet storage.

Unique to three NRC-licensed research reactors is the use cadmium (Cd) plates as NAM in the facility's wet fuel storage. On April 11, 2016, Rhode Island Atomic Energy Commission submitted a response to GL 2016-01 (ADAMS Accession No. ML16102A198), for Rhode Island Nuclear Science Center which was supplemented by a letter dated March 10, 2017 (ADAMS Accession No. ML17072A151). The NRC staff conducted a review of your responses to GL 2016-01 and noted that your facility uses Cd metal as NAM.

The NRC staff development of GL 2016-01, did not assess or otherwise consider the use, degradation, or deformation of Cd NAM. After reviewing your responses to GL 2016-01, the NRC staff reviewed the use of Cd plates in research reactor applications. The NRC staff determined that the use of Cd NAM has not been known to exhibit the same or a similar susceptibility to the degradation or deformation described in GL 2016-01 that has been known to afflict NAM utilizing variations of boron-10 based NAM. The NRC staff's conclusion is supported in part by nearly 60 years of operational experience. The degradation or deformation of Cd plate NAM has not been observed at any of the research reactor facilities where used in wet fuel storage applications. Furthermore, based upon the information reviewed, the NRC staff would not anticipate the onset of degradation or deformation given the physical and chemical properties of Cd and the environment in which the Cd NAM is used.

Based upon the information you submitted in response to GL 2016-01 and the results of the NRC staff review, the NRC staff has determined that the submission addresses the information requested in GL 2016-01. No further information or action is requested regarding this matter.

Sincerely,

***/RA Duane Hardesty Acting for/***

Alexander Adams, Jr., Chief  
Research and Test Reactors Licensing Branch  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

cc: See next page

cc:

Governor  
222 State House Room 115  
Providence, RI 02903

Howard Chun, Commissioner  
Cranston High School East  
899 Park Avenue  
Cranston, RI 02910

Dr. Clinton Chichester, Chairman  
Rhode Island Atomic Energy Commission  
College of Pharmacy  
Pharmacy Building  
7 Greenhouse Road  
Kingston, RI 02881

Dr. John Breen, Chairman  
Nuclear and Radiation Safety Committee  
Providence College  
Department of Chemistry and Biochemistry  
1 Cunningham Square  
Providence, RI 02918

Test, Research and Training  
Reactor Newsletter  
P.O. Box 118300  
University of Florida  
Gainesville, FL 32611

Supervising Radiological Health Specialist  
Office of Occupational and  
Radiological Health  
Rhode Island Department of Health  
3 Capitol Hill, Room 206  
Providence, RI 02908-5097

Dr. Nitin Padture, Commissioner  
School of Engineering, Brown University  
184 Hope Street, Box D  
Barus & Holley Building, Room 608  
Providence, RI 02912

Dr. Yana K. Reshetnyak, Commissioner  
Department of Physics  
University of Rhode Island  
East Hall, 2 Lippitt Road  
Kingston, RI 02881

Dr. Nancy E. Breen, Commissioner  
Marine and Natural Science Building 226  
Roger Williams University  
One Old Ferry Road  
Bristol, RI 02809

SUBJECT: RHODE ISLAND ATOMIC ENERGY COMMISSION - NON-POWER REACTOR  
CLOSEOUT OF GENERIC LETTER 2016-01, "MONITORING OF  
NEUTRON-ABSORBING MATERIALS IN SPENT FUEL POOLS," FOR RHODE  
ISLAND NUCLEAR SCIENCE CENTER DOCKET NO. 50-193  
(CAC NO. A11010) DATED: April 7, 2017

**DISTRIBUTION:**

PUBLIC

GBowman, NRR

AMendiola, NRR

TMensah, NRR

SStuchell, NRR

NParker, NRR

AAdams, NRR

PBoyle, NRR

LLund, NRR

DHardesty, NRR

PRLB r/f

**ADAMS Accession No.: ML17075A177; \*concurred via email**

OFFICE	NRR/DPR/PRLB*	NRR/DPR/PROB/LA*	NRR/DPR/PGCB/BC*	NRR/DPR/PRLB/BC
NAME	PBoyle	NParker	SStuchell	AAdams (DHardesty for)
DATE	4/7/17	4/7/17	4/7/17	4/7/17

**OFFICIAL RECORD COPY**