

| | | |
|---|-------------------------------------|------------------------------|
| Facility: <u>LaSalle</u> | Scenario No.: <u>NRC Scenario 1</u> | Op-Test No.: <u>NRC 15-1</u> |
| Examiners: _____ | Operators: _____ | _____ |
| _____ | _____ | _____ |
| <u>Initial Conditions:</u> Unit 1 is at 4% power during a Startup. | | |
| <u>Turnover:</u> Secure the RWCU drain to the Main Condenser. Continue control rod withdrawal in preparation for taking the Mode Switch to RUN. | | |

| Event No. | Malf. No. | Event Type* | Event Description |
|-----------|-----------|----------------|--|
| 1 | none | N (BOP) | Secure RT Reject IAW LOP-RT-09 |
| 2 | none | R (ATC) | Control Rod Withdrawals |
| 3 | none | T (SRO) | Damage to Fire Hose Station 109 Reported (TRM) |
| 4 | mni018 | I (ATC) | 'A' IRM fails UPSCALE, Half SCRAM |
| 5 | g8c75g14 | C (BOP) | TBCCW Header Pressure Low |
| 6 | meh002 | C (BOP) | 'B' EHC Pump TRIP, Standby Pumps Fails to Auto-Start |
| 7 | R0601 | T (SRO) | Low ADS Bottle Bank Nitrogen Pressure (TS) |
| 8 | mrd279 | C (ATC) | CRD FCV Fails CLOSED |
| 9 | mrw010 | M (ALL) | RWCU Leak in RT Pump Room |
| 10 | none | C (ALL) | RWCU Fails to Isolate |
| 11 | none | M (ALL) | Two Areas Above Max Safe, Emergency RPV Blowdown |

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (T)echnical Specification

| | |
|---|--|
| <u>ES-301-4 Quantitative attributes:</u> Total Malfunctions (5-8): 6 Malfunction(s) after EOP (1-2): 1 Abnormal Events (2-4): 4 Major Transient(s) /E-Plan entry (1-2): 2 EOPs (1-2): 2 EOP Contingencies (0-2): 1 Critical Tasks (2-3): 2 | <u>ES-301-5 Quantitative attributes:</u> BOP Normal: 1 ATC Reactivity (1 per set): 1 BOP I/C (4 / set): 2 ATC I/C (4 / set): 2 SRO-I I/C (4 / set inc 2 as ATC): 5 SRO Tech Spec (2 per set): 2 ALL Major Transients (2 per set): 2 |
|---|--|

Appendix D

Scenario Outline

[Form ES-D-1](#)

| Facility: LaSalle Scenario No.: NRC Scenario 2 Op-Test No.: <u>NRC 15-1</u> Examiners: _____ Operators: _____ _____ _____ | | | |
|---|------------------|--|----------------------------------|
| Initial Conditions: 100% power | | | |
| Turnover: SPE Blower swap IAW LOP-GS-05 | | | |
| Event No. | Malf. No. | Event Type* | Event Description |
| 1 | none | N (BOP) | SPE Blower SWAP IAW LOP-GS-05 |
| 2 | none | T (SRO) | U-2 Reports DIV 2 DG INOPERABLE |
| 3 | mcw014 | C (BOP) | '1A' WR Pump TRIP |
| 4 | r0342 | R (ATC) | 1E MPT Transformer Hot Spot |
| 5 | r0742 | T (SRO) | SBLC Squib Valve Continuity Lost |
| 6 | none | C (BOP) | 'B' VR Exhaust Fan TRIP |
| 7 | mcw015 mcw013 | C (ATC) | Complete Loss of RBCCW |
| 8 | mrp017 | M (ALL) | Electrical ATWS |
| 9 | none | C (ATC) | ARI Fails |
| (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor | | | |
| <u>ES-301-4 Quantitative attributes:</u> Total Malfunctions (5-8): 6 Malfunction(s) after EOP (1-2): 1 Abnormal Events (2-4): 3 Major Transient(s) /E-Plan entry (1-2): 1 EOPs (1-2): 1 EOP Contingencies (0-2): 1 Critical Tasks (2-3): 3 | | <u>ES-301-5 Quantitative attributes:</u> BOP Normal: 1 ATC Reactivity (1 per set): 1 BOP I/C (4 / set): 2 ATC I/C (4 / set): 2 SRO-I I/C (4 / set inc 2 as ATC): 4 SRO Tech Spec (2 per set): 2 ALL Major Transients (2 per set): 1 | |

Appendix D

Scenario Outline

[Form ES-D-1](#)

| Facility: LaSalle Scenario No.: NRC Scenario 3 Op-Test No.: <u> NRC 15-1 </u> Examiners: _____ Operators: _____ _____ _____ | | | |
|---|-----------|--|--|
| <p><u>Initial Conditions:</u> 100% Reactor power, RCIC is OOS ready to be returned to Standby.</p> <p><u>Turnover:</u> Warm RCIC Steam Line and return to Standby IAW LOP-RI-05 step E.9</p> | | | |
| Event No. | Malf. No. | Event Type* | Event Description |
| 1 | none | N (BOP) | Warm RCIC Steam Lines and Return to Standby (Optional) |
| 2 | mrw001 | C (BOP) | RT Pump TRIP (Optional) |
| 3 | r0414 | C (BOP) | OG Building Exhaust Fan TRIP (Optional) |
| 4 | mcn017 | R (ATC) | Earthquake Below OBE/SSE Limit, Small Condenser Air Leak |
| 5 | k3k02p1y | C (ATC) | Failure of the RR Ganged Controller in AUTO |
| 6 | mca014 | M (ALL) | Scram, Suppression Pool Leak |
| 7 | mrd040 | C (ATC) | Five Control Rods Remain Out |
| 8 | none | M (ALL) | Blowdown |
| (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (T)echnical Specification | | | |
| <p><u>ES-301-4 Quantitative attributes:</u></p> Total Malfunctions (5-8): 6 Malfunction(s) after EOP (1-2): 1 Abnormal Events (2-4): 4 Major Transient(s) /E-Plan entry (1-2): 2 EOPs (1-2): 2 EOP Contingencies (0-2): 2 Critical Tasks (2-3): 3 | | <p><u>ES-301-5 Quantitative attributes:</u></p> BOP Normal: 1 ATC Reactivity (1 per set): 1 BOP I/C (4 / set): 2 ATC I/C (4 / set): 2 SRO-I I/C (4 / set inc 2 as ATC): 4 SRO Tech Spec (2 per set): 0 ALL Major Transients (2 per set): 2 | |

| Facility: LaSalle Scenario No.: NRC Scenario 4 Op-Test No.: <u> NRC 15-1 </u> Examiners: _____ Operators: _____ _____ _____ | | | |
|---|------------------|--|--|
| <u>Initial Conditions:</u> 100% Reactor power, 'C' CD/CB OOS | | | |
| <u>Turnover:</u> Swap VR Supply/Exhaust Fans IAW LOP-VR-01 | | | |
| Event No. | Malf. No. | Event Type* | Event Description |
| 1 | none | N (BOP) | Swap VR Supply/Exhaust Fans IAW LOP-VR-01 |
| 2 | mms056 | R (ATC) | Abnormal Turbine Generator Vibrations |
| 3 | mai006 mai007 | C (BOP) | Station Air Compressor TRIP, Standby Fails to Auto Start |
| 4 | mni073 | I (ATC) | LPRM Fails Downscale |
| 5 | mnb061 | I (ATC) | 1NB10B Instrument Line Leak |
| 6 | none | T (SRO) | 1NB10B Instrument Line Leak |
| 7 | mms056 | M (ALL) | Abnormal Turbine Generator Vibrations, Manual SCRAM |
| 8 | mcf034 | M (ALL) | Feedwater Rupture Inside Primary Containment |
| 9 | mes032 | C (BOP) | HPCS Fails to Auto-Start |
| (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor | | | |
| <u>ES-301-4 Quantitative attributes:</u> Total Malfunctions (5-8): 7 Malfunction(s) after EOP (1-2): 2 Abnormal Events (2-4): 4 Major Transient(s) /E-Plan entry (1-2): 2 EOPs (1-2): 2 EOP Contingencies (0-2): 0 Critical Tasks (2-3): 2 | | <u>ES-301-5 Quantitative attributes:</u> BOP Normal: 1 ATC Reactivity (1 per set): 1 BOP I/C (4 / set): 2 ATC I/C (4 / set): 2 SRO-I I/C (4 / set inc 2 as ATC): 4 SRO Tech Spec (2 per set): 1 ALL Major Transients (2 per set): 2 | |

Facility: LaSalle Scenario No.: NRC Scenario 5 Op-Test No.: NRC 15-1
 Examiners: _____ Operators: _____

Initial Conditions: Shutdown in progress at approximately 35% power. Currently at Step E.1.9, ready to downshift RR Pumps to Slow Speed per LOP-RR-08.
Turnover: Continue Shutdown and swap to the 'A' VP Chiller and follow-up with RR downshift.

| Event No. | Malf. No. | Event Type* | Event Description |
|-----------|-----------|----------------|---|
| 1 | none | N (BOP) | Swap VP Chiller Trains IAW LOP-VP-02 |
| 2 | none | R (ATC) | Downshift RR Pumps IAW LOP-RR-08 |
| 3 | k2h06jti | C (ATC) | RR Pump TRIPs to Zero Speed after Downshift |
| 4 | none | T (SRO) | RR Pump TRIPs to Zero Speed after Downshift |
| 5 | k1k21p1n | C (BOP) | Spurious LPCS Initiation |
| 6 | none | T (SRO) | Spurious LPCS Initiation |
| 7 | k9d782rr | I (BOP) | Primary Containment Pressure Controller Fails |
| 8 | vhtm60ad | C (ATC) | TDRFP Oil Leak |
| 9 | mrc041 | M (ALL) | RR LOCA |
| 10 | mrp018 | C (ATC) | 'B' RPS Channel Fails to De-Energize |

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (T)echnical Specification

| | |
|---|--|
| <u>ES-301-4 Quantitative attributes:</u> Total Malfunctions (5-8): 6 Malfunction(s) after EOP (1-2): 1 Abnormal Events (2-4): 4 Major Transient(s) /E-Plan entry (1-2): 1 EOPs (1-2): 2 EOP Contingencies (0-2): 0 Critical Tasks (2-3): 2 | <u>ES-301-5 Quantitative attributes:</u> BOP Normal: 1 ATC Reactivity (1 per set): 1 BOP I/C (4 / set): 2 ATC I/C (4 / set): 3 SRO-I I/C (4 / set inc 2 as ATC): 5 SRO Tech Spec (2 per set): 2 ALL Major Transients (2 per set): 1 |
|---|--|

| Facility: LaSalle Scenario No.: NRC Scenario 6 Op-Test No.: <u> NRC 15-1 </u> Examiners: _____ Operators: _____ _____ _____ | | | |
|---|--------------------|--|--|
| <p><u>Initial Conditions:</u> Unit 1 is at 100% Reactor Power, Suppression Pool water level is currently at 1", Non-Divisional Work Week</p> | | | |
| <p><u>Turnover:</u> Lower Suppression Pool water level to 0" IAW LOP-RH-16 to Main Condenser.</p> | | | |
| Event No. | Malf. No. | Event Type* | Event Description |
| 1 | none | N (BOP) | Lower Suppression Pool Water Level to 0" IAW LOP-RH-16 |
| 2 | r1211 | C (BOP) | Gland Steam Packing Exhaust Blower Trip |
| 3 | mvp001 | C (BOP) | VP Chiller TRIP |
| 4 | r0591 r0593 | C (ATC) | 'A' RR Pump Loss of Cooling Water Flow |
| 5 | none | T (SRO) | Single Loop Operation (TS) |
| 6 | k1n32e12 mnb103 | R (ATC) | Spurious MSIV Closure, Fuel Failure |
| 7 | mrp005 | C (ATC) | 'B' RR Pump TRIP, Automatic SCRAM Fails |
| 8 | mnb106 | M (ALL) | Main Steam Line Leak in Main Steam Tunnel |
| 9 | none | C (ALL) | 'D' Inboard and Outboard MSIVs Fail to Isolate |
| 10 | none | M (ALL) | 1VT79YA/B/C Fail OPEN, High Off-site Release, Blowdown |
| (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (T)echnical Specification | | | |
| <p><u>ES-301-4 Quantitative attributes:</u></p> Total Malfunctions (5-8): 8 Malfunction(s) after EOP (1-2): 2 Abnormal Events (2-4): 4 Major Transient(s) /E-Plan entry (1-2): 2 EOPs (1-2): 3 EOP Contingencies (0-2): 1 Critical Tasks (2-3): 2 | | <p><u>ES-301-5 Quantitative attributes:</u></p> BOP Normal: 1 ATC Reactivity (1 per set): 1 BOP I/C (4 / set): 2 ATC I/C (4 / set): 2 SRO-I I/C (4 / set inc 2 as ATC): 5 SRO Tech Spec (2 per set): 1 ALL Major Transients (2 per set): 2 | |

Appendix D

Scenario Outline

[Form ES-D-1](#)

Facility: LaSalle Scenario No.: NRC Scenario 7 Op-Test No.: NRC 15-1
 Examiners: _____ Operators: _____

Initial Conditions: Reactor power at approximately 71%, Startup is in progress IAW LGP-1-1, Suppression Pool Cooling Online, ACB 1522 OOS.

Turnover: Continue power ascension per LGP-3-1 and QNE direction, Secure Suppression Pool Cooling IAW LOP-RH-13.

| Event No. | Malf. No. | Event Type* | Event Description |
|-----------|-----------|-------------|---|
| 1 | none | R (ATC) | Continue Power Ascension Using RR FCV |
| 2 | none | N (BOP) | Secure Suppression Pool Cooling IAW LOP-RH-13 |
| 3 | mrd280 | C (ATC) | CRD Pump TRIP |
| 4 | k5e17pr | C (BOP) | Hydrogen Cooling TCV Fails CLOSED |
| 5 | mrd079 | I (ATC) | Control Rod Drifts In |
| 6 | none | T (SRO) | INOPERABLE Control Rod |
| 7 | mee027 | C (BOP) | Loss of 135X-2 |
| 8 | none | T (SRO) | Loss of 135X-2 |
| 9 | mnb104 | M (ALL) | MSL Break Inside Primary Containment |
| 10 | mca015 | C (ALL) | Containment Bypass Path |
| 11 | none | M (ALL) | RPV Blowdown |

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (T)echnical Specification

| | |
|---|--|
| <u>ES-301-4 Quantitative attributes:</u> Total Malfunctions (5-8): 6 Malfunction(s) after EOP (1-2): 1 Abnormal Events (2-4): 4 Major Transient(s) /E-Plan entry (1-2): 2 EOPs (1-2): 2 EOP Contingencies (0-2): 1 Critical Tasks (2-3): 2 | <u>ES-301-5 Quantitative attributes:</u> BOP Normal: 1 ATC Reactivity (1 per set): 1 BOP I/C (4 / set): 2 ATC I/C (4 / set): 2 SRO-I I/C (4 / set inc 2 as ATC): 5 SRO Tech Spec (2 per set): 2 ALL Major Transients (2 per set): 2 |
|---|--|