

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8006190488 DOC. DATE: 80/06/13 NOTARIZED: NO DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga 05000323
 AUTH. NAME AUTHOR AFFILIATION
 CRANE, P.A. Pacific Gas & Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Advises that 12-inch containment pressure/vacuum relief valves will be limited, prior to fuel loading, to prohibit opening more than 50 degrees. Limit effective until valve can be closed from one open position following postulated LOCA.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: J. HANCHETT w/1 cy ALL MATL.


ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME		LTR	ENCL
	AD LICENSING	1	0	BC SCHWENCER, A.	1	0	
	LA LEE, J.	1	0	PM BUCKLEY, R.05	1	0	
INTERNAL:	A/D CORE & CS13	1	0	AUX SYS BR 18	1	0	
	CHEM ENG BR	1	0	CORE PERF BR 17	1	0	
	DIRECTOR NRR	1	0	EMERG PREP 22	1	0	
	GEOSCIEN BR 09	4	4	HYD/GEO BR 11	1	0	
	I&C SYS BR 20	1	1	I&E 06	3	3	
	KIRKWOOD 29	1	1	MPA	1	0	
	NRC PDR 02	1	1	OELD	1	0	
	QA BR 10	1	1	RAD ASSESS BR12	1	1	
	<u>REG FILE</u> 01	1	1	SIT ANAL BR 27	1	1	
EXTERNAL:	ACRS 30	10	10	LPDR 03	1	1	
	NSIC 04	1	1				

ADD:

- EFF TR SYS BR | |
- HANAVER, S. | |
- PROC/TST REV BR | |
- STRUCT ENG BR | |
- CONT SYS BR | |
- ACCID EVAL BR | |
- ENV ENG BR | |
- MATL ENG BR | |
- MECH ENG BR | |
- POWER SYS BR | |
- REAL SYS BR | |
- SIT ANLYS BR | |

JUN 20 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 51 ENCL 0



PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

MALCOLM H. FURBUSH
VICE PRESIDENT AND GENERAL COUNSEL
ROBERT OHLBACH
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN
PHILIP A. CRANE, JR.
HENRY J. LAPLANTE
JOHN B. GIBSON
ARTHUR L. HILLMAN, JR.
CHARLES W. THISSELL
DANIEL E. GIBSON
ASSISTANT GENERAL COUNSEL

June 13, 1980

GILBERT L. HARRICK
GLENN WEST, JR.
JOSEPH I. KELLY
HOWARD V. DOLUB
JAMES C. LOSSOON
ROBERT L. BORDON
PETER W. HANSEN
THEODORE L. LINGBERG, JR.
DOUGLAS A. DOLEBRY

EDWARD J. MCGANNEY
DAN GRAYSON LUSBOCK
JACK F. FALLIN, JR.
BERNARD J. DELLABANTA
JOSHUA BAR-LEV
JOSEPH S. ENGLERT, JR.
ROBERT L. HARRIS
RICHARD F. LOCKE
DAVID L. LUDVIGSON
SENIOR COUNSEL

DAVID W. ANDERSON
DIANA BERDMAN
LEIGH S. CASBIDY
HEATHER S. GIBSON
BRIAN S. DENTON
WILLIAM H. EDWARDS
DONALD D. ERICKSON
DAVID C. GILBERT
JUAN M. JAYD
F. RONALD LAUPHEIMER
HARRY W. LONG, JR.
PAULAY, MAINE
ROBERT B. MCLENNAN
RICHARD H. MOSS
J. MICHAEL REIDENBACH
IVOR E. SANDON
SUE ANN LEVIN SCHIFF
JACK W. SHUCK
DAVID J. WILKINSON
BRUCE R. WORTHINGTON

J. PETER BAUMGARTNER
STEVEN P. BURKE
PAMELA CHAPPELLE
ANDREY DAINES
MICHAEL D. DESHARAIS
DARY P. ENGINAS
JOHN N. FRYE
PATRICK D. GOLDEN
KERMIT R. KUBITZ
MEREC E. LIPSON
JOHN R. LOW
A. KIRK MCKENZIE
RICHARD L. MEISS
ROGER J. PETERS
ROBERT R. RICKETT
SHIRLEY A. SANDERSON
JO ANN SHAFFER
LOUIS E. VINCENT
SHIRLEY A. WOOD
KENNETH YANG
ATTORNEYS

Mr. A. Schwencer, Acting Chief
Licensing Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Docket No. 50-275
Docket No. 50-323
Diablo Canyon Units 1 & 2

Dear Mr. Schwencer:

In accordance with discussions with the Staff, the 12-inch containment pressure/vacuum relief valves will be limited, before fuel loading, to prohibit them from being opened more than fifty degrees. This limit will remain in effect until it can be demonstrated that the valves can be closed from a more open position following a postulated LOCA.

Very truly yours,

Philip A. Crane, Jr.

CC: Service List

Boo 5/10

A

8 008190 488

