

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8009250288 DOC.DATE: 80/09/22 NOTARIZED: NO  
 FACIL:50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Gas  
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Gas  
 AUTH.NAME AUTHOR AFFILIATION  
 CRANE,P.A. Pacific Gas & Electric Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 SCHWENCER,A. Licensing Branch 2

DOCKET #  
 05000275  
 05000323

SUBJECT: Forwards response to NRC 800606 ltr requesting addl info re shielding review,containment monitors & iodine sampling at facilities.Monitors are mutually redundant using separate power supplies from separate vital instrument busses.

DISTRIBUTION CODE: B001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 6  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES:J Hanchett w/1 copy all material. 05000275  
 J Hanchett w/1 copy all material. 05000323

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LITR	ENCL	ID CODE/NAME	LITR	ENCL
ACTION:	A/D LICENSNG	1	0	SCHWENCER,A.	1	0
	LEE,J.	1	0	BUCKLEY,B. 04	1	1
INTERNAL:	ACCID EVALI BR26	1	1	AUX SYS BR 07	1	1
	CHEM ENG BR 08	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMERG PREP 22	1	0	EQUIP QUAL BR13	1	1
	GEOSCIENCES 14	1	1	HUM FACT ENG BR	1	1
	HYD/GEO BR 15	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	LIC GUID BR	1	1
	LIC QUAL BR	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDR 02	1	1	OELD	1	0
	OP LIC BR	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
	<del>REG FILE</del> 01	1	1	SIT ANAL BR 24	1	1
STRUCT ENG BR25	1	1	SYS INTERAC BR	1	1	
EXTERNAL:	ACRS 27	16	16	LPDR 03	1	1
	NSIC 05	1	1			

SEP 26 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 51  
85 ENCL 49

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both manual data entry and the use of specialized software tools. The goal is to ensure that the data is both accurate and easy to interpret.

The third part of the document provides a detailed breakdown of the results. It shows that there has been a significant increase in sales over the period covered by the report. This is attributed to several factors, including improved marketing strategies and better customer service.

The following table summarizes the key findings of the study. It shows a clear upward trend in revenue, which is a positive indicator for the business. The data also suggests that there is still room for improvement in certain areas, such as operational efficiency.

Based on the analysis, several recommendations are made for the future. These include investing in new technology to streamline processes and continuing to focus on customer satisfaction. By implementing these suggestions, the business can expect to see further growth and success.

In conclusion, the report provides a comprehensive overview of the current state of the business. It highlights the achievements made so far and offers practical advice for the path forward. The data clearly shows that the business is on a strong trajectory, and with the right strategies in place, the future looks very promising.

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

MALCOLM H. FURBUSH  
VICE PRESIDENT AND GENERAL COUNSEL

ROBERT OHLBACH  
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN

PHILIP A. CRANE, JR.

HENRY J. LAPLANTE

JOHN B. GIBSON

ARTHUR L. HILLMAN, JR.

CHARLES W. THISSELL

DANIEL E. GIBSON

ASSISTANT GENERAL COUNSEL

September 22, 1980

GILBERT L. HARRICK  
GLENN WEST, JR.  
JOSEPH I. KELLY  
HOWARD V. GOLUB  
JAMES C. LOSSON  
ROBERT L. BORDON  
PETER W. HANSDEN  
THEODORE L. LINDBERG, JR.  
DOUGLAS A. GOLESBY

EDWARD J. MOGANNEY  
DAN GRAYSON LUSBOCK  
JACK F. FALLIN, JR.  
BERNARD J. DELLASANTA  
JOSHUA BAR-LEVY  
JOSEPH S. ENGLERT, JR.  
ROBERT L. HARRIS  
RICHARD F. LODGE  
DAVID L. LUDVIGSON  
SENIOR COUNSEL

DAVID W. ANDERSON  
DIANA BERGHAUSEN  
LEIGH S. CASBIOY  
HEATHER B. CIBENA  
BRIAN B. DENTON  
WILLIAM H. EDWARDS  
DONALD D. ERICKSON  
DAVID C. GILBERT  
JUAN M. JAYO  
F. RONALD LAUFMEIER  
HARRY W. LONG, JR.  
PAULA Y. MAINS  
ROBERT S. MCLENNAN  
RICHARD H. MOSS  
J. MICHAEL REIDENBACH  
IVOR E. SAHSON  
SUE ANN LEVIN SCHIFF  
JACK W. SHUCK  
DAVID J. WILLIAMSON  
BRUCE R. WORTHINGTON

J. PETER BAUMGARTNER  
STEVEN P. BURKE  
PAMELA CHAPPELLE  
AUDREY DAINES  
MICHAEL G. DESMARAIS  
GARY P. ENOCHAS  
JOHN N. FRYE  
PATRICK G. GOLDEN  
KERRIT R. KUBITZ  
MEREE E. LIPSON  
JOHN R. LOW  
A. KIRK MCKENZIE  
RICHARD L. MEISS  
ROBERT J. PETERS  
ROBERT R. RICKETT  
SHIRLEY A. SANDERSON  
JO ANN SHAFER  
LOUIS E. VINCENT  
SHIRLEY A. WOOD  
KENNETH YANG  
ATTORNEYS

Mr. A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Re: Docket No. 50-275  
Docket No. 50-323  
Diablo Canyon Units 1 & 2

Dear Mr. Schwencer:

Attached is PGandE's response to your request for additional information dated June 6, 1980 regarding Shielding Review, Containment Monitors, and iodine sampling at Diablo Canyon, Units 1 and 2.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,

*Philip A. Crane, Jr.*

Attachments (40)  
CC w/attachment: Service List

8009250/11

8009250 : 288

A



1952

1. The first part of the report deals with the general situation of the country and the progress of the work during the year. It is followed by a detailed account of the work done in each of the various departments. The report then goes on to discuss the results of the work and the progress made towards the completion of the various projects. Finally, it concludes with a summary of the work done and a list of the various projects which are still in progress.

( )


## SHIELDING REVIEW

### Question 331.18 (12.2.1, 12.3.2)

By November 1, 1980, the Pacific Gas and Electric Company plans to submit to the NRC a Shielding Review of the Diablo Canyon Power Plant. This Shielding Review is part of the PGandE response to NUREG-0578: "Short Term Lessons Learned Requirements." To formulate the PGandE response to Item 2.1.6.b of NUREG-0578, two meetings were held with the NRC on February 26, 1980 and April 4, 1980. During both meetings, the NRC commented favorably upon the scope and schedule of the Diablo Canyon Shielding Review. By mutual agreement, the Review was scheduled for submittal to the NRC during the last quarter of 1980, with a target date of November 1.

As defined in the PGandE response to NUREG-0578 and the April 4, 1980, NRC meeting, the Review will contain the items indicated below:

- The Review will discuss the calculational methods and source terms used in evaluating personnel access and the environmental qualification of equipment.
- The Review will discuss the systems assumed to contain high levels of radioactivity in a postulated post-accident situation. Deletion of any of the systems identified in meetings with the NRC will be explained.
- The Review will specify areas where personnel access is considered necessary for vital system operation after an accident. Deletion of any of the areas identified in meetings with the NRC will be explained.
- The Review will name the computer codes used in the Shielding analysis.
- The Review will present the projected doses to individuals for any necessary occupancy times in vital areas.
- An integral part of the Review is the environmental qualification of the safety-related equipment in the auxiliary building taking into account the radiation levels which would exist in the auxiliary building during the thirty days following an accident that has resulted in a degraded core condition. The Review will indicate the equipment which has not been qualified and will include plans and methods to qualify this equipment.
- The Review will include a brief description of the proposed plant modifications. These modifications will be complete by January 1, 1981 or prior to power ascension, whichever is later.



## CONTAINMENT MONITOR


### Question 331.19 (12.3.4)

The two high range containment monitors measure photons above 60 keV. Calibration is performed in a test lab using cobalt 60 at approximately 300 R/hr. No on-site capability exists to calibrate these devices. A functional check of electrode configuration and electrical operation of detector, cable, polarizing voltage application, and detector output measurement function is automatically performed every 25 minutes. The check can be initiated manually to compare system output to a fixed input.


The monitors are mutually redundant, using separate power supplies from separate vital instrument busses. They will be fully operational before January 1, 1981.

The supplier is repeating the environmental qualification tests after replacing an "O" ring which failed in the original test with a seal welded joint. No other problems were found. The qualification package, which includes both seismic and environmental qualifications, will be completed before January 1, 1981, and will comply with regulatory guides 1.89 and 1.100.


A containment layout showing the location of the monitors is attached.







"LOCATION OF HIGH RANGE CONTAINMENT MONITORS, RE 30 AND RE 31."



## IMPROVED IODINE

### Question 331.20 (12.3.4, 12.5.2)

The number and types of portable iodine samplers at Diablo Canyon are shown on Table 1. All listed samplers can be fitted with either silver zeolite or impregnated charcoal cartridges for the collection of iodine samples. Analysis of the cartridges for the portable samplers will be made utilizing a germanium gamma spectrum analysis system calibrated for this use. There will be, upon completion of the Technical Support Center, germanium gamma spectrum analysis systems in the following locations: radioanalytical counting room (adjacent to Chemistry Laboratory Level 85), whole body counting room (also on Level 85 adjacent to access control), Technical Support Center (TSC) Laboratory, mobile radioanalytical van, and California Polytechnic University. In addition, a portable gamma spectrum analysis system will be available prior to fuel loading which will be capable of being set up in various areas of the plant. This portable system will initially include a shielded sodium iodide detector. The detector on this system will be replaced with an intrinsic germanium detector prior to power ascension.

Procedures for post-accident iodine sampling are being developed and the radiation process monitors (RPMs) will be trained to perform these functions. This post-accident iodine sampling procedure is similar to existing procedures on collection and analysis of routine iodine samples. All gamma analysis systems described above are capable of determining sample results within 10 minutes after start of count, assuming there is sufficient activity on sample.



4. 1. 1.

2.

TABLE 1

IODINE AIR SAMPLERS

<u>SAMPLER DESCRIPTION</u>	<u>FEATURES</u>	<u>NUMBER ON SITE</u>
Radeco Constant Air Monitor	Constant Flow Pump-8 CFM max., single Channel I-131 analysis with BKG subtract, alarms for high activity or rate of change, and detector failure, recorder on portable unit	4
Radeco HD 28/B Sampler	Constant Flow Pump-4 CFM max., adjustable flow rate with indicator, elapsed time counter	8
Radeco HD 28 Sampler	Constant Flow Pump-1 to 3 CFM elapsed time counter	17

