

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8101210555 DOC. DATE: 81/01/16 NOTARIZED: NO
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Gas & Electric Co. 05000275
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Gas & Electric Co. 05000323
 AUTH. NAME: CRANE, P.A. AUTHOR AFFILIATION: Pacific Gas & Electric Co.
 RECIP. NAME: MIRAGLIA, F.J. RECIPIENT AFFILIATION: Licensing Branch 3

BUCKLEY
 05000275
 05000323

SUBJECT: Forwards environ qualification of Class IE control cable mfg by Continental Wire & Cable Co. Requests receipt of mail to be ack.

DISTRIBUTION CODE: 8001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 11
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: 1 cy: J Hanchett (Region V)
 1 cy: J Hanchett (Region V)

05000275
 05000323

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR	ENCL
ACTION:	A/D LICENSNG	1	0	MIRAGLIA, F.	1	0
	LEE, J.	1	0	BUCKLEY, B.	04	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 07	1	1
	CHEM ENG BR 08	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMERG PREP 22	1	0	EQUIP QUAL BR13	3	3
	GEOSCIENCES 14	1	1	HUM FACT ENG BR	1	1
	HYD/GEO BR 15	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	LIC GUID BR	1	1
	LIC QUAL BR	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDR 02	1	1	OELD	1	0
	OP LIC BR	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
	REG FILE 01	1	1	SIT ANAL BR 24	1	1
	STRUCT ENG BR25	1	1	SYS INTERAC BR	1	1
	EXTERNAL:	ACRS 27	16	16	LPDR 03	1
NSIC 05		1	1			

JAN 22 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR

58
 51 ENCL 52
 51

1000

[The page contains extremely faint and illegible text, possibly a list or a document with multiple columns. The characters are sparse and difficult to decipher.]

PACIFIC GAS AND ELECTRIC COMPANY

PG&E +

P. O. BOX 7442 • 77 BEALE STREET, 31ST FLOOR, SAN FRANCISCO, CALIFORNIA 94106
TELEPHONE (415) 781-4211 TELECOPIER (415) 543-7813

MALCOLM H. FURBUSH
VICE PRESIDENT AND GENERAL COUNSEL

ROBERT OHLBACH
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN
PHILIP A. CRANE, JR.
HENRY J. LAPLANTE
JOHN B. GIBSON

ARTHUR L. HILLMAN, JR.
CHARLES W. THISSELL
DANIEL E. GIBSON
ASSISTANT GENERAL COUNSEL

January 16, 1981

GILBERT L. HARRICK
GLENN WEST, JR.
JOSEPH I. KELLY
HOWARD V. GOLUB
JAMES C. LOOSDON
ROBERT L. BORDON
PETER W. HANSEN
RICHARD F. LOCKE
DAVID L. LUDVIGSON

EDWARD J. MCGANNEY
DAN GRAYSON LUSBOCK
JACK F. FALLIN, JR.
BERNARD J. DELLABANTA
JOSHUA BARLEY
JOSEPH S. ENDLEAT, JR.
ROBERT L. HARRIS
DOUGLAS A. GOLESBY

SENIOR COUNSEL

DAVID W. ANDERSON
DIANA BERGMAN
LEISH B. CASSIDY
AUDREY DAINES
WILLIAM H. EDWARDS
DONALD D. ERICKSON
DAVID G. GILBERT
STEVEN F. GREENWALD
JUAN M. JAYO
F. RONALD LAUPHEIMER
HARRY W. LONG, JR.
A. KIRK MCKENZIE
RICHARD L. MEISS
ROGER J. PETERS
ROBERT R. RICKETT
SHIRLEY A. SANDERSON
JO ANN SHAFER
LOUIS C. VINCENT
SHIRLEY A. WOOD
KENNETH YANG

J. PETER BAUMGARTNER
STEVEN P. BURKE
PAMELA CHAPPELLE
MICHAEL G. DESMARAIS
GARY P. ENGINAS
JOHN N. FRYE
PATRICK B. GOLDEN
PAULA Y. HAYNES
RICHARD C. JONES
MEREK E. LIPSON
JOHN R. LOW
ROBERT D. MCLENNAN
RICHARD H. MOSS
J. MICHAEL REIDENBACH
IVOR E. SANDSON
SUE ANN LEVIN SCHIFF
JACK W. SHUCK
DAVID J. WILLIAMSON
BRUCE R. WORTHINGTON

ATTORNEYS

Mr. Frank J. Miraglia, Chief
Licensing Branch No. 3
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Docket No. 50-275
Docket No. 50-323
Diablo Canyon Units 1 and 2

Subject: Environmental Qualification of Class IE Control Cable
Manufactured by Continental Wire and Cable Co. for
Diablo Canyon Units 1 and 2

Dear Mr. Miraglia:

The attached information describes the thermal analysis which demonstrates the environmental qualification for Continental control cable installed at Diablo Canyon.

Kindly acknowledge receipt of the material listed above on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,

Philip A. Grant

Attachment
CC w/attachment: Service List

Boo!
S/||

18101210555

P

Environmental Qualification of Class 1E Control Cable

Manufactured by Continental Wire and Cable Co. for Diablo Canyon Units 1 and 2

1. Introduction

The cable has been qualified to a temperature of 281°F (see Continental Wire and Cable Company test report No. CC2193S, March 1971). However, as stated in our letter dated December 27, 1978, the main steam line break peak temperature is 344°F. The purpose of this analysis is to determine the transient temperature response of the cable exposed to the MSLB conditions depicted in Figures 8 and 9 of our December 27, 1978, letter and compare the resulting temperature history of the critical point of the cable to the qualification temperature of 281°F. If the critical point remains below 281°F, analysis indicates the cable has been tested sufficiently for the MSLB environment.

2. Worst-Case Configuration

Figure 1 shows the cable cross section including material layers and thicknesses. The outermost layer is a 3/4 inch galvanized steel conduit housing a single cable containing two copper conductors insulated as shown. This is the worst-case configuration for this type of electric cable - a larger conduit or a conduit with several cables has higher thermal resistance than the case shown. The critical point of the cable chosen for this study, is the outer surface of the conduit (Node 2 in Figure 2).

3. Thermal Analysis Model

To solve the two dimensional transient heat transfer relation

$$\text{i.e.} \quad \frac{d^2T}{dx^2} + \frac{d^2T}{dy^2} = \frac{1}{\alpha} \frac{dT}{dt}$$

where T = temperature


x = x dimension

y = y dimension

t = time

α = thermal diffusivity

for the temperature T(r, θ , t) of the system, a computer program (TRUMP written by A. Edwards of Lawrence Livermore Lab), using finite element numerical solution was employed. To model the cable system, a nodal representation was constructed (see Figure 2). As shown, the calculational model is composed of each of the material



3. Thermal Analysis Model (Continued)

layers were determined by making the thickness equivalent to the actual thickness, the depths (perpendicular to the plane of the page) all unity, the lengths equal to 2π x mean radius of each layer, thereby retaining the equivalent total volume, and, therefore, total heat capacity of Figure 1. Each layer is divided into homogeneous regions (nodes) with corresponding node centers, areas, volume and thermal connections. The volumes of the nodes were made roughly continuous (smoothly diminishing) so that the resulting calculational time step $= \rho C V / KA$ is stable; the numbers correspond to node centers except 1, 2, 3, 70, 71, 72 which are zero-volume nodes.

Assumptions made in making the calculational model are:

- a. The cylindrical sections may be modeled as rectangular sections.
- b. Air in conduit may be treated as perfect insulator.
- c. The critical heat path at Point A and Point B of Figure 1 crosses a finite surface area of 0.01375 sq. ft. and 0.00107 sq. ft. respectively. Beyond these areas the air and asbestos act as perfect insulators.
- d. Thermal properties of the materials (Figure 3) remain constant.
- e. Radiation effects are negligible.
- f. Heat generated by conductors is negligible.

Boundary Condition Considerations

During the initial period of a main steamline break, the temperature of the cable, initially at 120°F, is below the saturation temperature corresponding to the partial pressure of the entering steam. As a result, condensation occurs on the surface of the conduit until the surface temperature approaches T_{sat} , when the liquid film vaporizes and the cable is exposed to superheated vapor. This effect results in two temperature environments to which the cable is exposed: T saturation during the condensation period, and T containment during the convective period. The corresponding heat transfer coefficients are h condensation and h convection. This point is noted in a PGandE letter dated December 18, 1978. The condensation time was found to be approximately 10 seconds. A conservative value of 25 seconds was used in the analysis; at t_{cond} , the condensation heat transfer coefficient of 400 Btu/hr ft²°F drops to the convective coefficient of 16 Btu/hr ft²°F.




4. Results

Figure 4 gives the critical layer temperature vs. time. After 165 seconds, the maximum temperature is 263.3°F. After this time the layer temperature will decrease as the conduit surface cools to saturation temperature. A copy of the computer printout is shown in Figure 5.

The values of h convection and t condensation used in the analysis were chosen such that the critical layer temperature calculated is the upper bound temperature.

5. Conclusion

The Continental Cable, as installed in the containment of the Diablo Canyon Power Plant, meets all requirements for nuclear safety related (Class 1E) wires and cables.







FIGURE 1 - CABLE DIAGRAM
 (Not to scale)



FIGURE 2 - NODE COMPUTER CALCULATION MODEL



—— HEAT FLOW PATH WITH THERMAL RESISTANCE



Figure 3 Material Properties

Dimensions and material properties supplied by manufacturer

<u>Material</u>	<u>Density</u> <u>(lbm/ft.³)</u>	<u>Capacity</u> <u>(Btu/lbm^oF)</u>	<u>Conductivity</u> <u>(Btu/hr.ft.^oF)</u>
Steel	490.0	0.110	26.0
Silicon Rubber	77.5	0.341	0.18
Mylar	87.5	0.320	0.08
Aluminum	169.0	0.210	119.0
Fiber Glass	159.0	0.920	0.94



Figure 4

Critical Temperature Vs. Time

<u>Temp. Node 2 (°F)</u>	<u>Time (Sec.)</u>	<u>Hr.</u>
120.	0	
136.7	15	.00417
160.5	30	.00833
173.3	45	.0125
187.8	60	.01667
202.8	75	.0208
217.5	90	.0250
231.1	105	.0292
243.6	120	.0333
256.8	140	.03889
262.9	160	.0444
max. → 263.3	165	.0458
temp. 261.8	180	.0500
258.8	200	.0556
256.1	220	.0611



Figure 5

TRUMP OUTPUT DATA

DATA DECK 1


TRANSIENT TEMPERATURE RESPONSE OF CABLE TO MSLB TRIAL2-SLAB

PRINTOUT CYCLE MF HSS KNIT DELTMX SMALL TVARY DTEMP DTMAXS NUTS
 39 2833 74 13 0 0.10000D 13 0.88976D-06 0.10000D 00 0.26158D-01 0.99388D-01 2

65sec= TOTAL TIME TIME STEP HEAT FLOW TEMP FROM FLUX FLUX RATE TEMP RATE
 4.58370D-02 hr 1.14793D-05 1.92490D 01 1.44103D 02 4.19944D 02 3.14381D 03

AVG TEMP HEAT CAPACITY HEAT CONTENT GEN RATE HEAT GEN TEMP FROM GEN
 2.64108D 02 1.33578D-01 3.52790D 01 0.0 0.0 0.0

NODE	TEMP	DT	DDT	GEN RATE	H	H	F
1	0.26500 03	-0.18960-02	-0.16510 03	0.0	0.14280-19	0.78160-20	-0.70450-04
2	0.26330 03	0.74520-03	0.64860 02	0.0	0.14190-19	0.77230-20	-0.59500-05
3	0.26500 03	-0.18960-02	-0.16510 03	0.0	0.14280-19	0.78160-20	-0.70450-04
4	0.26500 03	-0.17510-02	-0.15240 03	0.0	0.77610 01	0.42460 01	0.42460 01
5	0.26330 03	0.89420-03	0.77830 02	0.0	0.91710 00	0.49910 00	0.49910 00
6	0.26500 03	-0.17510-02	-0.15240 03	0.0	0.77610 01	0.42460 01	0.42460 01
7	0.26500 03	-0.16450-02	-0.14320 03	0.0	0.38800 01	0.21230 01	0.21230 01
8	0.26320 03	0.11120-02	0.96830 02	0.0	0.45840 00	0.24940 00	0.24940 00
9	0.26500 03	-0.16450-02	-0.14320 03	0.0	0.38800 01	0.21230 01	0.21230 01
10	0.26500 03	-0.16100-02	-0.14010 03	0.0	0.38800 01	0.21230 01	0.21230 01
11	0.26310 03	0.12600-02	0.10970 03	0.0	0.45830 00	0.24930 00	0.24930 00
12	0.26500 03	-0.16100-02	-0.14010 03	0.0	0.38800 01	0.21230 01	0.21230 01
23	0.25660 03	0.12960-01	0.11280 04	0.0	0.12510 01	0.66580 00	0.66580 00
24	0.25570 03	0.14150-01	0.12310 04	0.0	0.41390 00	0.21970 00	0.21970 00
25	0.25410 03	0.16040-01	0.13960 04	0.0	0.20810 00	0.10980 00	0.10980 00
37	0.25400 03	0.16130-01	0.14040 04	0.0	0.40630-01	0.21430-01	0.21440-01
38	0.25390 03	0.16230-01	0.14130 04	0.0	0.40620-01	0.21420-01	0.21430-01
49	0.25390 03	0.16200-01	0.14100 04	0.0	0.25620-01	0.13510-01	0.13540-01
50	0.25380 03	0.16280-01	0.14170 04	0.0	0.38720-01	0.20420-01	0.20420-01
61	0.24160 03	0.26150-01	0.22770 04	0.0	0.12230 00	0.61520-01	0.61520-01
62	0.25130 03	0.18400-01	0.16020 04	0.0	0.19660-01	0.10270-01	0.10270-01
63	0.24160 03	0.26150-01	0.22770 04	0.0	0.12230 00	0.61520-01	0.61520-01
77	0.24160 03	0.26160-01	0.22770 04	0.0	0.39840-01	0.20050-01	0.20050-01
78	0.24500 03	0.23570-01	0.20510 04	0.0	0.40400-01	0.20610-01	0.20610-01
79	0.24160 03	0.26160-01	0.22770 04	0.0	0.39840-01	0.20050-01	0.20050-01
70	0.24160 03	0.26160-01	0.22770 04	0.0	0.58040-20	0.29210-20	0.16920-07
71	0.24500 03	0.23570-01	0.20510 04	0.0	0.58860-20	0.30030-20	0.16230-07
72	0.24160 03	0.26160-01	0.22770 04	0.0	0.58040-20	0.29210-20	0.16920-07






Figure 8 Containment Pressure Transient for 0.910 ft² Split Break at 70% Power with Minimum Safeguards (NRC Model)



f .




Figure 9. Containment Temperature Transient for 0.910 Ft² Split Break at 70% Power

8181300728