

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103300087 DOC. DATE: 81/03/12 NOTARIZED: NO DOCKET #  
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275  
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga 05000323  
 AUTH. NAME AUTHOR AFFILIATION  
 CRANE, P.A. Pacific Gas & Electric Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 MIRAGLIA, F.J. Licensing Branch 3

SUBJECT: Forwards addl info requested by NRC 800827 ltr re application for OL Submittal addresses: main feedwater & steam piping feedwater isolation valves FCV-441, FCV-44, penetration sleeves & flued head & equipment hatch. *cc rtd*

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 53  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence


NOTES: 1 cy: J Hanchett (Region V) 05000275  
 1 cy: J Hanchett (Region V) 05000323

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
ACTION:	A/D LICENSNG	1	0	MIRAGLIA, F.	1	0
	LEE, J.	1	0	BUCKLEY, B. 04	1	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 07	1	1
	CHEM ENG BR 08	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMERG PREP 22	1	0	EQUIP QUAL BR13	3	3
	GEOSCIENCES 14	1	1	HUM FACT ENG BR	1	1
	HYD/GEO BR 15	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	LIC GUID BR	1	1
	LIC QUAL BR	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDR 02	1	1	OELD	1	0
	OP LIC BR	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
	<u>REG FILE</u> 01	1	1	SIT ANAL BR 24	1	1
STRUCT ENG BR25	1	1	SYS INTERAC BR	1	1	
EXTERNAL:	ACRS 27	16	16	LPDR 03	1	1
	NSIC 05	1	1			

MAR 31 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 58 ENCL 52

58  
52



# PACIFIC GAS AND ELECTRIC COMPANY

PG&E +

P. O. BOX 7442 • 77 BEALE STREET, 31ST FLOOR, SAN FRANCISCO, CALIFORNIA 94106  
TELEPHONE (415) 781-4211 TELECOPIER (415) 543-7813

MALCOLM H. FURBUSH  
VICE PRESIDENT AND GENERAL COUNSEL

ROBERT OHLBACH  
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN  
PHILIP A. CRANE, JR.

HENRY J. L&PLANTE  
JOHN B. GIBSON

ARTHUR L. HILLMAN, JR.

CHARLES W. THISSELL

DANIEL E. GIBSON  
ASSISTANT GENERAL COUNSEL

March 12, 1981

GILBERT L. HARRICK  
GLENN WEST, JR.  
JOSEPH I. KELLY  
HOWARD V. GOLUB  
JAMES C. LOSBON  
ROBERT L. BORDON  
PETER W. HANSEN  
RICHARD F. LOCKE  
DAVID L. LUDVIGSON  
WILLIAM H. EDWARDS  
F. RONALD LAUPHEIMER  
ROBERT R. RICKETT  
DAVID J. WILLIAMSON  
BRUCE R. WORTHINGTON

EDWARD J. MCDANNEY  
DAN GRAYSON LUSBOCK  
JACK F. FALLIN, JR.  
BERNARD J. DELLABANTA  
JOSHUA BAR-LEV  
JOSEPH S. ENGLERT, JR.  
ROBERT L. HARRIS  
DOUGLAS A. GOLESBY  
J. PETER BAUMDARTNER  
JOHN N. FRYE  
J. MICHAEL REIDENBACH  
IVOR E. BAMBON  
SHIRLEY A. WOOD

SENIOR COUNSEL

DAVID W. ANDERSON  
DIANA BERHUSEN  
LEIGH S. CASSIDY  
AUDREY DAINES  
DONALD D. ERICKSON  
PATRICK D. GOLDEN  
PAULA Y. HAYNES  
RICHARD C. JONES  
HARRY W. LONG, JR.  
JOHN R. LOW  
ROBERT B. MCLENNAN  
RICHARD M. MOSS  
SHIRLEY A. SANDERSON  
JACK W. SHUCK  
KENNETH YANG

IATHAN T. ANNAND  
STEVEN F. BURKE  
PAMELA CHAPPELLE  
DARY P. ENDMAS  
DAVID C. GILBERT  
STEVEN F. GREENWALD  
JUAN M. JAYO  
MEREK E. LIPSON  
JESSICA LORING  
A. KIRK MCKENZIE  
RICHARD L. MEIBS  
ROGER J. PETERS  
JO ANN SHAFER  
LOUIS E. VINGENT

ATTORNEYS

Mr. Frank J. Miraglia, Jr., Chief  
Licensing Branch No. 3  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Re: Docket No. 50-275  
Docket No. 50-323  
Diablo Canyon Units 1 and 2



Dear Mr. Miraglia:

Enclosed is additional information in response to Items 1 and 2 of paragraph 6 of the enclosure to the letter dated August 27, 1980 from Mr. A. Schwencer. Attachment 1 is a list of the documentation enclosed. We believe this documentation to be complete and to satisfy the requirements addressed.

We have also reviewed the estimate of the lowest service metal temperature in relation to the definition given in the footnote to Section NE-2331 to the 1977 Edition of the ASME Boiler and Pressure Vessel Code.


The containment lowest service metal temperature for Diablo Canyon was determined from the following data:

1. Atmospheric ambient conditions are obtained from Appendix 2.3A of the FSAR, Page 78, Figure 1-15. The mean minimum ambient temperature is 48°F.
2. In accordance with Operating Procedure H-2, the containment is operated at below 120°F during normal operation. The average operating temperature is conservatively assumed for this purpose to be 100°F.

3001  
S  
1/40

The lowest service metal temperature occurs for materials on the containment boundary which are exposed to outside air temperature, such as the equipment hatch. In this case, the lowest service

A 810330087



Mr., Frank J. Miraglia, Jr.

2


March 12, 1981

metal temperature, calculated as the arithmetic mean of the inside and outside temperatures, is 74°F. This value can be used in determining compliance with the various components of 10 CFR 50, Appendix A, Criterion 51 - Fracture Prevention of Containment Pressure Boundary.

Two advance copies of this submittal have been sent by courier to Mr. Bart Buckley.

Kindly acknowledge receipt of the above material on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,

Philip A. Grane, J

Attachment

CC w/attachment: Service List  
Mr. Bart Buckley

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.


In the second section, the author outlines the various methods used to collect and analyze the data. This includes both manual and automated techniques. The goal is to ensure that the information gathered is both reliable and comprehensive.

The final part of the report provides a detailed analysis of the results. It shows that there is a clear trend in the data, which suggests that the current approach is effective. However, there are still some areas that need further investigation to optimize the process.

The data shows a significant increase in activity over the period studied. This is consistent with the expectations set at the beginning of the project.

1. Main Feedwater Piping

.8103300087



500146-2 (1 of 2)

03

# FORM P-4A MANUFACTURERS' DATA REPORT FOR FABRICATED PIPING

As Required by the Provisions of the ASME Code Rules

1. Manufactured by \*THE M.W. KELLOGG CO., PARAMOUNT, CALIF. Order No. 2542  
(Name and Address of Manufacturer)

2. Manufactured for PACIFIC GAS & ELECTRIC CO., SAN FRANCISCO, CALIF. Order No: 4R-8707  
(Name and Address)

DIABLO CANYON (NORTH OF AVILA BEACH, CALIFORNIA)

(Destination)

3. Identification Feedwater, Unit No. 1 Ser. No. 1315  
(Main Steam, Boiler Feed, Blow-off or other Service Piping - state which)

4. Design Conditions of Piping 1415 psi 450 °F. Specified by PACIFIC GAS & ELECTRIC CO.  
(Pressure) (Temperature) (Name of Co.)

Code Design by PACIFIC GAS & ELECTRIC CO.

5. The construction complies with the ASME BOILER AND PRESSURE VESSEL CODE Par. PW-41. Materials and workmanship conform to the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

6. Descriptions of Piping: (Include materials identifications by ASME specification or other recognized Code designation.)

1 - Piping Ass'y Pc. Mk. 1-K16-556-47 per MWK Dwg. No. F-110

Pipe: 16" Sch. 80 Seamless SA-106 Gr. B

8" Sch. 60 Seamless SA-106 Gr. B (For Support Attach.)

B.W.Ftgs: 16" Sch. 80 Seamless SA-106 Gr. B (ASTM A234 Gr. WPB)

Weldolets: 3" Sch. 80 SA-105 Gr. II

Cplgs: 1" 3000# Socketweld SA-105 Gr. II

Plugs: 1" Scr'd SA-105 Gr. II

Plate: A-516 Gr. 70 (For Support Attachment)

All Pressure Retaining Materials Charpy Impact Tested

100% RT All Girth Butt welds; 100% MT All Welds Stress Relieved

Shop Hydrostatic Test NONE psi.

Certificate of Authorization No. 10409 to use the Pressure Piping Symbol expires 2-4-73

We certify the statements in this data report to be correct.

Date February 23, 1972 \*THE M.W. KELLOGG COMPANY By [Signature]  
(Fabricator) (Representative)

## CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA

and employed by DIVISION OF INDUSTRIAL SAFETY - of STATE OF CALIFORNIA

have inspected the piping described in this manufacturer's data report on Feb. 8 1972 and state that to the best of my knowledge and belief, the manufacturer has constructed this piping in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection

Date March 6 1972

[Signature] Inspector Commissions CALIF. NO. 857  
Nat'l Board, State, Province and No.

\*A Division of Pullman Incorporated

2-13



*p*



500146-2 (2122)

Form P-4A (Back)

8. Description of Field Fabrication:

WELDON EX-RAY PLUG, SA 105, GR II; WELD # 239C 3-7-75  
WELD ONE 3000<sup>th</sup> S.W. SOCKOLET, SA 105, GR II, WELD # 239D 3-7-75

9. Field Hydrostatic Test 1356 psi.

Certificate of Authorization No. 10372 to use the Pressure Piping Symbol expires 12/10/75

We certify the statements in this data report to be correct.

Date 9/15/75 \*THE M.W. KELLOGG CO. (Fabricator) By [Signature] (Representative)

10. We certify that the field assembly of the described piping conforms with the requirements of SECTION 1 of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 3/16, 1975 Signed \*THE M.W. KELLOGG CO. (Assembler) By [Signature] (Representative)

Our Certificate of Authorization No. 10372 to use the PP Symbol Expires 12/10 1975  
(A) (S) or (PP)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA have compared the statements in this manufacturer's data report with the described piping and state that the parts referred to as data items [?], not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or assembler has constructed and assembled this piping in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described piping was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date \_\_\_\_\_  
[Signature] Inspector Commissions CALIF. NO. 7716  
Nat'l Board, State, Province and No.



PHOENIX STEEL CORPORATION

TUBE DIVISION  
PHOENIXVILLE, PENNA.

*F110*

**67**

CERTIFICATE OF INSPECTION AND TESTS

8/26/70	DATE SHIPPED: 8/25/70	MILL ORDER NO. T-8371-A2-(105A)
S O L D T O	Standard Pipe & Supply Co., Inc. 301 City Line Avenue Bala Cynwyd, Pennsylvania 19004	CUSTOMER ORDER NO. 2604-D
		CAR NO. PC 577229
		SPECIFICATION: SA 106 B (O.H.)
S H I P T O	M. W. Kellogg Company #8504-4 <i>It #35 2/905</i>	MATERIAL: SEAMLESS TUBE
		CONTRACT NO. <del>P.O. # 8504-4</del> M. W. KELLOGG SPEC. NO. <del>N 9504 ES 3</del>

NO. PCS.	OD	WALL	LENGTH	TOTAL FT.	TOTAL WT.	HEAT NO.
	16.000"	x .844"				40148
Longitudinal Vee Notch Charpy at minus 0 F 22-21-20 Ft. Lbs.						
S-2 Check Analysis- one test per lot						
S-3 Transverse Tension- one test per lot						
S-4 Flattening Test- one test per lot- OK						
S-5 Etch Test- one test per lot- OK						
S-6 Etch Test- one test per lot- OK						


HEAT NO.	C.	Mn.	P.	S.	SL.	CR.	NI.	Mo.	CU
40148	.23	.86	.011	.026	.23	Ladle			
40148	.24	.86	.011	.027	.23	Check			

HEAT NO.	TENSILE		YIELD		% ELONG.		HARDNESS		GRAIN SIZE
	(KSI)	(KSI)	(KSI)	(KSI)	IN 2"	% RA	ROCKWELL	BRINELL	
40148	74.0	47.5	47.5	47.5	35.00	Norm. @ 1650 F	Temp. @ 1250 F	Long.	
40148	71.5	47.3	47.3	47.3	32.00	"	"	Trans.	

FLANGE	FLATTENING	OK	FLARING	CRUSH	HYDROSTATIC PSI	2225
JOMINY DISTANCE - 16TH. 1 2 4 6 8 10 12 14 16 20 24 28 32						

THE PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY'S REPORTS ARE AS SHOWN ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTING OR TESTING ARE PRESCRIBED IN THE APPLICABLE SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. BASED UPON SUCH INSPECTION AND TESTS, THE ABOVE MATERIALS HAVE BEEN APPROVED AS FULFILLING THE REQUIREMENTS OF SAID SPECIFICATIONS.

1&T-0153-R2 *AWP* *220* A. W. Peckham  
ENGINEER OF TESTS



METALLURGICAL DEPARTMENT

The M.W. Kellogg Company - Power Piping Division

PURCHASER \_\_\_\_\_

CUDAHY, WIS., August 19 19 70

PURCHASER'S ORDER NO. 88504-9

LSO NO. E 80627A

ADDRESS P.O. Box 881 River Road - Williamsport, Pa. 17704

INVOICE NO. N 29148


NO. PCS.	DESCRIPTION AND SPECIFICATION	HEAT NO. AND CODE	CHEMICAL COMPOSITION								PHYSICAL PROPERTIES				
			C	MN	P	S	SI	NI	CR	MO	YIELD STRENGTH LB. PER SQ. IN.	ULTIMATE STRENGTH LB. PER SQ. IN.	ELONG. %	RED. OF AREA	
Item 9	26" ID x 1.002 HW 90° IR ELR-5 A234-WPB 88504-MS-5	86A24 86A24	.21	.68	.016	.022	.21					46600	73200	31.0	58
			.26	.92	.017	.03	.21					48000	77500	28.0	51
	Item 30 26" ID x 0.871 HW 90° 8/60 Rec. Rad. A234-WPB 88504-MS-5 Weld Nos. 242, 243	61A256 61A256	.22	1.06	.016	.024	.21					48000	77500	28.0	51
	Item 37 16" B/80 30" IR ELR-5 A234-WPB 88504-MS-5	200353 200353	.20	.89	.013	.014	.22					42100	70200	34.0	66
			.19	.83	.011	.019	.20					42100	70200	34.0	66

SUBSCRIBED AND SWORN TO BEFORE ME THIS \_\_\_\_\_ DAY OF \_\_\_\_\_ 19 \_\_\_\_\_

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.  
Page 1 of 2

NOTARY PUBLIC  
MY COMMISSION EXPIRES \_\_\_\_\_  
LCO 1016 R1

\_\_\_\_\_  
METALLURGIST





# H. K. PORTER COMPANY, INC.

FABRICATED METALS DIVISION

P.O. BOX 95, ROUELLE, NEW JERSEY 07203



W-S FITTINGS WORKS  
AREA CODE 201  
TEL. 241-1600



ADDRESS MILL  
5 MILL WENT  
CHECK CHECK

CUSTOMER M. W. Kellogg

DATE 1/22/71 Rev. 2/16/71

CUSTOMER'S ORDER NO. N-8504-11

OUR NO. 1-65033

MATERIAL/SPECIFICATION .CS / ASTM Spec A-105 Gr. 2

DATE SHIPPED 12/8/70

DESCRIPTION			CHEMICAL ANALYSIS								PHYSICAL PROPERTIES (MIN.)				
ITEM NO.	DESCRIPTION	QUAN.	C.	Mn.	P.	S.	SI.	NL.	Chr.	Moly.	HEAT CODE NO.	TENSILE STRENGTH P.S.I.	YIELD POINT P.S.I.	% ELONGATION IN 2"	% RED. IN AREA
1	2" Half Coupling 3000 S/W <i>CHECK</i> Item 74	12	.30	.80	.009	.011	.23				FB-7	76,300	38,600	37	46
			.30	.74	.014	.030	.21				HT. NO. 5	614340	REPUBLIC STEEL		
2	1" ditto <i>CHECK</i> Item 75	180	.30	.70	.008	.014	.22				1A-9	79,100	45,800	28	37
			.30	.68	.010	.022	.24				HT. NO. 655X564	BETHLEHEM STEEL			
3	3/4" ditto <i>ITEM 76 CHECK</i>	40	.28	.73	.010	.010	.18				PA-8	72,800	39,600	46	52
			.27	.76	.015	.019	.23				HT. NO. 077699	U.S. STEEL			
	Heat Treatment														
	Material has been normalized at 1700-1750°F. held for one (1) hour per inch of thickness, followed by cooling in still air.														
	Sworn and subscribed to before me this 16th day of February, 1971														
	<i>Charles L. [Signature]</i>														


NOTARY PUBLIC OF NEW JERSEY  
My Commission Expires Mar. 24, 1971

I hereby certify that the above analysis is correct to the best of my knowledge and belief.

H. K. PORTER COMPANY, INC.

W-S FITTINGS WORKS

*[Signature]*



500146-3 (1 of 2)

# FORM P-4A MANUFACTURERS' DATA REPORT FOR FABRICATED PIPING

As Required by the Provisions of the ASME Code Rules

1. Manufactured by \*THE M.W. KELLOGG CO., PARAMOUNT, CALIF. Order No. 2542  
(Name and Address of Manufacturer)

2. Manufactured for PACIFIC GAS & ELECTRIC CO., SAN FRANCISCO, CALIF. Order No. 4R-8707  
(Name and Address)

DIABLO CANYON (NORTH OF AVILA BEACH, CALIFORNIA)  
(Destination)

3. Identification Feedwater, Unit No. 1, Ser. No: 1316  
(Main Steam, Boiler Feed, Blow-off or other Service Piping - state which)

4. Design Conditions of Piping 1415 psi 450 °F. Specified by PACIFIC GAS & ELECTRIC CO.  
(Pressure) (Temperature) (Name of Co.)

Code Design by PACIFIC GAS & ELECTRIC CO.

5. The construction complies with the ASME BOILER AND PRESSURE VESSEL CODE Par. PW-41. Materials and workmanship conform to the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

6. Descriptions of Piping: (Include materials identifications by ASME specification or other recognized Code designation.)

1 - Piping Ass'y Pc. Mk. 1-K16-556-48 per MWK Dwg. No. F-111  
Pipe: 16" Sch. 80 Seamless SA-106 Gr. B  
Flued Head: 26" X 16" SA-105 Gr. II (Furnished by Customer)  
Plugs: 1" Scr'd SA-105 Gr. II  
All Pressure Retaining Materials Charpy Impact Tested  
100% RT Girth Buttweld  
100% MT All Welds  
Stress Relieved

*Pen. 11.4.*

7. Shop Hydrostatic Test NONE psi.

Certificate of Authorization No. 10409 to use the Pressure Piping Symbol expires 2-4-73

We certify the statements in this data report to be correct.

Date Sept. 12, 1972 \*THE M.W. KELLOGG COMPANY By [Signature]  
(Fabricator) (Representative)

## CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA

and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA

have inspected the piping described in this manufacturer's data report on 19 72 and state that to the best of my knowledge and belief, the manufacturer has constructed this piping in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection

Date 9-13-1972

[Signature] Commissions CALIF. NO. 857  
Inspector Nat'l Board, State, Province and No.

\*A Division of Pullman Incorporated



590146-3 (2 of 2)

Form P-4A (Back)

8. Description of Field Fabrication:

WELD ONE X-RAY PLUG, SA105, GR II, WELD # ~~336~~ 336 Job 3-7-75

9. Field Hydrostatic Test 1350 psi.

Certificate of Authorization No. 10372 to use the Pressure Piping Symbol expires 12/10/75

We certify the statements in this data report to be correct.

Date 9/15/75 \*THE M.W. KELLOGG CO. By [Signature]  
(Fabricator) (Representative)

10. We certify that the field assembly of the described piping conforms with the requirements of SECTION 1 of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 3/19, 1975 Signed \*THE M.W. KELLOGG CO. By [Signature]  
(Assembler) (Representative)

Our Certificate of Authorization No. 10372 to use the PP Symbol Expires 12/10 19 75  
(A) (S) or (PP)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA have compared the statements in this manufacturer's data report with the described piping and state that the parts referred to as data items \_\_\_\_\_, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or assembler has constructed and assembled this piping in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described piping was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 3-19-75  
[Signature] Inspector Commissions CALIF. NO. 776  
Nat'l Board, State, Province and No.



PHOENIX STEEL CORPORATION

TUBE DIVISION  
PHOENIXVILLE, PENNA.

F 111

67

CERTIFICATE OF INSPECTION AND TESTS

8/26/70	DATE SHIPPED: 8/25/70	MILL ORDER NO. T-8371-A2-(105A)
S O L D T O	Standard Pipe & Supply Co., Inc. 301 City Line Avenue Bala Cynwyd, Pennsylvania 19004	CUSTOMER ORDER NO. 2604-D
		CAR NO. PC 577229
		SPECIFICATION: SA 106 B (O.H.)
S H I P T O	M. W. Kellogg Company #8504-4 <i>Ita = 35 11/905</i>	MATERIAL: SEAMLESS TUBE
		CONTRACT NO. <del>F.O. # 8504-3-105E-35</del> M. W. KELLOGG SPEC. NO. # 8504-ES-3

NO. PCS.	OD	WALL	LENGTH	TOTAL FT.	TOTAL WT.	HEAT NO.
	16.000"	x .844"				40148
Longitudinal Vee Notch Charpy at minus 0 F 22-21-20 Ft. Lbs.						
S-2 Check Analysis- one test per lot						
S-3 Transverse Tension- one test per lot						
S-4 Flattening Test- one test per lot- OK						
S-5 Etch Test- one test per lot- OK						
S-6 Etch Test- one test per lot- OK						

HEAT NO.	C.	Mn.	P.	S.	SL.	CR.	Ni.	Mo.	Cu.
40148	.23	.86	.011	.026	.23	Ladle			
40148	.24	.86	.011	.027	.23	Check			

HEAT NO.	TENSILE	YIELD	% ELONG.	% RA	HARDNESS		GRAIN
	(KSI)	(KSI)	IN 2"		ROCKWELL	BRINELL	
40148	74.0	47.5	35.00 Norm.	@ 1650 F	Temp.	@ 1250 F	Long.
40148	71.5	47.3	32.00 "	"	"	"	Trans.

FLANGE FLATTENING OK FLARING CRUSH HYDROSTATIC PSI 2225  
JOMINY DISTANCE - 16TH. 1 2 4 6 8 10 12 14 16 20 24 28 32

THE PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY'S REPORTS ARE AS SHOWN ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTION OR TESTING ARE PRESCRIBED BY THE APPLICABLE SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. BASED UPON SUCH INSPECTION AND TESTS, THE ABOVE MATERIALS HAVE BEEN APPROVED AS FULFILLING THE REQUIREMENTS OF SAID SPECIFICATIONS.

1&T-0153-R2 *ok* 2-43 A. W. Pecher  
ENGINEER OF TESTS



2. Main Steam Piping



# MODIFIED MANUFACTURERS' DATA REPORT FOR FABRICATED PIPING

As Required by Purchaser's Specification

1. Manufactured by \*THE M.W. KELLOGG CO., PARAMOUNT, CALIF. Order No. 2542  
(Name and Address of Manufacturer)

2. Manufactured for PACIFIC GAS & ELECTRIC CO., SAN FRANCISCO, CALIF. Order No. 4R- 8707  
(Name and Address)

DIABLO CANYON (NORTH OF AVILA BEACH, CALIFORNIA)  
(Destination)

3. Identification Main Steam, Unit No. 1, Ser. No. F-148C  
(Main Steam, Boiler Feed, Blow-off or other Service Piping - state which)

4. Design Conditions of Piping 1085 psi 600 °F. Specified by PACIFIC GAS & ELECTRIC CO.  
(Pressure) (Temperature) (Name of Co.)

Code Design by PACIFIC GAS & ELECTRIC CO.

5. The construction materials and workmanship complies with Pacific Gas & Electric Co. specification 8707.

6. Description of Piping: (Include materials identifications by ASME specifications or other recognized Code designation.) Note: Piping had been rolled from SA-516 GR. 70 plate and welded by a Fabricator in possession of the "PP" stamp only.

1 - Piping Ass'y Pc. Mk. 1-K15-225-84C per MWK Dwg. No. F-148C  
Pipe: 26" I.D. X 1.002" Min. Wall Welded SA-516 Gr. 70  
Flued Head: 40" X 28" SA-105 Gr. 11 (Furnished by Customer)  
Plug: 1" Scr'd SA-105 Gr. 11  
Pipe & Flued Head Charpy Impact Tested  
100% RT All Girth & Long. Welds  
100% MT All Welds  
Stress Relieved

7. Shop Hydrostatic Test NONE psi.

We certify the statements in this data report to be correct.

Date June 16, 1972 \*THE M.W. KELLOGG COMPANY By H. G. [Signature]  
(Fabricator) (Representative)

## CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA

and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA

have inspected the piping described in this manufacturer's data report on 19 72 and state that to the best of my knowledge and belief, the manufacturer has constructed this piping in accordance with the applicable sections of Pacific Gas & Electric Co. specification 8707.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection

Date 9-13-1972

[Signature] Inspector Commissions CALIF. NO. 857  
(State and No.)

\*A Division of Pullman Incorporated



**LADY CO.**  
 Metallurgical Analysis Report  
**METALLURGICAL DEPARTMENT**

PURCHASER The M.W. Kellogg Company - Power Piping Division

CUDAHY, WIS., September 14 19 70

PURCHASER'S ORDER NO. N 8504-1

LSO NO. E 80696H

ADDRESS P.O. Box 881 Reach Road-Williamsport, Pa.

INVOICE NO. N28557

rb

NO. PCS.	DESCRIPTION AND SPECIFICATION	HEAT NO. AND CODE	CHEMICAL COMPOSITION								PHYSICAL PROPERTIES						
			C	MN	P	S	SI	NI	CR	MO	YIELD STRENGTH LB. PER SQ. IN.	ULTIMATE STRENGTH LB. PER SQ. IN.	ELONG. %	RED. OF AREA			
Item 1	26" ID x 1.002 MW Rolled and welded Carbon Steel Pipe  A155- KCF- 70 and Kellogg Spec. N8504 ES-1  Weld No. <u>J88-1</u>  Pipe manufactured from A516 Gr. 70 Plate	63L 106 CUMAC															
			LADLE ANALYSIS								PARENT METAL						
			.24	1.05	.003	.020	.19					42100	74700	22.5			
			CHECK ANALYSIS								CENTER WELD						
			.26	1.04	.003	.013	.19						70300				
		42024151	ANALYSIS OF WELD WIRE														
			.11	1.94	.01	.02	.05										
			Transverse Hardness Survey								163-170 HB						

SUBSCRIBED AND SWORN TO BEFORE ME THIS

14th DAY OF September 19 70

Rose Newbroski  
 NOTARY PUBLIC

October 18, 1970

MY COMMISSION EXPIRES

LCO 1016 R1

Page 1 of 2

*[Handwritten initials]*  
 11/19

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

James P. King  
 METALLURGIST

*[Handwritten initials]*

S-I



8. Description of Field Fabrication:

ADD WELDED X-RAY PLUG, SA 105, GR II, WELD # 342A

3-7-75

9. Field Hydrostatic Test SEE MN-5 psi.

We certify the statements in this data report to be correct.

Date 9/24/75 \*THE M.W. KELLOGG CO. By [Signature]  
(Fabricator) (Representative)

10. We certify that the field assembly of the described piping conforms with the requirements of Pacific Gas and Electric Co. specification 8711.

Date 3/14, 19 75 Signed \*THE M.W. KELLOGG CO. By [Signature]  
(Assembler) (Representative)

Our Certificate of Authorization No. 10372 to use the PP Symbol Expires 12/10 19 75  
(A) (S) or (PP)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA have compared the statements in this manufacturer's data report with the described piping and state that the parts referred to as data items 8, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or assembler has constructed and assembled this piping in accordance with the applicable sections of Pacific Gas & Electric Co. Spec. 8711. The described piping was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10/13/75  
[Signature] Commissions CALIF. NO. 1275  
Inspector (State and No.)

\*A Division of Pullman Incorporated







# MODIFIED MANUFACTURERS' DATA REPORT FOR FABRICATED PIPING

As Required by Purchaser's Specification

1. Manufactured by \*THE M.W. KELLOGG CO., PARAMOUNT, CALIF. Order No. 2542  
(Name and Address of Manufacturer)

2. Manufactured for PACIFIC GAS & ELECTRIC CO., SAN FRANCISCO, CALIF. Order No. 4R-8707  
(Name and Address)

DIABLO CANYON (NORTH OF AVILA BEACH, CALIFORNIA)

(Destination)

3. Identification Main Steam, Unit No. 1, Ser. No. F-148A  
(Main Steam, Boiler Feed, Blow-off or other Service Piping - state which)

4. Design Conditions of Piping 1085 psi 600 °F. Specified by PACIFIC GAS & ELECTRIC CO.  
(Pressure) (Temperature) (Name of Co.)

Code Design by PACIFIC GAS & ELECTRIC CO.

5. The construction materials and workmanship complies with Pacific Gas & Electric Co. specification 8707.

6. Description of Piping: (Include materials identifications by ASME specifications or other recognized Code designation.) Note: Piping had been rolled from SA-516 GR. 70 plate and welded by a Fabricator in possession of the "PP" stamp only.

1 - Piping Ass'y Pc. Mk. 1-K15-225-84A per MWK Dwg. No. F-148A

Pipe: 26" I.D. X 1.002" Min. Wall Welded SA-516 Gr. 70 (Charpy Impact Tested)

Cplgs: 3/4" 3000# Socketweld SA-105 Gr. 11

Plug: 1" Scr'd SA-105 Gr. 11

100% RT All Long Welds (No Girth)

100% MT All Welds

Stress Relieved

Shop Hydrostatic Test NONE psi.

We certify the statements in this data report to be correct.

Date June 16, 1972 \*THE M.W. KELLOGG COMPANY By H. G. Luerto  
(Fabricator) (Representative)

## CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA

and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA

have inspected the piping described in this manufacturer's data report on 9-8-1972 and state that to the best of my knowledge and belief, the manufacturer has constructed this piping in accordance with the applicable sections of Pacific Gas & Electric Co. specification 8707.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection

Date 9-8-1972

J. E. Warren Commissions CALIF. NO. 857  
Inspector (State and No.)

A Division of Pullman Incorporated

REF: Dwg. 500139, Rev. 3



500:39-5 (2 of 2)

8. Description of Field Fabrication:

WELD X-RAY PLUG, SA 105 GRADE, WELD # 341A 3-7-75

9. Field Hydrostatic Test SEE MN-5 psi.

We certify the statements in this data report to be correct.

Date 9/24/75 \*THE M.W. KELLOGG CO. By [Signature]  
(Fabricator) (Representative)

10. We certify that the field assembly of the described piping conforms with the requirements of Pacific Gas and Electric Co. specification 8711.

Date 3/16, 1975 Signed \*THE M.W. KELLOGG CO. By [Signature]  
(Assembler) (Representative)

Our Certificate of Authorization No. 10372 to use the PP Symbol Expires 12/10 1975  
(A), (S) or (PP)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of CALIFORNIA and employed by ~~X~~ DIVISION OF INDUSTRIAL SAFETY of ~~STATE OF CALIFORNIA~~ have compared the statements in this manufacturer's data report with the described piping and state that the parts referred to as data items 8, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or assembler has constructed and assembled this piping in accordance with the applicable sections of Pacific Gas & Electric Co. Spec. 8711. The described piping was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10/13/75 [Signature] Commissions CALIF. NO. 1275  
Inspector (State and No.)

\*A Division of Puliman Incorporated



MADISON DISH CO.  
Metallurgical Analysis Report  
METALLURGICAL DEPARTMENT

PURCHASER The M.W. Kellogg Company - Power Piping Division

CUDAHY, WIS., September 14 19 70

PURCHASER'S ORDER NO. N8504-1

LSO NO. E80696H

ADDRESS P.O. Box 881 Reach Road - Williamsport, Pa.

INVOICE NO. N28557

rd

NO. PCS.	DESCRIPTION AND SPECIFICATION	HEAT NO. AND CODE	CHEMICAL COMPOSITION								PHYSICAL PROPERTIES						
			C	MN	P	S	SI	NI	CR	MO	YIELD STRENGTH LB. PER SQ. IN.	ULTIMATE STRENGTH LB. PER SQ. IN.	ELONG. %	RED. OF AREA			
Item 1	26" ID x 1.002 MW Rolled and Welded Carbon Steel Pipe	63L 106															
	A155-KCF-70 and Kellogg Spec. N8504 ES-1	63MAA	.24	1.05	.000	.020	.19										
	Weld No. J86	40224151	.26	1.04	.008	.018	.19										
	Pipe manufactured from A516 Gr. 70 Plate		.14	1.94	.011	.021	.05										
			LADLE ANALYSIS								PARENT METAL						
			CHECK ANALYSIS								CENTER WELD						
			ANALYSIS OF WELD WIRE														
			Transverse Hardness Survey - 163-170 BIN														

SUBSCRIBED AND SWORN TO BEFORE ME THIS

14th DAY OF September 19 70

*Pro. Benkowski*  
NOTARY PUBLIC

October 18, 1970

MY COMMISSION EXPIRES \_\_\_\_\_

Page 1 of 2

~~10/7~~  
11/19/70

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

*James P. Gigg*  
METALLURGIST

00  
S-I



# MODIFIED MANUFACTURERS' DATA REPORT FOR FABRICATED PIPING

As Required by Purchaser's Specification

1. Manufactured by THE M.W. KELLOGG CO., PARAMOUNT, CALIF. Order No. 2542  
(Name and Address of Manufacturer)

2. Manufactured for PACIFIC GAS & ELECTRIC CO., SAN FRANCISCO, CALIF. Order No. 4R- 8707  
(Name and Address)

DIABLO CANYON (NORTH OF AVILA BEACH, CALIFORNIA)  
(Destination)

3. Identification Main Steam, Unit No. 1, Ser. No. F-148B  
(Main Steam, Boiler Feed, Blow-off or other Service Piping - state which)

4. Design Conditions of Piping 1085 psi 600 °F. Specified by PACIFIC GAS & ELECTRIC CO.  
(Pressure) (Temperature) (Name of Co.)

Code Design by PACIFIC GAS & ELECTRIC CO.

5. The construction materials and workmanship complies with Pacific Gas & Electric Co. specification 8707.

6. Description of Piping: (Include materials identifications by ASME specifications or other recognized Code designation.) Note: Piping had been rolled from SA-516 GR. 70 plate and welded by a Fabricator in possession of the "PP" stamp only.

1 - Piping Ass'y Pc. Mk. 1-K15-225-84B per MWK Dwg. No. F-148B

Pipe: 26" I.D. X 1.002" Min. Wall Welded SA-516 Gr. 70  
4" XXHY Smls SA-106 Gr. B (For Support Attachment)

B.W.Ftgs: 26" I.D. X 1.002" Min. Wall, 24" Sch. 60 Welded SA-516 Gr. 70 (ASTM A234)  
26" I.D. X 1.002" Min. Wall Smls SA-106 Gr. C (ASTM A234 Gr. WPC)

Plugs: 1" Scr'd SA-105 Gr. 11  
Plates: A-516 Gr. 70 (For Support Attachment)

All Pressure Retaining Materials Charpy Impact Tested  
100% RT All Girth & Long. Welds; 100% MT All Welds  
Stress Relieved

7. Shop Hydrostatic Test NONE psi.

We certify the statements in this data report to be correct.

Date June 16, 1972 \*THE M.W. KELLOGG COMPANY .By H. G. La Jerte  
(Fabricator) (Representative)

## CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA

and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA

have inspected the piping described in this manufacturer's data report on 9-8-1972 and state that to the best of my knowledge and belief, the manufacturer has constructed this piping in accordance with the applicable sections of Pacific Gas & Electric Co. specification 8707.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection

Date 9-8-1972

Je Warren Commissions CALIF. NO. 859  
Inspector (State and No.)

\*A Division of Pullman Incorporated



8. Description of Field Fabrication:

WELD X-RAY PLUG, SA105, GR11, WELD# 338A	3-7-75
ADD PIPE SUPPORT SA116 GR70, WELD# X1686	3-11-75

9. Field Hydrostatic Test SEE MN-5 psi.

We certify the statements in this data report to be correct.

Date 9/24/75 \*THE M.W. KELLOGG CO. By [Signature]  
(Fabricator) (Representative)

10. We certify that the field assembly of the described piping conforms with the requirements of Pacific Gas and Electric Co. specification 8711.

Date 3/16, 1975 Signed \*THE M.W. KELLOGG CO. By [Signature]  
(Assembler) (Representative)

Our Certificate of Authorization No. 10372 to use the PP Symbol Expires 12/10 1975  
(A) (S) or (PP)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CALIFORNIA and employed by DIVISION OF INDUSTRIAL SAFETY of STATE OF CALIFORNIA have compared the statements in this manufacturer's data report with the described piping and state that the parts referred to as data items 4, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or assembler has constructed and assembled this piping in accordance with the applicable sections of Pacific Gas & Electric Co. Spec. 8711. The described piping was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10/13/75 Commissions CALIF. NO. 1275  
[Signature] Inspector (State and No.)


\*A Division of Pullman Incorporated



ITEM	QTY	DESCRIPTION	SPEC.	SOURCE	MARE NO. 1-K15-225-84B	N8504	F-148B	0
		CARB. STL ASS'Y <td></td> <td></td> <td>SYSTEM LEAD MAIN STEAM <td>JOB NO. <td>SHEET NO. <td>REV. </td></td></td></td>			SYSTEM LEAD MAIN STEAM <td>JOB NO. <td>SHEET NO. <td>REV. </td></td></td>	JOB NO. <td>SHEET NO. <td>REV. </td></td>	SHEET NO. <td>REV. </td>	REV.
1	1	26" I.D. x 1.002" WELDED PIPE EE = 2' 10 1/16"	SA 516 GR 70 A	F-151-43 17-26	REF. DWG. 500139 REV. 3			
		MK N# MI-1-3 LGTH = 3' 6"	MT. 228215	DH44	STRESS 423 °F	HYDRO-TEST	RADIO-GRAPH	MAGNA-FLUX
2	1	26" I.D. x 1.002" LR 79°-4' ELL ENDS BEVELED PER PFI-ES-21 FIG. 3	A234 WP 4	RO-2 17-10	HEAT °F/HR	HEAT °F/HR	ALL BUTT WELDS	ALL WELDS
3	1	26" I.D. (1.002") x 26" I.D. (1.002") x 24" O.D. 5/60 RED. TEE (USE TEE MK'D "A") ENDS BEVELED PER PFI-ES-21 FIG. 3	N8504 ES-5	WT 864742	HOLD. HRS	HOLD. HRS	INSP. CODE	EST. WT. 2675
			SA 516 GR 70 A	RO-2 17-10	FURNACE COOL	COOL	CUST/AUTH	ASME SECT. I
			N8504 ES-5	WT 991111	MIN. PREHEAT		BEVEL ENDS	CLEAN
					K-123		SK #1	ES-1 JPI01
4	1	1" DIA. x 1.002" Lg RADICG. PLUG PER SK #2, IT. 1	SA-105	RO-12 17-79				
5	1	CODE NAME R	85-70-851	WT 310125				
6	1	1/8" THK x 2 1/2" WIDE NAME R BAND	208B. STL					
7	2	26" I.D. x 1/8" W. x 5/32" THK SPLIT K-INSERT	AS-18	RO-7741 244-2711				
8	1	4" X 4" SMLS PIPE, EE = 2' 0" (MT. L22313)	A100 GR B	RO-2542-24				
9	1	1" THK x 1 1/2" x 1 1/2" R (MT. 228215)	AS-18	RO-2542-43				
10	1	5/8" THK x 4 1/4" x 3' 0" SHAPED R (MT. D20165)	AS-18	RO-2542-43				
11	2	5/8" THK x 6 1/2" x 3' 6" SHAPED R (MT. D20165)	AS-18	RO-2542-43				
12	2	5/8" THK x 6 1/2" x 3' 0" SHAPED R (MT. D20165)	AS-18	RO-2542-43				
13	1	5/8" THK x 4 1/4" x 2' 0" SHAPED R (MT. D20165)	AS-18	RO-2542-43				

-NOTES-

- 1- PROTECT FIELD END PREPS. WITH DEOXY ALUMINITE
- 2- PAINT RED OXIDE PRIMER
- 3- QUALITY ASSURANCE REQUIRED
- 4- ALL SHOP BUTT WELDS TO BE K-INSERT WELDS
- 5- PAINT STENCIL ON PIPE O.D. "P.G.F. DESIGN CODE CLASS B"



FOR DETAIL SEE SK #27

AND ATTACH TO BAND #6

F-148B  
D85, 600  
72

COMIT. STAMP

WELD PROC

(A) PI-KI-F6-SAW-29-1G

(C) DEE }  
(G) HUK } PI-SV-F4-SMAW-7-5G

REV.				DATE				BY				DESCRIPTION			
												28" PIPE ASSEMBLY			
												DRAWN: JLS CHK'D: JLS APP'D: JLS			
												THE H. W. KELLORS COMPANY POWER PIPING DIVISION			



D I C H C O  
Metallurgical Analysis Report

METALLURGICAL DEPARTMENT

PURCHASER The M.W. Kellogg Company - Power Piping Division

CUDAHY, WIS., March 25 19 71

PURCHASER'S ORDER NO. N8504-1

LSO NO. E80696H

ADDRESS P.O. Box 881 Reach Road - Williamsport, Pa. 17704

INVOICE NO. W39848

NO. PCS.	DESCRIPTION AND SPECIFICATION	HEAT NO. AND CODE	CHEMICAL COMPOSITION								PHYSICAL PROPERTIES				
			C	MN	P	S	SI	NI	CR	MO	YIELD STRENGTH KSI	ULTIMATE STRENGTH KSI	ELONG. %	RED. OF AREA	
Item 1	26" I.D. x 1.002 MW Rolled and Welded Carbon Steel Pipe	EO 8660 DEWIT	.26	1.00	.013	.022	.20					46.8	78.7	25.5	
	A155-KCF-70 and Kellogg Spec. N8504-ES-1	411A7211	.25	1.04	.013	.020	.19						71.9		
	Weld No. T3-1 T3-2														
	Pipe manufactured from A516 Gr. 70 plate														
	Guided Weld														
	Transverse Hardness survey														
	Pipe was welded in accordance with (L) Procedure														
	Welds were radiographically inspected per (L) Procedure														
	and Instruction sheet No. 1														
	Weld was Magnetic Particle inspected per (L) Procedure														
	Pipe conforms to the specified Hydrostatic test requirements														
	Heat treated per (L) Procedure														

SUBSCRIBED AND SWORN TO BEFORE ME THIS 25th DAY OF March 1971

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

Rose Burdowski  
NOTARY PUBLIC (Exp. 13, 1974)

[Signature]  
METALLURGIST

MY COMMISSION EXPIRES \_\_\_\_\_

120



M. I. G. O.  
 Analysis Report  
 METALLURGICAL DEPARTMENT

(6)

PURCHASER The M. W. Kellogg Company - Power Piping Division

CUDAHY, WIS., December 1, 19 70

PURCHASER'S ORDER NO. N 8504-2

LSO NO. E 80697A

ADDRESS P.O. Box 881 Roach Road, Williamsport, Pa. 17704

INVOICE NO. N 28179

NO. PCS.	DESCRIPTION AND SPECIFICATION	HEAT NO. AND CODE	CHEMICAL COMPOSITION									PHYSICAL PROPERTIES						
			C	MN	P	S	SI	NI	CR	MO	YIELD STRENGTH LB. PER SQ. IN.	ULTIMATE STRENGTH LB. PER SQ. IN.	ELONG. %	RED. OF AREA				
6	Item 9 26" I.D. x 1.002 M/W 90° L.R. Ells A234 WPC & N 8504-ES-5	86A742 NM3AJ	.21	.68	.019	.021	.16											
			.26	.92	.017	.015	.15					46600	73200	31.0	58.0			
			Vee notch impacts at 0° = 25.0 - 24.5 - 23.0 ft. lbs. Brinell Hardness = 137 BHN Manufactured from A106 Gr. C Pipe															
1	Item 10 26" I.D. x 1.002 M/W 79° 4° L.R. Ells A234 WPC & N 8504-ES-5	86A742 NM3AK	.21	.68	.019	.021	.16											
			.26	.88	.015	.020	.15					47700	73100	32.0	59.0			
			Vee notch impacts at 0° = 24.5 - 24.0 - 20.5 ft. lbs. Brinell Hardness = 137 BHN Manufactured from A106 Gr. C Pipe Above fittings conform to the specified Hydrostatic test.															

SUBSCRIBED AND SWORN TO BEFORE ME THIS

1st DAY OF December 19 70

[Signature]  
 NOTARY PUBLIC

MY COMMISSION EXPIRES August 27, 1972

1 of 2

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

[Signature]  
 METALLURGIST

(8)



METALLURGICAL DEPARTMENT

The M. W. Kellogg Company - Power Piping Division

PURCHASER \_\_\_\_\_

CUDAHY, WIS., March 2, 1971

PURCHASER'S ORDER NO. N8504-2

LSO NO. E80697A

ADDRESS P.O. Box 831 Reach Road, Williamsport, Pa. 17704

INVOICE NO. N 29575

COLLECTED REPORT

NO. PCS.	DESCRIPTION AND SPECIFICATION	HEAT NO. AND CODE	CHEMICAL COMPOSITION								PHYSICAL PROPERTIES				
			C	MN	P	S	SI	NI	CR	Mo	YIELD STRENGTH KSI	ULTIMATE STRENGTH KSI	ELONG. %	RED. OF AREA	
2	<p>Item 11</p> <p>26" I.D. 1.002 M/W x</p> <p>26" I.D. 1.002 M/W x</p> <p>24" S/60 Red. Tees</p> <p>A234 WPB-W N8504-2</p> <p>ES-5</p> <p>Weld Nos. J1.6-1</p> <p>J1.6-3</p>	<p>09L1111</p> <p>CMBDL</p> <p>402A151</p>	<p>LADLE ANALYSIS</p>								<p>MIL. TENSILE</p>				
			.25	1.02	.010	.015	.20					41.3	72.0	22.3	
			<p>CHECK ANALYSIS</p>								<p>C. TENSILE</p>				
			.30	.94	.005	.014	.18						79.1		
			<p>WELD WIRE ANALYSIS</p>												
			.14	1.94	.011	.021	.05								
			<p>Vee notch impact at 0°F. = 46.0 - 33.0 - 27.0 ft. lbs.</p> <p>Hardness Survey - BHN 136 to 161.</p> <p>Welds were radiographically inspected per (I) Procedure 9-Q-2.2 and Instruction Sheet #1.</p> <p>Welds were magnetic particle inspected per (II) Procedure 9-G-105.</p> <p>Fittings will conform to the specified hydrostatic test.</p> <p>Manufactured from A516 Grade 70 plate.</p>												

SUBSCRIBED AND SWORN TO BEFORE ME THIS

2nd DAY OF March 1971

*Lorraine Zupica*

NOTARY PUBLIC

August 27, 1972

MY COMMISSION EXPIRES

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

*[Signature]*

METALLURGIST

38



7

3. Main Feedwater Isolation Valve

FCV-441



ASSEMBLY INSPECTION REPORT

JOB NO: 0480-2 CONTRACT NO: 14-16-G-0932  
 CUSTOMER: P.G. & E VALVE NO: #4 TAG NO: 16-G-0132  
 ITEM NO: 14 VALVE SIZE: 16" PRESSURE: 900 OPERATION: Motor  
 VALVE TYPE: Gate

VALVE TEST REPORT

JOB NO: 0480-2  
 CUSTOMER: P.G. & E CONTRACT NO: 14-16-G-0932 ITEM NO: 14  
 TYPE & SIZE: 16" - 900# Gate RC Motor Op DRAWING NO: 15-1557-3  
 SERIAL NO: 0480-2-1-4 TAG NO: 16-G-0932 WEIGHT: \_\_\_\_\_

(REQUIRED)

FCV-441

(ACTUAL)

	PRESS	TIME	MAX TORQUE	ALLOW SEAT LEAK	PRESS	TIME	MAX TORQUE	SEAT LEAK	INSPECTED	DATE
HYDRO TEST BODY	3250	23 Min	—	None	3250	23 MIN	—	0	✓	2-15-72
HYDRO TEST SEAT	2200	5 Min	Motor	42 cc PH	2200	5 MIN	Motor	A-2 cc PH B-9 cc PH	✓	2-15-72
AIR TEST SEAT										
TEST BACK SEAT	3250	23 Min	—	None	3250	23 MIN	Motor	0	✓	2-15-72

COMMENTS: \_\_\_\_\_

(REQUIRED)

OPERATOR

(ACTUAL)

TIME TO OPEN	60 sec	54 sec
TIME TO CLOSE	60 sec	54 sec
LIMIT SWITCHES SET	OPEN OK	CLOSED OK
TORQUE SWITCHES SET	OPEN: 2	CLOSED: 2

WITNESSED BY: \_\_\_\_\_ DATE: \_\_\_\_\_ ACCEPTED BY: [Signature] DATE: 2-15-72  
 Authorized Inspector \_\_\_\_\_ Anchor Valve Company

Form NQA 8-5

PART I CERTIFICATIONS REQUIRED				PART II VALVE IDENTIFICATION RECORD			
PART	MATL	HT	UT	SERIAL NO.	HEAT NO.	NUT IDENT NO.	CHECKED BY/DATE
BODY	R216 WCB	X	X	0480-2-1-4	H 1037		2-15-72
BONNET/CAP	R216 WCB	X	X	0480-2-2-4	H 1380		2-15-72
DISC	R216 WCB	X	X	0480-2-4-1	H 1355		2-15-72
STEM	R182 GFE 6mm	X	X	0480-2-5-4	R13212		2-15-72
SEAT RING	R216 WCB	X	X				
STUDS	R183 RT						
NUTS	F02908						
BYPASS	A106 GGG		X				
PART III				ACCEPTED BY			
PARTS DEBURRED							2-15-72
PARTS CLEANED							2-15-72
ASSEMBLY CHECKED							2-15-72
DISC CLEARS BORE (GATE)							2-15-72
CAVITIES FREE OF FOREIGN MATL							2-15-72
STUDS & NUTS TIGHT							2-15-72
STEM BACKSEATS							2-15-72
GEAR BACKLASH CHECKED							2-15-72
LANTERN RINGS INSTALLED							
TACKLEDS & SET SCREW SECURE							
HANDHEEL & GLAND NUTS TIGHT							
GREASE FITTINGS INSTALLED							
GEARS LUBRICATED WITH							
BEARINGS LUBRICATED WITH							

Form NQA 8-4 (6/70) ACCEPTED BY: [Signature] DATE: 2-15-72  
 ANCHOR VALVE CO







No.	By	Date	Defect Type	Location	Size	Depth	Remarks
1	W. J. Miller	9-20-71	Crack	Gate	1/2"	1/8"	See drawing for location
2	W. J. Miller	9-20-71	Crack	Gate	2-3"	1/8"	See drawing for location
3	W. J. Miller	9-20-71	Crack	Gate	3-4"	1/8"	See drawing for location
4	W. J. Miller	9-20-71	Crack	Gate	4-1"	1/8"	See drawing for location

PS 151

DEFECT - WELDING RECORD

DEFECT TYPE  
 G - Gas  
 B - Build Up  
 M - Mach. Error  
 S - Shrink  
 C - Crack  
 I - Inclusion  
 V - Visual  
 MT - Mag. Part  
 RT - Radiography  
 PT - Penetrant  
 UT - Ultrasonic

W. J. Miller

PO No. 8583-0480-2  
 2552  
 Pat. No. 2822-5-4  
 U-1355

HEADQUARTERS OFFICE  
 145 North Bayshore Blvd.  
 San Mateo, California  
 342-4163 & 347-9011  
 OAKLAND OFFICE  
 850 - 87th Street  
 Oakland, California  
 852-1100



ANCHOR EQUIPMENT CO.  
 24747 Claiwter Road  
 Hayward, Calif.

CERTIFIED INSPECTION REPORT


Control No.  
 Report No. SM-09-020-71  
 Date 9-20-71

Serial No.	View No.	Acc.	Req.	Go	Too	Good	Def.	Ret.	Ret.	OTHER
04802-3										
SAI-1										
	1-2	X								
	2-3	X								
	3-4	X								
	4-1	X								

P.O. No. 8584-0480-2  
 Part Name Disc 16" 900# Gate  
 Part No. 2822-5-4  
 Heat No. H-1355  
 Material Cast Steel  
 Radiographic Insp. Spec. ASTM E94-68  
 Acceptance Std. ASTM E71, E186 & E280  
 Class 2; except defect types D, E, F, & G are unacceptable  
 Other Insp. MT  RT   
 Insp. Spec. ASME Sec. III para. N-626  
 Acceptance Std. SAME  
 Our Shipper 12520  
 Foundry Job No. 36773  
 Cust. Shipper 0804  
 Qty. Rec. 1  
 Qty. Insp. 1  
 Total Accept. 1  
 Total Rej. 0  
 Qty. X-Rayed 1  
 Qty. Accept. 1  
 Qty. Rej. 0  
 No. of Views 4  
 Other Insp. 1  
 Qty. Accept. 1  
 Qty. Rej. 0  
 Contract No. 14-16-G0932  
 P. G. & E.  
 Drawing No. 6037-1-5  
 ASSS No. 35-99-66-7-XRE.  
 Reviewed by: \_\_\_\_\_  
 P. G. & E. INSPECTOR  
 Interpreter: Roy Beck  
 K. D. Miller

The R. P. & E. Co. does not warrant the accuracy of the data appearing on this report and is not responsible for any loss or damage due to its use.





**CERTIFIED  
INSPECTION  
REPORT**

Control No.  
Report No.  
Date **1-22-72**

SAN MATEO OFFICE  
145 North Bayshore Blvd.  
San Mateo, California  
342-4183 & 347-9011

OAKLAND OFFICE  
850 - 57th Street  
Oakland, California  
652-1100

**ANCHOR VALVE**  
24747 Clawiter Road  
Hayward, California

Serial No.	View No.	Ass.	Ref.	Gen.	Year	Month	Day	Ins.	Surf.	OTHER
802-1										
SN-44										
	1-2	X								
	2-3	X								
	4-5	X								
	5-6	X								
	7-8	X								
	8-9	X								
	10-11	X								
	11-12	X								
	13-14	X								
	14-15	X								
	16-17	X								
	17-18	X								
	19-21	X								
	20-21	X								
	22-23	X								
	23-24	X								
	25-26	X								
	26-27	X								
	28-29	X								
	29-30	X								
	31-32	X								
	33-34	X								
	34-35	X								
	35-36	X								
	37-38	X								
	38-39	X								
	40-41	X								
	42-43	X								
	44-45	X								
	46-47	X								
	48-49	X								
	50-51	X								
	52-53	X								
	54-55	X								
	56-57	X								
	58-59	X								
	60-61	X								
	62-63	X								
	64-65	X								
	66-67	X								

P.O. No. **8584-0480-2**  
Part Name **Body 16" 9007 Gate**  
Part No. **2822-5-1**  
Heat No. **H-2037**  
Material **Cast Steel**

Radiographic Insp. Sp. **ASTM E94-68**

Acceptance Std. **ASTM E71, E136, & E280 Class 2; except defect types D, E, F, & G are unacceptable.**

Other Insp. **MT & PT**  
Insp. Spec. **ASME sec III para N-626**  
Acceptance Std. **same**

Our Shipper **13230**  
Foundry Job No. **36771**  
Cust. Shipper **0921**

Qty. Rec.	FILM USED
1	3 1/2 x 8 1/2
1	5 x 7
1	4 1/2 x 8 1/2
0	3 1/2 x 17
1	4 1/2 x 17
1	8 x 10
0	7 x 17
0	10 x 12
0	14 x 17

Qty. X-Rayed **1**  
Qty. Accept. **1**  
Qty. Rej. **0**  
No. of Views **106**

Other Insp. **1**  
Qty. Accept. **1**  
Qty. Rej. **0**

**MT**

Contract No. **P. G. & E. 12-8-GC629**  
Drawing No. **6037-1.5** | RSSS No. **35-99-66-7**  
Reviewed by **XRENCO**

**P. G. & E. Inspector**  
Interpreter **K. D. HILLER**

CPCT-D **PACIFIC STEEL CASTING COMPANY**  
Berkeley

**CERTIFICATE OF PHYSICAL AND CHEMICAL TESTS**

CUSTOMER **Anchor Valve Co.** HEAT NO. **H. 2037**  
**24747 Clawiter Rd.** STEEL SPEC. **ASTM A 216 WCB**  
**Hayward, Calif.** DATE **10-25-71**

Contract No. **PG & E 14-16-G 0932**  
Customer's Order No. **8583-0480-2**  
PSC Order No. **36771**  
Pattern No. **2822-5-1 0480-2-1-4**  
Part Name **Body**  
Serial No. **4**, Heat Code No. **#4N**, Total Pcs. This Heat **1**

CHEMICAL ANALYSIS	
C	.25 -
Mn	.70 -
P	.027 -
S	.029 -
Si	.40 -
NI	
Cr	
Mo	
Al	
Co	

YIELD STRENGTH	52000	PSI	
TENSILE STRENGTH	77500	PSI	
ELONGATION	33	%	
REDUCTION OF AREA	54.7	%	
BEND TEST			
IMPACT TEST RESULTS		ft. lbs.	TYPE OF IMPACT TEST
IMPACT TEST TEMPERATURE		°F	Charpy V. Notch

**HEAT TREATMENT PROCESSES**

NORMALIZE @ **1650-1690 °F** For **5:00** Hours, Temper @ **1110-1170 °F** For **3:30** Hours

WATER QUENCH @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours, Temper @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours

STRESS RELIEVE (Post Weld Heat Treat) @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours

We hereby certify that the material represented by this report is in conformance with the above indicated Steel Specification and also meets all applicable special requirements of  Article \_\_\_\_\_ of the ASME Draft Code for Pumps and Valves.  Section III of the ASME Boiler and Pressure Vessel Code.

Certified By  
**Charles Lee**  
CHARLES LEE, Quality Assurance Mgr.

MT Performed By **XIRAY ENGINEERING CO.** Acceptable per Paragraph \_\_\_\_\_



1981 MAR 19 AM 10: 12

*for castings: measurements conform to ASME  
SA-613 article 5 RG. Dimensions below are  
exclusive of flanges and non-pressure retaining boundary part.*

PAC G&E 60 SF

WU INFOMASTER 1-017185M078 03/19/81  
TLX ANCORCO HYWD  
PD HAYWARD CALIFORNIA  
TWX 910 372 6587 PAC G&E 60 SF  
ATTENTION MR BACIARELLI ROOM 1491

AS DISCUSSED IN OUR TELECON 3-19-81 PREVIOUSLY REPORTED  
DIMENSIONS FOR THE VALVE DEPICTED ON A/DV DWG 1557-3 → MAIN FEEDWATER  
WERE MAXIMUM SECTION THICKNESSES. NOMINAL THICKNESS OF ISOL. VALVES.  
THE PRESSURE BOUNDARY IS AS FOLLOWS:

{ BODY 2"  
BONN 2-1/2"  
DISC 2"

JOHN CHAPPELL  
ANCORCO HYWD  
3-19-81

1308 EST

PAC G&E 60 SF



CPCT-D

PACIFIC STEEL CASTING COMPANY  
Berkeley

CERTIFICATE OF PHYSICAL AND CHEMICAL TESTS

CUSTOMER Anchor Valve Co. HEAT NO. I-133  
24747 Clawiter Rd. STEEL SPEC. ASTM A216 WCB  
Hayward, Calif. 94545 DATE 1/18/72

Contract No. PG&E 14-16-G0932  
Customer's Order No. 8583-0480-2  
PSC Order No. 36774  
Pattern No. 2822-5-1  
Part Name Body 0480-02-1-9  
Serial No. 9, Heat Code No. 9, Total Pcs. This Heat 1

CHEMICAL ANALYSIS	
C.	.25
Mn.	.69
P.	.021
S.	.023
Si.	.39
Ni.	.05
Cr.	.09
Mo.	.07
Al.	.073
Cu.	.13

YIELD STRENGTH	55,000	PSI
TENSILE STRENGTH	79,000-	PSI
ELONGATION	31	%
REDUCTION OF AREA	53.0	%
BEND		
IMPACT TEST RESULTS		ft. lbs.
IMPACT TEST TEMPERATURE		°F

TYPE OF IMPACT TEST  
Charpy V. Notch

HEAT TREATMENT PROCESSES

NORMALIZE @ 1650-1670 °F For 4:10 Hours, Temper @ 1140-1170 °F For 5:00 Hours  
WATER QUENCH @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours, Temper @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours  
STRESS RELIEVE (Post Weld Heat Treat) . . . . . @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours

We hereby certify that the material represented by this report is in conformance with the above indicated Steel Specification and also meets all applicable special requirements of  Article \_\_\_\_\_ of the ASME Draft Code for Pumps and Valves.  
 Section III of the ASME Boiler and Pressure Vessel Code.

Certified By  
Charles Lee  
CHARLES LEE, Quality Assurance Mgr.

MT Performed By XRAY ENGINEERING CO. Acceptable per Paragraph \_\_\_\_\_  
RT Performed By XRAY ENGINEERING CO. Acceptable per Paragraph \_\_\_\_\_



CERTIFICATE OF PHYSICAL AND CHEMICAL TESTS

CUSTOMER

Anchor Valve Co.

HEAT NO. H 2054

24747 Clawiter Rd.

STEEL SPEC. ASTM A 216 WCB

Hayward, Calif.

DATE 10-26-71

Contract No. PG & E 14-16-G-0932

Customer's Order No. 8583-0480-2

PSC Order No. 36776

Pattern No. 2822-5-4

Part Name Disc 0480-02-4-3

Serial No. 34, Heat Code No. #1-4, Total Pcs. This Heat 4

CHEMICAL ANALYSIS

C. .24

Mn. .70

P. .026

S. .028

Si. .40

Ni.

Cr.

Mo.

Al.

Cu.

YIELD STRENGTH 45000 PSI

TENSILE STRENGTH 72500 PSI

ELONGATION 35 %

REDUCTION OF AREA 60.3 %

BRAKE TEST

IMPACT TEST RESULTS ft. lbs. TYPE OF IMPACT TEST

IMPACT TEST TEMPERATURE °F. Charpy V. Notch

HEAT TREATMENT PROCESSES

NORMALIZE @ 1670-1690 °F For 5:00 Hours, Temper @ 1140-1170 °F For 3:00 Hours

WATER QUENCH @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours, Temper @ \_\_\_\_\_ °F For \_\_\_\_\_ Hour

STRESS RELIEVE (Post Weld Heat Treat) @ \_\_\_\_\_ °F For \_\_\_\_\_ Hour

We hereby certify that the material represented by this report is in conformance with the above indicated Steel Specification and also meets all applicable special requirements of  Article \_\_\_\_\_ of the ASME Draft Code for Pumps and Valves.  Section III of the ASME Boiler and Pressure Vessel Code.

Certified By

*Charles Lee*  
CHARLES LEE, Quality Assurance Mgr.

MT Performed By XRAY ENGINEERING CO. Acceptable per Paragraph \_\_\_\_\_

RT Performed By XRAY ENGINEERING CO. Acceptable per Paragraph \_\_\_\_\_



CERTIFICATE OF PHYSICAL AND CHEMICAL TESTS

CUSTOMER Anchor Valve Co. HEAT NO. H-2054  
24747 Clawiter Rd. STEEL SPEC. ASTM A216 WCB  
Hayward, Calif. DATE 10-26-71

Contract No. P.G.&E. 14-16-G-0932

Customer's Order No. 8583-0480-2

PSC Order No. 36775

Pattern No. 2822-5-2 0480-2-2-5

Part Name Bonnet

Serial No. 5, Heat Code No. S/B 5-8 14, Total Pcs. This Heat 4

CHEMICAL ANALYSIS

C. .24 -

Mn. .70 -

P. .026 -

S. .028 -

Si. .40 -

Ni.

Cr.

Mo.

Al.

Cu.

YIELD STRENGTH 45,000 PSI -

TENSILE STRENGTH 72,500 PSI -

ELONGATION 35 % -

REDUCTION OF AREA 60.3 % -

BE LT

IMPACT TEST RESULTS ft. lbs. TYPE OF IMPACT TEST

IMPACT TEST TEMPERATURE °F Charpy V. Notch

HEAT TREATMENT PROCESSES

NORMALIZE @ 1650-1690 °F For 5:00 Hours, Temper @ 1125-1160 °F For 3:30 Hours

WATER QUENCH @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours, Temper @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours

STRESS RELIEVE (Post Weld Heat Treat) @ \_\_\_\_\_ °F For \_\_\_\_\_ Hours

We hereby certify that the material represented by this report is in conformance with the above indicated Steel Specification and also meets all applicable special requirements of  Article \_\_\_\_\_ of the ASME Draft Code for Pumps and Valves.

Section III of the ASME Boiler and Pressure Vessel Code.

Certified By

Charles W. Lee

CHARLES LEE, Quality Assurance Mgr.

11-2-71 sw.

MT Performed By XRAY ENGINEERING CO. Acceptable per Paragraph \_\_\_\_\_

RT Performed By XRAY ENGINEERING CO. Acceptable per Paragraph \_\_\_\_\_



4. Main Steam Isolation Valve

FCV-44



11167 - 111601 - V  
QUAKER ALLOY CASTING CO., MYERSTOWN, PA.

Report of Chemical Analysis and Physical Properties

CUSTOMER Lehigh & Keokuk Co. ORDER No. 22048-B FILE No. \_\_\_\_\_  
ADDRESS \_\_\_\_\_ PATTERN No. 67-C-25-13 DESIGNATION Q71  
ATTENTION OF \_\_\_\_\_ SPECIFICATION 11216 for 11167 DATE 4-14-71

HEAT No.	C	Mn	Si	P	S	Cr.	NI	Mo	V	Yield P.S.I.	Tensile P.S.I.	Elong. Per Cent.	Red. of Area Per Cent.	Serial #	Lot #	Pct Shipt
6758	26	89	51	.021	.013	.08	NIL	.05	3.21%	47,500	81,000	26.0	45.2	J466	U-690546	1
6732	25	71	42	.017	.015	.12	.07	.02	21-20-20	39,500	76,500	30.0	53.5	J543	U-690547	1
F6758 UNIT 2 ISOLATION VALUE																
F6732 UNIT 3 " "																
100% Radiography in Accordance with ASME Section V																
100% Hydrostatic Testing in Accordance with ASME Section VIII																
Heat treated in accordance with ASTM A217																
QUALITY CONTROL																
REVIEWED & ACCEPTED																

REMARKS: 4-14-71 J.A.  
O.S.W.  
10/19/72

DATE 4/15/71 BY W.J.C.

"I Certify the above information is correct."

QUAKER ALLOY CASTING CO.  
BY Mark M. Landis  
METALLURGIST



ASLR  
 Schutte & Koorting Co.  
 Bucks County  
 Cornwell Hts., Pa. 19020

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

DATE: 3-12-71 FILE NO: 70-01-01  
 CONSIGNEE:

MILL ORDER NO. 38786-1  
 CUSTOMER P.O. 13776E  
 EZ 31071 DF

*1169-00600 V*  
*M. 2-22*

PECIFICATIONS.  
 A-515-69 Gr. 55

RECORDED AND INDEXED 6 1971 9:00 AM

BEND TEST O.K. HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B
245	19	48	016	021		22							

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG: IN 2	% R.A.	BHN	IMPACTS	DESCRIPTION
245	6	447	647	33				8-34-1/4 Dia. x 5-1/2"

Specs and tests norm.

*10/19/72*

S & K QUALITY CONTROL  
 P.O. M 69-00606 1/2 607V  
 M. K. COVER  
 REVIEWED & ACCEPTED  
 DATE 10/19/72 BY *MP*

We hereby certify that the above figures are correct as contained in the records of the company

SUPERVISOR TESTING *[Signature]*



PURCHASER:

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

DATE: 9-22-72

FILE NO. 9-02-02

DATE:

CONSIGNER:

3 Schutte & Koerting Co.  
Bucks County  
Cornwell Heights, Pa. 19020

## TEST CERTIFICATE

MILL ORDER NO.  
18546-1CUSTOMER P.O.  
21173E

CJ 91972 DR

SPECIFICATIONS:

8A-542 CL 2 1971 Addenda ✓

BEND TEST

O.K.

HOMOGENEITY TEST

## CHEMICAL ANALYSIS

Basic

Proc.

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	
B5137	13	48	014	023		22		2.24	96					Elec. V.I.P. Steel

## PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	BHN	IMPACTS	DESCRIPTION
B5137	5B	1189 1059	1299 1163	18 19				(16- 3-9/16" x 23-1/2 Dia. 16- 3-9/16" x 3-9/16 x 9-1/2.

Circles, plates and tests heated 1650°F ±25°F., held 3/4hr. per inch min. and waterquenched to 500°F. then tempered 1140°F., held 1/2 hr. per inch min. held

Mill Inspection by Schutte & Koerting

11/3/72

S & K QUALITY CONTROL  
P.O. M69-00606-V  
M.K. DISC & PIN  
REVIEWED & ACCEPTED  
DATE 10/9/72 BY MP

We hereby certify that the above figures are correct as contained in the records of the company.

SUPERVISOR-TESTING

*J. J. Line*



JED Manufacturing Company, Inc.



Area Code 5535 Lena St. 1-215 848-8221

Phila., Pa. 19144

ROLLED and CUT THREADED PRODUCTS

STUDS • U BOLTS • HIGH TENSILE BOLTS & NUTS • ALLOY & CARBON STEEL • NON FERROUS FASTENERS

Sold To Schutto & Koerting Co.  
 Cornwello Heights,  
 Bucks County, Penna. 19020

Vlu *10*  
 Ship To   
 Same

ORDER DATE 8/19/70 SHIPPING DATE 8/17/71 INVOICE DATE REQ. NO. AC 999 YOUR ORDER NO. 13517 E OUR ORDER NO. 13445

INV. COPIES 3 TAX  EXEMPT  SUBJECT  CERTIFICATION S  I  F.O.B.  SHIPPING PT.  L/O.  QUOTE  MERCHANDISE MUST NOT BE RETURNED, WITHOUT OUR CONSENT.  P.O.

QTY	SIZE	DESCRIPTION
		NO VARIATION IN SHIPMENT
(A) 176	176	Alloy Steel A 193 B-16 STUDS to dwg. #67-S-230 (pt. #1A)
(B) 16	16	DETTO 60-S-12 (pt. #1B)
16	17	5/8" x 3-1/2" - ALLOY STEEL A 193 B-16 STUDS S&K Spec. 1-C

P.O. M69-01066-1 ✓

CERTIFICATION

This will certify that the items purchased on the above order number conforms to the specification of:

*10/19/71*

1 7/8 φ STUDS	A193	B-16
HEAT NO.	66785	
C	.40	✓
MN	.69	✓ TENSILE 143,000 ✓
P	.008	✓ YIELD 135,000 ✓
S	.020	✓ ELONG. 19.0% ✓
SI	.28	✓ R.A. 63.5% ✓
CR	1.07	✓ HARDNESS 302
Mo	.54	✓
VA	.32	✓

S&K QUALITY CONTROL  
 P.O. M69-00606-1  
 M.K. / A & B  
 REVIEWED & ACCEPTED  
 DATE 10-22-71 BY MB

Frederick R. Ott



5. Penetration Sleeves and Flued Heads





February 11, 1970

Pittsburgh-Des Moines Steel Company  
P. O. Box 1447-  
Provo, Utah 84601

Attn: - Mr. John Lott

Reference: Your purchase order #39711  
Our order #50-5642

See the attached test reports from Capitol Pipe #43719.

Item #	Size	Heat #
2054 thru 2058 & 2053	12" Sch 80	192967
2102 thru 2105	14" Sch 80	69084

Sincerely yours,

Jay Anderson  
Office Manager

FJA/glj



**NUCLEAR**

**ARMCO ARCADE STEEL CORPORATION**

**AMBRIDGE WORKS**

Ambridge, Pennsylvania

**REPORT OF TESTS**

OK'D 2-17-70  
per B. YERK  
ASTM A-500

CUSTOMER

*Capital Pipe & Steel Products, Inc.*

DATE 10-28-69

SPECIFICATION

*ASTM A333 & ASME SA333 - GR. 1 Item 2102 thru 2105*

OUR ORDER NO 000133702-021

MATERIAL


*Sm. Gr. 1 Steel Pipe*

CUSTOMER'S ORDER NO.

47189

*150' CAP. PIPE #43719*


IDENTIFICATION STRIP TEST	TENSILE TESTS			HYDRO TEST PSI	HEAT NUMBER	ANALYSIS												
	YIELD PSI	ULTIMATE PSI	% ELONG. IN 2 IN			C	Mn	P	S	SI	NI	Cr	Mo					
<i>NORM</i>																		
<i>14 x 750</i>	<i>49200</i>	<i>76300</i>	<i>42.5</i>	<i>1900</i>	<i>69084</i>	<i>24</i>	<i>91</i>	<i>012</i>	<i>017</i>								<i>CHEM.</i>	
						<i>25</i>	<i>92</i>	<i>010</i>	<i>016</i>									<i>CHECK</i>
<i>V-NOTCH CHURPY - 50°F</i>			<i>26-21</i>	<i>-21</i>	<i>= 23 AVG.</i>	<i>24</i>	<i>92</i>	<i>010</i>	<i>016</i>									<i>- LADLE</i>
																		<i>10x10mm SIZE</i>
																		<i>MATERIAL NORM. AT 1600°F. - 45 MIN. SOAK - STILL AIR COOLED</i>
																		<i>CHURPY SPECIMENS STR. REL. AT 1100°F. - 45 MIN. SOAK - FURNACE COOLED</i>
																		<i>Flattening Tests OK</i>
																		<i>Sworn to and subscribed before me this 29th day of October A.D. 1969.</i>
																		<i>Pauline Dimitrakis</i>
																		<i>PAULINE DIMITRAKIS, NOTARY PUBLIC AMBRIDGE BOROUGH, BEAVER COUNTY MY COMMISSION EXPIRES MARCH 4, 1972</i>



*Tubular Service #50-8692*

THE CHEMICAL ANALYSES AND PHYSICAL OR MECHANICAL TESTS ABOVE ARE CORRECT AS CONTAINED IN THE RECORDS OF ARMCO STEEL CORPORATION.

*C. Hesselroth*







# MILLS-WOLF STEEL, INC.

7721 PINEMONT • HOUSTON, TEXAS 77040 • TELEPHONE 714 • HO 2-2601

## TEST CERTIFICATE

DATE 4/70  
FILE NO. 870 5544

PURCHASER **Pittsburg-Des Moines Steel Co.**  
P.O. Box 1447  
Provo, Utah 84601

*OK'D per  
ASME SA-516 GR 70  
PDM MSB 4/3/70  
P/beck*

PLG. STRUCT & MULL QUAL  
BENDING TESTS.

FIRE BOX QUALITIES  
BENDING TESTS. **ok**  
HOMOGENEITY TESTS. **ok**

### CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	Producer:
<u>C7758</u>	.21	1.07	.015	.010		.15								LeTourneau

### PHYSICAL PROPERTIES

CUSTOMER P.O.	SPECIFICATIONS	MELT NO.	SLAB NO.	YIELD P.S.I.	TENSILE P.S.I.	% ELONG. IN 2"	DESCRIPTION
39711 - Add #1 Item #299	ASME SA-516 Gr 70 A-300 Cl 1  Normalized - Longitudinal Charpy V-Notch Impact Tested @ -500F. @ 15 Ft. Lbs., MIN. Values: <u>1/21</u> , <u>2/22</u> , <u>3/25</u> <i>ok</i>	<u>C7758</u>	<u>162</u>	46000	75000	25.0	1 - 1-1/4 x 64 x 258

I HEREBY CERTIFY THAT THE ABOVE TESTS ARE CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF AND CONFORM TO THE REQUIREMENTS OF THE SPECIFICATIONS AS LISTED.

*Paul W.*





PRODUCTION DEPARTMENT - METALLURGICAL  
**United States Steel Corporation**

PH 2

REPORT OF PIPELINE PRODUCTS  
LORAIN-CUYA U.S.S. ORDER NO. 1027940 LOAD TALLY OR INVOICE NO.  
 ORDER NO. 105271  
 TRUCK NO. 646123 SHIPPER NO. & DATE 06/24/70

**RECEIVED**  
 JUL 3 1970

KEYSTONE PIPE & SUPPLY CO  
 PO BOX 991  
 BUTLER PENNSYLVANIA

MAIL TO  
 KEYSTONE PIPE & SUPPLY CO  
 PO BOX 991  
 BUTLER PENNSYLVANIA

WE HEREBY CERTIFY THAT THE FIGURES SET FORTH BELOW ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

30470  
 ITEM #S 2032 THRU 2046

MILL CERTIFIED

MATERIAL  
 S&LS

SIGNATURE E. J. WARTOCTA  
 DATE JUL 29 1970  
 DIVISION QUALITY CONTROL

ITEM NUMBER	MATERIAL DESCRIPTION			HEAT NUMBER	MIN. HYDRO TEST PRESSURE P.S.I.	YIELD STRENGTH P.S.I.	TENSILE STRENGTH P.S.I.	ELONGATION	
	PIPE SIZE INCHES	WALL INCHES	GRADE					SPECIFICATION	INCHES
20	12	B	AST A100	81A304	2130	42800	74900	2	420
20	1031	B	AST A100	84E826	2710	37800	74300	2	360
20	1031	B	AST A100	82E825	2710	36200	70700	2	410

**PDM**  
 PROVO QUALITY ASSURANCE  
 ASTM: ASME SA-333  
 GRADE 1 (FLATTENING TEST)  
 DATE JUL 20 1970  
 BY [Signature]  
**APPROVED**

FLATTENING TESTS OK ✓

PIPE SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE.

ITEM NO.	TYPE	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Cb	Co
4	LAC	8113	20	53	007	002	006												
5	LAC	84E826	20	59	007	002	006												
5	LAC	82E825	20	51	006	002	006												

REF DIR 3040-29AR





# PITTSBURGH TESTING LABORATORY

PAGE 3

ESTABLISHED 1881  
850 POPLAR STREET, PITTSBURGH, PA. 15220

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

REPLY TO:  
170  
PA. 1523




Revised 5/24/71 \*\*  
CLIENT'S No. 50-C-1867

AREA CODE 412 . TELEPHONE 922-4000

LABORATORY No. 7-5779  
ORDER No. PG-10039

REPORT  
April 3, 1971



Report of: Charpy Impact Tests  
V Notch, Minus 30° F.

Report to: Keystone Tubular Service Corporation  
Post Office Box 991  
Butler, Pennsylvania 16001


### SPECIMEN IDENTIFICATION      SIZE OF SPECIMEN      IMPACT FOOT POUNDS

Ht. 82E815	10 MM x 10 MM	51 ✓
Ht. 82E815	10 MM x 10 MM	35 ✓
Ht. 82E815	10 MM x 10 MM	44 ✓
Ht. 233220 24" Diameter	10 MM x 10 MM	66
Ht. 233220 24" Diameter	10 MM x 10 MM	66
Ht. 233220 24" Diameter	10 MM x 10 MM	56.5
<del>*26" Diameter</del>	<del>10 MM x 10 MM</del>	<del>3.5</del>
<del>*26" Diameter</del>	<del>10 MM x 10 MM</del>	<del>8</del>
<del>*26" Diameter</del>	<del>10 MM x 10 MM</del>	<del>3</del>
Ht. 84E856	10 MM x 10 MM	28.5 ✓
Ht. 84E856	10 MM x 10 MM	33.5 ✓
Ht. 84E856	10 MM x 10 MM	31 ✓

The above samples were heat treated per ASTM A333, Para. 4.4.1.1 before machining and testing.

\*No heat number.

\*\*Revised per client's instructions.



PITTSBURGH TESTING LABORATORY

*Earl Gallagher*  
Earl Gallagher, Manager  
Physical Testing Department

REF DUR# 30470-29 PR





# PITTSBURGH TESTING LABORATORY

ESTABLISHED 1881

850 POPLAR STREET, PITTSBURGH, PA. 15220

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

FORM 007 REV. 68

PAGE 4



Revised 5/24/71

CLIENT'S No. 30-C-1867


AREA CODE 412 . TELEPHONE 923-4000

LABORATORY No. 713770

ORDER No. PG-10039

## REPORT

April 8, 1971



Report of: Charpy Impact Tests  
V Notch, Minus 30° F.


Report to: Keystone Tubular Service Corporation  
Post Office Box 991  
Butler, Pennsylvania 16001

SPECIMEN IDENTIFICATION	SIZE OF SPECIMEN	IMPACT FOOT POUNDS	
		EXPAND	SHEAR
Ht. 82E815	10 MM x 10 MM	51 .035	42
Ht. 82E815	10 MM x 10 MM	35 .038	42
Ht. 82E815	10 MM x 10 MM	44 .029	47
Ht. 833220 24" Diameter	10 MM x 10 MM	66 .024	20
Ht. 833220 24" Diameter	10 MM x 10 MM	60 .026	20
Ht. 833220 24" Diameter	10 MM x 10 MM	56.5 .026	20
26" Diameter	10 MM x 10 MM	8.5	
*26" Diameter	10 MM x 10 MM	REJECTED THIS	
*26" Diameter	10 MM x 10 MM	SIZE & HEAT 3	
Ht. 84E856	10 MM x 10 MM	28.5 .028	25
Ht. 84E856	10 MM x 10 MM	33.5 .026	25
Ht. 84E856	10 MM x 10 MM	51 .026	25

The above samples were heat treated per ASTM A925, Para. 4.4.1.1 before machining and testing.

No heat number.

Revised per client's instructions.



PITTSBURGH TESTING LABORATORY

*Earl Gallagher*  
Earl Gallagher, Manager  
Physical Testing Department

REF. DVR 30470-29PR



TELEPHONE  
-662-6277



HEAT TREATING  
FLAME HARDENING  
INDUCTION HARDENING  
CASE HARDENING

**PITTSBURGH COMMERCIAL HEAT TREATING CO.**  
49TH STREET & A.V.R.R., PITTSBURGH, PA. 15201

E.J. GOX, PRESIDENT



*2 copies*

METAL TREATING CERTIFICATION

We hereby certify that we have performed  
the following metal treating operation:

Customer: Keystone Pipe & Supply  
P.O. Box 992  
Butler, Pa 16001

PDM Contract  
30470

Customer's Purchase Order Number: 5002156

Quantity and Part: 25 Pieces Tubing

Material: 4106 Tubing


Our Shop Order Number: #60604

Treatment: Material was Hardened 1475°F (+25°F) held for  
a minimum of one (1) hour per inch of thickness  
Then water quenched in agitated water

Tempered 1080°F (+15°F) Held for a minimum of  
one (1) hour per inch of thickness  
Then air cooled

Results on hardness-Random inspection 170/217 BHN

Date of Treatment: 4-13-1971 to 4-21-1971



Pittsburgh Commercial Heat Treating Co.

By [Signature]

PCHT Form QA20

REF. DVR-30470-298



470  
-590



# KEYSTONE TUBULAR SERVICE CORP.

A SUBSIDIARY OF THE MARMON GROUP, INC.

750 West 1625 South, Salt Lake City, Utah 84104 ☎ 801-467-1546

June 8, 1971

Pittsburgh-Des Moines Steel  
P. O. Box 1447  
Provo, Utah 84601

Attn: Mr. John Lott

Reference: Your order #30470 .

- 26" OD X 3/4" Wall x 5'-0" item # 2022
- 24" Sch 80 x 5'-2" item # 2023 through 2026
- 20" Sch 80 x 5'-5" item # 2032 through 2043
- 20" Sch 80 x 5'-2" item # 2044 through 2046.
- 24" Sch 40 x 5'-2" item # 2027 through 2031

4  
12  
3  
5

Due to the lack of availability of A-333 Gr. 1 nuclear steel and after discussing with Pittsburgh-Des Moines' engineers, we selected A-53-Gr. B & A-106 Gr. B material with the proper physical & chemical analysis and performed heat treatment and charpy V notch impact test in accordance with A-333 Gr. 1 nuclear and Pittsburgh-Des Moines specification MS9.

The material was impact tested by Pittsburgh Testing Laboratories and the results are shown on their laboratory reports #713779, 710235, & 715315 which are attached.

The heat treatment was performed by Pittsburgh Commercial Heat Treating Company. Temper charts, furnace charts, certifications and evidence of calibration are attached.

Sincerely yours,

KEYSTONE TUBULAR SERVICE

*Jay Anderson*  
Jay Anderson

Office Manager

REF DVR # 30470 - 29 PR



6. Equipment Hatch



TEST REPORT OF PLATES  
 WORKS HOMESTEAD DISTRICT U.S.S. ORDER NO. 172896 LOAD TALLY OR INVOICE NO. 163436324  
 CUSTOMER ORDER NO. 30711-PTS 1/14/71  
 CAR OR TRUCK NO. MRP 048160 SHIPPER NO. & DATE 44852 3/15/71 160

PROVO QUALITY ASSURANCE  
 ASTM ASME SA-516  
 GRADE 70  
 DATE APR 28 1971  
 BY [Signature]  
**APPROVED**

PITTSBURGH DES MOINES STEEL CO  
 P.O. BOX 1447  
 PROVO UTAH 84601

PITTSBURGH DES MOINES STEEL  
 2TH SOUTH & 5TH EAST  
 PROVO UTAH

WE HEREBY CERTIFY THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

ASME SA-516-69-BS-70 PRESSURE VESSEL QUAL. 10" CHARTY-V-NOTCH-TIPA  
 CIP VALUERS 20" T LBS MIN AVG 3" SPLC AT MINUS 20 DEG F IN ACCORD  
 WITH SA300-68 & SA370-PLTS NDRM ADDN TEST SPECIMENS SR AT 9 HRS


WILL CERT T/R APPLICABLE ANALYSIS AND TEST RESULTS & CERT T/R APPLICABLE ANALYSIS AND TEST RESULTS TO SOLD TO WITH MR JOHN LOTT P  
 ?? ZURCH AGENT

SIGNATURE R. W. MAXSON, CH. MGT.  
 DATE 03/25/71

ITEM NO.	HEAT NO.	TEST OR PIECE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI.	TENSILE STR. PSI.	ELONGATION %		% RED. OF AREA
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			IN 8"	IN 2"	
558	668094	046315 PC	1	4 1/2	59	93	8180	47600	76700		30.0	
Longitudinal V Notch Charpy Impact Tests 10 x 10 MM Made at Minus 20 Deg F. 20-42-31 Ft Lbs. % Shear Rate - 40-33-37 and Lateral Expansion - .018-.033-.028 Mils. LATERAL EXPANSION AND PERCENT SHEAR FOR INFORMATION ONLY. Plates and Tests Normalized Test specimens only Stress Relieved @ 1125 Deg F. Maintained 9 hours. Furnace cooled to below 600 Deg F. Heating Rate - 90 Deg F. per hour. Cooling Rate - 90 Deg F. per hour. Furnace Charts attached to Test Reports 3/31/71												

ITEM SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE \* B OR H INDICATE COMPLIANCE OF BEND OR HOMO TESTS, RESPECTIVE

HEAT NO.	TYPE	C	Mn	P	S	Si	Al	Ni	V	B	Ti	Cb	Co	Grain Size #8	FINE GRN S
668094	PLATE	2	1.2	0.15	0.15	0.20									





ADDENDUM

LOWEST SERVICE METAL TEMPERATURE FOR  
FEEDWATER AND MAIN STEAM LINE COMPONENTS.

The lowest service metal temperature for the Feedwater and Main Steam lines components were deduced using the minimum inside containment temperature of 100<sup>0</sup>F (item 2, letter) and the process fluid temperature in these lines of 434<sup>0</sup>F and 536<sup>0</sup>F (Feedwater and Steam respectively). These lines are also insulated with class IV or better insulation. It is obviously conservative to assume a lowest service metal temperature of 100<sup>0</sup>F for the sleeves, flued heads and valves in these lines.

In the case of auxiliary feedwater injection, the mean fluid temperature is 40<sup>0</sup>F. When the large mass of insulated lines, steam generator and other components is considered together with the short time involved for the reactor shut-down under these conditions, one finds that the temperature of the components such as valves and flued heads will not drop below the conservative 100<sup>0</sup>F value estimated above.

These values can be used in determining compliance of the various components with 10 CFR 50, Appendix A, Criterion 51 - Fracture Prevention of Containment Pressure Boundary.



Attachment 1

List of Documentation

1. Main Feedwater Piping
2. Main Steam Piping
3. Main Feedwater Isolation Valve - FCV-441
4. Main Steam Isolation Valve
5. Penetration Sleeves and Flued Heads
6. Equipment Hatch (Thickest Hatch)

