

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8306170350. DOC. DATE: 83/06/10 NOTARIZED: NO DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Gas 05000275
 AUTH. NAME: AUTHOR AFFILIATION
 KRECHTING, J.E. Stone & Webster Engineering Corp.
 RECIP. NAME: RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director
 MARTIN, J.B. Region 5, Office of Director
 MANEATIS, G.A. Pacific Gas & Electric Co.

SUBJECT: Forwards June 1983 semimonthly open item report.

DISTRIBUTION CODE: D0133 COPIES RECEIVED: LTR: 1 ENCL: 1 SIZE: 13
 TITLE: Diablo Canyon (50-275) Independent Design Verification Program

NOTES: J Hanchett 1cy PDR Documents.

05000275

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL
	NRR	LB3 BC	1	0	NRR	LB3 LA	1	1	
	BUCKLEY, B.	06	1	1					
INTERNAL:	ELD/HDS2		1	0	IE/DEPER	DIR	1	1	
	IE/DEPER/EPB	11	1	1	IE/DQASIP	DIR	1	1	
	NRR SCHIERLING		1	1	NRR/DE/CEB	12	1	1	
	NRR/DE/EQB	13	1	1	NRR/DE/GB	14	1	1	
	NRR/DE/MEB	15	2	2	NRR/DE/QAB	16	1	1	
	NRR/DE/SGEB		1	1	NRR/DSI/ASB	18	1	1	
	NRR/DSI/ICSB		1	1	NRR/DSI/PSB		1	1	
	<u>REG FILE</u>	04	1	1	RGNS	08	2	2	
	RM/DDAMI/MIB		1	0					
EXTERNAL:	ACRS	19	16	16	LPDR	03	2	2	
	NRC PDR	02	1	1	NSIC	05	1	1	
	NTIS		1	1					
NOTES:			1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTR 44 ENCL 41

CONFIDENTIAL
 The following information was obtained from a confidential source who has provided reliable information in the past. This information was obtained from a confidential source who has provided reliable information in the past. This information was obtained from a confidential source who has provided reliable information in the past.

The following information was obtained from a confidential source who has provided reliable information in the past. This information was obtained from a confidential source who has provided reliable information in the past. This information was obtained from a confidential source who has provided reliable information in the past.

The following information was obtained from a confidential source who has provided reliable information in the past. This information was obtained from a confidential source who has provided reliable information in the past. This information was obtained from a confidential source who has provided reliable information in the past.

DATE	ACTIVITY	LOCATION	STATUS	REMARKS
10/15/68
10/16/68
10/17/68
10/18/68
10/19/68
10/20/68
10/21/68
10/22/68
10/23/68
10/24/68
10/25/68
10/26/68
10/27/68
10/28/68
10/29/68
10/30/68
10/31/68

STONE & WEBSTER ENGINEERING CORPORATION



245 SUMMER STREET, BOSTON, MASSACHUSETTS

ADDRESS ALL CORRESPONDENCE TO P.O. BOX 2325, BOSTON, MASS. 02107

W.U. TELEX: 94-0001
94-0977

BOSTON
NEW YORK
CHERRY HILL, N.J.
DENVER
CHICAGO
HOUSTON
PORTLAND, OREGON
WASHINGTON, D.C.

DESIGN
CONSTRUCTION
REPORTS
EXAMINATIONS
CONSULTING
ENGINEERING

Mr. G. A. Maneatis, Executive Vice President
Facilities Development
Pacific Gas and Electric Company
77 Beale Street
San Francisco, CA 94106

June 10, 1983
J.O. No. 14296
DCS-464

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

J. B. Martin, Regional Administrator
Region V
U. S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, CA 94956

Dr. W. E. Cooper
Teledyne Engineering Services
130 Second Avenue
Waltham, MA 02254

Docket No. 50-275
Diablo Canyon Unit 1
License No. DPR-76

SWEC JUNE SEMIMONTHLY REPORT

Gentlemen:

Enclosed is Open Item Report 8065 issued by SWEC since our last semi-monthly report.

Very truly yours,

John E. Krechting
J. E. Krechting
Project Engineer, Diablo Canyon Nuclear Power Plant

cc: ~~H.~~ Schierling (2)
R. R. Fray
R. F. Reedy
E. T. Denison
M. J. Strumwasser

D. F. Fleischaker
J. R. Reynolds
B. Norton
A. C. Gehr
R. B. Hubbard

J. R. Phillips
J. Roeset
M. Axelrad

DESIGNATED ORIGINAL
Certified By: *Per H. Schierling*

*2013
1/1*

8306170350 830610
PDR ADDCK 05000275
R PDR



1950

OPEN ITEM REPORT

File No. 8065

File Revision No. 0

1. Date reported to PG&E and TES June 8, 1983
2. Scheduled for SWEC (Originator) Semimonthly Report No. _____
3. Responsive to PG&E Technical Program: Task _____ (if applicable)
4. Prepared as a result of:
 - a. QA Audit and Review Report of _____
 - b. Field Inspection Deficiency
 - c. Independent Calculation Deficiency
 - d. Seismic Input Deficiency
 - e. Design Methodology Deficiency
 - f. Other Deficiency
5. Structure(s), system(s) or component(s) involved:

Please see Attachment 1 through 4

6. Description of Concern:

Please see Attachments 1 through 4

7. Significance of Concern:

Please see Attachments 1 through 4


8. Recommendation:

Please see Attachments 1 through 4

9. Signature: _____

John E. Tjallingii

(Originator/Organization)



Structure (s), system (s) or component(s) involved:

Feedwater line no. 555

Main Steam Line no. 227

Description of Concern:

The horizontal portion of Main Steam Line no. 227 at elevation 179'-10½ is impinged upon by forward jet impingement flow from postulated break nos. 3 and 4 on feedwater line no. 555.


The DCP Jet Impingement Review Sheets do not identify this portion of the Main Steam Line as a target for either of these break cases, though identifying the lower horizontal portion of the Main Steam Line as a target for reverse flow from break no. 3.

Significance of Concern:

The Main Steam Line is a safety-related target and should be considered in the safety evaluation regarding the effects of the two postulated FW break cases.

Recommendation:

The horizontal portion of the Main Steam Line should be identified as a target for forward flow from postulated break nos. 3 and 4 and a safety evaluation should be performed by the DCP for each break. The safety evaluation should consider the effects on the Main Steam Line coincident with the effects on all other targets for the same postulated jet zones.



Structure (s), system (s) or component(s) involved:

Line No. 12 - RCL PP Disc #4 - Break Location No. 2

Conduit KX-578 (Yellow)

Conduit KX-582 (Yellow)

Description of Concern:

Conduit KX-582 has been misidentified as conduit KX-578. Conduit KX-578 is identified as a target on the DCP Jet Impingement Review Sheets for postulated break No. 2 at the Reactor Coolant Pump (RCP) Outlet. The IDVP field inspection, has determined that KX-578 is outside the zone of influence (Z01) for this break. Conduit KX-582 was determined to be within the Z01 but was not identified as a target on the DCP Jet Impingement Review Sheets. ---


(See Attached Sketch)

Significance of Concern:

The safety evaluation was performed for conduit KX-578 though conduit KX-582 is the affected target. Conduit KX-582 may contain different cables than conduit KX-578, which may be needed to safely shutdown the plant.


Recommendation:

The DCP should perform a safety evaluation to determine if conduit KX-582 is needed to safely shutdown the plant for a postulated break at the RCP outlet (Break No. 2 on Line No. 12).




▲ 5010.65


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46



PLAN VIEW



JET IMPINGES IN THIS AREA



Structure (s), system (s) or component(s) involved:

Safety-related (grey) conduit KX-428 (3/4") leading to TE 1315. Letdown line No. 24.

Description of Concern:

A pipe rupture on letdown line 24 at break location No. 16 (see Figure 1) results in a blowdown jet vertically upward, which impinges upon safety-related (grey) conduit KX-428 (approximately 160" above the break location). (see Figure 2)

Significance of Concern:

As the conduit is color coded grey and therefore safety-related, it may contain cables which are essential for reactor shutdown under conditions resulting from postulated break 16 on line 24.

Recommendation:

A safety evaluation should be conducted to determine if conduit KX-428 is essential for reactor shutdown under the conditions associated with the postulated pipe break 16 on line 24.





FIGURE 1. BREAK NO. 16 ON LINE 24. - ISOMETRIC SKETCH

9-14-82

PG & E U & HU E L E I T	PROJECT DC 1	FILE No. N/A
	ANAL NO. 9-109	REV 0 DATE 9-9-82
	PROGRAM ME 101	ANALYST M. HANOVER
	TEMP 579°F	SPECTRA
COMMENTS		
APPROVED	<i>[Signature]</i>	DATE 7/10/82
DESIGN REVIEWED		DATE

Checked By: R Dhanwan 9-9-82



- LEGEND:
- NODAL POINT
 - X— SPRING HANGER
 - E— FIXED END
 - X— PINNED END
 - E—X— SHUBBER

ANALYSIS 9-109
REV. 0



DIABLO CANYON NUCLEAR
POWER PLANT UNIT NO. 1
LETDOWN LOOP 2, TO REGEN.
HEAT EXCHANGER


DRAWN: G.D.L.

GLOBAL COORDINATE
SYSTEM



FIGURE 2





Structure (s), system (s) or component(s) involved:

Vertical supports for line 63, excess letdown line, loop 2 cold leg.
Letdown line no. 24.

Description of Concern:

A pipe rupture on letdown line 24 at break location 12 (see Figure 1) results in a traveling jet. The traveling jet sweeps horizontally and impinges upon two of the vertical supports for the excess letdown line 63 (see Figures 2&3).

Significance of Concern:

As more than one support for the safety-related line 63 is being affected by jet impingement from break 12 on line 24, the interaction may affect the stresses in line 63, such that the piping integrity may be impaired.

Recommendation:

A safety evaluation should be conducted to determine if Excess Letdown line 63 is essential for reactor shutdown under the conditions associated with the postulated rupture of Letdown line 24, and to assure compliance with licensing commitments in FSAR Section 3.6.





FIGURE 1. BREAK NO. 12 ON LINE 24 - ISOMETRIC SKETCH



LEGEND

- NODAL POINT
- E FIXED END
- X PINNED END
- W X SPRING HANGER
- E X SNUBBER



PG & E	M & Nu E DEPT	PIPING DESIGN GR	
PROJECT	DC-1	FILE No.	N/A
ANAL No.	9-110	REV	0
DATE	9/8		
PROGRAM	ME 101	ANALYST	M. HANDU
TEMP	—	SPECTRA	—
COMMENTS	ANALYSIS ISOMETRIC		
APPROVED	<i>[Signature]</i>	DATE	9/9/8
DESIGN REVIEWED		DATE	

CHECKED BY: *RD* DATE: 9-8


LOCATION: CONTAINMENT STRUCTURE

REF.: PG & E DWG. 43799?

NOTES: ALL BENDS ARE 90°

DRWN: G.P.L

PIABLO CANYON NUCLE
POWER PLANT UNIT NO
LETDOWN LOOP-2, TO RI
HEAT EXCHANGER



FIELD INSPECTION REPORT - JET IMPINGEMENT REVIEW INSIDE CONTAINMENT
DIABLO CANYON UNIT 1 - JOB ORDER No. 14296.40


TASK 11.6.3.1
 DATE 5/25/83
 PAGE _____

BREAK IDENTIFICATION						LOCATION OF BREAK			REFERENCES		
SYSTEM	LOOP	LINE NO.	BREAK NO.	BRK. TYP.	BRK. CAT.	AREA	LOCATION	ELEVATION	DCP JET IMP. REVIEWSHEETS	DRAWINGS	OTHER DOCUMENTS
LETDN	2	24	12	TRAVEL C	LOCA NON-LOCA	F	INDUSTRIAL END OF BRK. 12 65-7R	101-6"	24-1, 6 NUMBERED BY _____	FIG. 2.6.5 500042-0 FIG. 2.6.5 500051-2	

SKETCHES AND FIELD NOTES

ADDITIONAL REPORTS

7 SUPPORTS FOR LINE 63 EXCESS LETDOWN LOOP 2 C.L.



SUPPORT 1

SUPPORT 2

2 SUPPORTS ARE IMPINGED UPON BY TRAVELING JET FROM BREAK 12 ON LINE 24 AS THE LINE WHIPS

FIGURE 2A





FIGURE 2B



FIGURE 2.C



↑
SUPPORT (2) FOR LINE 63
(TOO DARK TO SEE ON PHOTO)



1437983
1501243
SEC 63-6
-50584




FIGURE 3. TRAVELING JET FROM BREAK 12 ON LINE 24 IMPINGING ON SUPPORTS FOR LINE 63.
AREA "F"

