

PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER
VICE PRESIDENT
NUCLEAR POWER GENERATION

October 22, 1985

PGandE Letter No.: DCL-85-326

Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
Post Accident Sampling System - Conductivity Analysis

Dear Mr. Knighton:

In PGandE Letter DCL-85-047, dated February 1, 1985, regarding the SENTRY Post Accident Sampling System, PGandE indicated that a review was being performed to determine whether reactor coolant conductivity analysis is required to assess core damage.

As a result of this review, PGandE has concluded that the analysis of reactor coolant conductivity is not required. Therefore, reactor coolant conductivity will be deleted as an acceptance criterion from Revision 3 of Diablo Canyon procedure STP G-14, "Operability Determination of Post Accident Sampling Program", for DCPD Units 1 and 2.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,



cc: L. J. Chandler
R. T. Dodds
J. B. Martin
B. Norton
H. E. Schierling
CPUC
Diablo Distribution

0577S/0037K/ERK/1710

| | |
|------------|----------------|
| 8510300065 | 851022 |
| PDR | ADOCK 05000275 |
| P | PDR |

A046
1/0



11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61